

**Haaff Elementary**

Sample ID	Sample Date	Sample Time	Fixture Type	Cadmium (ppb)	Copper (ppb)	Iron (ppb)	Lead (ppb)	Zinc (ppb)	Location	Action
HAAFF1	3/6/2018	6:14 AM	SC-1S	<1.00	54.4	<500	1.43	9.17	Backflow #1	No Action Taken
HAAFF2	3/6/2018	6:18 AM	SC-1M	<1.00	42.6	<500	<1.00	6.05	Backflow #2	No Action Taken
HAAFF3-L	3/6/2018	6:20 AM	DFD	<1.00	75.5	<500	6.44	173	Gymnasium	No Action Taken
HAAFF3-R	3/6/2018	6:20 AM	DFD	<1.00	71.0	<500	2.76	102	Gymnasium	No Action Taken
HAAFF4-L	3/6/2018	6:21 AM	DFD	1.59	163	<500	8.81	335	Hallway near Gymnasium	No Action Taken
HAAFF4-R	3/6/2018	6:21 AM	DFD	<1.00	105	<500	2.97	244	Hallway near Gymnasium	No Action Taken
HAAFF5-L	3/6/2018	6:23 AM	DFD	<1.00	239	<500	7.62	70.7	Cafeteria	No Action Taken
HAAFF5-R	3/6/2018	6:23 AM	DFD	<1.00	104	<500	3.66	8.00	Cafeteria	No Action Taken
HAAFF6-L	3/6/2018	6:24 AM	KSF	<1.00	404	<500	1.56	195	Kitchen Sink	No Action Taken
HAAFF6-R	3/6/2018	6:24 AM	KSF	<1.00	686	<500	1.21	142	Kitchen Sink	No Action Taken
HAAFF7	3/6/2018	6:25 AM	TL	<1.00	195	<500	<1.00	384	Office	No Action Taken
HAAFF8	3/6/2018	6:26 AM	DFS	<1.00	238	<500	1.06	211	Hallway near Office	No Action Taken
HAAFF9	3/6/2018	6:28 AM	TL	<1.00	199	<500	5.57	358	Teachers Lounge	No Action Taken
HAAFF10	3/6/2018	6:29 AM	TL	<1.00	164	<500	6.61	248	Teachers Lounge	No Action Taken
SL 15SEC	3/6/2018	5:48 AM		<1.00	44.7	<500	1.5	20.4	Meter	No Action Taken
SL 45SEC	3/6/2018	5:48 AM		<1.00	38.9	<500	1.65	13.3	Meter	No Action Taken

**Fixture Type: DFS - Drinking Fountain with single faucet, DFD - Drinking Fountain with double faucet, \*SC - Service Connection Tap; KS - Kitchen Sink; TL - Teachers Lounge Sink**

\* Service Connection Tap is not a point for consumption water