

Risley International Academy of Innovation

Sample ID	Sample Date	Sample Time	Fixture Type	Cadmium (ppb)	Copper (ppb)	Iron (ppb)	Lead (ppb)	Zinc (ppb)	Location	Action
RS1	4/19/2018	5:48 AM	SC-1S	<1.00	1.99	<500	<1.00	2.87	Backflow #1	No Action Taken
RS2	4/19/2018	5:52 AM	SC-1M	<1.00	1.68	<500	<1.00	1.95	Backflow #2	No Action Taken
RS3	4/19/2018	5:53 AM	DFS	<1.00	162	<500	<1.00	3.63	Hallway near Classroom #121	No Action Taken
RS4	4/19/2018	5:54 AM	TL	<1.00	199	<500	1.53	375	Teachers Lounge	No Action Taken
RS5	4/19/2018	5:55 AM	DFS	<1.00	79.7	<500	<1.00	5.24	Hallway near Classroom #113	No Action Taken
RS6	4/19/2018	5:56 AM	DFS	<1.00	204	<500	<1.00	10.8	Hallway near Classroom #111	No Action Taken
RS7	4/19/2018	5:57 AM	DFS	<1.00	185	<500	<1.00	22.9	Hallway near Classroom #107	No Action Taken
RS8	4/19/2018	5:58 AM	IM	<1.00	13.3	<500	<1.00	7.78	Kitchen Ice Machine	No Action Taken
RS9-L	4/19/2018	5:59 AM	KSF	<1.00	47.9	<500	<1.00	349	Kitchen	No Action Taken
RS9-R	4/19/2018	5:59 AM	KSF	<1.00	44.3	<500	<1.00	289	Kitchen	No Action Taken
RS10	4/19/2018	6:00 AM	DFS	<1.00	124	<500	<1.00	4.21	Cafeteria	No Action Taken
RS11	4/19/2018	6:02 AM	DFS	<1.00	134	<500	<1.00	106	Gym	No Action Taken
RS12	4/19/2018	6:03 AM	DFS	<1.00	212	<500	1.04	153	Classroom #142	No Action Taken
RS13	4/19/2018	6:05 AM	DFS	<1.00	112	<500	<1.00	10.9	Hallway near Classroom #213	No Action Taken
RS14	4/19/2018	6:06 AM	DFS	<1.00	304	<500	<1.00	12.0	Hallway near Classroom #207	No Action Taken
SL 15SEC*	4/19/2018	6:13 AM		<1.00	28.0	<500	8.12	17.0	Meter	No Action Taken
SL 45SEC*	4/19/2018	6:14 AM		<1.00	14.0	<500	3.06	9.90	Meter	No Action Taken

Fixture Type: DFS - Drinking Fountain with single faucet, DFD - Drinking Fountain with double faucet, *SC - Service Connection Tap; KS - Kitchen Sink; TL - Teachers Lounge Sink

* Service Connection Tap is not a point for consumption water