

CHEHALEM_LOCATION	SAMPLE ID	DATE	LEAD RESULT (ppb)
Kitchen	22430700-001KF24A	4/18/2024	ND
Kitchen	22430700-002KF24A	4/18/2024	5.77
Cafeteria	22430700-003WB24A	4/18/2024	ND
Cafeteria	22430700-004DW24A	4/18/2024	ND
Health Room	22430700-005NS24A	4/18/2024	0.721
A100	22430700-006CF24A	4/18/2024	0.425
A100	22430700-007DW24A	4/18/2024	0.399
A102	22430700-008CF24A	4/18/2024	0.224
A102	22430700-009DW24A	4/18/2024	0.293
A104	22430700-010CF24A	4/18/2024	0.233
A104	22430700-011DW24A	4/18/2024	ND
A106	22430700-012CF24A	4/18/2024	0.241
A106	22430700-013DW24A	4/18/2024	ND
A108	22430700-014CF24A	4/18/2024	ND
A108	22430700-015DW24A	4/18/2024	0.269
A110	22430700-016CF24A	4/18/2024	ND
A110	22430700-017DW24A	4/18/2024	0.263
A112	22430700-018CF24A	4/18/2024	0.231
A112	22430700-019DW24A	4/18/2024	ND
A114	22430700-020CF24A	4/18/2024	ND
A114	22430700-021DW24A	4/18/2024	ND
A116	22430700-022CF24A	4/18/2024	0.83
A116	22430700-023DW24A	4/18/2024	ND
A118	22430700-024CF24A	4/18/2024	0.234
A118	22430700-025DW24A	4/18/2024	ND
A120	22430700-026CF24A	4/18/2024	0.222
A120	22430700-027DW24A	4/18/2024	ND
A122	22430700-028CF24A	4/18/2024	ND
A122	22430700-029DW24A	4/18/2024	ND
Gym	22430700-030DW24A	4/18/2024	ND
Main Hall	22430700-031DW24A	4/18/2024	0.235
Staff Lounge	22430700-032SF24A	4/18/2024	1.19
Staff Lounge	22430700-033WC24A	4/18/2024	ND
B Hall	22430700-034DW24A	4/18/2024	3.7
Library Workroom	22430700-035SF24A	4/18/2024	0.621
B100	22430700-036CF24A	4/18/2024	1.93
B100	22430700-037DW24A	4/18/2024	ND
B102	22430700-038CF24A	4/18/2024	1.67
B102	22430700-039DW24A	4/18/2024	0.21
B104	22430700-040CF24A	4/18/2024	0.463
B104	22430700-041DW24A	4/18/2024	0.425
B106	22430700-042CF24A	4/18/2024	1.24
B106	22430700-043DW24A	4/18/2024	1.2
B108	22430700-044CF24A	4/18/2024	1.57
B108	22430700-045DW24A	4/18/2024	ND

B110	<i>(restricted access)</i>	22430700-046CF24A	4/18/2024	15.5
B110	<i>(post-mitigation)</i>	22430700-046CF24C	7/12/2024	2.95
B110		22430700-047DW24A	4/18/2024	11.7
B110		22430700-047DW24C	7/12/2024	0.495
M102		22430700-048CF24A	4/18/2024	5.37
M102		22430700-049DW24A	4/18/2024	12.7
M104		22430700-050CF24A	4/18/2024	5.51
M104		22430700-051DW24A	4/18/2024	ND
M106		22430700-052CF24A	4/18/2024	4.14
M106		22430700-053DW24A	4/18/2024	2.92
M108		22430700-054CF24A	4/18/2024	11.4
M108		22430700-055DW24A	4/18/2024	1.37
M110		22430700-056CF24A	4/18/2024	0.599
M110		22430700-057DW24A	4/18/2024	2.13