

GLTHS SCHOOL BUILDING COMMITTEE (MSBA Project)

Minutes of May 18, 2017 Meeting

Members Present: Mr. Bourgeois, Mr. Boutin, Mr. Byrne, Ms. Davis,
Mr. Giggey, Mr. LeMay, Mr. Morin, Mr. O'Hare,

Also Present: James Riefstahl, Joslin Lesser; Recording Secretary

Meeting was called to order at 5:48 p.m.

Roll call was taken with the above mentioned members present. Mr. Bahou,
Mr. Espinola, Mr. Tatseos & Ms. Turner arrived after roll call.

Mr. Byrne and Mr. Riefstahl explained that the leak was not being caused by any roof damage but due to an issue with the flashing not being high enough under the cladding. Previous estimates to repair the wall panel were approximately \$50,000. An alternate repair that was attempted did not work. A new estimate from Greenwood Industries for \$28,500 was presented to the committee for approval.

Discussion took place.

MOTION: by Mr. Boutin, seconded by Mr. Bahou to approve the \$28,500 roof repair estimate.

Further discussion took place regarding getting new estimates and having a special building committee meeting on May 30.

MOTION: by Mr. Bahou, seconded by Mr. O'Hare to table the roof repair approval until May 30.

ROLL CALL VOTE: 12 Yes

MOTION: by Mr. Tatseos, seconded by Mr. LeMay to adjourn at 6:28 p.m.

ROLL CALL VOTE: 12 Yes