



181 US Hwy 46
Mine Hill, NJ 07803
(908) 654-8068
(800) 783-0567
Fax 908-654-8069

LEAD IN DRINKING WATER REPORT

Performed At:

Administration Building
Clark Mills School
Lafayette Mills School
MEMS School
Milford Brook School
Pine Brook School
Taylor Mills School
Wembrook School
Transportation Building

Performed For:

Camile Robinson
Manalapan-Englishtown
Regional Schools
116 Millhurst Road
Manalapan, NJ 07726

Prepared By:

LEW Corporation
181 US Hwy 46
Mine Hill, NJ 07803

Phone (908) 654-8068
Fax (908) 654-8069
Website <http://www.LEWCorp.com>
Inspection Date: 11/13- 11/14/2021
Project Number: 210489

Table of Contents

| | |
|----------------------------------|---|
| Contact Information | 3 |
| Introduction | 4 |
| Sampling Methodology | 4 |
| Drinking Water Results | 5 |
| Recommendations | 6 |
| Additional Recommendations | 6 |

Appendices


| | |
|------------|-----------------|
| Appendix A | Exceedances |
| Appendix B | Recommendations |
| Appendix C | All results |
| Appendix D | Floor Plan(S) |
| Appendix E | Laboratory Data |

Contact Information

Agency

| | |
|-----------------|---|
| Client Contact: | Camille Robinson |
| Client Name: | Manalapan – Englishtown Regional Schools |
| Street Address | 116 Millhurst Road Manalapan, NJ 07726 |
| Phone Number: | 732-786-2500 |

Risk Assessor(s)

| | |
|-------------------|---|
| site Assessor(s): | Robert Carlucci |
| License: | LBP-I-14664-1 |
| Signature: |  |
| Date: | 12/29/2021 |
| E-Mail | Rcarlucci@lewcorp.com |

Firm

| | |
|--------------------|---|
| Organization: | LEW Corporation |
| Certification #: | NJDCA 00015 E |
| Street: | 181 US Hwy 46 |
| City, State & Zip: | Mine Hill, NJ 07803 |
| Phone Number: | 908-654-8068 |
| Web Address: | http://www.lewcorp.com |

Laboratory

| | |
|-----------------------|------------------------------------|
| Organization: | Environmental Hazard Services, LLC |
| Street: | 7469 Whitepine Road |
| City, State & Zip: | Richmond, VA 23237 |
| NJDEP Certification # | VA008 |
| Phone Number: | 800-347-4010 |

Introduction

LEW Corporation was contracted by Manalapan-Englishtown Regional Schools to test for the presence of lead in drinking water in five schools in the district. This particular report refers only to the results of the water sampling at the Manalapan-Englishtown Regional Schools.

Sampling Methodology

LEW Corporation followed the July 13, 2016 amendments to NJAC 6A:26. Full details on sampling practices can be found in District's Sampling Plan.

All samples were collected in 250mL wide mouth plastic containers that was prepackaged by the analytical laboratory. The sample containers may contain nitric acid, if expedited analysis is required. If not, nitric acid will be added to each sample upon arrival at the laboratory. At each sample location, the first draw sample was taken after it was determined that the water had been standing in the plumbing system for greater than eight hours but less than forty-eight hours. If second draw samples were collected, they were collected following a flushing protocol outlined in the District's Sampling Plan.

Drinking Water Results

On December 11th- 12th 2021, LEW Corporation collected the following number of water samples:

Taylor Mills School

- 27 first draw samples
- 3 samples above the 15ppb action level

Milford Brook School

- 23 first draw samples
- 1 sample above the 15ppb action level

Pine Brook School

- 31 first draw samples
- 5 sample above the 15ppb action level

Clark Mills School

- 57 first draw samples
- 3 sample above the 15ppb action level

Manalapan-Englishtown Middle School

- 65 first draw samples
- 1 sample above the 15ppb action level

Lafayette Mills School

- 30 first draw samples
- 2 sample above the 15ppb action level

Transportation Building

- 4 first draw samples
- 0 sample above the 15ppb action level

Administration Building

- 4 first draw samples
- 0 sample above the 15ppb action level

Wemrock Brook School

- 62 first draw samples
- 4 sample above the 15ppb action level

The complete list of samples that exceeded the 15ppb limit can be found in Appendix A. The complete list of all sample results can be found in Appendix C. The laboratory results can be found in Appendix E.

Certain outlets could not or were not tested due to various reasons. The following table lists those locations and the reason why samples were not collected.

| School | Sample Location | Reason for not testing. |
|---------------|--------------------------------------|-------------------------|
| Wemrock Brook | Drinking fountain left near room 216 | Not Working |
| Clark Mills | Room E left bubbler | Turned off |
| Clark Mills | Room F right bubbler | Turned Off |
| Clark Mills | Room bubbler | Not Working |
| Clark Mills | Room N bubbler | Not Working |
| Clark Mills | Room R bubbler | Not Working |
| Pine Brook | Kitchen sink 3 | No longer in use |

Recommendations

Those outlets where the first draw sample tested below 15ppb are not considered to be elevated and no mitigation is necessary.

For those outlets where the first draw sample exceeds 15ppb the following steps are recommended:

- 1) Immediately discontinue use of the outlets.
- 2) Conduct second draw (flush) samples on these outlets to further delineate source of contamination.

A complete list of recommendations per outlet can be found in Appendix B.

Additional Recommendations

- 1) Follow-up samples should be collected after any remediation efforts in order to determine the efficacy of the work.
- 2) Any of the inoperable/non-functioning outlets listed above that are brought back into service should be sampled.
- 3) Comply with all requirements set forth in NJAC 6A:26.

Appendix A Exceedances

| Building | Date Collected | Date Analyzed | Sample ID | Sample Location | Concentration ppB |
|---------------|----------------|---------------|---------------|-------------------------------------|-------------------|
| Taylor Mills | 12/04/2021 | 12/14/2021 | TM-9-S2-A | Art Room Sink | 19.3 |
| Taylor Mills | 12/04/2021 | 12/14/2021 | TM-10-S3-A | Art Room Sink | 16.8 |
| Taylor Mills | 12/04/2021 | 12/14/2021 | TM-11-S4-A | Art Room Sink | 52.7 |
| Milford Brook | 12/04/2021 | 12/14/2021 | MB-22-DFR-13 | Water Fountain by room 13 Right | 17.8 |
| Pine Brook | 12/04/2021 | 12/14/2021 | PB-2-S-K | Kitchen Sink | 48.9 |
| Pine Brook | 12/04/2021 | 12/14/2021 | PB-5-PFL-K | Kitchen Food Prep | 19.9 |
| Pine Brook | 12/04/2021 | 12/14/2021 | PB-16-DFR-M | Water Fountain by Main Office Right | 36.4 |
| Pine Brook | 12/04/2021 | 12/14/2021 | PB-23-S1-RM32 | Room 32 Sink | 23.2 |
| Pine Brook | 12/04/2021 | 12/14/2021 | PB-25-S-RM33 | Room 33 Sink | 36.8 |
| Clark Mills | 12/04/2021 | 12/14/2021 | CM-7-S3-K | Kitchen Sink 3 | 57.6 |
| Clark Mills | 12/04/2021 | 12/14/2021 | CM-8-S4-K | Kitchen Sink 4 | 19.9 |
| Clark Mills | 12/04/2021 | 12/14/2021 | CM-22-BB-46 | Room 46 Bubbler | 620 |
| Middle School | 12/04/2021 | 12/14/2021 | MS-51-PF4-K | Pot Filler 4 | 18.7 |
| | | | | | |

| | | | | | |
|-----------------|------------|------------|---------------|------------------------------|------|
| Lafayette Mills | 12/04/2021 | 12/14/2021 | LM-15-DF-RM23 | Water Fountain by Room 23 | 22.9 |
| Lafayette Mills | 12/04/2021 | 12/14/2021 | LM-21-DF-RM31 | Drinking Fountain by room 31 | 29.7 |
| Wemrock | 12/04/2021 | 12/14/2021 | WB-2-S-S | Stage Sink | 17.5 |
| Wemrock | 12/04/2021 | 12/14/2021 | WB-5-S2-K | Kitchen Sink | 66.5 |
| Wemrock | 12/04/2021 | 12/14/2021 | WB-33-S1-117 | Art Room Sink 1 | 17.7 |
| Wemrock | 12/04/2021 | 12/14/2021 | WB-34-S2-117 | Art Room Sink 2 | 26.0 |

Appendix B Recommendations

| Building | Sample Location | Concentration ppB | Recommendations |
|---------------|--|-------------------|---|
| Taylor Mills | Art Room Sink | 19.3 | 1) Immediately discontinue use of the outlets. 2) Conduct second draw (flush) samples on this outlet to further delineate source of contamination. |
| Taylor Mills | Art Room Sink | 16.8 | 1) Immediately discontinue use of the outlets. 2) Conduct second draw (flush) samples on this outlet to further delineate source of contamination. |
| Taylor Mills | Art Room Sink | 52.7 | 1) Immediately discontinue use of the outlets. 2) Conduct second draw (flush) samples on this outlet to further delineate source of contamination. |
| Milford Brook | Water Fountain by room 13 Right | 17.8 | 1) Immediately discontinue use of the outlets. 2) Conduct second draw (flush) samples on this outlet to further delineate source of contamination. |
| Pine Brook | Kitchen Sink (looking counter clockwise) | 77.1 | 1) Immediately discontinue use of the outlets. 2) Conduct second draw (flush) samples on this outlet to further delineate source of contamination. |
| Pine Brook | Room 32 Sink | 23.2 | 1) Immediately discontinue use of the outlets. 2) Conduct second draw (flush) samples on this outlet to further delineate source of contamination. |
| Pine Brook | Kitchen Food Prep | 19.9 | 1) Immediately discontinue use of the outlets. 2) Conduct second draw (flush) samples on this outlet to further delineate source of contamination. |
| Pine Brook | Water Fountain by Main Office Right | 36.4 | 1) Immediately discontinue use of the outlets. 2) Conduct second draw (flush) samples on this outlet to further delineate source of contamination. |
| Pine Brook | Room 33 Sink | 36.8 | 1) Immediately discontinue use of the outlets. 2) Conduct second draw (flush) samples on this outlet to further delineate source of contamination. |

| | | | |
|-----------------|------------------------------|------|---|
| Clark Mills | Kitchen Sink 3 | 57.6 | <ol style="list-style-type: none"> 1) Immediately discontinue use of the outlets. 2) Conduct second draw (flush) samples on this outlet to further delineate source of contamination. |
| Clark Mills | Kitchen Sink 4 | 19.9 | <ol style="list-style-type: none"> 1) Immediately discontinue use of the outlets. 2) Conduct second draw (flush) samples on this outlet to further delineate source of contamination. |
| Clark Mills | Room 46 Bubbler | 620 | <ol style="list-style-type: none"> 1) Immediately discontinue use of the outlets. 2) Conduct second draw (flush) samples on this outlet to further delineate source of contamination. |
| Middle School | Pot Filler 4 | 18.7 | <ol style="list-style-type: none"> 1) Immediately discontinue use of the outlets. 2) Conduct second draw (flush) samples on this outlet to further delineate source of Contamination |
| Lafayette Mills | Water Fountain by Room 23 | 22.9 | <ol style="list-style-type: none"> 1) Immediately discontinue use of the outlets. 2) Conduct second draw (flush) samples on this outlet to further delineate source of Contamination |
| Lafayette Mills | Drinking Fountain by room 31 | 29.7 | <ol style="list-style-type: none"> 1) Immediately discontinue use of the outlets. 2) Conduct second draw (flush) samples on this outlet to further delineate source of Contamination |
| Wemrock | Stage Sink | 17.5 | <ol style="list-style-type: none"> 1) Immediately discontinue use of the outlets. 2) Conduct second draw (flush) samples on this outlet to further delineate source of Contamination |
| Wemrock | Kitchen Sink | 66.5 | <ol style="list-style-type: none"> 1) Immediately discontinue use of the outlets. 2) Conduct second draw (flush) samples on this outlet to further delineate source of Contamination |
| Wemrock | Art Room Sink 1 | 17.7 | <ol style="list-style-type: none"> 1) Immediately discontinue use of the outlets. 2) Conduct second draw (flush) samples on this outlet to further delineate source of Contamination |
| Wemrock | Art Room Sink 2 | 26.0 | <ol style="list-style-type: none"> 1) Immediately discontinue use of the outlets. 2) Conduct second draw (flush) samples on this outlet to further delineate source of Contamination |

Appendix C All Results

| Lab Sample Number | Sample ID | Date | Location | ug/L (ppb) | Analysis Date |
|---------------------|---------------|------------|----------------------------------|------------|---------------|
| Taylor Mills | | | | | |
| 21-12-00969-001 | TM-1-DF-BR | 12/04/2021 | WATER FOUNTAIN BY BOILER ROOM | 5.79 | 12/14/2021 |
| 21-12-00969-002 | TM-2-DFL-AP | 12/04/2021 | WATER FOUNTAIN BY AP LEFT | <1.00 | 12/14/2021 |
| 21-12-00969-003 | TM-3-DFR-AP | 12/04/2021 | WATER FOUNTAIN BY AP RIGHT | <1.00 | 12/14/2021 |
| 21-12-00969-004 | TM-4-DFL-148 | 12/04/2021 | WATER FOUNTAIN BY ROOM148 LEFT | 4.34 | 12/14/2021 |
| 21-12-00969-005 | TM-5-DFR-148 | 12/04/2021 | WATER FOUNTAIN BY ROOM 148 RIGHT | 7.11 | 12/14/2021 |
| 21-12-00969-006 | TM-6-S-N | 12/04/2021 | NURSE OFFICE | 4.63 | 12/14/2021 |
| 21-12-00969-007 | TM-7-DF-MO | 12/04/2021 | WATER FOUNTAIN BY MAIN OFFICE | <1.00 | 12/14/2021 |
| 21-12-00969-008 | TM-8-S1-A | 12/04/2021 | ART ROOM SINK | <1.00 | 12/14/2021 |
| 21-12-00969-009 | TM-9-S2-A | 12/04/2021 | ART ROOM SINK | 19.3 | 12/14/2021 |
| 21-12-00969-010 | TM-10-S3-A | 12/04/2021 | ART ROOM SINK | 16.8 | 12/14/2021 |
| 21-12-00969-011 | TM-11-S4-A | 12/04/2021 | ART ROOM SINK | 52.7 | 12/14/2021 |
| 21-12-00969-012 | TM-12-DFL-149 | 12/04/2021 | WATER FOUNTAIN BY ROOM 149 LEFT | <1.00 | 12/14/2021 |
| 21-12-00969-013 | TM-13-DFR-149 | 12/04/2021 | WATER FOUNTAIN BY ROOM 149 RIGHT | <1.00 | 12/14/2021 |
| 21-12-00969-014 | TM-14-S-LMC | 12/04/2021 | LMC SINK | 1.50 | 12/14/2021 |
| 21-12-00969-015 | TM-15-DFL-210 | 12/04/2021 | WATER FOUNTAIN BY ROOM 210 LEFT | 1.17 | 12/14/2021 |
| 21-12-00969-016 | TM-16-DFR-210 | 12/04/2021 | WATER FOUNTAIN BY ROOM 210 RIGHT | <1.00 | 12/14/2021 |
| 21-12-00969-017 | TM-17-DF-CR | 12/04/2021 | WATER FOUNTAIN BY COPY ROOM | 1.62 | 12/14/2021 |
| 21-12-00969-018 | TM-18-S-FR | 12/04/2021 | FACULTY ROOM SINK | <1.00 | 12/14/2021 |
| 21-12-00969-019 | TM-19-FP-K | 12/04/2021 | KITCHEN FOOD PREP | 1.70 | 12/14/2021 |
| 21-12-00969-020 | TM-20-S1-K | 12/04/2021 | KITCHEN SINK | 1.23 | 12/14/2021 |
| 21-12-00969-021 | TM-21-S2-K | 12/04/2021 | KTICHEN SINK | <1.00 | 12/14/2021 |
| 21-12-00969-022 | TM-22-S3-K | 12/04/2021 | KTICHEN SINK | 1.68 | 12/14/2021 |
| 21-12-00969-023 | TM-23-S4-K | 12/04/2021 | KITCHEN SINK | 1.48 | 12/14/2021 |
| 21-12-00969-024 | TM-24-S5-K | 12/04/2021 | KITCHEN SINK | <1.00 | 12/14/2021 |

| | | | | | |
|-----------------------------|---------------|------------|-----------------------------------|-------|------------|
| 21-12-00969-025 | TM-25-DFL-302 | 12/04/2021 | WATER FOUNTAIN BY ROOM 302 LEFT | 1.33 | 12/14/2021 |
| 21-12-00969-026 | TM-26-DFR-302 | 12/04/2021 | WATER FOUNTAIN BY ROOM 302 RIGHT | 2.70 | 12/14/2021 |
| 21-12-00969-027 | TM-S-SR | 12/04/2021 | SUN ROOM | <1.00 | 12/14/2021 |
| Milford Brook School | | | | | |
| 21-12-00971-001 | MB-1-S-CO | 12/04/2021 | CUSTODIAL OFFICE SINK | 10.4 | 12/13/2021 |
| 21-12-00971-002 | MB-2-DFL-G | 12/04/2021 | WATER FOUNTAIN BY GYM LEFT | 8.78 | 12/13/2021 |
| 21-12-00971-003 | MB-3-DFR-G | 12/04/2021 | WATER FOUNTAIN BY GYM RIGHT | 6.80 | 12/13/2021 |
| 21-12-00971-004 | MB-4-DFL-C | 12/04/2021 | WATER FOUNTAIN IN CAFETERIA LEFT | 4.00 | 12/13/2021 |
| 21-12-00971-005 | MB-5-DFR-C | 12/04/2021 | WATER FOUNTAIN IN CAFETERIA RIGHT | 4.04 | 12/13/2021 |
| 21-12-00971-006 | MB-6-SL-K | 12/04/2021 | KITCHEN SINK LEFT | 7.64 | 12/13/2021 |
| 21-12-00971-007 | MB-7-SR-K | 12/04/2021 | KITCHEN SINK RIGHT | 11.7 | 12/13/2021 |
| 21-12-00971-008 | MB-8-DFL-LC | 12/04/2021 | WATER FOUNTAIN BY LC LEFT | 2.79 | 12/13/2021 |
| 21-12-00971-009 | MB-9-DFR-LC | 12/04/2021 | WATER FOUNTAIN BY LC RIGHT | 3.84 | 12/13/2021 |
| 21-12-00971-010 | MB-10-DFL-30 | 12/04/2021 | WATER FOUNTAIN BY ROOM 30 | 7.85 | 12/13/2021 |
| 21-12-00971-011 | MB-11-DFR-30 | 12/04/2021 | WATER FOUNTAIN BY ROOM 30 | 9.41 | 12/13/2021 |
| 21-12-00971-012 | MB-12-DFL-2 | 12/04/2021 | WATER FOUNTAIN BY ROOM 2 LEFT | <1.00 | 12/13/2021 |
| 21-12-00971-013 | MB-13-DFR-2 | 12/04/2021 | WATER FOUNTAIN BY ROOM 2 RIGHT | <1.00 | 12/13/2021 |
| 21-12-00971-014 | MB-14-S1-A | 12/04/2021 | ART ROOM SINK 1 | 5.16 | 12/13/2021 |
| 21-12-00971-015 | MB-15-S2-A | 12/04/2021 | ART ROOM SINK 2 | 7.93 | 12/13/2021 |
| 21-12-00971-016 | MB-16-DFL-CR | 12/04/2021 | WATER FOUNTAIN BY COPY ROOM LEFT | <1.00 | 12/13/2021 |
| 21-12-00971-017 | MB-17-DFR-CR | 12/04/2021 | WATER FOUNTAIN BY COPY ROOM RIGHT | <1.00 | 12/13/2021 |
| 21-12-00971-018 | MB-18-S-N | 12/04/2021 | NRUSE SINK | 1.60 | 12/13/2021 |
| 21-12-00971-019 | MB-19-DF-CC | 12/04/2021 | WATER FOUNTAIN BY CC | <1.00 | 12/13/2021 |
| 21-12-00971-020 | MB-20-S-FR | 12/04/2021 | FACULTY ROOM SINK | 2.84 | 12/13/2021 |
| 21-12-00971-021 | MB-21-DFL-13 | 12/04/2021 | WATER FOUNTAIN BY ROOM 13 LEFT | 13.0 | 12/13/2021 |
| 21-12-00971-022 | MB-22-DFR-13 | 12/04/2021 | WATER FOUNTAIN BY ROOM 13 RIGHT | 17.8 | 12/13/2021 |

| | | | | | |
|--------------------------|----------------|------------|--------------------------------------|-------|------------|
| 21-12-00971-023 | MB-23-SR | 12/04/2021 | SUN ROOM | <1.00 | 12/13/2021 |
| Pine Brook School | | | | <1.00 | 11/22/2021 |
| 21-12-00982-001 | PB-1-FP-K | 12/04/2021 | KITCHEN FOOD PREP | 1.24 | 12/14/2021 |
| 21-12-00982-002 | PB-2-S-K | 12/04/2021 | KITCHEN SINK | 48.9 | 12/14/2021 |
| 21-12-00982-003 | PB-4-FP-K | 12/04/2021 | KITCHEN FOOD PREP | <1.00 | 12/14/2021 |
| 21-12-00982-004 | PB-5-FPL-K | 12/04/2021 | KITCHEN FOOD PREP | 19.9 | 12/14/2021 |
| 21-12-00982-005 | PB-6-FPR-K | 12/04/2021 | KITCHEN FOOD PREP | 5.44 | 12/14/2021 |
| 21-12-00982-006 | PB-7-S-K | 12/04/2021 | KITCHEN SINK | 4.26 | 12/14/2021 |
| 21-12-00982-007 | PB-8-DFL-S | 12/04/2021 | WATER FOUNTAIN BY STORAGE ROOM LEFT | 4.19 | 12/14/2021 |
| 21-12-00982-008 | PB-9-DFR-S | 12/04/2021 | WATER FOUNTAIN BY STORAGE ROOM RIGHT | 1.42 | 12/14/2021 |
| 21-12-00982-009 | PB-10-DF-GR | 12/04/2021 | WATER FOUNTAIN BY GIRLS ROOM | <1.00 | 12/14/2021 |
| 21-12-00982-010 | PB-11-DFL-MR14 | 12/04/2021 | WATER FOUNTAIN BY ROOM 14 LEFT | 1.70 | 12/14/2021 |
| 21-12-00982-011 | PB-12-DFR-RM14 | 12/04/2021 | WATER FOUNTAIN BY ROOM 14 RIGHT | 1.30 | 12/14/2021 |
| 21-12-00982-012 | PB-13-DFL-N | 12/04/2021 | WATER FOUNTAIN BY NURSE LEFT | 3.58 | 12/14/2021 |
| 21-12-00982-013 | PB-14-DFR-N | 12/04/2021 | WATER FOUNTAIN BY NURSE RIGHT | 3.56 | 12/14/2021 |
| 21-12-00982-014 | PB-15-DFL-M | 12/04/2021 | WATER FOUNTAIN BY MAIN OFFICE LEFT | 11.3 | 12/14/2021 |
| 21-12-00982-015 | PB-16-DFR-M | 12/04/2021 | WATER FOUNTAIN BY MAIN OFFICE RIGHT | 36.4 | 12/14/2021 |
| 21-12-00982-016 | PB-17-DF-RM16 | 12/04/2021 | WATER FOUNTAIN BY ROOM 16 | 3.40 | 12/14/2021 |
| 21-12-00982-017 | PB-18-DFL-RM17 | 12/04/2021 | WATER FOUNTAIN BY ROOM 17 LEFT | <1.00 | 12/14/2021 |
| 21-12-00982-018 | PB-19-DFR-RM17 | 12/04/2021 | WATER FOUNTAIN BY ROOM 17 RIGHT | <1.00 | 12/14/2021 |
| 21-12-00982-019 | PB-20-S-F | 12/04/2021 | FACULTY ROOM SINK | <1.00 | 12/14/2021 |
| 21-12-00982-020 | PB-21-DFL-RM31 | 12/04/2021 | WATER FOUNTAIN BY ROOM 31 LEFT | <1.00 | 12/14/2021 |
| 21-12-00982-021 | PB-22-DFR-RM31 | 12/04/2021 | WATER FOUNTAIN BY ROOM 31 RIGHT | <1.00 | 12/14/2021 |
| 21-12-00982-022 | PB-23-S1-RM32 | 12/04/2021 | ROOM 32 SINK | 23.2 | 12/14/2021 |
| 21-12-00982-023 | PB-24-S2-RM32 | 12/04/2021 | ROOM 32 SINK | 10.8 | 12/14/2021 |
| 21-12-00982-024 | PB-25-S-RM33 | 12/04/2021 | ROOM 33 SINK | 36.8 | 12/14/2021 |

| | | | | | |
|---------------------------|----------------|------------|----------------------------------|------------|------------|
| 21-12-00982-025 | PB-26-DFL-RM33 | 12/04/2021 | WATER FOUNTAIN BY ROOM 33 LEFT | <1.00 | 12/14/2021 |
| 21-12-00982-026 | PB-27-DFR-RM33 | 12/04/2021 | WATER FOUNTAIN BY ROOM 33 RIGHT | <1.00 | 12/14/2021 |
| 21-12-00982-027 | PB-28-DF-RM34 | 12/04/2021 | WATER FOUNTAIN BY ROOM 34 | 2.51 | 12/15/2021 |
| 21-12-00982-028 | PB-29-DFL-RM37 | 12/04/2021 | WATER FOUNTAIN BY ROOM 37 LEFT | <1.00 | 12/15/2021 |
| 21-12-00982-029 | PB-30-DFR-RM37 | 12/04/2021 | WATER FOUNTAIN BY ROOM 37 RIGHT | <1.00 | 12/15/2021 |
| 21-12-00982-030 | PB-31-DF-G | 12/04/2021 | WATER FOUNTAIN BY GYM | 4.74 | 12/15/2021 |
| 21-12-00982-031 | PB-32-S-SR | 12/04/2021 | SUN ROOM | <1.00 | 12/15/2021 |
| Clark Mills School | | | | | |
| 21-12-00988-001 | CM-1-DFL-18A | 12/04/2021 | WATER FOUNTAIN ROOM 18A LEFT | 12/14/2021 | 2.54 |
| 21-12-00988-002 | CM-2-DFR-18A | 12/04/2021 | WATER FOUNTAIN ROOM 18A RIGHT | 12/14/2021 | 1.66 |
| 21-12-00988-003 | CM-3-S-FR | 12/04/2021 | FACULTY ROOM SINK | 12/14/2021 | <1.00 |
| 21-12-00988-004 | CM-4-FP-K | 12/04/2021 | KITCHEN FOOD PREP | 12/14/2021 | 3.40 |
| 21-12-00988-005 | CM-5-S1-K | 12/04/2021 | KITCHEN SINK 1 | 12/14/2021 | 1.16 |
| 21-12-00988-006 | CM-6-S2-K | 12/04/2021 | KITCHEN SINK 2 | 12/14/2021 | 1.64 |
| 21-12-00988-007 | CM-7-S3-K | 12/04/2021 | KITCHEN SINK 3 | 12/14/2021 | 57.6 |
| 21-12-00988-008 | CM-8-S4-K | 12/04/2021 | KITCHEN SINK 4 | 12/14/2021 | 19.9 |
| 21-12-00988-009 | CM-9-S5-K | 12/04/2021 | KITCHEN SINK 5 | 12/14/2021 | <1.00 |
| 21-12-00988-010 | CM-10-S6-K | 12/04/2021 | KITCHEN SINK 6 | 12/14/2021 | 2.06 |
| 21-12-00988-011 | CM-11-DFL-S20 | 12/04/2021 | WATER FOUNTAIN BY STAGE 20 LEFT | 12/14/2021 | 1.84 |
| 21-12-00988-012 | CM-12-DFR-S20 | 12/04/2021 | WATER FOUNTAIN BY STAGE 20 RIGHT | 12/14/2021 | 2.35 |
| 21-12-00988-013 | CM-B-S-21 | 12/04/2021 | ROOM 21 SINK | 12/14/2021 | 4.60 |
| 21-12-00988-014 | CM-14-S-22 | 12/04/2021 | ROOM 22 SINK | 12/14/2021 | <1.00 |
| 21-12-00988-015 | CM-15-DFL-25 | 12/04/2021 | WATER FOUNTAIN BY ROOM 25 LEFT | 12/14/2021 | <1.00 |
| 21-12-00988-016 | CM-16-DFR-25 | 12/04/2021 | WATER FOUNTAIN BY ROOM 25 RIGHT | 12/14/2021 | <1.00 |
| 21-12-00988-017 | CM-17-DFL-27 | 12/04/2021 | WATER FOUNTAIN BY ROOM 27 LEFT | 12/14/2021 | 1.78 |
| 21-12-00988-018 | CM-18-DFR-27 | 12/04/2021 | WATER FOUNTAIN BY ROOM 27 RIGHT | 12/14/2021 | 1.74 |
| 21-12-00988-019 | CM-19-DFL-32 | 12/04/2021 | WATER FOUNTAIN BY ROOM 32 LEFT | 12/14/2021 | <1.00 |
| 21-12-00988-020 | CM-20-DFR-32 | 12/04/2021 | WATER FOUNTAIN BY ROOM 32 RIGHT | 12/14/2021 | 4.40 |

| | | | | | |
|-----------------|--------------|------------|---------------------------------|------------|-------|
| 21-12-00988-021 | CM-21-S-LMC | 12/04/2021 | MEDIA CENTER SINK | 12/14/2021 | 7.82 |
| 21-12-00988-022 | CM-22-BB-46 | 12/04/2021 | ROOM 46 BUBBLER | 12/15/2021 | 620 |
| 21-12-00988-023 | CM-23-BB-47 | 12/04/2021 | ROOM 47 BUBBLER | 12/14/2021 | 4.23 |
| 21-12-00988-024 | CM-24-BB-49 | 12/04/2021 | ROOM 49 BUBBLER | 12/14/2021 | 11.8 |
| 21-12-00988-025 | CM-25-BB-48 | 12/04/2021 | ROOM 48 BUBBLER | 12/14/2021 | 5.07 |
| 21-12-00988-026 | CM-26-DF-50B | 12/04/2021 | WATER FOUNTAIN BY ROOM 50 B | 12/14/2021 | 1.11 |
| 21-12-00988-027 | CM-27-S-50B | 12/04/2021 | ROOM 50 B SINK | 12/14/2021 | 7.56 |
| 21-12-00988-028 | CM-28-S-60 | 12/04/2021 | ROOM 60 SINK | 12/14/2021 | 1.64 |
| 21-12-00988-029 | CM-29-DF-A | 12/04/2021 | WATER FOUNTAIN BY ROOM A | 12/14/2021 | <1.00 |
| 21-12-00988-030 | CM-30-BBR-E | 12/04/2021 | ROOM E BUBBLER RIGHT | 12/14/2021 | 8.78 |
| 21-12-00988-031 | CM-32-BBL-F | 12/04/2021 | ROOM F BUBBLER LEFT | 12/14/2021 | 3.99 |
| 21-12-00988-032 | CM-34-BBL-G | 12/04/2021 | ROOM G BUBBLER LEFT | 12/14/2021 | 6.40 |
| 21-12-00988-033 | CM-35-BBR-G | 12/04/2021 | ROOM G BUBBLER RIGHT | 12/14/2021 | 8.88 |
| 21-12-00988-034 | CM-36-BBL-H | 12/04/2021 | ROOM H BUBBLER LEFT | 12/14/2021 | 3.39 |
| 21-12-00988-035 | CM-37-BBR-H | 12/04/2021 | ROOM H BUBBLER RIGHT | 12/14/2021 | 1.66 |
| 21-12-00988-036 | CM-38-BB-I | 12/04/2021 | ROOM I BUBBLER | 12/14/2021 | 1.57 |
| 21-12-00988-037 | CM-39-BB-J | 12/04/2021 | ROOM J BUBBLER | 12/14/2021 | 4.72 |
| 21-12-00988-038 | CM-40-S-FR | 12/04/2021 | FACULTY ROOM SINK | 12/15/2021 | 1.96 |
| 21-12-00988-039 | CM-41-BB-K | 12/04/2021 | ROOM K BUBBLER | 12/14/2021 | <1.00 |
| 21-12-00988-040 | CM-42-BB-L | 12/04/2021 | ROOM L BUBBLER | 12/14/2021 | 1.19 |
| 21-12-00988-041 | CM-45-BB-O | 12/04/2021 | ROOM O BUBBLER | 12/14/2021 | <1.00 |
| 21-12-00988-042 | CM-46-BB-P | 12/04/2021 | ROOM P BUBBLER | 12/14/2021 | 1.06 |
| 21-12-00988-043 | CM-47-BB-Q | 12/04/2021 | ROOM Q BUBBLER | 12/14/2021 | 1.34 |
| 21-12-00988-044 | CM-49-BB-S | 12/04/2021 | ROOM S BUBBLER | 12/14/2021 | <1.00 |
| 21-12-00988-045 | CM-50-BB-T | 12/04/2021 | ROOM T BUBBLER | 12/14/2021 | 1.12 |
| 21-12-00988-046 | CM-51-DFL-13 | 12/04/2021 | WATER FOUNTAIN BY ROOM 13 LEFT | 12/14/2021 | <1.00 |
| 21-12-00988-047 | CM-52-DFR-13 | 12/04/2021 | WATER FOUNTAIN BY ROOM 13 RIGHT | 12/14/2021 | <1.00 |
| 21-12-00988-048 | CM-53-DFL-9 | 12/04/2021 | WATER FOUNTAIN BY ROOM 9 LEFT | 12/14/2021 | 1.60 |
| 21-12-00988-049 | CM-54-DFR-9 | 12/04/2021 | WATER FOUNTAIN BY ROOM 9 RIGHT | 12/14/2021 | 3.06 |

| | | | | | |
|----------------------|--------------|---------------------------------------|--------------------------------|------------|------------|
| 21-12-00988-050 | CM-55-DFL-6 | 12/04/2021 | WATER FOUNTAIN BY ROOM 6 LEFT | 12/14/2021 | 1.06 |
| 21-12-00988-051 | CM-56-DFR-6 | 12/04/2021 | WATER FOUNTAIN BY ROOM 6 RIGHT | 12/14/2021 | 3.63 |
| 21-12-00988-052 | CM-57-S-N | 12/04/2021 | NURSE OFFICE SINK | 12/14/2021 | 2.08 |
| 21-12-00988-053 | CM-58-DFL-4B | 12/04/2021 | WATER FOUNTAIN BY 4B LEFT | 12/14/2021 | 2.68 |
| 21-12-00988-054 | CM-59-DFR-4B | 12/04/2021 | WATER FOUNTAIN BY 4B RIGHT | 12/14/2021 | 1.62 |
| 21-12-00988-055 | CM-60-S-S | 12/04/2021 | ROOM 2 SINK | 12/14/2021 | 1.45 |
| 21-12-00988-056 | CM-61-S-1 | 12/04/2021 | ROOM 1 SINK | 12/14/2021 | 1.44 |
| 21-12-00988-057 | CM-62-S-SR | 12/04/2021 | SUN ROOM | 12/14/2021 | <1.00 |
| Middle School | | | | | |
| 21-12-00993-001 | MS-1-DF-LD | LOADING DOCK WATER FOUNT | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-00993-002 | MS-2-S1-LS | LIFE SKILLS SINK 1 | 12/05/2021 | 1.65 | 12/14/2021 |
| 21-12-00993-003 | MS-3-S2-LS | LIFE SKILLS SINK 2 | 12/05/2021 | 1.77 | 12/14/2021 |
| 21-12-00993-004 | MS-4-S3-LS | LIFE SKILLS SINK 3 | 12/05/2021 | 1.04 | 12/14/2021 |
| 21-12-00993-005 | MS-5-S4-LS | LIFE SKILLS SINK 4 | 12/05/2021 | 1.26 | 12/14/2021 |
| 21-12-00993-006 | MS-6-S5-LS | LIFE SKILLS SINK 5 | 12/05/2021 | 1.11 | 12/14/2021 |
| 21-12-00993-007 | MS-7-S6-LS | LIFE SKILLS SINK 6 | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-00993-008 | MS-8-DFL-ME | WATER FOUNTAIN IN MAIN ENTRANCE LEFT | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-00993-009 | MS-9-DFR-ME | WATER FOUNTAIN IN MAIN ENTRANCE RIGHT | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-00993-010 | MS-10-S-MO | MAIN OFFICE SINK | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-00993-011 | MS-11-S-N | NURSE OFFICE SINK | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-00993-012 | MS-12-BB-E | EXAM ROOM BUBBLER | 12/05/2021 | 5.06 | 12/14/2021 |

| | | | | | |
|-----------------|----------------|---|------------|-------|------------|
| 21-12-00993-013 | MS-13-DFL-111 | WATER FOUNTAIN BY ROOM 111 LEFT | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-00993-014 | MS-14-DFLC-111 | WATER FOUNTAIN BY ROOM 111 LEFT CENTER' | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-00993-015 | MS-15-DFRC-111 | WATER FOUNTAIN BY ROOM 111 RIGHT CENTER | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-00993-016 | MS-16-DFR-111 | WATER FOUNTAIN BY ROOM 111 RIGHT | 12/05/2021 | 1.00 | 12/14/2021 |
| 21-12-00993-017 | MS-17-DFL-1009 | WATER FOUNTAIN BY ROOM 1009 LEFT | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-00993-018 | MS-18-DFL-1009 | WATER FOUNTAIN BY ROOM 1009 CENTER | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-00993-019 | MS-19-DFR-1009 | WATER FOUNTAIN BY ROOM 1009 RIGHT | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-00993-020 | MS-20-DFL-126 | WATER FOUNTAIN BY ROOM 126 LEFT | 12/05/2021 | 1.89 | 12/14/2021 |
| 21-12-00993-021 | MS-21-DFCL-126 | WATER FOUNTAIN CENTER LEFT | 12/05/2021 | 1.01 | 12/14/2021 |
| 21-12-00993-022 | MS-22-DFCR-126 | WATER FOUNTAIN CENTER RIGHT | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-00993-023 | MS-23-DFR-126 | WATER FOUNTAIN BY 126 RIGHT | 12/05/2021 | 1.92 | 12/14/2021 |
| 21-12-00993-024 | MS-24-S-126 | ROOM 126 SINK 1 | 12/05/2021 | 1.40 | 12/14/2021 |
| 21-12-00993-025 | MS-25-S2-126 | ROOM 126 SINK 2 | 12/05/2021 | 5.36 | 12/14/2021 |
| 21-12-00993-026 | MS-26-S3-126 | ROOM 126 SINK 3 | 12/05/2021 | 4.38 | 12/14/2021 |
| 21-12-00993-027 | MS-27-S1-128 | ROOM 128 SINK 1 | 12/05/2021 | 4.59 | 12/14/2021 |
| 21-12-00993-028 | MS-28-S2-128 | ROOM 128 SINK 2 | 12/05/2021 | 1.92 | 12/14/2021 |
| 21-12-00993-029 | MS-29-S3-128 | ROOM 128 SINK 3 | 12/05/2021 | 6.19 | 12/14/2021 |

| | | | | | |
|-----------------|----------------|---------------------------------|------------|-------|------------|
| 21-12-00993-030 | MS-30-S4-128 | ROOM 128 SINK 4 | 12/05/2021 | 1.18 | 12/14/2021 |
| 21-12-00993-031 | MS-31-S5-128 | ROOM 128 SINK 5 | 12/05/2021 | 2.72 | 12/14/2021 |
| 21-12-00993-032 | MS-32-S-FL | FACULTY LOUNGE | 12/05/2021 | 1.82 | 12/14/2021 |
| 21-12-00993-033 | MS-33-S1-G | SINK NEAR GYM LEFT | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-00993-034 | MS-34-S2-G | SINK NEAR GYM CENTER | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-00993-035 | MS-35-S3-G | SINK NEAR GYM RIGHT | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-00993-036 | MS-36-DFL-SDIN | WATER FOUNTAIN BY DINING LEFT | 12/05/2021 | 1.06 | 12/14/2021 |
| 21-12-00993-037 | MS-37-DFC-SDIN | WATER FOUNTAIN BY DINING CENTER | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-00993-038 | MS-38-DFR-SDIN | WATER FOUNTAIN BY DINING RIGHT | 12/05/2021 | <1.00 | 12/15/2021 |
| 21-12-00993-039 | MS-39-FP-K | KITCHEN FOOD PREP | 12/05/2021 | 14.3 | 12/15/2021 |
| 21-12-00993-040 | MS-40-S1-K | KITCHEN SINK | 12/05/2021 | 2.97 | 12/15/2021 |
| 21-12-00993-041 | MS-41-S2-K | KITCHEN SINK 2 | 12/05/2021 | 1.86 | 12/15/2021 |
| 21-12-00993-042 | MS-42-S3-K | KITCHEN SINK 3 | 12/05/2021 | 3.39 | 12/15/2021 |
| 21-12-00993-043 | MS-43-BF-K | KITCHEN POT FILLER 1 | 12/05/2021 | 3.77 | 12/15/2021 |
| 21-12-00993-044 | MS-44-S4-K | KITCHEN SINK 4 | 12/05/2021 | 3.33 | 12/15/2021 |
| 21-12-00993-045 | MS-45-PF2-K | KITCHEN POT FILLER 2 | 12/05/2021 | 7.10 | 12/15/2021 |
| 21-12-00993-046 | MS-46-55-K | KITCHEN SINK 5 | 12/05/2021 | 8.54 | 12/15/2021 |
| 21-12-00993-047 | MS-47-FP2-K | KITCHEN FOOD PREP 2 | 12/05/2021 | 2.70 | 12/15/2021 |
| 21-12-00993-048 | MS-48-FP3-K | KITCHEN FOOD PREP 3 | 12/05/2021 | 7.74 | 12/15/2021 |
| 21-12-00993-049 | MS-49-FP4-K | KITCHEN FOOD PREP 4 | 12/05/2021 | 1.19 | 12/15/2021 |
| 21-12-00993-050 | MS-50-PF3-K | KITCHEN POT FILLER 3 | 12/05/2021 | 4.01 | 12/15/2021 |
| 21-12-00993-051 | MS-51-PF4-K | KITCHEN POT FILLER 4 | 12/05/2021 | 18.7 | 12/15/2021 |

| | | | | | |
|-----------------|----------------|---|------------|-------|------------|
| 21-12-00993-052 | MS-52-IM-K | ICE MACHINE | 12/05/2021 | 4.41 | 12/15/2021 |
| 21-12-00993-053 | MS-53-DF-237 | WATER FOUNTAIN BY ROOM 237 | 12/05/2021 | <1.00 | 12/15/2021 |
| 21-12-00993-054 | MS-54-DF-232 | WATER FOUNTAIN BY ROOM 232 LEFT | 12/05/2021 | 3.53 | 12/15/2021 |
| 21-12-00993-055 | MS-55-DFCL-232 | WATER FOUNTAIN BY ROOM 232 CENTER ELFT | 12/05/2021 | <1.00 | 12/15/2021 |
| 21-12-00993-056 | MS-56-DFCR-232 | WATER FOUNTAIN BY ROOM 232 CENTER RIGHT | 12/05/2021 | <1.00 | 12/15/2021 |
| 21-12-00993-057 | MS-57-DFR-232 | WATER FOUNTAIN BY ROOM 232 RIGHT | 12/05/2021 | 1.92 | 12/15/2021 |
| 21-12-00993-058 | MS-58-DFL-2011 | WATER FOUNTAIN BY ROOM 2011 LEFT | 12/05/2021 | <1.00 | 12/15/2021 |
| 21-12-00993-059 | MS-59-DFC-2011 | WATER FOUNTAIN BY ROOM 2011 CENTER | 12/05/2021 | <1.00 | 12/15/2021 |
| 21-12-00993-060 | MS-60-DFL-2011 | WATER FOUNTAIN BY ROOM 2011 RIGHT | 12/05/2021 | <1.00 | 12/15/2021 |
| 21-12-00993-061 | MS-61-DFL-217 | WATER FOUNTAIN BY 217 LEFT | 12/05/2021 | 1.02 | 12/15/2021 |
| 21-12-00993-062 | MS-62-DFCL-217 | WATER FOUNTAIN BY 217 LEFT CENTER | 12/05/2021 | <1.00 | 12/15/2021 |
| 21-12-00993-063 | MS-63-DFCR-217 | WATER FOUNTAIN BY 217 CENTER RIGHT | 12/05/2021 | <1.00 | 12/15/2021 |
| 21-12-00993-064 | MS-64-DFR-217 | WATER FOUNTAIN BY 217 RIGHT | 12/05/2021 | <1.00 | 12/15/2021 |
| 21-12-00993-065 | MS-65-STSR | SUN ROOM | 12/05/2021 | <1.00 | 12/15/2021 |

| Lafayette Mills | | | | | |
|-----------------|---------------|----------------------------|------------|-------|------------|
| 21-12-01004-001 | LM-1-DF-DR | WATER FOUNTAIN DINING ROOM | 12/04/2021 | <1.00 | 12/14/2021 |
| 21-12-01004-002 | LM-2-S-DR | DINING ROOM SINK | 12/04/2021 | <1.00 | 12/14/2021 |
| 21-12-01004-003 | LM-3-FP-K | KITCHEN FOOD PREP SINK | 12/04/2021 | 2.40 | 12/14/2021 |
| 21-12-01004-004 | LM-4-SL-K | KITCHEN SINK LEFT | 12/04/2021 | 1.52 | 12/14/2021 |
| 21-12-01004-005 | LM-5-SR-K | KITCHEN SINK RIGHT | 12/04/2021 | <1.00 | 12/14/2021 |
| 21-12-01004-006 | LM-6-DFL-AP | WATER FOUNTAIN BY AP LEFT | 12/04/2021 | 1.54 | 12/14/2021 |
| 21-12-01004-007 | LM-7-DFR-AP | WATER FOUNTAIN BY AP RIGHT | 12/04/2021 | <1.00 | 12/14/2021 |
| 21-12-01004-008 | LM-8-DF-RM9 | WATER FOUNTAIN BY ROOM 9 | 12/04/2021 | <1.00 | 12/14/2021 |
| 21-12-01004-009 | LM-9-DF-RM12 | WATER FOUNTAIN BY ROOM 12 | 12/04/2021 | <1.00 | 12/14/2021 |
| 21-12-01004-010 | LM-10-DF-RM5 | WATER FOUNTAIN BY ROOM 5 | 12/04/2021 | 1.06 | 12/14/2021 |
| 21-12-01004-011 | LM-11-DF-RM8 | WATER FOUNTAIN BY ROOM 8 | 12/04/2021 | 1.15 | 12/14/2021 |
| 21-12-01004-012 | LM-12-DF-RM1 | WATER FOUNTAIN BY ROOM 1 | 12/04/2021 | 3.49 | 12/14/2021 |
| 21-12-01004-013 | LM-13-DF-RM4 | WATER FOUNTAIN BY ROOM 4 | 12/04/2021 | 2.53 | 12/14/2021 |
| 21-12-01004-014 | LF-14-S-FR | FACULTY ROOM SINK | 12/04/2021 | <1.00 | 12/14/2021 |
| 21-12-01004-015 | LM-15-DF-RM23 | WATER FOUNTAIN BY ROOM 23 | 12/04/2021 | 22.9 | 12/14/2021 |
| 21-12-01004-016 | LM-16-DF-RM22 | WATER FOUNTAIN BY ROOM 22 | 12/04/2021 | 5.54 | 12/14/2021 |

| | | | | | |
|--------------------------------|---------------|--------------------------------------|------------|-------|------------|
| 21-12-01004-017 | LM-17-SL-RM22 | ART ROOM 22 SINK LEFT | 12/04/2021 | 1.52 | 12/14/2021 |
| 21-12-01004-018 | LM-18-SR-RM22 | ART ROOM 22 SINK RIGHT | 12/04/2021 | <1.00 | 12/14/2021 |
| 21-12-01004-019 | LM-19-DF-RM27 | WATER FOUNTAIN BY ROOM 27 | 12/04/2021 | <1.00 | 12/14/2021 |
| 21-12-01004-020 | LM-20-DF-RM24 | WATER FOUNTAIN BY ROOM 24 | 12/04/2021 | <1.00 | 12/14/2021 |
| 21-12-01004-021 | LM-21-DF-RM31 | WATER FOUNTAIN BY ROOM 31 | 12/04/2021 | 29.7 | 12/14/2021 |
| 21-12-01004-022 | LM-22-DF-RM28 | WATER FOUNTAIN BY ROOM 28 | 12/04/2021 | 8.37 | 12/14/2021 |
| 21-12-01004-023 | LM-23-S-N | NURSE OFFICE SINK | 12/04/2021 | 1.32 | 12/14/2021 |
| 21-12-01004-024 | LM-24-DF-RM15 | WATER FOUNTAIN BY ROOM 15 | 12/04/2021 | 1.66 | 12/14/2021 |
| 21-12-01004-025 | LM-25-DF-RM16 | WATER FOUNTAIN BY ROOM 16 | 12/04/2021 | 2.09 | 12/14/2021 |
| 21-12-01004-026 | LM-26-DF-RM19 | WATER FOUNTAIN BY ROOM 19 | 12/04/2021 | 4.40 | 12/14/2021 |
| 21-12-01004-027 | LM-27-DF-RM18 | WATER FOUNTAIN BY ROOM 18 | 12/04/2021 | 7.68 | 12/14/2021 |
| 21-12-01004-028 | LM-28-DFL-G | WATER FOUNTAIN BY GYM LEFT | 12/04/2021 | 1.85 | 12/14/2021 |
| 21-12-01004-029 | LM-29-DFR-G | WATER FOUNTAIN BY GYM RIGHT | 12/04/2021 | <1.00 | 12/14/2021 |
| 21-12-01004-030 | LM-S-SR | SUN ROOM | 12/04/2021 | <1.00 | 12/14/2021 |
| Transportation Building | | | | | |
| 21-12-01019-001 | T-1-DFL-L | WATER FOUNTAIN LEFT | 12/04/2021 | 2.66 | 12/14/2021 |
| 21-12-01019-002 | T-2-DFR-L | WATER FOUNTAIN RIGHT | 12/04/2021 | 1.54 | 12/14/2021 |

| | | | | | |
|--------------------------------|---------------|---------------------------------|------------|-------|------------|
| 21-12-01019-003 | T-3-S-K | KITCHEN SINK | 12/04/2021 | <1.00 | 12/14/2021 |
| 21-12-01019-004 | T-4-SR | SUN ROOM | 12/04/2021 | <1.00 | 12/14/2021 |
| Administration Building | | | | | |
| 21-12-01024-001 | A-1-DF-S | WATER FOUNTAIN 1ST FLR | 12/04/2021 | <1.00 | 12/14/2021 |
| 21-12-01024-002 | A-2-DF-S | WATER FOUNTAIN 2ND FLOOR | 12/04/2021 | <1.00 | 12/14/2021 |
| 21-12-01024-003 | A-3-S | ROOM 405 SINK | 12/04/2021 | 7.23 | 12/14/2021 |
| 21-12-01024-004 | A-4-SR | SUN ROOM | 12/04/2021 | <1.00 | 12/14/2021 |
| Wembrook School | | | | | |
| 21-12-01044-001 | WB-1-S-CBR | CUSTODIAL SINK | 12/05/2021 | <1.00 | 12/15/2021 |
| 21-12-01044-002 | WB-2-S-S | STAGE SINK | 12/05/2021 | 17.5 | 12/15/2021 |
| 21-12-01044-003 | WB-3-FP-K | KITCHEN FOOD PREP | 12/05/2021 | 2.24 | 12/15/2021 |
| 21-12-01044-004 | WB-4-S1-K | KITCHEN SINK | 12/05/2021 | 1.27 | 12/15/2021 |
| 21-12-01044-005 | WB-5-S2-K | KITCHEN SINK | 12/05/2021 | 66.5 | 12/15/2021 |
| 21-12-01044-006 | WB-6-S3-K | KITCHEN SINK | 12/05/2021 | 10.8 | 12/15/2021 |
| 21-12-01044-007 | WB-7-S4-K | KITCHEN SNK | 12/05/2021 | 1.85 | 12/14/2021 |
| 21-12-01044-008 | WB-8-S5-K | KITCHEN SINK | 12/05/2021 | 1.06 | 12/14/2021 |
| 21-12-01044-009 | WB-9-S-FR | FACULTY ROOM | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-01044-010 | WB-10-S-A102 | ROOM A102 SINK | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-01044-011 | WB-11-S-N | NURSE SINK | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-01044-012 | WB-12-BB-102 | ROOM 102 SINK BUBBLER | 12/05/2021 | 2.50 | 12/14/2021 |
| 21-12-01044-013 | WB-13-BB-103 | ROOM 103 BUBBLER | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-01044-014 | WB-14-BB-106 | ROOM 106 BUBBLER | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-01044-015 | WB-15-BB-107 | ROOM 107 BUBBLER | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-01044-016 | WB-16-BB-108 | ROOM 108 BUBBLER | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-01044-017 | WB-17-BB-109 | ROOM 109 BUBBLER | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-01044-018 | WB-18-DFL-111 | WATER FOUNTAIN BY ROOM 111 LEFT | 12/05/2021 | 3.06 | 12/14/2021 |

| | | | | | |
|-----------------|---------------|----------------------------------|------------|-------|------------|
| 21-12-01044-019 | WB-19-DFR-111 | WATER FOUNTAIN BY ROOM 111 RIGHT | 12/05/2021 | 2.78 | 12/14/2021 |
| 21-12-01044-020 | WB-20-BB-111 | ROOM 111 SINK | 12/05/2021 | 1.14 | 12/14/2021 |
| 21-12-01044-021 | WB-21-BB-112 | ROOM 112 BUBBLER | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-01044-022 | WB-22-BB-121 | ROOM 121 BUBBLER | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-01044-023 | WB-23-BB-123 | ROOM 123 BUBBLER | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-01044-024 | WB-24-BB-124 | ROOM 124 BUBBLER | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-01044-025 | WB-25-BB-125 | ROOM 125 BUBBLER | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-01044-026 | WB-26-BB-126 | ROOM 126 BUBBLER | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-01044-027 | WB-27-BB-127 | ROOM 127 BUBBLER | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-01044-028 | WB-28-BB-128 | ROOM 128 BUBBLER | 12/05/2021 | 1.48 | 12/14/2021 |
| 21-12-01044-029 | WB-29-BB-129 | ROOM 129 BUBBLER | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-01044-030 | WB-30-BB-130 | ROOM 130 BUBBLER | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-01044-031 | WB-31-DFR-G | WATER FOUNTAIN BY GYM RIGHT | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-01044-032 | WB-32-DFL-G | WATER FOUNTAIN BY GYM LEFT | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-01044-033 | WB-33-S1-117 | ART ROOM SINK 1 | 12/05/2021 | 17.7 | 12/14/2021 |
| 21-12-01044-034 | WB-34-S2-117 | ART ROOM SINK 2 | 12/05/2021 | 26.0 | 12/14/2021 |
| 21-12-01044-035 | WB-35-S3-117 | ART ROOM SINK 3 | 12/05/2021 | 8.85 | 12/14/2021 |
| 21-12-01044-036 | WB-36-S4-117 | ART ROOM SINK 4 | 12/05/2021 | 6.02 | 12/14/2021 |
| 21-12-01044-037 | WB-37-BB-110 | ROOM 110 BUBBLER | 12/05/2021 | 1.66 | 12/14/2021 |
| 21-12-01044-038 | WB-38-DFL-110 | WATER FOUNTAIN BY ROOM 110 LEFT | 12/05/2021 | 4.16 | 12/14/2021 |
| 21-12-01044-039 | WB-39-DFR-110 | WATER FOUNTAIN BY ROOM 110 RIGHT | 12/05/2021 | 1.19 | 12/14/2021 |
| 21-12-01044-040 | WB-40-S-LMC | MEDIA CENTER SINK | 12/05/2021 | 1.31 | 12/14/2021 |
| 21-12-01044-041 | WB-41-S-206 | ROOM 206 SINK | 12/05/2021 | <1.00 | 12/14/2021 |
| 21-12-01044-042 | WB-42-BB-207 | ROOM 207 BUBBLER | 12/05/2021 | <1.00 | 12/14/2021 |

[illegible]