



*Serving With Pride The  
Township of Manalapan  
and the  
Borough of Englishtown*

**Nicole Santora, Ed.D.**  
*Superintendent of Schools*  
nicolesantora@mersnj.us

Peter M. Friedman Building  
54 Main Street  
Englishtown, N.J. 07726-1599  
(732) 786-2500  
(732) 786-2541 FAX

January 14, 2022

Dear Wemrock Brook Community,

The New Jersey legislature passed a law in 2016 for the periodic testing of lead in drinking water in all schools. We have just completed our next prescribed testing, which included all water outlets, 303 units. In Wemrock Brook School, four outlets showed an elevated level (over 15 ppb).

Location	Concentration	Recommendations
Stage Sink	17.5	<ol style="list-style-type: none"><li>1. Immediately discontinue use of the outlets.</li><li>2. Conduct second draw (flush) samples on this outlet to further delineate the source of contamination.</li></ol>
Kitchen Sink	66.5	<ol style="list-style-type: none"><li>1. Immediately discontinue use of the outlets.</li><li>2. Conduct second draw (flush) samples on this outlet to further delineate the source of contamination.</li></ol>
Art Room Sink 1	17.7	<ol style="list-style-type: none"><li>1. Immediately discontinue use of the outlets.</li><li>2. Conduct second draw (flush) samples on this outlet to further delineate the source of contamination.</li></ol>
Art Room Sink 2	26.0	<ol style="list-style-type: none"><li>1. Immediately discontinue use of the outlets.</li><li>2. Conduct second draw (flush) samples on this outlet to further delineate the source of contamination.</li></ol>

Our first step was to take the unit out of service or in some cases post a sign stating that the water is not for consumption. The affected units will be retested and if the results remain elevated, the fixture will be filtered with an appropriate device or replaced. The District will submit the results and remediation efforts to the State for approval. In addition, the results will also be posted on the district website.

For more information on reducing lead exposure in your home and the health effects of lead, visit the [EPA's website](#) or call the National Lead Information Center at 800.424.LEAD.

Thank you,

Nicole Santora, Ed.D  
Superintendent of Schools