



*Serving With Pride The
Township of Manalapan
and the
Borough of Englishtown*

Nicole Santora, Ed.D.
Superintendent of Schools
nicolesantora@mersnj.us

Peter M. Friedman Building
54 Main Street
Englishtown, N.J. 07726-1599
(732) 786-2500
(732) 786-2541 FAX

January 14, 2022

Dear Milford Brook Community,

The New Jersey legislature passed a law in 2016 for the periodic testing of lead in drinking water in all schools. We have just completed our next prescribed testing, which included all water outlets, 303 units. In Milford Brook School, one outlet showed an elevated level (over 15 ppb).

Location	Concentration	Recommendations
Water Fountain by Room 13 right	17.8	<ol style="list-style-type: none">1. Immediately discontinue use of the outlets.2. Conduct second draw (flush) samples on this outlet to further delineate the source of contamination.

Our first step was to take the unit out of service or in some cases post a sign stating that the water is not for consumption. The affected units will be retested and if the results remain elevated, the fixture will be filtered with an appropriate device or replaced. The District will submit the results and remediation efforts to the State for approval. In addition, the results will also be posted on the district website.

For more information on reducing lead exposure in your home and the health effects of lead, visit the [EPA's website](#) or call the National Lead Information Center at 800.424.LEAD.

Thank you,

Nicole Santora, Ed.D
Superintendent of Schools