



ADDENDUM NO. #3 TO **ASBESTOS ABATEMENT** **SPECIFICATIONS**

Asbestos Abatement Prior to Demolition
@
Morris Adler Elementary School

Owner:

Southfield Public Schools
24661 Lahser Road
Southfield, Michigan 48033

Building(s):

Morris Adler Elementary School
19100 Filmore Road
Southfield, Michigan 48075

AEG Project #: **AE230880**
Issue Date: Tuesday, October 24, 2023
Bids Due: **10:00 A.M., Friday, October 27, 2023**

The following changes have been made to the asbestos abatement specification for asbestos abatement activities at Morris Adler Elementary School and should be incorporated into the Scope-of-Work.

1. **Bid No. 23.01 – Asbestos Abatement Prior to Renovations at Morris Adler Elementary School**

Adler Elementary School, Project Group AE-1 – “Area B Abatement” (Pages 21-25)

Due to clarification of room names to match maps in the specification and addition of materials to be abated, this entire project has been corrected to include additional asbestos floor tile, non-asbestos floor tile mastic and tagged fire doors materials. A copy of the corrected project scope of work and requirements for “Adler Elementary School – Project Group AE-1 - “Area B Abatement”” is located in Attachment #1. Please refer to the corrected “Adler Elementary School – Project Group AE-1 - “Area B Abatement”” included in this addendum only. Do not refer to the “Adler Elementary School – Project Group AE-1 - “Area B Abatement”” issued in the specification or Addendum #1 documents.

Southfield Public Schools
Bid No. 23.01
Addendum No. #3
Attachment #1

Project Group AE-1 - "Area B Abatement"

Project Summary:

The first project for abatement at Morris Adler Elementary School includes the removal and disposal of all asbestos flooring materials, including all asbestos floor tile, all non-asbestos floor tile mastic, all non-asbestos carpet, all basketball backboards with asbestos coating, all interior door frames with asbestos caulk, all sinks with asbestos undercoating and all tagged fire doors identified throughout renovation areas. This project will include, but is not limited to, Area B renovation areas. These projects at Morris Adler Elementary School will involve multiple negative pressure enclosures and regulated areas to remove the asbestos materials using Class II removal procedures. The project will begin on Monday, November 6, 2023, and will be complete with all abatement activities, including tear down activities, by the end of the work day on Friday, November 10, 2023. The project schedule allows for a total of five (5) work days (Monday-Friday) to complete the project.

Abatement Activities:

1. Remove and dispose of all asbestos floor tile from the identified areas at Morris Adler Elementary School.
 2. Remove and dispose of all non-asbestos floor tile mastic from the identified areas at Morris Adler Elementary School.
 3. Remove and dispose of all non-asbestos carpet from the identified areas at Morris Adler Elementary School.
 4. Remove and dispose of all basketball backboards with asbestos coating material from the identified areas at Morris Adler Elementary School.
 5. Remove and dispose of all interior door frames with asbestos caulk from the identified areas at Morris Adler Elementary School.
 6. Remove and dispose of all sinks with asbestos undercoating from the identified areas at Morris Adler Elementary School.
 7. Remove and dispose of all tagged fire doors from the identified areas at Morris Adler Elementary School.
-

Summary of Locations:

| Room / Location Materials -> | FT | Non-ACM FTM | Carpet | Backboard | Door Frame | Sink | Fire Door |
|--|-------|----------------|--------|-----------|---------------|------|-----------|
| Boiler Room | | | | | | | 1 |
| Library | 1,440 | 1,440 | 1,440 | | | | |
| Main Office (General Office) | 660 | 660 | 660 | | | | |
| Main Office - Storage | 180 | 180 | 180 | | | | |
| Main Office – Work Room | 225 | 225 | 225 | | | | 2 |
| Main Office – Work Room Office | 140 | 140 | 140 | | | | 2 |
| Multipurpose Room – Marked Areas | 120 | 120 | | 4 | | | |
| Art Room (Per Specification Map) | 840 | 840 | | | 1 | 1 | |
| Resource Room (Per Specification Map) | 840 | 840 | 840 | | 1 | 1 | |
| Music Room (Per Specification Map) | | | | | 1 | 1 | |

ADDENDUM NO. #3

| Room / Location Materials -> | FT | Non-ACM FTM | Carpet | Backboard | Door Frame | Sink | Fire Door |
|---|----|----------------|--------|-----------|---------------|------|-----------|
| Custodial Closet Near Planetarium | | | | | | | 1 |
| Custodial Closet Outside Boiler Room | | | | | | | 1 |

Key for Table

| | |
|-------------|--|
| FT | Asbestos Floor Tile |
| Non-ACM FTM | Non-Asbestos Floor Tile Mastic |
| Carpet | Non-Asbestos Carpet |
| Backboard | Basketball Backboard with Asbestos Coating |
| Door Frame | Interior Door Frame with Asbestos Caulk |
| Sink | Sink with Asbestos Undercoating |
| Fire Door | Tagged Fire Door |

The scope of abatement for Project Group AE-1 includes all asbestos floor tile, non-asbestos floor tile mastic, non-asbestos carpet, basketball backboards with asbestos coating, interior door frame with asbestos caulk, sink with asbestos undercoating and tagged fire door materials.

Abatement Requirements:

The Contractor will be allowed to construct multiple negative pressure enclosures for the complete removal of all of the materials detailed in the “Abatement Activities” for Project Group AE-1.

1. The Contractor is responsible for all of the materials listed in the “Abatement Activities” located inside of the project areas. The project areas include all portions of the functional spaces listed in the “Summary of Locations” table. When present in, connected to or adjacent to the room, materials located in bathrooms, closets, storage rooms, below fixtures (such as radiators, cabinets and bookcases), behind furniture and inside sink cabinets, flooring materials are included when exposed by pre-abatement demolition activities. Additional descriptions for certain areas are listed below:
 - Material Below Sink Cabinets/Casework: The Contractor will remove all asbestos flooring material and non-asbestos floor tile mastic material up to the sink cabinets/casework. Any material which extends below the sink cabinets/casework and cannot be pulled out will remain in place and will be sealed in place.
2. The regulated areas will be emptied of all furniture, furnishings, and moveable objects prior to the start of the project. This activity will be completed by the Owner.
3. The exact routing of projects and configuration of the number of regulated areas/combination of functional spaces will be coordinated on-site. When possible, adjoining functional spaces will be combined into a single regulated area. All negative pressure enclosures established for the removal of asbestos thermal system insulation, not utilizing glovebags, will be set-up in accordance with the following **minimum** guidelines prior to the start of any abatement activities:
 - Critical barriers, constructed of a minimum of one (1) layer of six-mil polyethylene sheeting, will be set-up over all access points to non-project areas, such as doors to adjoining rooms/hallways and exterior doors/windows. Asbestos warning signs will be placed on the non-project side of the critical barrier when necessary to prohibit entrance. No access will be made from these locations into the project area at any time (except through the decontamination chamber).
 - Critical barriers, constructed of a minimum of one (1) layer of six-mil polyethylene sheeting, will be placed over all ceiling return vents, electrical equipment, and all items which cannot be decontaminated inside of the project area. Critical barriers, constructed of a minimum of two (2) layers of six-mil polyethylene sheeting, will be placed over all in ceiling vents.

ADDENDUM NO. #3

- A minimum of one (1) layer of six-mil polyethylene sheeting will be placed over all wall surfaces, all counters and other non-floor surfaces in the project areas.
 - A minimum of two (2) layer of six-mil polyethylene sheeting will be placed over all non-asbestos flooring inside of or adjacent to the project areas (such as carpeting in the room, ceramic tile in the bathrooms, or other floor tile and carpeting in the hallways). THE CONTRACTOR WILL BE RESPONSOSIBLE FOR DAMAGE TO ADJACENT FLOORING.
 - A minimum of one (1) air filtration devices (AFDs) will be required in each functional space in excess of 700 square feet. This minimum number of machines is desired to create a minimum negative pressure of 0.02 inches of water equivalent, sufficient air changes and appropriate air flow through the enclosure. The Contractor will be responsible for properly securing the exhaust tubes in any exterior windows and/or doors used for exhaust locations.
 - A three stage decontamination chamber will be required for this project. The decontamination chamber will be connected at a location convenient to building access and waste out activities and will be coordinated on-site. A black polyethylene barrier will be placed in front of the decontamination chamber to provide an additional visual barrier to the work area.
 - The construction of a bag-out chamber will be permitted. The exact location, set-up, position and construction of the bag-out chamber must be reviewed with Arch Environmental Group, Inc.'s Project Coordinator. Bag out chambers set-up without the review and approval of Arch Environmental Group, Inc. will be sealed and/or torn down at the discretion of Arch Environmental Group, Inc.
 - Visual barriers, constructed of a minimum of one (1) layer of black polyethylene sheeting, will be set-up at various locations to provide an additional visual barrier to the work area. The exact number and locations will be determined on site, based on building occupancy and usage patterns.
4. All asbestos floor tile abatement activities will be completed in accordance with the listed "Class II Non-Friable Floor Tile Abatement Procedures" (General Procedures for Asbestos Abatement, Item 11.2") and with all applicable provisions of the OSHA Asbestos Standard (1926.1101(g) – "Methods of Compliance").
 5. **The Contractor will be required use friable means, including mechanical means, to remove the non-asbestos floor tile mastic in the project area. The materials will be removed inside of an established negative pressure enclosure.**
 6. The Contractor will be responsible for the removal and disposal of all carpet materials in locations identified to have asbestos flooring materials. All non-asbestos carpet removal activities will be completed in accordance with the listed "Non-Asbestos Carpet Material Removal Procedures" ("General Procedures for Asbestos Abatement, Item 11.1") and with all applicable provisions of the OSHA Asbestos Standard (1926.1101(g) - "Methods of Compliance") regarding disturbances to floor tile materials.
 7. All regulated areas for the removal of interior door frames with asbestos caulk and basketball backboards with asbestos coating, will be set-up in accordance with the following minimum guidelines prior to the start of any abatement activities:
 - Asbestos banner tape and asbestos warning signs will be set-up extending a minimum of 8' in all directions from the door frames and basketball backboards.

- A minimum of one (1) layer of six-mil polyethylene sheeting will be set-up on the floor in all directions from door frames and basketball backboards and will be secured to the floor below the door frames and basketball backboards. The polyethylene sheeting will be sufficient in length to catch all door caulk, frame debris and backboard coating material which may fall to the ground and to wrap the door frames and basketball backboards for disposal.
 - AFDs and decontamination units will not be required, unless special conditions exist.
 - All door frames and basketball backboards will be removed using intact removal methods. The Contractor will not be allowed to cut through any door caulk or backboard coating material using mechanical means. The competent person will be required to ensure that all door frames and basketball backboards are removed intact and that all procedures relating to the removal are strictly followed.
8. The Contractor will disconnect and wrap all sinks with asbestos undercoating materials in a minimum of one (1) layer of six-mil polyethylene sheeting, seal the polyethylene sheeting, label the waste and place the waste in the on-site dumpster. The Contractor will wet-wipe and HEPA vacuum the floor below the sink only if the sink is damaged.
 9. The Contractor will wrap all fire doors in a minimum of one (1) layer of six-mil polyethylene sheeting, seal the polyethylene sheeting, label the waste and place the waste in the on-site dumpster. The Contractor will wet-wipe and HEPA vacuum the floor below the door only if the door is damaged and packing material is visible.
 10. All asbestos-containing materials must be removed using wet methods and then bagged and sealed immediately. Bags will be randomly checked as they are transported from the enclosure and double bagged. All bags determined to not be adequately wet will be sent back into the enclosure. No bags may remain open inside the enclosure. The Contractor will be permitted to leave sealed bags inside the enclosure overnight. All bags must be removed from the enclosure prior to the start of the visual inspection.
 11. All surfaces inside the enclosure will be fully washed with a combination of wire brushing, rinsing, wet-wiping and HEPA vacuuming during the final cleaning portion of the project. During final cleaning activities, the ceiling will be rinsed and then encapsulated during the lock down portion of the project.
 12. At the conclusion of the final cleaning activities in the enclosure, a visual inspection will be completed in accordance with the listed "Visual Inspection Procedures" (Item #5, "General Requirements and Information").

Final Clearance Sample Requirements:

PCM Clearance Air Samples

Each of the regulated areas established for the removal of the materials described in Project Group AE-1 will be cleared using Phase Contrast Microscopy (PCM). Pursuant to the requirements of AHERA, five (5) PCM samples will be collected from each regulated area. All five samples must be analyzed below 0.01 fibers per cubic centimeter allow for tear down of the enclosure. All PCM air samples will be collected in accordance with the AHERA regulation and all EPA recommended guidelines. Arch Environmental Group, Inc. reserves the right to reduce the number of clearance samples to one (1) for regulated areas involving only the removal of non-friable asbestos flooring materials.

Project Schedule:

The Contractor will start the project on Monday, November 6, 2023, and will be complete with all abatement activities, including tear down activities, by the end of the work day on Friday, November 10, 2023. The project schedule allows for a total of five (5) work days (Monday-Friday) to complete the project. Additional project dates include:

ADDENDUM NO. #3

Southfield Public Schools

Asbestos Abatement Prior to Renovations @ Morris Adler Elementary School

| # | Location | Start | Ready for Pas | End | # Days |
|------|----------|-----------------|---------------------------------|---------------------------------|--------|
| AE-1 | Area B | Monday, 11-6-23 | Friday, 11-10-23 @ 5:30 p.m. | Friday, 11-10-23 @ 5:30 p.m. | 5 |

END OF ADDENDUM