

Oak Hills

LOCATION	SAMPLE ID	DATE	LEAD RESULT (ppb)
Kitchen	22431800-001KF24A	3/21/2024	1.3
Cafeteria	22431800-002WB24A	3/21/2024	ND
Cafeteria	22431800-003DW24A	3/21/2024	ND
Health Room	22431800-004NS24A	3/21/2024	0.379
Main Hall (by Café)	22431800-005DW24A	3/21/2024	ND
A100	22431800-006CF24A	3/21/2024	4.12
A100	22431800-007DW24A	3/21/2024	5.22
A102	22431800-008CF24A	3/21/2024	1.79
A102	22431800-009DW24A	3/21/2024	2.26
A104	22431800-010CF24A	3/21/2024	1.64
A104	22431800-011DW24A	3/21/2024	1.85
A106	22431800-012CF24A	3/21/2024	3.15
A106	22431800-013DW24A	3/21/2024	3.23
A108	22431800-014CF24A	3/21/2024	2.05
A108	22431800-015DW24A	3/21/2024	2.87
A110	22431800-016CF24A	3/21/2024	3.84
A110	22431800-017DW24A	3/21/2024	2.59
Library Office	22431800-018SF24A	3/21/2024	7.76
South Library Hall	22431800-019DW24A	3/21/2024	0.438
A112	22431800-020CF24A	3/21/2024	1.49
A112	22431800-021DW24A	3/21/2024	1.78
A114	22431800-022CF24A	3/21/2024	1.26
A114	22431800-023DW24A	3/21/2024	0.854
A116	22431800-024CF24A	3/21/2024	1.21
A116	22431800-025DW24A	3/21/2024	2.11
A118	22431800-026CF24A	3/21/2024	1.71
A118	22431800-027DW24A	3/21/2024	1.81
A120	22431800-028CF24A	3/21/2024	1.77
A120	22431800-029DW24A	3/21/2024	1.26
A122	22431800-030CF24A	3/21/2024	1.74
A122	22431800-031DW24A	3/21/2024	2.55
Hall North of Library	22431800-032WB24A	3/21/2024	ND
Hall North of Library	22431800-033DW24A	3/21/2024	ND
Work Room 2 <i>(restricted access)</i>	22431800-034SF24A	3/21/2024	22.8
Work Room 2 <i>(post mitigation)</i>	22431800-058SF24A	6/13/2024	11.8
Work Room 2 <i>(post mitigation)</i>	22431800-034SF24A	7/12/2024	4.11
Staff Break Room	22431800-035SF24A	3/21/2024	1.2
B100	22431800-036CF24A	3/21/2024	8.59
B100	22431800-037DW24A	3/21/2024	3.19
B102	22431800-038CF24A	3/21/2024	4.71
B102	22431800-039DW24A	3/21/2024	0.439
B104	22431800-040CF24A	3/21/2024	6.22
B104	22431800-041DW24A	3/21/2024	0.856
B106	22431800-042CF24A	3/21/2024	7.14

B106	22431800-043DW24A	3/21/2024	2.05
B Hall	22431800-044WB24A	3/21/2024	ND
B Hall	22431800-045DW24A	3/21/2024	ND
B116	22431800-046CF24A	3/21/2024	2.15
B116	22431800-047DW24A	3/21/2024	ND
B118	22431800-048CF24A	3/21/2024	0.896
B118	22431800-049DW24A	3/21/2024	4.37
B120	22431800-050CF24A	3/21/2024	2.25
B120	22431800-051DW24A	3/21/2024	2.44
B124 *(B122)	22431800-054CF24A (A)	3/21/2024	2.52
B124	22431800-054CF24A (B)	3/21/2024	2.31
B124 *(B122)	22431800-055DW24A (A)	3/21/2024	1.48
B124	22431800-055DW24A (B)	3/21/2024	3.3
B126	22431800-056CF24A	3/21/2024	2.39
B126	22431800-057DW24A	3/21/2024	1.89