

**BAS 2019 Bond**  
**Uninterruptible Power Supply FAQ**  
**Updated January 6, 2020**

1. Are any of these UPSs going to be 2 post racks?  
Yes, 16 two-post free standing racks.
2. Is it OK to quote a lithium-ion UPS?  
Yes
3. For installation, who will be responsible for powering down the equipment?  
Brighton Area Schools will coordinate with your installation team and someone from our network team will be present at switchover time.
4. Are you going to want network cards or temperature and humidity probes?  
Network cards will be needed for all equipment.
5. Do you have a breakdown of how many UPS/PDU units will be at each location?
  - a. Miller - 3 units
  - b. Spencer- 1 Unit
  - c. BECC - 5 units
  - d. BHS - 17 Units
  - e. Maltby - 4 Units
  - f. Scranton - 3 units
  - g. Transportation - 1 Unit
  - h. Hawkins - 2 units
  - i. Hilton - 2 units
  - j. Hornung - 1 Unit
6. Can we ship UPS/PDU to each location where it will be installed?  
Yes
7. What equipment will need to be removed?  
Existing Eaton UPS units and spare battery packs

8. Do we need to provide disposal services for removed equipment?

Yes

9. Are we responsible for the waste disposal created from unpacking new equipment?

No, there are dumpsters at each location.

10. Also the 16 that are 2 post racks is the current UPS on the bottom? (for center of gravity purposes)

All UPS units at BAS, regardless of rack, are at the bottom of the rack.

11. One asks if you will need network cards. Answer is yes. The model you specify does not have a network card and nowhere in the bid does it request network card. Should this be a separate line item?

Yes, a separate line item please

12. These UPS (the smt) has smart connect which gives you the ability to monitor via the APC smart connect software. Can you please clarify.

Smart Connect software is not necessary for this project. UPS monitoring will be handled through the network card.