

**Appendix D**  
Excel Template for Lead Results

Client : PARS Environmental  
Project ID : Brielle School, 605 Union Lane

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
BES-Field Blank	N	P21-07892-01	PAS	NJDEP 15001	7/28/2021	5:11	SM 3113 B	7/30/2021	8:01	-0.23	2.00	1	N	ND
BES-1-C7BR-BF-P	N	P21-07892-02	PAS	NJDEP 15001	7/28/2021	5:14	SM 3113 B	7/30/2021	8:05	0.730	2.00	1	N	ND
BES-1-C7GR-BF-P	N	P21-07892-03	PAS	NJDEP 15001	7/28/2021	5:15	SM 3113 B	7/30/2021	8:29	2.17	2.00	1	N	
BES-1-9-CF-P	N	P21-07892-04	PAS	NJDEP 15001	7/28/2021	5:17	SM 3113 B	7/30/2021	8:33	9.83	2.00	1	N	
BES-1-11-BF-P	N	P21-07892-05	PAS	NJDEP 15001	7/28/2021	5:18	SM 3113 B	7/30/2021	8:37	3.13	2.00	1	N	
BES-1-8-CF-P	N	P21-07892-06	PAS	NJDEP 15001	7/28/2021	5:21	SM 3113 B	7/30/2021	8:41	1.69	2.00	1	N	J
BES-1-10-SB-P	N	P21-07892-07	PAS	NJDEP 15001	7/28/2021	5:22	SM 3113 B	7/30/2021	8:45	11.7	2.00	1	N	
BES-1-10-BF-P	N	P21-07892-08	PAS	NJDEP 15001	7/28/2021	5:23	SM 3113 B	7/30/2021	8:49	0.970	2.00	1	N	J
BES-1-7-CF-P	N	P21-07892-09	PAS	NJDEP 15001	7/28/2021	5:22	SM 3113 B	7/30/2021	8:53	14.6	2.00	1	N	
BES-1-6-CF-P	N	P21-07892-10	PAS	NJDEP 15001	7/28/2021	5:24	SM 3113 B	7/30/2021	8:57	1.93	2.00	1	N	J
BES-1-1-CF-P	N	P21-07892-11	PAS	NJDEP 15001	7/28/2021	5:25	SM 3113 B	7/30/2021	9:01	1.21	2.00	1	N	J
BES-1-1-BF-P	N	P21-07892-12	PAS	NJDEP 15001	7/28/2021	5:26	SM 3113 B	7/30/2021	9:14	0.012	2.00	1	N	ND
BES-1-2-3-BP-P	N	P21-07892-13	PAS	NJDEP 15001	7/28/2021	5:28	SM 3113 B	7/30/2021	9:18	0.490	2.00	1	N	ND
BES-1-2-3-CF-P	N	P21-07892-14	PAS	NJDEP 15001	7/28/2021	5:29	SM 3113 B	7/30/2021	9:22	0.970	2.00	1	N	J
BES-1-4-CF-P	N	P21-07892-15	PAS	NJDEP 15001	7/28/2021	5:30	SM 3113 B	7/30/2021	9:26	2.41	2.00	1	N	
BES-1-5-CF-P	N	P21-07892-16	PAS	NJDEP 15001	7/28/2021	5:33	SM 3113 B	7/30/2021	9:30	2.17	2.00	1	N	
BES-1-HS3-BT-P	N	P21-07892-17	PAS	NJDEP 15001	7/28/2021	5:34	SM 3113 B	7/30/2021	9:34	0.012	2.00	1	N	ND
BES-1-S1-CF-P	N	P21-07892-18	PAS	NJDEP 15001	7/28/2021	5:35	SM 3113 B	7/30/2021	9:38	9.35	2.00	1	N	
BES-1-12-CF-P	N	P21-07892-19	PAS	NJDEP 15001	7/28/2021	5:40	SM 3113 B	7/30/2021	9:43	2.17	2.00	1	N	
BES-1-T5GR-BF-P	N	P21-07892-20	PAS	NJDEP 15001	7/28/2021	5:41	SM 3113 B	7/30/2021	9:47	0.730	2.00	1	N	ND
BES-1-T6BR-BF-P	N	P21-07892-21	PAS	NJDEP 15001	7/28/2021	5:42	SM 3113 B	7/30/2021	9:59	0.730	2.00	1	N	ND
BES-1-13-CF-P	N	P21-07892-22	PAS	NJDEP 15001	7/28/2021	5:45	SM 3113 B	7/30/2021	10:37	1.45	2.00	1	N	J
BES-1-18-CF-P	N	P21-07892-23	PAS	NJDEP 15001	7/28/2021	5:46	SM 3113 B	7/30/2021	10:41	1.93	2.00	1	N	J
BES-1-14-CF-P	N	P21-07892-24	PAS	NJDEP 15001	7/28/2021	5:47	SM 3113 B	7/30/2021	10:45	2.65	2.00	1	N	
BES-1-19-CF-P	N	P21-07892-25	PAS	NJDEP 15001	7/28/2021	5:50	SM 3113 B	7/30/2021	10:49	0.730	2.00	1	N	ND
BES-1-15-CF-P	N	P21-07892-26	PAS	NJDEP 15001	7/28/2021	5:51	SM 3113 B	7/30/2021	10:52	6.96	2.00	1	N	
BES-1-20-CF-P	N	P21-07892-27	PAS	NJDEP 15001	7/28/2021	5:52	SM 3113 B	7/30/2021	10:56	2.17	2.00	1	N	
BES-1-16-CF-P	N	P21-07892-28	PAS	NJDEP 15001	7/28/2021	5:52	SM 3113 B	7/30/2021	11:24	17.7	4.00	2	N	
BES-1-21-CF-P	N	P21-07892-29	PAS	NJDEP 15001	7/28/2021	5:53	SM 3113 B	7/30/2021	11:28	10.3	2.00	1	N	
BES-1-A2-NS1-P	N	P21-07892-30	PAS	NJDEP 15001	7/28/2021	5:55	SM 3113 B	7/30/2021	11:32	0.250	2.00	1	N	ND
BES-1-A2-NS2-P	N	P21-07892-31	PAS	NJDEP 15001	7/28/2021	5:56	SM 3113 B	7/30/2021	11:37	0.012	2.00	1	N	ND
BES-1-A2-IM-P	N	P21-07892-32	PAS	NJDEP 15001	7/28/2021	5:57	SM 3113 B	7/30/2021	11:41	-0.47	2.00	1	N	ND
BES-1-A2-BF-P	N	P21-07892-33	PAS	NJDEP 15001	7/28/2021	5:58	SM 3113 B	7/30/2021	11:45	0.970	2.00	1	N	J
BES-1-22-CF-P	N	P21-07892-34	PAS	NJDEP 15001	7/28/2021	5:59	SM 3113 B	7/30/2021	11:49	0.250	2.00	1	N	ND
BES-1-S4-TF-P	N	P21-07892-35	PAS	NJDEP 15001	7/28/2021	6:01	SM 3113 B	7/30/2021	11:53	0.012	2.00	1	N	ND
BES-1-S4-IM-P	N	P21-07892-36	PAS	NJDEP 15001	7/28/2021	6:01	SM 3113 B	7/30/2021	11:57	15.3	2.00	1	N	
BES-1-24BR-BF-P	N	P21-07892-37	PAS	NJDEP 15001	7/28/2021	6:02	SM 3113 B	7/30/2021	12:51	420	100	50	N	
BES-1-24GR-BF-P	N	P21-07892-38	PAS	NJDEP 15001	7/28/2021	6:03	SM 3113 B	7/30/2021	12:55	98.3	20.0	10	N	
BES-1-T11GR-BF-P	N	P21-07892-39	PAS	NJDEP 15001	7/28/2021	6:07	SM 3113 B	7/30/2021	12:22	2.89	2.00	1	N	
BES-1-T10BR-BF-P	N	P21-07892-40	PAS	NJDEP 15001	7/28/2021	6:08	SM 3113 B	7/30/2021	12:43	0.490	2.00	1	N	ND
BES-1-37-CF1-P	N	P21-07892-41	PAS	NJDEP 15001	7/28/2021	6:09	SM 3113 B	7/30/2021	8:49	0.370	2.00	1	N	ND
BES-1-37-CF2-P	N	P21-07892-42	PAS	NJDEP 15001	7/28/2021	6:09	SM 3113 B	7/30/2021	9:05	-0.07	2.00	1	N	ND
BES-1-37-CF3-P	N	P21-07892-43	PAS	NJDEP 15001	7/28/2021	6:10	SM 3113 B	7/30/2021	9:17	1.48	2.00	1	N	J
BES-1-37-CF4-P	N	P21-07892-44	PAS	NJDEP 15001	7/28/2021	6:10	SM 3113 B	7/30/2021	9:20	0.810	2.00	1	N	ND
BES-1-32-CF-P	N	P21-07892-45	PAS	NJDEP 15001	7/28/2021	6:18	SM 3113 B	7/30/2021	9:24	7.24	2.00	1	N	
BES-1-HC3-BT-P	N	P21-07892-46	PAS	NJDEP 15001	7/28/2021	6:20	SM 3113 B	7/30/2021	9:28	-0.74	2.00	1	N	ND
BES-1-33-CF-P	N	P21-07892-47	PAS	NJDEP 15001	7/28/2021	6:21	SM 3113 B	7/30/2021	9:32	1.92	2.00	1	N	J
BES-1-T12BR-BF-P	N	P21-07892-48	PAS	NJDEP 15001	7/28/2021	6:23	SM 3113 B	7/30/2021	9:36	-0.29	2.00	1	N	ND
BES-1-T13GR-BF-P	N	P21-07892-49	PAS	NJDEP 15001	7/28/2021	6:24	SM 3113 B	7/30/2021	9:40	2.59	2.00	1	N	
BES-1-A17KIT-FP1-P	N	P21-07892-50	PAS	NJDEP 15001	7/28/2021	6:27	SM 3113 B	7/30/2021	9:44	0.370	2.00	1	N	ND
BES-1-A17KIT-FP2-P	N	P21-07892-51	PAS	NJDEP 15001	7/28/2021	6:28	SM 3113 B	7/30/2021	9:49	0.150	2.00	1	N	ND
BES-1-A17KIT-IM-P	N	P21-07892-52	PAS	NJDEP 15001	7/28/2021	6:29	SM 3113 B	7/30/2021	12:24	0.150	2.00	1	Y	ND
BES-1-T17BR-BF-P	N	P21-07892-53	PAS	NJDEP 15001	7/28/2021	6:36	SM 3113 B	7/30/2021	10:01	-0.96	2.00	1	N	ND
BES-1-T18GR-BF-P	N	P21-07892-54	PAS	NJDEP 15001	7/28/2021	6:37	SM 3113 B	7/30/2021	10:05	3.03	2.00	1	N	
BES-1-HC1-BT-P	N	P21-07892-55	PAS	NJDEP 15001	7/28/2021	6:38	SM 3113 B	7/30/2021	10:09	-0.52	2.00	1	N	ND
BES-1-45-CF1-P	N	P21-07892-56	PAS	NJDEP 15001	7/28/2021	6:42	SM 3113 B	7/30/2021	10:13	-0.29	2.00	1	N	ND
BES-1-45-CF2-P	N	P21-07892-57	PAS	NJDEP 15001	7/28/2021	6:42	SM 3113 B	7/30/2021	10:17	1.70	2.00	1	N	J
BES-1-45-CF3-P	N	P21-07892-58	PAS	NJDEP 15001	7/28/2021	6:43	SM 3113 B	7/30/2021	10:21	0.150	2.00	1	N	ND
BES-1-45-CF4-P	N	P21-07892-59	PAS	NJDEP 15001	7/28/2021	6:44	SM 3113 B	7/30/2021	10:26	4.80	2.00	1	N	
BES-1-45-CF5-P	N	P21-07892-60	PAS	NJDEP 15001	7/28/2021	6:45	SM 3113 B	7/30/2021	10:30	0.590	2.00	1	N	ND
BES-1-45-CF6-P	N	P21-07892-61	PAS	NJDEP 15001	7/28/2021	6:45	SM 3113 B	7/30/2021	10:34	-0.07	2.00	1	N	ND
BES-1-45-CF7-P	N	P21-07892-62	PAS	NJDEP 15001	7/28/2021	6:46	SM 3113 B	7/30/2021	10:58	-0.74	2.00	1	N	ND
BES-1-44-CF-P	N	P21-07892-63	PAS	NJDEP 15001	7/28/2021	6:47	SM 3113 B	7/30/2021	11:02	0.150	2.00	1	N	ND
BES-1-43-CF-P	N	P21-07892-64	PAS	NJDEP 15001	7/28/2021	6:48	SM 3113 B	7/30/2021	11:06	-0.52	2.00	1	N	ND
BES-1-42-CF-P	N	P21-07892-65	PAS	NJDEP 15001	7/28/2021	6:55	SM 3113 B	7/30/2021	11:10	1.70	2.00	1	N	J
BES-1-41-CF-P	N	P21-07892-66	PAS	NJDEP 15001	7/28/2021	6:55	SM 3113 B	7/30/2021	11:14	2.37	2.00	1	N	
BES-1-40-CF-P	N	P21-07892-67	PAS	NJDEP 15001	7/28/2021	6:56	SM 3113 B	7/30/2021	11:18	-0.96	2.00	1	N	ND
BES-1-39-CF1-P	N	P21-07892-68	PAS	NJDEP 15001	7/28/2021	6:56	SM 3113 B	7/30/2021	11:30	-0.07	2.00	1	N	ND
BES-1-39-CF2-P	N	P21-07892-69	PAS	NJDEP 15001	7/28/2021	6:57	SM 3113 B	7/30/2021	11:34	3.47	2.00	1	N	

**Appendix D**  
**Excel Template for Lead Results**

Client : PARS Environmental  
 Project ID : Brielle School, 605 Union Lane

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
BES-1-39-CF3-P	N	P21-07892-70	PAS	NJDEP 15001	7/28/2021	6:57	SM 3113 B	7/30/2021	11:38	-0.74	2.00	1	N	ND
BES-1-39-CF4-P	N	P21-07892-71	PAS	NJDEP 15001	7/28/2021	6:58	SM 3113 B	7/30/2021	11:42	1.48	2.00	1	N	J
BES-1-39-CF5-P	N	P21-07892-72	PAS	NJDEP 15001	7/28/2021	6:59	SM 3113 B	7/30/2021	11:46	3.25	2.00	1	N	
BES-1-39-CF6-P	N	P21-07892-73	PAS	NJDEP 15001	7/28/2021	7:00	SM 3113 B	7/30/2021	11:50	0.590	2.00	1	N	ND
BES-1-56-CF1-P	N	P21-07892-74	PAS	NJDEP 15001	7/28/2021	7:05	SM 3113 B	7/30/2021	11:54	-0.29	2.00	1	N	ND
BES-1-56-CF2-P	N	P21-07892-75	PAS	NJDEP 15001	7/28/2021	7:06	SM 3113 B	7/30/2021	11:58	-0.29	2.00	1	N	ND
BES-1-25-CF1-P	N	P21-07892-76	PAS	NJDEP 15001	7/28/2021	7:06	SM 3113 B	7/30/2021	12:28	10.6	2.00	1	N	
BES-1-25-CF2-P	N	P21-07892-77	PAS	NJDEP 15001	7/28/2021	7:07	SM 3113 B	7/30/2021	12:58	52.5	20.0	10	N	
BES-1-25-CF3-P	N	P21-07892-78	PAS	NJDEP 15001	7/28/2021	7:07	SM 3113 B	7/30/2021	12:36	7.02	2.00	1	N	
BES-1-25-CF4-P	N	P21-07892-79	PAS	NJDEP 15001	7/28/2021	7:08	SM 3113 B	7/30/2021	12:40	4.80	2.00	1	N	

Exceeds EPA Action Limit (> 15.5ppb)

Bldg ID - Floor - Room / Location ID - Outlet Type / Number in Sequence - (P)primary / (F)lush

OUTLET TYPE

- BF = Bathroom Faucet
- CF = Classroom Faucet
- DW = Drinking Water Fountain
- FP = Food Prep
- HS = Hand Sink
- IM = Ice Machine
- KC = Kitchen Outlet, Cold
- KT= Kettle
- SB = Sink/Bubbler Combination
- TF = Teachers Faucet
- WC = Water Cooler
- BT= Bottle Filler
- HB= Hose Bib