

120 East Davis Street Fayette, MO 65248-1405 (660) 248-1911 www.inovatia.com

Date: 7/16/2024

RE: Drinking Water Lead Analysis Facility: Stafford R-VI

Date Received:05/20/24Time Received:11:00Relinquished by:Bob FranklinSampler:Bob Franklin

Chain of Custody Number: Pb-0243

Enclosed please find results for the sample(s) received as described above. The values reported are in conformance with internal and method quality control guidelines.

If you have questions or need more information, please contact us.

Thank you for your interest in working with Inovatia Laboratories.

Sincerely,

ennifer Vandelicht

Jennifer Vandelicht Quality Assurance

Note: Testing Performed by NELAC Facility E87688

Enclosures: Chain of Custody Record(s)



Analysis Report

Total Lead by ICP-MS

hain of Custody: Pb-0243 Facility: Stafford R-VI

Sample Matrix: Water Method of Analysis: EPA 200.8

| | | | | Result | |
|-------------|---|-----------|--------|--------|-----------|
| Laboratory | | Date | Sample | ug/L | Reporting |
| Number | Customer Sample Number | Collected | Туре | (ppb) | Limit |
| Pb-0243-001 | CENTRAL OFFICE BOYS RR SINK | 5/17/2024 | Flush | 2.58 | 1.0 |
| Pb-0243-002 | CENTRAL OFFICE GIRLS RR SINK | 5/17/2024 | Flush | 4.28 | 1.0 |
| Pb-0243-003 | CENTRAL OFFICE FOOD PREP SINK | 5/17/2024 | Flush | 1.44 | 1.0 |
| Pb-0243-004 | CENTRAL OFFICE HALL GIRLS RR SINK ON RIGHT | 5/17/2024 | Flush | 7.25 | 1.0 |
| Pb-0243-005 | CENTRAL OFFICE HALL GIRLS RR SINK IN MIDDLE | 5/17/2024 | Flush | 8.14 | 1.0 |
| Pb-0243-006 | CENTRAL OFFICE HALL BOYS RR SINK ON RIGHT | 5/17/2024 | Flush | 10.4 | 1.0 |
| Pb-0243-007 | CENTRAL OFFICE HALL BOYS RR SINK IN MIDDLE | 5/17/2024 | Flush | 7.97 | 1.0 |
| Pb-0243-008 | CENTRAL OFFICE HALL BOYS RR SINK ON LEFT | 5/17/2024 | Flush | 2.94 | 1.0 |
| Pb-0243-009 | CENTRAL OFFICE HALL FOUNTAIN | 5/17/2024 | Flush | 2.22 | 1.0 |
| Pb-0243-010 | CENTRAL OFFICE HALL BOTTLE FILLER | 5/17/2024 | Flush | 1.08 | 1.0 |
| Pb-0243-011 | HS RM23 FACS LEFT TO RIGHT FOOD PREP SINK3 | 5/17/2024 | Flush | 4.66 | 1.0 |
| Pb-0243-012 | HS RM23 FACS LEFT TO RIGHT FOOD PREP SINK5 | 5/17/2024 | Flush | 15.2 | 1.0 |
| Pb-0243-013 | HS LIBRARY FOOD PREP SINK | 5/17/2024 | Flush | 2.50 | 1.0 |
| Pb-0243-014 | HS RM2 & 3 CHEMICAL LAB HAND SINK | 5/17/2024 | Flush | 1.01 | 1.0 |
| Pb-0243-015 | HS RM3 LAB BACK WINDOW HAND SINK ON LEFT | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-016 | HS RM3 HALL GIRLS RR SINK IN MIDDLE | 5/17/2024 | Flush | 1.25 | 1.0 |
| Pb-0243-017 | HS RM3 HALL BOYS RR SINK ON RIGHT | 5/17/2024 | Flush | 3.84 | 1.0 |
| Pb-0243-018 | HS RM3 HALL BOYS RR SINK IN MIDDLE | 5/17/2024 | Flush | 5.95 | 1.0 |
| Pb-0243-019 | HS RM4 SCIENCE HAND SINK ON FAR RIGHT | 5/17/2024 | Flush | 2.00 | 1.0 |
| Pb-0243-020 | HS RM4 SCIENCE HAND SINK ON RIGHT | 5/17/2024 | Flush | 2.10 | 1.0 |
| Pb-0243-021 | HS RM4 SCIENCE HAND SINK ON LEFT | 5/17/2024 | Flush | 1.44 | 1.0 |
| Pb-0243-022 | HS RM4 SCIENCE HAND SINK ON FAR LEFT | 5/17/2024 | Flush | 1.62 | 1.0 |
| Pb-0243-023 | HS RM5 SCIENCE LAB HAND SINK1 | 5/17/2024 | Flush | 3.00 | 1.0 |
| Pb-0243-024 | HS RM5 SCIENCE LAB HAND SINK2 | 5/17/2024 | Flush | 3.71 | 1.0 |
| Pb-0243-025 | HS RM5 SCIENCE LAB HAND SINK3 | 5/17/2024 | Flush | 5.50 | 1.0 |
| Pb-0243-026 | HS RM5 SCIENCE LAB HAND SINK4 | 5/17/2024 | Flush | 3.27 | 1.0 |
| Pb-0243-027 | HS RM5 SCIENCE LAB HAND SINK5 | 5/17/2024 | Flush | 3.31 | 1.0 |
| Pb-0243-028 | HS RM5 SCIENCE LAB HAND SINK6 | 5/17/2024 | Flush | 2.59 | 1.0 |
| Pb-0243-029 | HS RM5 SCIENCE LAB HAND SINK7 | 5/17/2024 | Flush | 4.53 | 1.0 |
| Pb-0243-030 | HS RM5 SCIENCE LAB HAND SINK8 | 5/17/2024 | Flush | 3.24 | 1.0 |
| Pb-0243-031 | HS RM5 SCIENCE LAB HAND SINK9 | 5/17/2024 | Flush | 4.23 | 1.0 |
| Pb-0243-032 | HS RM5 SCIENCE LAB HAND SINK10 | 5/17/2024 | Flush | 6.84 | 1.0 |
| Pb-0243-033 | HS RM5 SCIENCE LAB HAND SINK11 | 5/17/2024 | Flush | 4.26 | 1.0 |
| Pb-0243-034 | HS RM5 SCIENCE LAB HAND SINK12 | 5/17/2024 | Flush | 3.11 | 1.0 |
| Pb-0243-035 | HS RM5 SCIENCE LAB HAND SINK13 | 5/17/2024 | Flush | 4.95 | 1.0 |
| | | | | | |

This report has been produced for the exclusive and confidential use of our clients. Reference to the analyses, the results, or the company is prohibited without obtaining prior written consent.



Analysis Report

Total Lead by ICP-MS

hain of Custody: Pb-0243

Facility: Stafford R-VI

Sample Matrix: Water Method of Analysis: EPA 200.8

| | | | | Result | |
|-------------|--|-----------|--------|--------|-----------|
| Laboratory | | Date | Sample | ug/L | Reporting |
| Number | Customer Sample Number | Collected | Туре | (ppb) | Limit |
| Pb-0243-036 | HS WORKROOM GIRLS RR SINK | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-037 | HS WORKROOM BOYS RR SINK | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-038 | HS TECH ROOM HAND SINK | 5/17/2024 | Flush | 5.75 | 1.0 |
| Pb-0243-039 | HS RM26 LIFE SKILLS FOOD PREP SINK ON RIGHT | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-040 | HS RM26 LIFE SKILLS FOOD PREP SINK ON RIGHT SCULLERY SPRAYER | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-041 | HS RM26 LIFE SKILLS FOOD PREP SINK ON LEFT | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-042 | HS RM26 LIFE SKILLS FOOD PREP SINK ON LEFT SCULLERY SPRAYER | 5/17/2024 | Flush | 1.13 | 1.0 |
| Pb-0243-043 | MS BREAKROOM FOOD PREP SINK | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-044 | MS RM18 7TH GRADE SCIENCE HAND SINK ON FAR RIGHT | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-045 | MS RM18 7TH GRADE SCIENCE HAND SINK ON RIGHT | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-046 | MS RM18 7TH GRADE SCIENCE HAND SINK ON LEFT | 5/17/2024 | Flush | 2.38 | 1.0 |
| Pb-0243-047 | MS RM18 7TH GRADE SCIENCE HAND SINK ON FAR LEFT | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-048 | MS OFFICE LUNCHROOM FOOD PREP SINK | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-049 | MS RM31 HAND SINK ON RIGHT | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-050 | MS KITCHEN MIXER AREA FOOD PREP SINK | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-051 | MS KITCHEN DISH SINK ON RIGHT | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-052 | MS KITCHEN DISH SINK ON LEFT | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-053 | MS KITCHEN SCULLERY SPRAYER | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-054 | TRACK TICKET BOOTH BOYS RR SINK ON FAR LEFT | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-055 | OLD GYM BASEMENT RR SINK | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-056 | OLD GYM FOOTBALL LOCKER FOUNTAIN | 5/17/2024 | Flush | 273 | 1.0 |
| Pb-0243-057 | NEW GYM SOUTH BOYS RR SINK ON RIGHT | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-058 | NEW GYM NORTH GIRLS RR SINK ON FAR RIGHT | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-059 | NEW GYM NORTH GIRLS RR SINK ON RIGHT | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-060 | NEW GYM NORTH BOYS RR SINK ON FAR RIGHT | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-061 | NEW GYM NORTH BOYS RR SINK ON RIGHT | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-062 | NEW GYM NORTH BOYS RR SINK ON LEFT | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-063 | NEW GYM NORTH BOYS RR SINK ON FAR LEFT | 5/17/2024 | Flush | ND | 1.0 |
| Pb-0243-064 | ELEM K/1ST RM222 HAND SINK | 5/17/2024 | Flush | ND | 1.0 |
| | | | | | |



120 East Davis Street Fayette, MO 65248-1405 (660) 248-1911 www.inovatia.com

Matrix: Water

Grab/Composite: Grab

Preservation: HNO3

Chain of Custody: Pb-0243

Number of Containers:

Contact Name:Bob FranklinCompany Name:Get the Lead Out LLCAddress:PO Box 118City,State,zipSturgeon, MO 65284Phone Number:417-294-6112E-Mail:bobfranklin@gettheleadoutmo.us

Facility: Strafford R-VI Facility Address: 201 W McCabe Strafford, MO 65757-8841 Facility Contact: Dr. Mark Hedger

Lab Number **Customer Sample Number Date Collected** 1 Pb-0243-001 CENTRAL OFFICE BOYS RR SINK 5/17/2024 2 Pb-0243-002 5/17/2024 CENTRAL OFFICE GIRLS RR SINK 3 Pb-0243-003 5/17/2024 CENTRAL OFFICE FOOD PREP SINK 4 Pb-0243-004 CENTRAL OFFICE HALL GIRLS RR SINK ON RIGHT 5/17/2024 5 Pb-0243-005 CENTRAL OFFICE HALL GIRLS RR SINK IN MIDDLE 5/17/2024 6 Pb-0243-006 CENTRAL OFFICE HALL BOYS RR SINK ON RIGHT 5/17/2024 7 Pb-0243-007 5/17/2024 CENTRAL OFFICE HALL BOYS RR SINK IN MIDDLE 8 Pb-0243-008 CENTRAL OFFICE HALL BOYS RR SINK ON LEFT 5/17/2024 9 Pb-0243-009 CENTRAL OFFICE HALL FOUNTAIN 5/17/2024 10 Pb-0243-010 CENTRAL OFFICE HALL BOTTLE FILLER 5/17/2024 11 Pb-0243-011 5/17/2024 HS RM23 FACS LEFT TO RIGHT FOOD PREP SINK3 12 Pb-0243-012 5/17/2024 HS RM23 FACS LEFT TO RIGHT FOOD PREP SINK5 13 Pb-0243-013 5/17/2024 HS LIBRARY FOOD PREP SINK 14 Pb-0243-014 5/17/2024 HS RM2 & 3 CHEMICAL LAB HAND SINK 15 Pb-0243-015 HS RM3 LAB BACK WINDOW HAND SINK ON LEFT 5/17/2024 16 Pb-0243-016 HS RM3 HALL GIRLS RR SINK IN MIDDLE 5/17/2024 17 Pb-0243-017 5/17/2024 HS RM3 HALL BOYS RR SINK ON RIGHT 18 Pb-0243-018 HS RM3 HALL BOYS RR SINK IN MIDDLE 5/17/2024 19 Pb-0243-019 5/17/2024 HS RM4 SCIENCE HAND SINK ON FAR RIGHT 20 Pb-0243-020 HS RM4 SCIENCE HAND SINK ON RIGHT 5/17/2024 21 Pb-0243-021 HS RM4 SCIENCE HAND SINK ON LEFT 5/17/2024 22 Pb-0243-022 HS RM4 SCIENCE HAND SINK ON FAR LEFT 5/17/2024 23 Pb-0243-023 HS RM5 SCIENCE LAB HAND SINK1 5/17/2024 24 Pb-0243-024 5/17/2024 HS RM5 SCIENCE LAB HAND SINK2 25 Pb-0243-025 HS RM5 SCIENCE LAB HAND SINK3 5/17/2024 26 Pb-0243-026 5/17/2024 HS RM5 SCIENCE LAB HAND SINK4 27 Pb-0243-027 5/17/2024 HS RM5 SCIENCE LAB HAND SINK5 28 Pb-0243-028 5/17/2024 HS RM5 SCIENCE LAB HAND SINK6

64

| 29 | Pb-0243-029 | HS RM5 SCIENCE LAB HAND SINK7 | 5/17/2024 |
|----|-------------|--|-----------|
| | Pb-0243-030 | HS RM5 SCIENCE LAB HAND SINK8 | 5/17/2024 |
| 31 | Pb-0243-031 | HS RM5 SCIENCE LAB HAND SINK9 | 5/17/2024 |
| 32 | Pb-0243-032 | HS RM5 SCIENCE LAB HAND SINK10 | 5/17/2024 |
| | Pb-0243-033 | HS RM5 SCIENCE LAB HAND SINK11 | 5/17/2024 |
| 34 | Pb-0243-034 | HS RM5 SCIENCE LAB HAND SINK12 | 5/17/2024 |
| 35 | Pb-0243-035 | HS RM5 SCIENCE LAB HAND SINK13 | 5/17/2024 |
| 36 | Pb-0243-036 | HS WORKROOM GIRLS RR SINK | 5/17/2024 |
| 37 | Pb-0243-037 | HS WORKROOM BOYS RR SINK | 5/17/2024 |
| 38 | Pb-0243-038 | HS TECH ROOM HAND SINK | 5/17/2024 |
| 39 | Pb-0243-039 | HS RM26 LIFE SKILLS FOOD PREP SINK ON RIGHT | 5/17/2024 |
| 40 | Pb-0243-040 | HS RM26 LIFE SKILLS FOOD PREP SINK ON RIGHT SCULLERY SPRAYER | 5/17/2024 |
| 41 | Pb-0243-041 | HS RM26 LIFE SKILLS FOOD PREP SINK ON LEFT | 5/17/2024 |
| 42 | Pb-0243-042 | HS RM26 LIFE SKILLS FOOD PREP SINK ON LEFT SCULLERY SPRAYER | 5/17/2024 |
| 43 | Pb-0243-043 | MS BREAKROOM FOOD PREP SINK | 5/17/2024 |
| 44 | Pb-0243-044 | MS RM18 7TH GRADE SCIENCE HAND SINK ON FAR RIGHT | 5/17/2024 |
| 45 | Pb-0243-045 | MS RM18 7TH GRADE SCIENCE HAND SINK ON RIGHT | 5/17/2024 |
| 46 | Pb-0243-046 | MS RM18 7TH GRADE SCIENCE HAND SINK ON LEFT | 5/17/2024 |
| 47 | Pb-0243-047 | MS RM18 7TH GRADE SCIENCE HAND SINK ON FAR LEFT | 5/17/2024 |
| 48 | Pb-0243-048 | MS OFFICE LUNCHROOM FOOD PREP SINK | 5/17/2024 |
| 49 | Pb-0243-049 | MS RM31 HAND SINK ON RIGHT | 5/17/2024 |
| 50 | Pb-0243-050 | MS KITCHEN MIXER AREA FOOD PREP SINK | 5/17/2024 |
| 51 | Pb-0243-051 | MS KITCHEN DISH SINK ON RIGHT | 5/17/2024 |
| 52 | Pb-0243-052 | MS KITCHEN DISH SINK ON LEFT | 5/17/2024 |
| 53 | Pb-0243-053 | MS KITCHEN SCULLERY SPRAYER | 5/17/2024 |
| 54 | Pb-0243-054 | TRACK TICKET BOOTH BOYS RR SINK ON FAR LEFT | 5/17/2024 |
| 55 | Pb-0243-055 | OLD GYM BASEMENT RR SINK | 5/17/2024 |
| 56 | Pb-0243-056 | OLD GYM FOOTBALL LOCKER FOUNTAIN | 5/17/2024 |
| 57 | Pb-0243-057 | NEW GYM SOUTH BOYS RR SINK ON RIGHT | 5/17/2024 |
| 58 | Pb-0243-058 | NEW GYM NORTH GIRLS RR SINK ON FAR RIGHT | 5/17/2024 |
| 59 | Pb-0243-059 | NEW GYM NORTH GIRLS RR SINK ON RIGHT | 5/17/2024 |
| 60 | Pb-0243-060 | NEW GYM NORTH BOYS RR SINK ON FAR RIGHT | 5/17/2024 |
| 61 | Pb-0243-061 | NEW GYM NORTH BOYS RR SINK ON RIGHT | 5/17/2024 |
| 62 | Pb-0243-062 | NEW GYM NORTH BOYS RR SINK ON LEFT | 5/17/2024 |
| 63 | Pb-0243-063 | NEW GYM NORTH BOYS RR SINK ON FAR LEFT | 5/17/2024 |
| 64 | Pb-0243-064 | ELEM K/1ST RM222 HAND SINK | 5/17/2024 |

Hand Delivery Method: Coolant: Arrival Temperature:

Sampler Signature:

Bob Franklin

Relinquished By:

ladely Received By:

Date/Time: 5/17/2024

Date/Time:

Date/Time: <u>202405-20</u> /100