

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012420360  
**LIMS Reference ID:** AC20360  
**EMSL Customer ID:** CLCS25

**Attention:** Brian Logel  
 Clarence Central Schools [CLCS25]  
 9600 Clarence Center Road  
 Clarence Center, NY 14032  
 (716) 407-9131  
 blogel@clarenceschools.org

**Project Name:** Clarence Center Elementary  
**Customer PO:** 242454  
**EMSL Sales Rep:** David Prince  
**Received:** 06/18/2024 09:30  
**Reported:** 07/10/2024 18:26

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CC-01/RM 120 Lav Sink Lims Reference ID: AC20360-01 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	3.55		1	1.00	µg/L	06/21/24 12:48	07/02/24 18:12	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-02/RM 120 Counter Sink Lims Reference ID: AC20360-02 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	2.66		1	1.00	µg/L	06/21/24 12:48	07/02/24 18:18	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-03/RM 119 Lav Sink Lims Reference ID: AC20360-03 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	4.88		1	1.00	µg/L	06/21/24 12:48	07/02/24 18:20	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-04/RM 119 Counter Sink Lims Reference ID: AC20360-04 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	1.94		1	1.00	µg/L	06/21/24 12:48	07/02/24 18:22	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-05/RM 118 Lav Sink Lims Reference ID: AC20360-05 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	3.49		1	1.00	µg/L	06/21/24 12:48	07/02/24 18:28	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-06/RM 118 Counter Sink Lims Reference ID: AC20360-06 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	6.07		1	1.00	µg/L	06/21/24 12:48	07/02/24 18:30	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-07/RM 117 Lav Sink Lims Reference ID: AC20360-07 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	3.06		1	1.00	µg/L	06/21/24 12:48	07/02/24 18:32	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-08/RM 117 Counter Sink Lims Reference ID: AC20360-08 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	1.94		1	1.00	µg/L	06/21/24 12:48	07/02/24 18:34	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-09/Boys Locker Sink Lims Reference ID: AC20360-09 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	06/21/24 12:48	07/02/24 18:36	LXK	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012420360  
**LIMS Reference ID:** AC20360  
**EMSL Customer ID:** CLCS25

**Attention:** Brian Logel  
 Clarence Central Schools [CLCS25]  
 9600 Clarence Center Road  
 Clarence Center, NY 14032  
 (716) 407-9131  
 blogel@clarenceschools.org

**Project Name:** Clarence Center Elementary  
**Customer PO:** 242454  
**EMSL Sales Rep:** David Prince  
**Received:** 06/18/2024 09:30  
**Reported:** 07/10/2024 18:26

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CC-10/Office 112 Lav Sink Lims Reference ID: AC20360-10 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	06/21/24 12:48	07/02/24 18:37	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-11/Creepy Lav Sink Lims Reference ID: AC20360-11 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	06/21/24 12:48	07/02/24 18:39	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-12/Nurse Counter Sink Lims Reference ID: AC20360-12 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	06/21/24 12:48	07/03/24 12:23	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-13/Nurse Lav Sink Lims Reference ID: AC20360-13 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	06/21/24 12:48	07/02/24 18:51	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-14/Office Break RM Lav Lims Reference ID: AC20360-14 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	2.22		1	1.00	µg/L	06/21/24 12:48	07/03/24 12:27	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-15/Principal Lav Sink Lims Reference ID: AC20360-15 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	12.6		1	1.00	µg/L	07/01/24 17:49	07/05/24 21:10	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-16/Gym Bottle Filler Lims Reference ID: AC20360-16 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	06/21/24 12:48	07/02/24 18:57	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-17/Girls Locker Sink #1 Lims Reference ID: AC20360-17 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	06/21/24 12:48	07/02/24 18:58	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-18/Girls Locker Sink #2 Lims Reference ID: AC20360-18 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	06/21/24 12:48	07/02/24 19:00	LXK	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012420360  
**LIMS Reference ID:** AC20360  
**EMSL Customer ID:** CLCS25

**Attention:** Brian Logel  
 Clarence Central Schools [CLCS25]  
 9600 Clarence Center Road  
 Clarence Center, NY 14032  
 (716) 407-9131  
 blogel@clarenceschools.org

**Project Name:** Clarence Center Elementary  
**Customer PO:** 242454  
**EMSL Sales Rep:** David Prince  
**Received:** 06/18/2024 09:30  
**Reported:** 07/10/2024 18:26

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CC-19/Lunch RM Bottle Filler Lims Reference ID: AC20360-19 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	06/21/24 12:48	07/02/24 19:02	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-20/RM 201 Lav Sink Lims Reference ID: AC20360-20 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	4.09		1	1.00	µg/L	06/21/24 12:48	07/02/24 19:04	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-22/Boys Gang Lav Sink #1 Lims Reference ID: AC20360-21 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	4.47		1	1.00	µg/L	06/21/24 12:59	07/05/24 16:48	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-23/Boys Gang Lav Sink #2 Lims Reference ID: AC20360-22 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	3.01		1	1.00	µg/L	06/21/24 12:59	07/05/24 16:57	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-24/Boys Gang Lav Sink #3 Lims Reference ID: AC20360-23 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	5.13		1	1.00	µg/L	06/21/24 12:59	07/05/24 16:59	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-25/Girls Gang Lav Sink #1 Lims Reference ID: AC20360-24 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	3.33		1	1.00	µg/L	06/21/24 12:59	07/05/24 17:01	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-26/Girls Gang Lav Sink #2 Lims Reference ID: AC20360-25 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	4.74		1	1.00	µg/L	06/21/24 12:59	07/05/24 17:03	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-27/Girls Gang Lav Sink #3 Lims Reference ID: AC20360-26 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	1.83		1	1.00	µg/L	06/21/24 12:59	07/05/24 17:05	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-28/RM 204 Counter Sink Lims Reference ID: AC20360-27 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	1.86		1	1.00	µg/L	06/21/24 12:59	07/05/24 17:07	LXK	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012420360  
**LIMS Reference ID:** AC20360  
**EMSL Customer ID:** CLCS25

**Attention:** Brian Logel  
 Clarence Central Schools [CLCS25]  
 9600 Clarence Center Road  
 Clarence Center, NY 14032  
 (716) 407-9131  
 blogel@clarenceschools.org

**Project Name:** Clarence Center Elementary

**Customer PO:** 242454  
**EMSL Sales Rep:** David Prince  
**Received:** 06/18/2024 09:30  
**Reported:** 07/10/2024 18:26

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CC-29/RM 204 Lav Sink Lims Reference ID: AC20360-28 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	7.87		1	1.00	µg/L	06/21/24 12:59	07/05/24 17:09	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-30/RM 203 Counter Sink Lims Reference ID: AC20360-29 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	5.93		1	1.00	µg/L	06/21/24 12:59	07/05/24 17:11	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-31/RM 203 Lav Sink Lims Reference ID: AC20360-30 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	3.59		1	1.00	µg/L	06/21/24 12:59	07/05/24 17:13	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-32/RM 205 Counter Sink Lims Reference ID: AC20360-31 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	2.81		1	1.00	µg/L	06/21/24 12:59	07/05/24 17:26	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-33/RM 205 Lav Sink Lims Reference ID: AC20360-32 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	06/21/24 12:59	07/05/24 17:32	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-34/RM 206 Counter Sink Lims Reference ID: AC20360-33 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	2.99		1	1.00	µg/L	06/21/24 12:59	07/05/24 17:34	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-35/RM 206 Lav Sink Lims Reference ID: AC20360-34 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	4.41		1	1.00	µg/L	06/21/24 12:59	07/05/24 17:36	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-36/RM 207 Sink Lims Reference ID: AC20360-35 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	1.77		1	1.00	µg/L	06/21/24 12:59	07/03/24 13:08	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-37/RM 207 Fountain Lims Reference ID: AC20360-36 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	3.57		1	1.00	µg/L	06/21/24 12:59	07/05/24 17:40	LXK	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012420360  
**LIMS Reference ID:** AC20360  
**EMSL Customer ID:** CLCS25

**Attention:** Brian Logel  
 Clarence Central Schools [CLCS25]  
 9600 Clarence Center Road  
 Clarence Center, NY 14032  
 (716) 407-9131  
 blogel@clarenceschools.org

**Project Name:** Clarence Center Elementary  
**Customer PO:** 242454  
**EMSL Sales Rep:** David Prince  
**Received:** 06/18/2024 09:30  
**Reported:** 07/10/2024 18:26

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CC-38/RM 208 Sink (A) Lims Reference ID: AC20360-37 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	10.3		1	1.00	µg/L	06/21/24 12:59	07/03/24 12:42	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-39/RM 209 Sink (A) Lims Reference ID: AC20360-38 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	5.01		1	1.00	µg/L	06/21/24 12:59	07/05/24 17:48	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-40/RM 210 Sink (A) Lims Reference ID: AC20360-39 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	5.51		1	1.00	µg/L	06/21/24 12:59	07/03/24 12:44	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-41/RM 211 Sink (A) Lims Reference ID: AC20360-40 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	4.09		1	1.00	µg/L	06/21/24 12:59	07/05/24 17:52	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-42/RM 212 Sink (A) Lims Reference ID: AC20360-41 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	1.16		1	1.00	µg/L	06/21/24 14:26	07/02/24 23:32	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-43/Art RM Sink #1 Lims Reference ID: AC20360-42 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	6.08		1	1.00	µg/L	06/24/24 13:46	07/01/24 15:05	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-44/Art RM Sink #2 Lims Reference ID: AC20360-43 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	2.30		1	1.00	µg/L	06/24/24 13:46	07/01/24 15:10	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-45/Art KILN RM Sink Lims Reference ID: AC20360-44 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	10.6		1	1.00	µg/L	06/24/24 13:46	07/01/24 15:12	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-46/RM 303 Sink Lims Reference ID: AC20360-45 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	16.9		1	1.00	µg/L	06/24/24 13:46	07/01/24 15:14	LXK	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012420360  
**LIMS Reference ID:** AC20360  
**EMSL Customer ID:** CLCS25

**Attention:** Brian Logel  
 Clarence Central Schools [CLCS25]  
 9600 Clarence Center Road  
 Clarence Center, NY 14032  
 (716) 407-9131  
 blogel@clarenceschools.org

**Project Name:** Clarence Center Elementary  
**Customer PO:** 242454  
**EMSL Sales Rep:** David Prince  
**Received:** 06/18/2024 09:30  
**Reported:** 07/10/2024 18:26

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CC-47/RM 305 Sink Lims Reference ID: AC20360-46 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	23.8		1	1.00	µg/L	06/21/24 14:26	07/02/24 23:38	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-48/RM 307 Sink Lims Reference ID: AC20360-47 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	4.74		1	1.00	µg/L	06/24/24 13:46	07/01/24 15:16	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-49/Library Office Sink 310 Lims Reference ID: AC20360-48 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	8.78		1	1.00	µg/L	06/24/24 13:46	07/01/24 15:22	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-50/Store 312 Sink Lims Reference ID: AC20360-49 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	06/24/24 13:46	07/01/24 15:24	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-51/RM 313 Sink Lims Reference ID: AC20360-50 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	20.4		1	1.00	µg/L	06/24/24 13:46	07/01/24 15:26	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-52/RM 314 Sink Lims Reference ID: AC20360-51 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	34.8		1	1.00	µg/L	06/21/24 14:26	07/02/24 23:40	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-53/RM 315 Sink Lims Reference ID: AC20360-52 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	20.2		1	1.00	µg/L	06/21/24 14:26	07/02/24 23:41	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-54/RM 316 Sink Lims Reference ID: AC20360-53 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	17.2		1	1.00	µg/L	06/24/24 13:46	07/01/24 15:28	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-55/RM 323 Sink Lims Reference ID: AC20360-54 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	7.53		1	1.00	µg/L	06/24/24 13:46	07/01/24 15:30	LXK	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012420360  
**LIMS Reference ID:** AC20360  
**EMSL Customer ID:** CLCS25

**Attention:** Brian Logel  
 Clarence Central Schools [CLCS25]  
 9600 Clarence Center Road  
 Clarence Center, NY 14032  
 (716) 407-9131  
 blogel@clarenceschools.org

**Project Name:** Clarence Center Elementary  
**Customer PO:** 242454  
**EMSL Sales Rep:** David Prince  
**Received:** 06/18/2024 09:30  
**Reported:** 07/10/2024 18:26

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CC-56/RM 324 Sink Lims Reference ID: AC20360-55 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	12.8		1	1.00	µg/L	06/24/24 13:46	07/01/24 15:31	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-57/RM 325 Sink Lims Reference ID: AC20360-56 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	14.7		1	1.00	µg/L	06/21/24 14:26	07/02/24 23:43	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-58/RM 326 Sink Lims Reference ID: AC20360-57 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	27.0		1	1.00	µg/L	06/21/24 14:26	07/02/24 23:49	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-59/Boys Library Lav Sink #1 Lims Reference ID: AC20360-58 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	2.27		1	1.00	µg/L	06/21/24 14:26	07/02/24 23:51	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-60/Boys Library Lav Sink #2 Lims Reference ID: AC20360-59 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	3.17		1	1.00	µg/L	06/24/24 13:46	07/01/24 15:37	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-61/Boys Library Lav Sink #3 Lims Reference ID: AC20360-60 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	3.77		1	1.00	µg/L	06/24/24 13:46	07/01/24 15:39	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-62/Girls Library Lav Sink #1 Lims Reference ID: AC20360-61 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	3.27		1	1.00	µg/L	06/24/24 13:46	07/01/24 15:45	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-63/Girls Library Lav Sink #2 Lims Reference ID: AC20360-62 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	2.00		1	1.00	µg/L	06/24/24 13:46	07/01/24 15:47	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: CC-64/Girls Library Lav Sink #3 Lims Reference ID: AC20360-63 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	07/01/24 17:49	07/05/24 21:12	LXK	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012420360  
**LIMS Reference ID:** AC20360  
**EMSL Customer ID:** CLCS25

**Attention:** Brian Logel  
 Clarence Central Schools [CLCS25]  
 9600 Clarence Center Road  
 Clarence Center, NY 14032  
 (716) 407-9131  
 blogel@clarenceschools.org

**Project Name:** Clarence Center Elementary  
**Customer PO:** 242454  
**EMSL Sales Rep:** David Prince  
**Received:** 06/18/2024 09:30  
**Reported:** 07/10/2024 18:26

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CC-65/Girls Library Lav Sink #4      Lims Reference ID: AC20360-64 Matrix: Drinking Water      Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	3.80		1	1.00	µg/L	06/19/24 16:14	06/20/24 22:47	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: CC-66/Staff Lav Sink      Lims Reference ID: AC20360-65 Matrix: Drinking Water      Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	10.5		1	1.00	µg/L	06/19/24 16:28	06/20/24 20:03	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: CC-67/RM 333 Sink      Lims Reference ID: AC20360-66 Matrix: Drinking Water      Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	13.9		1	1.00	µg/L	06/19/24 16:28	06/20/24 20:05	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: CC-68/RM 334 Sink      Lims Reference ID: AC20360-67 Matrix: Drinking Water      Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	20.2		1	1.00	µg/L	06/19/24 16:14	06/20/24 22:54	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: CC-69/RM 335 Sink      Lims Reference ID: AC20360-68 Matrix: Drinking Water      Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	10.4		1	1.00	µg/L	06/19/24 16:28	06/20/24 20:07	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: CC-70/RM 336 Sink      Lims Reference ID: AC20360-69 Matrix: Drinking Water      Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	52.4		1	1.00	µg/L	06/19/24 16:14	06/20/24 22:56	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: CC-72/Fountain By 334      Lims Reference ID: AC20360-70 Matrix: Drinking Water      Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	7.42		1	1.00	µg/L	06/19/24 16:28	06/20/24 20:09	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: CC-73/Kitchen Lav Sink      Lims Reference ID: AC20360-71 Matrix: Drinking Water      Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	10.5		1	1.00	µg/L	06/19/24 16:14	06/20/24 22:58	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: CC-74/Kitchen Hand Sink      Lims Reference ID: AC20360-72 Matrix: Drinking Water      Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	24.5		1	1.00	µg/L	06/19/24 16:14	06/20/24 23:00	JW1	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012420360  
**LIMS Reference ID:** AC20360  
**EMSL Customer ID:** CLCS25

**Attention:** Brian Logel  
 Clarence Central Schools [CLCS25]  
 9600 Clarence Center Road  
 Clarence Center, NY 14032  
 (716) 407-9131  
 blogel@clarenceschools.org

**Project Name:** Clarence Center Elementary

**Customer PO:** 242454  
**EMSL Sales Rep:** David Prince  
**Received:** 06/18/2024 09:30  
**Reported:** 07/10/2024 18:26

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: CC-75/Kitchen Triple Sink Lims Reference ID: AC20360-73 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	24.9		1	1.00	µg/L	06/19/24 16:14	06/20/24 23:07	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: CC-76/Kitchen Island Sink Lims Reference ID: AC20360-74 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	8.75		1	1.00	µg/L	06/19/24 16:14	06/20/24 23:10	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: CC-77/Gang Lav Water Fountain Lims Reference ID: AC20360-75 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	06/19/24 16:14	06/20/24 23:12	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: CC-78/Fountain By 112 Lims Reference ID: AC20360-76 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	06/19/24 16:14	06/20/24 23:14	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: CC-79/RM 208 Sink (B) Lims Reference ID: AC20360-77 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	14.2		1	1.00	µg/L	06/19/24 16:14	06/20/24 23:16	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: CC-80/RM 210 Sink (B) Lims Reference ID: AC20360-78 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	2.03		1	1.00	µg/L	06/19/24 16:14	06/20/24 23:19	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: CC-81/RM 209 Sink (B) Lims Reference ID: AC20360-79 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	06/19/24 16:14	06/20/24 23:26	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: CC-82/RM 212 Sink (B) Lims Reference ID: AC20360-80 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	5.75		1	1.00	µg/L	06/19/24 16:14	06/20/24 23:28	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: CC-83/RM 211 Sink (B) Lims Reference ID: AC20360-81 Matrix: Drinking Water Sampled: 06/06/24 06:00:00									
<b>Metals</b>									
Lead	3.85		1	1.00	µg/L	06/19/24 16:14	06/20/24 23:35	JW1	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
Telephone: 856-858-4800 Fax:856-786-5974  
EMSL-CIN-01

**EMSL Order ID:** 012420360  
**LIMS Reference ID:** AC20360  
**EMSL Customer ID:** CLCS25

**Attention:** Brian Logel  
Clarence Central Schools [CLCS25]  
9600 Clarence Center Road  
Clarence Center, NY 14032  
(716) 407-9131  
blogel@clarenceschools.org

**Project Name:** Clarence Center Elementary  
  
**Customer PO:** 242454  
**EMSL Sales Rep:** David Prince  
**Received:** 06/18/2024 09:30  
**Reported:** 07/10/2024 18:26

**Analytical Results**  
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: CC-84/Bottle Filler By 301      Lims Reference ID: AC20360-82 Matrix: Drinking Water      Sampled: 06/06/24 06:00:00

**Metals**

Lead	<1.00		1	1.00	µg/L	06/19/24 16:14	06/20/24 23:37	JW1	EPA 200.8 (DA)/EPA 200.8
------	-------	--	---	------	------	----------------	----------------	-----	--------------------------

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012420360  
**LIMS Reference ID:** AC20360  
**EMSL Customer ID:** CLCS25

**Attention:** Brian Logel  
 Clarence Central Schools [CLCS25]  
 9600 Clarence Center Road  
 Clarence Center, NY 14032  
 (716) 407-9131  
 blogel@clarenceschools.org

**Project Name:** Clarence Center Elementary

**Customer PO:** 242454  
**EMSL Sales Rep:** David Prince  
**Received:** 06/18/2024 09:30  
**Reported:** 07/10/2024 18:26

**Certified Analyses included in this Report**

Analyte	Certifications
<b><i>EPA 200.8 in Drinking Water</i></b>	
Lead	NJDEP

**List of Certifications**

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	68-00367	11/30/2024
NYSDOH	New York State Department of Health	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2024
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2024
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2024
California ELAP	California Water Boards	1877	06/30/2024
AIHA LAP	EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC-ELLAP Accredited	100194	01/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2024

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
Telephone: 856-858-4800 Fax:856-786-5974  
EMSL-CIN-01

**EMSL Order ID:** 012420360  
**LIMS Reference ID:** AC20360  
**EMSL Customer ID:** CLCS25

**Attention:** Brian Logel  
Clarence Central Schools [CLCS25]  
9600 Clarence Center Road  
Clarence Center, NY 14032  
(716) 407-9131  
blogel@clarenceschools.org

**Project Name:** Clarence Center Elementary

**Customer PO:** 242454  
**EMSL Sales Rep:** David Prince  
**Received:** 06/18/2024 09:30  
**Reported:** 07/10/2024 18:26

**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. All results for soil samples are reported on a dry weight basis, unless otherwise noted.



**Lead Chain of Custody**  
EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.  
200 Route 130 North  
Cinnaminson, NJ 08077

EMSL ANALYTICAL, INC.  
TESTING LABS • PRODUCTS • TRAINING

AC 20360

PHONE: (800) 220-3675  
EMAIL: CinnaminsonLeadLab@emsl.com

<b>Customer Information</b>	Customer ID:		Billing ID:	
	Company Name: <b>Clarence Central School District</b>		Company Name: <b>Clarence Central School District</b>	
	Contact Name: <b>Brian Logel</b>		Billing Contact: <b>Same as Contact Info</b>	
	Street Address: <b>9625 Main Street</b>		Street Address:	
	City, State, Zip: <b>Clarence, NY 14031</b>	Country: <b>USA</b>	City, State, Zip:	Country:
Phone: <b>716-407-9131</b>		Phone:		
Email(s) for Report: <b>blogel@clarenceschools.org</b>		Email(s) for Invoice:		

Project Information			
Project Name/No: <b>Clarence Center Elementary</b>		Purchase Order: <b>242454</b>	
EMSL LIMS Project ID: <small>(If applicable, EMSL will provide)</small>		US State where samples collected: <b>NY</b>	State of Connecticut (CT) must select project location: <input type="checkbox"/> Commercial (Taxable) <input type="checkbox"/> Residential (Non-Taxable)
Sampled By Name: <b>Brian Logel</b>	Sampled By Signature:	No. of Samples in Shipment	

**Turn-Around-Time (TAT)**

3 Hour  
  6 Hour  
  24 Hour  
  32 Hour  
  48 Hour  
  72 Hour  
  96 Hour  
  1 Week  
  2 Week

Please call ahead for large projects and/or turnaround times 6 Hours or Less. \*32 Hour TAT available for select tests only; samples must be submitted by 11:30am.

MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
<b>CHIPS</b> <input type="checkbox"/> % by wt. <input type="checkbox"/> ppm (mg/kg) <input type="checkbox"/> mg/cm <sup>2</sup> <small>*Reporting Limit based on a minimum 0.25g sample weight. **Not appropriate for Ceramic Tiles - XRF is recommended</small>	SW 846-7000B	Flame Atomic Absorption	0.008% (80ppm)	<input type="checkbox"/>
	SW 846-6010D*	ICP-OES	0.0004% (4ppm)	<input type="checkbox"/>
	NIOSH 7082	Flame Atomic Absorption	4µg/filter	<input type="checkbox"/>
<b>AIR</b>	NIOSH 7300M / NIOSH 7303M	ICP-OES	0.5µg/filter	<input type="checkbox"/>
	NIOSH 7300M / NIOSH 7303M	ICP-MS	0.05µg/filter	<input type="checkbox"/>
	SW 846-7000B	Flame Atomic Absorption	10µg/wipe	<input type="checkbox"/>
<b>WIPE</b> <input type="checkbox"/> ASTM <input type="checkbox"/> NON-ASTM <small>*if no box is checked, non-ASTM Wipe is assumed</small>	SW 846-6010D*	ICP-OES	1.0µg/wipe	<input type="checkbox"/>
	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
<b>TCLP</b>	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
<b>SPLP</b>	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
	22 CCR App. II, 7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>
<b>TTLIC</b>	22 CCR App. II, SW 846-6010D*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>
	22 CCR App. II, 7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
<b>STLC</b>	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
	SW 846-7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>
<b>Soil</b>	SW 846-6010D*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>
	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
<b>Wastewater</b> Unpreserved <input type="checkbox"/> Preserved with HNO3 <input type="checkbox"/> PH<2	EPA 200.7	ICP-OES	0.020 mg/L (ppm)	<input type="checkbox"/>
	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	<input type="checkbox"/>
<b>Drinking Water</b> Unpreserved <input type="checkbox"/> Preserved with HNO3 <input checked="" type="checkbox"/> PH<2	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	<input checked="" type="checkbox"/>
	40 CFR Part 50	ICP-OES	12 µg/filter	<input type="checkbox"/>
<b>TSP/SPM Filter</b>				<input type="checkbox"/>
<b>Other:</b>				<input type="checkbox"/>

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
See Attached Sheets	Clarence Center Elementary		6/6/24
	pages 2 to 5		
	82 Total Samples		

Method of Shipment:		Sample Condition Upon Receipt:	
Relinquished by: <b>Brian Logel</b>	Date/Time: <b>6/14/24</b>	Received by: <i>Colleen Palladino</i>	Date/Time: <b>6/18/24 9:30</b>
Relinquished by:	Date/Time:	Received by:	Date/Time:



### Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.  
200 Route 130 North  
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

EMSL ANALYTICAL, INC.  
TESTING LABS • PRODUCTS • TRAINING

AC20360

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
	Clarence Center Elementary		6/6/24 @ 6 AM
CC-01	RM 120 LAV SINK		
CC-02	RM 120 COUNTER SINK		
CC-03	RM 119 LAV SINK		
CC-04	RM 119 COUNTER SINK		
CC-05	RM 118 LAV SINK		
CC-06	RM 118 COUNTER SINK		
CC-07	RM 117 LAV SINK		
CC-08	RM 117 COUNTER SINK		
CC-09	BOYS LOCKER SINK		
CC-10	OFFICE 112 LAV SINK		
CC-11	CREEPY LAV SINK		
CC-12	NURSE COUNTER SINK		
CC-13	NURSE LAV SINK		
CC-14	OFFICE BREAK RM LAV		
CC-15	PRINCIPAL LAV SINK		
CC-16	GYM BOTTLE FILLER		
CC-17	GIRLS LOCKER SINK #1		
CC-18	GIRLS LOCKER SINK #2		
CC-19	LUNCH RM BOTTLE FILLER		
CC-20	RM 201 LAV SINK		
CC-21	RM 201 COUNTER SINK	No Sample	
CC-22	BOYS GANG LAV SINK #1		
CC-23	BOYS GANG LAV SINK #2		
CC-24	BOYS GANG LAV SINK #3		PAGE 2
Method of Shipment:		Sample Condition Upon Receipt:	
Relinquished by:	Date/Time:	Received by:	Date/Time:
Relinquished by:	Date/Time:	Received by:	Date/Time:

Controlled Document - COC-25 Lead R17 05/09/2022

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



# Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.  
200 Route 130 North  
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

EMSL ANALYTICAL, INC.  
TESTING LABS • PRODUCTS • TRAINING

AC 26360

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
	Clarence Center Elementary		
CC-25	GIRLS GANG LAV SINK #1		
CC-26	GIRLS GANG LAV SINK #2		
CC-27	GIRLS GANG LAV SINK #3		
CC-28	RM 204 COUNTER SINK		
CC-29	RM 204 LAV SINK		
CC-30	RM 203 COUNTER SINK		
CC-31	RM 203 LAV SINK		
CC-32	RM 205 COUNTER SINK		
CC-33	RM 205 LAV SINK		
CC-34	RM 206 COUNTER SINK		
CC-35	RM 206 LAV SINK		
CC-36	RM 207 SINK		
CC-37	RM 207 FOUNTAIN		
CC-38	RM 208 SINK (A)		
CC-39	RM 209 SINK (A)		
CC-40	RM 210 SINK (A)		
CC-41	RM 211 SINK (A)		
CC-42	RM 212 SINK (A)		
CC-43	ART RM SINK #1		
CC-44	ART RM SINK #2		
CC-45	ART KILN RM SINK		
CC-46	RM 303 SINK		
CC-47	RM 305 SINK		PAGE 3
Method of Shipment:		Sample Condition Upon Receipt:	
Relinquished by:	Date/Time:	Received by:	Date/Time
Relinquished by:	Date/Time:	Received by:	Date/Time

Controlled Document - COC-25 Lead R17 05/09/2022

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



# Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.  
200 Route 130 North  
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

EMSL ANALYTICAL, INC.  
TESTING LABS • PRODUCTS • TRAINING

AC20360

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
	Clarence Center Elementary		
CC-48	RM 307 SINK		
CC-49	LIBRARY OFFICE SINK 310		
CC-50	STORE 312 SINK		
CC-51	RM 313 SINK		
CC-52	RM 314 SINK		
CC-53	RM 315 SINK		
CC-54	RM 316 SINK		
CC-55	RM 323 SINK		
CC-56	RM 324 SINK		
CC-57	RM 325 SINK		
CC-58	RM 326 SINK		
CC-59	BOYS LIBRARY LAV SINK #1		
CC-60	BOYS LIBRARY LAV SINK #2		
CC-61	BOYS LIBRARY LAV SINK #3		
CC-62	GIRLS LIBRARY LAV SINK #1		
CC-63	GIRLS LIBRARY LAV SINK #2		
CC-64	GIRLS LIBRARY LAV SINK #3		
CC-65	GIRLS LIBRARY LAV SINK #4		
CC-66	STAFF LAV SINK		
CC-67	RM 333 SINK		
CC-68	RM 334 SINK		
CC-69	RM 335 SINK		
CC-70	RM 336 SINK		PAGE 4
Method of Shipment:		Sample Condition Upon Receipt:	
Relinquished by:	Date/Time:	Received by:	Date/Time
Relinquished by:	Date/Time:	Received by:	Date/Time

Controlled Document - COC-25 Lead R17 05/09/2022

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.





# Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.  
200 Route 130 North  
Cinnaminson, NJ 08077

EMSL ANALYTICAL, INC.  
TESTING LABS • PRODUCTS • TRAINING

AC20360

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
	Clarence Center Elementary		
CC-71	FOUNTAIN BY 313	NO SAMPLE	
CC-72	FOUNTAIN BY 334		
CC-73	KITCHEN LAV SINK		
CC-74	KITCHEN HAND SINK		
CC-75	KITCHEN TRIPLE SINK		
CC-76	KITCHEN ISLAND SINK		
CC-77	GANG LAV WATER FOUNTAIN		
CC-78	FOUNTAIN BY 112		
CC-79	RM 208 SINK (B)		
CC-80	RM 210 SINK (B)		
CC-81	RM 209 SINK (B)		
CC-82	RM 212 SINK (B)		
CC-83	RM 211 SINK (B)		
CC-84	BOTTLE FILLER BY 301		
			6/6/24 @ 7 AM
			PAGE 5

Method of Shipment:		Sample Condition Upon Receipt:	
Relinquished by:	Date/Time:	Received by:	Date/Time:
Relinquished by:	Date/Time:	Received by:	Date/Time:

Controlled Document - COC-25 Lead R17 05/09/2022

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

CLARENCE CENTRAL SCHOOL DISTRI  
716 407-9131  
9625 MAIN STREET  
CLARENCE NY 14031


55 LBS

1 OF 1

DWT: 21,16,15  
AH

8/14/24, 3:01 PM

SHIP TO:  
8002203675  
EMSL ANALYTICAL, INC.  
200 ROUTE 130 NORTH  
CINNAMINSON NJ 08077



NJ 081 9-05



**UPS GROUND**

TRACKING #: 1Z 55A V35 03 9652 3407




BILLING: P/P

ONLY FOR UPS SHIPPING ONLY

XOL 24.06.05

NV45 24.0A 06/2024\*



abbottmark