



Environmental and Laboratory Services

Dover Location:
90 1/2 West Blackwell St., Dover, NJ 07801
Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:
8A Railroad Ave, Marlboro, NJ 07746
Phone: (732) 308-3500, Fax (732) 308-3503

Date: May 11, 2022
Client: Water Management Services
Address: 53 Killdeer Place
Hackettstown, NJ 07840

PWSID#:
Project Location: Lawrence School

Analytical Results

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-001						
Sample Location:	FP-1 Kitchen Sink Left	Customer Sample Number:							
Sampled By:	R. Busacco								
Sample Date/Time:	4/20/2022 16:14								

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/9/2022	14:23	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-002						
Sample Location:	FP-2 Kitchen Sink Right	Customer Sample Number:							
Sampled By:	R. Busacco								
Sample Date/Time:	4/20/2022 16:14								

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.41	µg/L	15	5/9/2022	14:28	JGW	2	1

Water Management Services

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-003
Sample Location:	FP-3 Kitchen Sink Island	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 16:16		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/9/2022	14:34	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-004
Sample Location:	WC-1 Fountain Gym	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 16:17		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/3/2022	21:09	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-005
Sample Location:	DW-13 Fountain Room 110	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 16:19		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/9/2022	14:56	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-006
Sample Location:	WC-2 Fountain Hall by 109	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 16:21		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.14	µg/L	15	5/9/2022	15:02	JGW	2	1

Water Management Services

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-007
Sample Location:	DW-12 Room 109	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 16:23		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/9/2022	15:08	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-008
Sample Location:	DW-11 Room 108	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 16:25		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/9/2022	15:14	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-009
Sample Location:	DW-10 Room 107	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 16:27		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/9/2022	15:19	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-010
Sample Location:	DW-9 Room 105	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 16:29		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/9/2022	15:24	JGW	2	1

Water Management Services

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-011
Sample Location:	DW-8 Room 104	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 16:31		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.34	µg/L	15	5/9/2022	15:30	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-012
Sample Location:	DW-7 Room 103	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 16:32		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/9/2022	15:35	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-013
Sample Location:	WC-3 Fountain Main Hall	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 16:33		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/9/2022	15:41	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-014
Sample Location:	FP-4 Faculty Room Main	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 16:35		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	4.40	µg/L	15	5/9/2022	15:46	JGW	2	1

Water Management Services

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-015
Sample Location:	DW-4 Room 114	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 16:37		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.16	µg/L	15	5/9/2022	16:36	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-016
Sample Location:	DW-3 Room 110	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 16:38		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/9/2022	16:42	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-017
Sample Location:	DW-2 Room 112	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 16:40		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/9/2022	16:47	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-018
Sample Location:	DW-1 Room 111	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 16:41		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.04	µg/L	15	5/9/2022	16:52	JGW	2	1

Water Management Services

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-019
Sample Location:	DW-23 Room 215	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 16:45		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/9/2022	17:53	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-020
Sample Location:	DW-22 Room 214	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 16:47		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/9/2022	17:59	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-021
Sample Location:	DW-21 Room 213	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 16:48		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/9/2022	18:04	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-022
Sample Location:	WC-4 Fountain Hall by 212	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 16:50		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	3.52	µg/L	15	5/9/2022	18:10	JGW	2	1

Water Management Services

Sample Matrix: Drinking Water		Lab Sample Number: 220426004-023							
Sample Location: DW-20 Room 212		Customer Sample Number:							
Sampled By: R. Busacco									
Sample Date/Time: 4/20/2022 16:57									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/9/2022	18:15	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220426004-024							
Sample Location: DW-14 Room 211		Customer Sample Number:							
Sampled By: R. Busacco									
Sample Date/Time: 4/20/2022 16:53									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/9/2022	18:21	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220426004-025							
Sample Location: DW-15 Room 210		Customer Sample Number:							
Sampled By: R. Busacco									
Sample Date/Time: 4/20/2022 16:54									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/9/2022	18:26	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220426004-026							
Sample Location: DW-16 Room 209		Customer Sample Number:							
Sampled By: R. Busacco									
Sample Date/Time: 4/20/2022 16:56									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.03	µg/L	15	5/9/2022	19:16	JGW	2	1

Water Management Services

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-027
Sample Location:	DW-17 Room 208	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 16:58		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/9/2022	19:22	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-028
Sample Location:	DW-18 Room 207	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 16:59		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/9/2022	19:27	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-029
Sample Location:	WC-5 Fountain Hall CST	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 17:01		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/9/2022	19:33	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-030
Sample Location:	DW-19 Room 206	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 17:02		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/9/2022	19:38	JGW	2	1

Water Management Services

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-031
Sample Location:	DW-24 Room 151	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 17:05		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	6.37	µg/L	15	5/9/2022	19:44	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-032
Sample Location:	DW-25 Room 150	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 17:07		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	6.32	µg/L	15	5/9/2022	19:49	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-033
Sample Location:	DW-26 Room 152	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 17:09		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	4.13	µg/L	15	5/9/2022	19:55	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220426004-034
Sample Location:	DW-27 Room 153	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 17:11		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	4.09	µg/L	15	5/9/2022	20:17	JGW	2	1

Water Management Services

NJ Lab ID# 14013 (Dover)


NJ Lab ID# 13033 (Marlboro)

NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.

Any method followed by an asterisk (*) was analyzed by the Agra-Marlboro laboratory.

All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.



Susan VanVeen, Laboratory Manager

May 11, 2022



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name:	Water Management Services, Inc.	Report to:	Agra Environmental Services
Address:	PO Box 142		90 1/2 West Blackwell Street
	Allamuchy, NJ 07820		Dover, NJ 07801
Project Location:			Phone: (973) 989-0010
Customer Contact:	Ron Busacco		Fax: (973) 989-0156
Phone - Work/Cell:	(201) 274-4527		

#	Asc./HCl Vials	pH:	_____
#	HCl Vials	pH:	_____
# 34	Na ₂ S ₂ O ₃ 250	Cl ₂ :	_____
#	HNO ₃	pH:	_____
#	H ₂ SO ₄	pH:	_____
#	NaOH	pH:	_____
#	unpreserved		_____
#	other		_____
#	other		_____

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake Page 1 of 4

Project: Lawrence School	Collection	PWSID# 1924318						for laboratory use only	Field Analysis		
Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl ₂ or PO ₄
220426004	FP-1 Kitchen Sink Left - 001	4/20/22	16:14	X		DW	1	H2SO4	Lead (1st Draw)		
	FP-2 Kitchen Sink Right - 002	4/20/22	16:14	X		DW	1	H2SO4	Lead (1st Draw)		
	FP-3 Kitchen Sink Island - 003	4/20/22	16:16	X		DW	1	H2SO4	Lead (1st Draw)		
	WC-1 Fountain Gym - 004	4/20/22	16:17	X		DW	1	H2SO4	Lead (1st Draw)		
	DW-13 Fountain Room 110 - 005	4/20/22	16:19	X		DW	1	H2SO4	Lead (1st Draw)		
	WC-2 Fountain Hall by 109 - 006	4/20/22	16:21	X		DW	1	H2SO4	Lead (1st Draw)		
	DW-12 Room 109 - 007	4/20/22	16:23	X		DW	1	H2SO4	Lead (1st Draw)		
	DW-11 Room 108 - 008	4/20/22	16:25	X		DW	1	H2SO4	Lead (1st Draw)		
	DW-10 Room 107 - 009	4/20/22	16:27	X		DW	1	H2SO4	Lead (1st Draw)		
	DW-9 Room 105 - 010	4/20/22	16:29	X		DW	1	H2SO4	Lead (1st Draw)		

Sampled By (name/company): Ron Busacco / WMS	Are these samples for compliance? (circle one): Yes or No	Indicate laboratory location where analysis request was performed
	NJDEP Laboratory Certification (Dover, NJ) #14013 NJDEP Laboratory Certification (Marlboro, NJ) #13033	
Reporting Requirements (Check Box):	Standard <input checked="" type="checkbox"/> NJ Reduced <input type="checkbox"/> Other (Specify) _____	Cooler Temperature Upon Receipt at lab: <i>N/A</i>

Sample Custody Exchanges (Please use full legal signature)						Comments:
Relinquished By: <i>Ron Busacco</i>	Date: 4/22/22	Time: 1555	Received By: <i>Shelly Gleyto</i>	Date: 4/22/22	Time: 1625	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____ Invoice Number _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one) Yes or No



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name:	Water Management Services, Inc.	Report to:	Agra Environmental Services	# _____ Asc./HCl Vials pH: _____
Address:	PO Box 142		90 1/2 West Blackwell Street	# _____ HCl Vials pH: _____
	Allamuchy, NJ 07820		Dover, NJ 07801	# _____ Na ₂ S ₂ O ₃ Cl ₂ : _____
Project Location:			Phone: (973) 989-0010	# _____ HNO ₃ pH: _____
Customer Contact:	Ron Busacco		Fax: (973) 989-0156	# _____ H ₂ SO ₄ pH: _____
Phone - Work/Cell:	(201) 274-4527			# _____ NaOH pH: _____
				# _____ unpreserved _____
				# _____ other _____
				# _____ other _____

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake Page 2 of 4

Project: Lawrence School	Collection	PWSID# 1924318						for laboratory use only	Field Analysis		
Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl ₂ or PO ₄
220426004	DW-8 Room 104	4/20/22	16:31	X		DW	1	H ₂ SO ₄ HNO ₃	Lead (1st Draw)		
	DW-7 Room 103	4/20/22	16:32	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	WC-3 Fountain Main Hall	4/20/22	16:33	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	FP-4 Faculty Room Main	4/20/22	16:35	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	DW-4 Room 114	4/20/22	16:37	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	DW-3 Room 110	4/20/22	16:38	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	DW-2 Room 112	4/20/22	16:40	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	DW-1 Room 111	4/20/22	16:41	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	DW-23 Room 215	4/20/22	16:45	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	DW-22 Room 214	4/20/22	16:47	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		

Sampled By (name/company): Ron Busacco/WM	Are these samples for compliance? (circle one): Yes or No	Indicate laboratory location where analysis request was performed
	NJDEP Laboratory Certification (Dover, NJ) #14013	
	NJDEP Laboratory Certification (Marlboro, NJ) #13033	
Reporting Requirements (Check Box):	Standard <input checked="" type="checkbox"/> NJ Reduced <input type="checkbox"/> Other (Specify) _____	Cooler Temperature Upon Receipt at lab: N/A

Sample Custody Exchanges (Please use full legal signature)						Comments:
Relinquished By: Ron Busacco	Date: 4/22/22	Time: 1535	Received By: Shirley Glynne	Date: 4/22/22	Time: 1625	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____ Invoice Number _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one) Yes or No



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name:	Water Management Services, Inc.	Report to:	Agra Environmental Services	# _____ Asc./HCl Vials pH: _____
Address:	PO Box 142		90 1/2 West Blackwell Street	# _____ HCl Vials pH: _____
	Allamuchy, NJ 07820		Dover, NJ 07801	# _____ Na ₂ S ₂ O ₃ Cl ₂ : _____
Project Location:			Phone: (973) 989-0010	# _____ HNO ₃ pH: _____
Customer Contact:	Ron Busacco		Fax: (973) 989-0156	# _____ H ₂ SO ₄ pH: _____
Phone - Work/Cell:	(201) 274-4527			# _____ NaOH pH: _____
				# _____ unpreserved _____
				# _____ other _____
				# _____ other _____

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake Page 3 of 4

Project: Lawrence School	Collection	PWSID# 1924318							for laboratory use only	Field Analysis	
Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl ₂ or PO ₄
220426034	DW-21 Room 213 - 021	4/20/22	16:48	X		DW	1	H ₂ SO ₄ H ₂ O ₂	Lead (1st Draw)		
	WC-4 Fountain Hall by 212 - 022	4/20/22	16:50	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	DW-20 Room 212 - 023	4/20/22	16:57	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	DW-14 Room 211 - 024	4/20/22	16:53	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	DW-15 Room 210 - 025	4/20/22	16:54	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	DW-16 Room 209 - 026	4/20/22	16:56	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	DW-17 Room 208 - 027	4/20/22	16:58	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	DW-18 Room 207 - 028	4/20/22	16:59	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	WC-5 Fountain Hall CST - 029	4/20/22	17:01	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	DW-19 Room 206 - 030	4/20/22	17:02	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		

Sampled By (name/company): Ron Busacco / WMS	Are these samples for compliance? (circle one): Yes or No	Indicate laboratory location where analysis request was performed
	NJDEP Laboratory Certification (Dover, NJ) #14013	
	NJDEP Laboratory Certification (Marlboro, NJ) #13033	
Reporting Requirements (Check Box):	Standard <input checked="" type="checkbox"/> NJ Reduced <input type="checkbox"/> Other (Specify) <input type="checkbox"/>	Cooler Temperature Upon Receipt at lab: N/A

Sample Custody Exchanges (Please use full legal signature)						Comments:
Relinquished By: Ron Busacco	Date: 4/24/22	Time: 1555	Received By: Shelly [Signature]	Date: 4/22/22	Time: 1635	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____ Invoice Number _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one) Yes or No



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Water Management Services, Inc.	Report to:	Agra Environmental Services	# ___ Asc./HCl Vials pH: ___
Address: PO Box 142	h20management@optonline.net	90 1/2 West Blackwell Street	# ___ HCl Vials pH: ___
Allamuchy, NJ 07820		Dover, NJ 07801	# ___ Na ₂ S ₂ O ₃ Cl ₂ : ___
Project Location:		Phone: (973) 989-0010	# ___ HNO ₃ pH: ___
Customer Contact: Ron Busacco		Fax: (973) 989-0156	# ___ H ₂ SO ₄ pH: ___
Phone - Work/Cell: (201) 274-4527			# ___ NaOH pH: ___
			# ___ unpreserved ___
			# ___ other ___
			# ___ other ___

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake Page 4 of 4

Project: Lawrence School		Collection		PWSID# 1924318		for laboratory use only		Field Analysis			
Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl ₂ or PO ₄
220426004	DW-24 Room151	4/20/22	17:05	X		DW	1	H2SO4 HNO3	Lead (1st Draw)		
	DW-25 Room 150	4/20/22	17:07	X		DW	1	H2SO4	Lead (1st Draw)		
	DW-26 Room 152	4/20/22	17:09	X		DW	1	H2SO4	Lead (1st Draw)		
	DW-27 Room 153	4/20/22	17:11	X		DW	1	H2SO4	Lead (1st Draw)		

Sampled By (name/company): Ron Busacco / WMS	Are these samples for compliance? (circle one): Yes or No	Indicate laboratory location where analysis request was performed
	NJDEP Laboratory Certification (Dover, NJ) #14013	
	NJDEP Laboratory Certification (Marlboro, NJ) #13033	
Reporting Requirements (Check Box):	Standard <input checked="" type="checkbox"/> NJ Reduced <input type="checkbox"/> Other (Specify) <input type="checkbox"/>	Cooler Temperature Upon Receipt at lab: N/A

Sample Custody Exchanges (Please use full legal signature)						Comments:
Relinquished By: Ron Busacco	Date: 4/22/22	Time: 1555	Received By: Sherry Hight	Date: 4/22/22	Time: 1625	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Date Faxed _____ Invoice Number _____						
Is sample known to be hazardous? (circle one) Yes or No						