



Environmental and Laboratory Services

Dover Location:

90 1/2 West Blackwell St., Dover, NJ 07801
Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:

8A Railroad Ave, Marlboro, NJ 07746
Phone: (732) 308-3500, Fax (732) 308-3503

Date: May 06, 2022
Client: Water Management Services
Address: 53 Killdeer Place
Hackettstown, NJ 07840

PWSID#:
Project Location: Wantage School

Analytical Results

Sample Matrix:	Drinking Water	Lab Sample Number:	220425002-001						
Sample Location:	WC-1 Fountain Main Hall	Customer Sample Number:							
Sampled By:	R. Busacco								
Sample Date/Time:	4/20/2022 15:30								

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	EPA200.8	< 1.00	µg/L	15	5/4/2022	18:48	BM	1	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220425002-002						
Sample Location:	NS Sink Nurse	Customer Sample Number:							
Sampled By:	R. Busacco								
Sample Date/Time:	4/20/2022 15:32								

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	EPA200.8	< 1.00	µg/L	15	5/4/2022	18:53	BM	1	1

Water Management Services

Sample Matrix:	Drinking Water	Lab Sample Number:	220425002-003
Sample Location:	FP-1 Kitchen Sink Right	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 15:34		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	EPA200.8	< 1.00	µg/L	15	5/4/2022	18:58	BM	1	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220425002-004
Sample Location:	FP-2 Kitchen Sink Left	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 15:36		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	EPA200.8	1.09	µg/L	15	5/4/2022	19:02	BM	1	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220425002-005
Sample Location:	WC-2 Fountain 2nd Floor	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 15:38		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	EPA200.8	< 1.00	µg/L	15	5/4/2022	19:07	BM	1	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220425002-006
Sample Location:	WC-3 Fountain Between B&G	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 15:41		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	EPA200.8	< 1.00	µg/L	15	5/4/2022	19:12	BM	1	1

Water Management Services

Sample Matrix:	Drinking Water	Lab Sample Number:	220425002-007
Sample Location:	DW-1 Fountain by Rm 7	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 15:43		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	EPA200.8	8.65	µg/L	15	5/4/2022	19:17	BM	1	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220425002-008
Sample Location:	WC-4 Fountain by Rm 8A	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 15:45		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	EPA200.8	< 1.00	µg/L	15	5/4/2022	19:22	BM	1	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220425002-009
Sample Location:	FP-3 Sink Faculty Room	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 15:46		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	EPA200.8	< 1.00	µg/L	15	5/4/2022	19:27	BM	1	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220425002-010
Sample Location:	DW-2 Fountain by Rm 6	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 15:48		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	EPA200.8	7.15	µg/L	15	5/4/2022	19:31	BM	1	1

Water Management Services

Sample Matrix:	Drinking Water	Lab Sample Number:	220425002-011
Sample Location:	DW-3 Fountain by Rm 5	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 15:49		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	EPA200.8	2.69	µg/L	15	5/4/2022	20:00	BM	1	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220425002-012
Sample Location:	DW-4 Fountain by Rm 2	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 15:50		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	EPA200.8	5.06	µg/L	15	5/4/2022	20:05	BM	1	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220425002-013
Sample Location:	DW-6 Outside Fountain	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 15:53		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	EPA200.8	1.24	µg/L	15	5/4/2022	20:10	BM	1	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220425002-014
Sample Location:	WC-5 Fountain by Rm 11	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 15:55		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	EPA200.8	2.83	µg/L	15	5/4/2022	20:15	BM	1	1

Water Management Services

Sample Matrix:	Drinking Water	Lab Sample Number:	220425002-015
Sample Location:	DW-5 Fountain by Rm 12	Customer Sample Number:	
Sampled By:	R. Busacco		
Sample Date/Time:	4/20/2022 15:57		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	EPA200.8	9.55	µg/L	15	5/4/2022	20:20	BM	1	1

NJ Lab ID# 14013 (Dover)

NJ Lab ID# 13033 (Marlboro)

NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.

Any method followed by an asterisk (*) was analyzed by the Agra-Marlboro laboratory.

All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen

Susan VanVeen, Laboratory Manager

May 06, 2022



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name:	Water Management Services, Inc.	Report to:	Agra Environmental Services
Address:	PO Box 142		90 1/2 West Blackwell Street
	Allamuchy, NJ 07820		Dover, NJ 07801
Project Location:			Phone: (973) 989-0010
Customer Contact:	Ron Busacco		Fax: (973) 989-0156
Phone - Work/Cell:	(201) 274-4527		

- # _____ Asc./HCl Vials pH: _____
- # _____ HCl Vials pH: _____
- # 15 Na₂S₂O₈ 250 ml Cl₂: _____
- # _____ HNO₃ pH: _____
- # _____ H₂SO₄ pH: _____
- # _____ NaOH pH: _____
- # _____ unpreserved _____
- # _____ other _____
- # _____ other _____

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake Page 1 of 2

Project: Wantage School		Collection		PWSID#		for laboratory use only		Field Analysis			
Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl ₂ or PO ₄
<u>210425002</u>											
	WC-1 Fountain Main Hall - <u>001</u>	4/20/22	15:30	X		DW	1	H ₂ SO ₄ <u>HNO₃</u>	Lead (1st Draw)		
	NS Sink Nurse - <u>002</u>	4/20/22	15:32	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	<u>FP-1</u> Kitchen Sink Right - <u>003</u>	4/20/22	15:34	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	FP-2 Kitchen Sink Left - <u>004</u>	4/20/22	15:36	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	WC-2 Fountain 2nd Floor - <u>005</u>	4/20/22	15:38	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	WC-3 Fountain Between B&G - <u>006</u>	4/20/22	15:41	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	DW-1 Fountain by Rm 7 - <u>007</u>	4/20/22	15:43	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	WC-4 Fountain by Rm 8A - <u>008</u>	4/20/22	15:45	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	FP-3 Sink Faculty Room - <u>009</u>	4/20/22	15:46	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		
	<u>DW-1</u> Fountain by Rm 6 - <u>010</u>	4/20/22	15:48	X		DW	1	H ₂ SO ₄	Lead (1st Draw)		

Sampled By (name/company): Ron Busacco / WMS

Are these samples for compliance? (circle one): Yes or No

Indicate laboratory location where analysis request was performed

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box):

Standard	<input checked="" type="checkbox"/>	NJ Reduced	<input type="checkbox"/>	Other (Specify)	<input type="checkbox"/>
----------	-------------------------------------	------------	--------------------------	-----------------	--------------------------

Cooler Temperature Upon Receipt at lab: N/A

Sample Custody Exchanges (Please use full legal signature)

Relinquished By: <u>Ron Busacco</u>	Date: <u>4/22/22</u>	Time: <u>1555</u>	Received By: <u>Sherry [Signature]</u>	Date: <u>4/22/22</u>	Time: <u>1625</u>	Comments: <u>* pres. w/ #003 4/22/22 @ 1629 [Signature]</u>
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	

Date Faxed _____
Invoice Number _____

Is sample known to be hazardous? (circle one)
Yes or No



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name:	Water Management Services, Inc.	Report to:	Agra Environmental Services	# _____	Asc./HCl Vials	pH: _____
Address:	PO Box 142		90 1/2 West Blackwell Street	# _____	HCl Vials	pH: _____
	Allamuchy, NJ 07820		Dover, NJ 07801	# _____	Na ₂ S ₂ O ₃	Cl ₂ : _____
Project Location:			Phone: (973) 989-0010	# _____	HNO ₃	pH: _____
Customer Contact:	Ron Busacco		Fax: (973) 989-0156	# _____	H ₂ SO ₄	pH: _____
Phone - Work/Cell:	(201) 274-4527			# _____	NaOH	pH: _____
				# _____	unpreserved	_____
				# _____	other	_____
				# _____	other	_____

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake

Page 2 of 2

Project: Wantage School		Collection		PWSID#				for laboratory use only		Field Analysis	
Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl ₂ or PO ₄
L20425002	DW-3 Fountain by Rm 5 - <i>all</i>	4/20/22	15:49	X		DW	1	H2SO4	Lead (1st Draw)		
	DW-4 Fountain by Rm 2 - <i>all</i>	4/20/22	15:50	X		DW	1	H2SO4	Lead (1st Draw)		
	DW-6 Outside Fountain - <i>all</i>	4/20/22	15:53	X		DW	1	H2SO4	Lead (1st Draw)		
	WC-5 Fountain by Rm 11 - <i>all</i>	4/20/22	15:55	X		DW	1	H2SO4	Lead (1st Draw)		
	DW-5 Fountain by Rm 12 - <i>all</i>	4/20/22	15:57	X		DW	1	H2SO4	Lead (1st Draw)		

Sampled By (name/company): <i>Ron Busacco / WMS</i>	Are these samples for compliance? (circle one): Yes or No	Indicate laboratory location where analysis request was performed
	NJDEP Laboratory Certification (Dover, NJ) #14013	
	NJDEP Laboratory Certification (Marlboro, NJ) #13033	
Reporting Requirements (Check Box):	Standard <input checked="" type="checkbox"/> <input type="checkbox"/> NJ Reduced <input type="checkbox"/> Other (Specify)	Cooler Temperature Upon Receipt at lab: <i>N/A</i>

Sample Custody Exchanges (Please use full legal signature)						Comments:
Relinquished By: <i>Ron Busacco</i>	Date: <i>4/22/22</i>	Time: <i>1555</i>	Received By: <i>Sherry</i>	Date: <i>4/22/22</i>	Time: <i>1625</i>	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____ Invoice Number _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one) Yes or No