



HADDON TOWNSHIP BOARD OF EDUCATION

500 RHOADS AVENUE • WESTMONT, NEW JERSEY 08108
PHONE: 856-869-7750 ext. 1100 • FAX: 856-854-7792
WEBSITE: www.haddontwpschools.com

Robert J. Fisicaro, Ed.D.
Superintendent of Schools
856-869-7750 Ext. 1100
rfisicaro@htsd.us

Jennifer Gauld
School Business Administrator/
Board Secretary
856-869-7750 Ext. 1105
jgauld@htsd.us

Elizabeth Mennig
Assistant Superintendent for
Curriculum & Instruction
856-869-7750 Ext. 1108
lmennig@htsd.us

May 11, 2022

Haddon Township Parents/Guardians/Staff,

The Haddon Township Board Education is highly committed to the safety of our students and staff. In compliance with New Jersey Department of Education regulations, lead in water testing for drinking water locations was performed on April 15, 2022 at all district locations. The purpose of the sampling was to identify and address any drinking water location above the EPA action level of 15.5 parts per billion (ppb). A drinking water location is an outlet that is designed or expected to be used for water consumption. These included, but were not limited to, classroom water fountains or sinks, water coolers, sinks in nurse's offices, faculty break rooms, and locations in kitchens used for food preparation. Bathroom, custodial, art room, and science room sinks were not sampled, as these are not expected nor designed to be used for water consumption.

Water was allowed to stay motionless in each facility for a minimum of eight hours prior to sampling. After this time of inactivity, an "initial draw" sample was collected from the first water to come out of the outlet. After the initial draw sample was collected, water was allowed to flush for 30 seconds, and a second "flush" sample was collected. The purpose of the flush sample is to help determine if contamination does exist, whether it is originating from the outlet itself or from the building's plumbing.

A summary of each location above the action level, as well as the short-term response, is found below:

District Offices

| SAMPLE LOCATION | FIRST DRAW SAMPLE RESULT | FLUSH SAMPLE RESULT | SHORT TERM RESPONSE |
|-----------------|-----------------------------|---------------------------|------------------------|
| NONE | | | |

Edison Elementary School

| SAMPLE LOCATION | FIRST DRAW SAMPLE RESULT | FLUSH SAMPLE RESULT | SHORT TERM RESPONSE |
|---|--------------------------|---------------------|----------------------|
| Bubbler – 1 st Floor Hallway | 17.8 ppb | 9.52 ppb | Taken out of service |

Jennings Elementary School

| SAMPLE LOCATION | FIRST DRAW SAMPLE RESULT | FLUSH SAMPLE RESULT | SHORT TERM RESPONSE |
|-----------------|--------------------------|---------------------|---------------------|
| NONE | | | |

Stoy Elementary School

| SAMPLE LOCATION | FIRST DRAW SAMPLE RESULT | FLUSH SAMPLE RESULT | SHORT TERM RESPONSE |
|-----------------|--------------------------|---------------------|---------------------|
| NONE | | | |

Strawbridge Elementary School

| SAMPLE LOCATION | FIRST DRAW SAMPLE RESULT | FLUSH SAMPLE RESULT | SHORT TERM RESPONSE |
|-----------------|--------------------------|---------------------|---------------------|
| NONE | | | |

Van Sciver Elementary School

| SAMPLE LOCATION | FIRST DRAW SAMPLE RESULT | FLUSH SAMPLE RESULT | SHORT TERM RESPONSE |
|-------------------------------|--------------------------|---------------------|----------------------|
| Sink – Room 151 | 107 ppb | 53.2 ppb | Taken out of service |
| Bubbler – Room 154 | 20.9 ppb | 13.6 ppb | Taken out of service |
| Bubbler – Room 102 | 72.8 ppb | 7.80 ppb | Taken out of service |
| Bubbler – Room 101 | 43.0 ppb | 7.36 ppb | Taken out of service |
| Bubbler – Room 104, Left Side | 22.9 ppb | 9.92 ppb | Taken out of service |

Rohrer Middle School

| SAMPLE LOCATION | FIRST DRAW SAMPLE RESULT | FLUSH SAMPLE RESULT | SHORT TERM RESPONSE |
|-----------------|--------------------------|---------------------|---------------------|
| NONE | | | |

Haddon Township High School

| SAMPLE LOCATION | FIRST DRAW SAMPLE RESULT | FLUSH SAMPLE RESULT | SHORT TERM RESPONSE |
|-----------------|-----------------------------|---------------------------|------------------------|
| NONE | | | |

At this time, permanent solutions for each of these locations are being evaluated. The district will notify staff, students, and parents as these solutions are implemented.

Sincerely,

Jennifer Gauld