



ADDENDUM NO. 03

PUTNAM MIDDLE SCHOOL
HVAC PROJECT
35 WICKER STREET
PUTNAM, CONNECTICUT

R&D File No. 24103.02

August 12, 2024

The following list of changes are hereby made to the bid documents dated July 31, 2024 for the project referred to above. Bidders shall indicate receipt of this addendum on the bid form and reflect the changes in bids submitted. Additional compensation or change orders will not be granted after the contract is awarded or during construction due to omission of the listed items by the bidder.

1. QUESTION: The model numbers depict 2.0-ton units however the “tonnage” is 2.5-ton. Which tonnage is required?

ANSWER: There are two capacities models used in each school. The four unit that are in the gymnasium in both schools shall be 2.5-ton. The rest of the units will be 1.5 ton.

END OF ADDENDUM NO. 03