

Radon Testing Results Summary: Riverdale Grade School

Notes:

- The radon **Action Level** is **4.0 pCi/L**.

Legend:

- Test results **equal to or greater than the Action Level** of 4.0 pCi/L are **highlighted in red and precede a "High" value** in the "Initial Level" or "Final Level" column.

Building Name	Room Description (per floor plan)	Initial Test Date	Initial Test Kit Serial #	Initial Test Type	Initial Test Result (pCi/L)	Initial Level	Final Retest Date	Final Test Kit Serial #	Final Test Type	Final Test Result (pCi/L)	Final Level
Main Building	105	8/12/21	AA128718	Detector Kit	0.8	Low					
Main Building	116	8/12/21	AA128716	Detector Kit	0.8	Low					
Main Building	109	8/12/21	AA128715	Detector Kit	1.3	Low					
Main Building	110	8/12/21	AA128711	Detector Kit	1.1	Low					
Main Building	106	8/12/21	AA128710	Detector Kit	1.3	Low					
Main Building	101	8/12/21	AA128709	Detector Kit	0.8	Low					
Main Building	102	8/12/21	AA128708	Detector Kit	1.3	Low					
Main Building	120	8/12/21	A128707	Detector Kit	1.1	Low					
Main Building	122	8/12/21	AE994775	Detector Kit	1.1	Low					
Main Building	118	8/12/21	AE994777	Detector Kit	1.7	Low					
Main Building	114	8/12/21	AE994772	Detector Kit	0.8	Low					
Main Building	136	8/12/21	AE994773	Detector Kit	1.0	Low					
Main Building	135	8/12/21	AE994767	Detector Kit	1.3	Low					
Main Building	127	8/12/21	AE994750	Detector Kit	0.8	Low					
Main Building	131	8/12/21	AE994737	Detector Kit	0.8	Low					
Main Building	132	8/12/21	AE994745	Detector Kit	1.0	Low					
Main Building	130	8/12/21	AE994739	Detector Kit	1.0	Low					
Main Building	128	8/12/21	AE994735	Detector Kit	0.9	Low					
Commons		8/12/21	AE994770	Detector Kit	0.6	Low					
Gymnasium	North	8/12/21	AE994776	Detector Kit	0.9	Low					
Gymnasium	South	8/12/21	AE994774	Detector Kit	0.7	Low					
Music Building	Office	8/12/21	AE994762	Detector Kit	1.3	Low					
Music Building	South	8/12/21	AE994779	Detector Kit	1.1	Low					
Music Building	North	8/12/21	AE994780	Detector Kit	1.2	Low					
District Office	Middle Office	8/12/21	AE994761	Detector Kit	1.1	Low					
District Office	NW Office	8/12/21	AE994769	Detector Kit	0.6	Low					
District Office	SW Office	8/12/21	AE994781	Detector Kit	1.3	Low					
District Office	Front Office	8/12/21	AE994766	Detector Kit	0.6	Low					