



August 14, 2024

Josh Hustad  
Director of Facility Operations  
Raytown School District  
5911 Blue Ridge Boulevard  
Raytown, Missouri 64133

**Project: Limited Lead in Drinking Water Testing**  
**Address: 8211 Sterling Avenue, Raytown, Missouri 64138**

Mr. Josh Hustad

On July 9, 2024, under the guidance of Jeff Hurst, Josh Milne, of Axiom Service Professionals (ASP), conducted lead in drinking water sampling at the above referenced address. A total of 50 samples were collected from various potential drinking water outlets including sources used for drinking, cooking, or cleaning of cooking and eating utensils throughout the building.

### **Drinking Water Standards**

The use of lead solder and other lead-containing materials as defined in the EPA Safe Drinking Water Act in connecting household plumbing to public water supplies was prohibited as of 1986. The act established the definition of "lead free" to be less than 8% as a weighted average across wetted surfaces of a pipe, pipe fitting, plumbing fitting, and fixture and 0.2% lead for solder and flux. In 2011, the definition of "lead free" as it applied to wetted surfaces of a pipe, pipe fitting, and plumbing fitting and fixture was reduced from 8% to 0.25% as a weighted average. Many older structures still have lead pipe or lead-soldered plumbing internally, which may substantially increase the lead content of water at the tap. Nationwide regulations controlling the lead content of drinking-water coolers in schools went into effect in 1989.

In 1991, the EPA published the Lead and Copper Rule establishing limits on the amount of lead and copper in drinking water. This regulation can be found under 40 CFR Part 141, Subpart I. Reference: <https://www.epa.gov/dwreginfo/lead-and-copper-rule>

The EPA has set lead in drinking water standards as outlined below.

- For lead, the maximum contaminant level goal (MCLG) is zero. This is the levels determined to be safe by toxicological and biomedical considerations, independent of feasibility. EPA's National Primary Drinking Water Regulations for Lead establish a treatment level of **0.015 mg/L** or **15 ppb** (parts per billion) in municipal drinking water systems.

The Missouri Senate Bill 681 “Get the Lead Out of School Drinking Water Act”, passed in 2022, has set the standard summarized below.

Reference: [https://www.senate.mo.gov/22info/BTS\\_Web/Bill.aspx?SessionType=R&BillID=71259862](https://www.senate.mo.gov/22info/BTS_Web/Bill.aspx?SessionType=R&BillID=71259862)

- On or before January 1, 2024, each school shall conduct an inventory of all drinking water outlets and all outlets that are used for dispensing water for cooking or for cleaning cooking and eating utensils in each of the school's buildings. A plan for testing should then be developed, prioritizing early childhood education programs and elementary schools, and made available to the public.
- The bill outlines that beginning in the 2023-2024 school year and for each subsequent school year, each school shall provide drinking water with a lead concentration below five parts per billion (**5 ppb**). Any school with greater than or equal to 5 ppb shall provide results and remediation plans to parents and staff within 7 business days of receiving results.

### Drinking Fountain Identification

Drinking fountains throughout the school were visually assessed to determine if they matched those listed by the EPA to be lead-containing. The list of drinking fountains reported by the EPA to contain lead-lined holding tanks or solder joints is presented as Appendix B. Below is a list of drinking fountains within the school that match those reported by the EPA to be lead-containing.

Location	Make	Model #	Serial #
None Matching			

### Water Sampling Methods:

Water samples were collected from each selected location as “first draw” and/or “flush”. First draw samples typically represent worst case sample results. A flush sample is typically collected to determine if an elevation is originating beyond the fixture in the fixture supply line or beyond. Samples were deposited into a non-preserved 250-milliliter sterile Nalgene screw top bottle. Immediately following sample collection, the samples were delivered to Keystone Laboratories located at 8857 Long Street, Lenexa, Kansas 66215. Upon arrival at the laboratory, samples were preserved through addition of nitric acid.

Keystone Laboratories is accredited through the Missouri Department of Natural Resources for analysis of lead in water.

Below is a summary of the water sampling results as reported in Appendix C by Keystone Laboratories. Results exceeding the applicable drinking water standards are shown in **red text**.

### July 9, 2024 Water Sampling Results:

Sample #	Location	Source Under Test	Test Type	Lead Result (ppb)
8211-1-FD	Raytown South High - Clinic	Sink Tap	First Draw	1.6
8211-2-FD	Raytown South High - Near Room 1	Drinking Fountain	First Draw	<0.4
8211-3-FD	Raytown South High - Near Room 8	Drinking Fountain	First Draw	<0.4
8211-4-FD	Raytown South High - Near Room 11	Drinking Fountain	First Draw	<0.4
8211-5-FD	Raytown South High - Near Little Theater - Left	Drinking Fountain	First Draw	1.4
8211-6-FD	Raytown South High - Near Little Theater - Right	Drinking Fountain	First Draw	9
8211-7-FD	Raytown South High - Across from Room 122	Bottle Filler	First Draw	<0.4

Sample #	Location	Source Under Test	Test Type	Lead Result (ppb)
8211-8-FD	Raytown South High - Outside Room 128 - Left	Drinking Fountain	First Draw	<0.4
8211-9-FD	Raytown South High - Across from Room 114A	Drinking Fountain	First Draw	<0.4
8211-10-FD	Raytown South High - Near Room 109 - Left	Drinking Fountain	First Draw	<0.4
8211-11-FD	Raytown South High - Near Room 109 - Right	Drinking Fountain	First Draw	<0.4
8211-12-FD	Raytown South High - Outside Office - Left	Drinking Fountain	First Draw	<0.4
8211-13-FD	Raytown South High - Outside Office - Right	Drinking Fountain	First Draw	<0.4
8211-14-FD	Raytown South High - Across from E5	Drinking Fountain	First Draw	<0.4
8211-15-FD	Raytown South High - Near Room 111 - Left	Drinking Fountain	First Draw	<0.4
8211-16-FD	Raytown South High - Outside Room 111 - Right	Drinking Fountain	First Draw	<0.4
8211-17-FD	Raytown South High - Near Room 218	Drinking Fountain	First Draw	<0.4
8211-18-FD	Raytown South High - Outside Room 218	Bottle Filler	First Draw	46.9
8211-19-FD	Raytown South High - Near Room 210	Bottle Filler	First Draw	<0.4
8211-20-FD	Raytown South High - Outside Room 200 - Left	Drinking Fountain	First Draw	<0.4
8211-21-FD	Raytown South High - Outside Room 200 - Right	Drinking Fountain	First Draw	<0.4
8211-22-FD	Raytown South High - Counselor's Lounge	Sink Tap	First Draw	<0.4
8211-23-FD	Raytown South High - Room 136	Sink Tap	First Draw	<0.4
8211-24-FD	Raytown South High - Room 115	Sink Tap	First Draw	1
8211-25-FD	Raytown South High - Concession Stand - Left	Sink Tap	First Draw	4.1
8211-26-FD	Raytown South High - Concession Stand - Right	Sink Tap	First Draw	0.9
8211-27-FD	Raytown South High - Prep Sink Near Serving Line	Sink Tap	First Draw	0.9
8211-28-FD	Raytown South High - Triple Sink - Left	Sink Tap	First Draw	<0.4
8211-29-FD	Raytown South High - Triple Sink - Right	Sink Tap	First Draw	0.8
8211-30-FD	Raytown South High - Tilt Skillet - Left	Sink Tap	First Draw	18.4
8211-31-FD	Raytown South High - Tilt Skillet - Right	Sink Tap	First Draw	19.1
8211-32-FD	Raytown South High - Prep Double Sink Near Serving Line	Sink Tap	First Draw	0.9
8211-33-FD	Raytown South High - FACS Teacher's Station	Sink Tap	First Draw	<0.4

Sample #	Location	Source Under Test	Test Type	Lead Result (ppb)
8211-34-FD	Raytown South High - FACS 1	Sink Tap	First Draw	<0.4
8211-35-FD	Raytown South High - FACS 2	Sink Tap	First Draw	2.4
8211-36-FD	Raytown South High - FACS 3	Sink Tap	First Draw	0.5
8211-37-FD	Raytown South High - FACS 4	Sink Tap	First Draw	0.6
8211-38-FD	Raytown South High - FACS 5	Sink Tap	First Draw	0.7
8211-39-FD	Raytown South High - FACS 6	Sink Tap	First Draw	0.7
8211-40-FD	Raytown South High - Cafeteria	Drinking Fountain	First Draw	<0.4
8211-41-FD	Raytown South High - Concession Stand Triple Sink - Left	Sink Tap	First Draw	<0.4
8211-42-FD	Raytown South High - Concession Stand Triple Sink - Right	Sink Tap	First Draw	<0.4
8211-43-FD	Raytown South High - Coffee Maker Tap - North	Sink Tap	First Draw	54.6
8211-44-FD	Raytown South High - Coffee Maker Tap - South	Sink Tap	First Draw	17.8
8211-45-FD	Raytown South High - Outside Concession Stand	Ice Machine	First Draw	3.2
8211-46-FD	Raytown South High - Concession Stand - South	Drinking Fountain	First Draw	0.5
8211-47-FD	Raytown South High - Concession Stand - North	Drinking Fountain	First Draw	<0.4
8211-48-FD	Raytown South High - Concession Stand between Restrooms	Drinking Fountain	First Draw	<0.4
8211-49-FD	Raytown South High - Concession Stand	Spigot	First Draw	<0.4
8211-50-FD	Raytown South High - Concession - Small	Ice Machine	First Draw	4.6

Photos of the sampling locations are provided in Appendix D. A diagram containing identifiers on the outlets tested is provided in Appendix E.



## Short-Term Control Measures

- Per the State of Missouri Senate Bills Nos. 681 & 662, a remediation plan should be developed and executed.
- Take immediate steps to prevent use from the failed source(s).
- Shut-off problem outlets
- Post “Not for Drinking/Cooking” at Problem Outlets. If initial sample results from an outlet(s) exceed the remediation trigger level, but are not routinely used for human ingestion (e.g., handwashing), clear signage can be posted to notify people that the outlet is not to be used for drinking or cooking until the problem is resolved.
- Consider performing follow-up flush testing in order to attempt to identify what component within the system is the source of the elevated lead concentration. This testing will assist to pinpoint where lead is getting into drinking water (i.e., fixtures versus interior plumbing) so that appropriate corrective measures can be taken.
- Shut-off or disconnection of problem outlets can provide a permanent solution. If the outlet is frequently used, this likely is not a practical long-term solution.
- Provide point-of-use (POU) filters at problem taps. Filters need routine maintenance (e.g., cartridge filter units need to be replaced periodically) to remain effective.

## Permanent Control Measures

- Per the State of Missouri Senate Bills Nos. 681 & 662, a remediation plan should be developed and executed.
- Replacement of Problem Outlets and any identified upstream plumbing components (e.g., valves, leaded solder) to permanently address the problem. EPA's revised March 2015 guidance, How to Identify Lead-Free Certification Marks for Drinking Water System & Plumbing Products, can be a useful resource selecting leadfree plumbing.
- Provide point-of-use filters (POU) at problem taps as a long-term or permanent control measure. When doing this, facilities should be sure to create maintenance schedules and identify a point of contact to be in charge of making sure they are properly maintained.
- Reconfigure Plumbing. Ongoing renovation of school or childcare buildings may provide an opportunity to modify the plumbing system to redirect water supplied for drinking or cooking to bypass sources of lead contamination. Before undertaking such an alternative, be certain that you have properly identified all of the sources of lead contamination in drinking water.
- Remove and replace any drinking water coolers or drinking water outlets that the United States Environmental Protection Agency has determined are not lead-free under the federal Lead Contamination Control Act of 1988, as amended; except the school shall not be required to replace those drinking water outlets or water coolers that tested in accordance with state regulations and have been determined to be dispensing drinking water with a lead concentration less than five (5) part per billion (ppb); however, such drinking water outlet or water cooler shall be subject to all testing requirements and shall not be excluded from testing under subsection 10 of the Missouri Senate Bills Nos. 681 & 662, Section 160.077.
- Consider filtration of incoming water at the point of entry (POE) to the building.

## Required Communication

- Contact staff and parents via written notification within seven (7) business days after receiving the test result.
- The notification shall include at least:
  - The test results and a summary that explains such results;
  - A description of any remedial steps taken; and
  - A description of general health effects of lead contamination and community specific resources; and
- Provide bottled water if there is not enough water to meet the drinking water needs of the students, teachers, and staff.
- Submit such annual testing results to the Missouri Department of Health and Senior Services (DHSS).
- Before August 1, 2024, or the first day on which students will be present in the building, whichever is later, and annually thereafter, each school shall conduct testing for lead by first-draw and follow-up flush samples of a random sampling of at least twenty-five percent (25%) of remediated drinking water outlets until all remediated sources have been tested as recommended by the 2018 version of the United States Environmental Protection Agency's "Training, Testing, and Taking Action" program. The testing shall be conducted and the results analyzed for both types of tests by an entity or entities approved by the department.
- Any measures taken to remediate any elevated lead levels identified must be recorded and documented.

## General Recommendations

- Retesting of all potential cooking and drinking water sources is required five (5) years from previous testing completed.
- If the condition changes or significant alterations to existing plumbing is undertaken, consider performing additional lead in drinking water sampling.
- Ensure that the plumbing system is not used as an electrical ground.
- If equipment is added that could affect water pH, alkalinity, or hardness, consider performing lead in drinking water sampling.

Any work resulting from this report should be conducted in accordance with the EPA Safe Drinking Water Act, Missouri SB 681 & 662, HUD Lead Regulations 24 CFR 35, EPA Lead Regulations 40 CFR 745, and Consumer Product Safety Commission document #5056.

If you have any questions concerning this report, please contact me at 816-678-7894.

Sincerely,



Jeff Hurst  
Axiom Service Professionals LLC  
[jeffh@axiomservicepros.com](mailto:jeffh@axiomservicepros.com)

### **Limitations Drinking Water Testing**

The presence or absence of lead and copper (if collected) in drinking water applies only to the test locations on the date of the field visit and it should be understood that conditions may change due to deterioration, pH, alkalinity, hardness, use levels, or maintenance. The results noted within this report were accurate at the time of the evaluation and in no way reflect the conditions at the property before or after the date of the evaluation. No other environmental concerns or conditions were addressed during this evaluation.

## **Appendix A Certifications**



**STATE OF MISSOURI**  
**DEPARTMENT OF HEALTH AND SENIOR SERVICES**

**LEAD OCCUPATION LICENSE REGISTRATION**

Issued to:

**Jeffrey A. Hurst**

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

**Lead Risk Assessor**  
Category of License

Issuance Date: **8/1/2022**  
Expiration Date: **8/1/2024**  
License Number: **000801-200166567**



**Missouri Department of Health  
and Senior Services**

Lead Occupation License - ID Badge

License Number:

**000801-200166567**

**Lead Risk Assessor**

**Jeffrey  
Hurst**

Expiration Date: **8/1/2024**

*Paula F. Nickelson*

**Paula F. Nickelson  
Acting Director**

**Department of Health and Senior Services**

**Jefferson City, MO 65102**



**Appendix B**  
**EPA Listed Lead Containing Drinking Fountains**

Table C-1  
Water Coolers With Other Lead Components

#### EBCO Manufacturing

- All pressure bubbler water coolers with shipping dates from 1962 through 1977 have a bubbler valve containing lead. The units contain a single, 50-50 tin-lead solder joint on the bubbler valve. Model numbers for coolers in this category are not available.
- The following models of pressure bubbler coolers produced from 1978 through 1981 contain one 50-50 tin-lead solder joint each.

CP3	DP15W	DPM8	7P	13P	DPM8H	DP15M	DP3R	DP8A
DP16M	DP5S	C10E	PX-10	DP7S	DP13SM	DP7M	DP7MH	DP7WD
WTC10	DP13M-60	DP14M	CP10-50	CP5	CP5M	DP15MW	DP3R	DP14S
DP20-50	DP7SM	DP10X	DP13A	DP13A-50	EP10F	DP5M	DP10F	CP3H
CP3-50	DP13M	DP3RH	DP5F	CP3M	EP5F	13PL	DP8AH	DP13S
CP10	DP20	DP12N	DP7WM	DP14A-50/60				

#### Halsey Taylor

- Lead solder was used in these models of water coolers manufactured between 1978 and the last week of 1987:

WMA-1	SCWT/SCWT-A	SWA-1	DC/DHC-1
S3/5/10D	BFC-4F/7F/4FS/7FS	S300/500/100D	

- The following coolers manufactured for Haws Drinking Faucet Company (Haws) by Halsey Taylor from November 1984 through December 18, 1987 are not lead-free because they contain 2 tin-lead solder joints. The model designations for these units are as follows:

HC8WT	HC14F	HC6W	HWC7D	HC8WTH	HC14FH	HC8W	HC2F	HC14WT
HC14FL	HC14W	HC2FH	HC14WTH	HC8FL	HC4F	HC5F	HC14WL	HCBF7D
HC4FH	HC10F	HC16WT	HCBF7HO	HC8F	HC8FH	HC4W	HWC7	

Table C-2  
Halsey Taylor Water Coolers With Lead-Lined Tanks

- The following six model numbers have one or more units in the model series with lead-lined tanks:

WM8A    WT8A    GC10ACR    GC10A    GC5A    RWM13A

- The following models and serial numbers contain lead-lined tanks:

WM14A Serial No. 843034	WM14A Serial No. 843006	WT11A Serial No. 222650
WT21A Serial No. 64309550	WT21A Serial No. 64309542	LL14A Serial No. 64346908

# **Appendix C**

## **Laboratory Analytical Report**



Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HG0152

AXIOM Service Professionals

Jeff Hurst  
PO Box 47166  
Kansas City, MO 64188

Project Name: 8211 Sterling Avenue

Project / PO Number: 8211 Sterling Avenue  
Received: 07/18/2024  
Reported: 08/07/2024

Work Order Special Information

Hurst, Jeff  
8211 Sterling Avenue

Analytical Testing Parameters

Client Sample ID: 8211-1-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-01  
Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 9:24

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	1.6	0.4	ppb	2		08/05/24 1620	08/06/24 1850	RVV

Client Sample ID: 8211-2-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-02  
Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 9:45

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 1853	RVV

Client Sample ID: 8211-3-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-03  
Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 9:47

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 1856	RVV

Client Sample ID: 8211-4-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-04  
Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 9:49

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 1859	RVV

Microbac Laboratories, Inc., Lenexa

8857 Long Street | Lenexa, KS 66215 | 913-321-7856 p | www.microbac.com



Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HG0152

Client Sample ID: 8211-5-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-05

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 9:54

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	1.4	0.4	ppb	2		08/05/24 1620	08/06/24 1902	RVV

Client Sample ID: 8211-6-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-06

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 9:57

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	9.0	0.4	ppb	2		08/05/24 1620	08/06/24 1905	RVV

Client Sample ID: 8211-7-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-07

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 9:58

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 1908	RVV

Client Sample ID: 8211-8-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-08

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 10:02

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 1911	RVV

Client Sample ID: 8211-9-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-09

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 10:07

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 1926	RVV

Microbac Laboratories, Inc., Lenexa

8857 Long Street | Lenexa, KS 66215 | 913-321-7856 p | www.microbac.com





Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HG0152

Client Sample ID: 8211-10-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-10

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 10:10

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 1935	RVV

Client Sample ID: 8211-11-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-11

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 10:14

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 1938	RVV

Client Sample ID: 8211-12-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-12

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 10:16

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 1941	RVV

Client Sample ID: 8211-13-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-13

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 10:18

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 1944	RVV

Client Sample ID: 8211-14-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-14

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 10:19

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 1947	RVV

Microbac Laboratories, Inc., Lenexa

8857 Long Street | Lenexa, KS 66215 | 913-321-7856 p | www.microbac.com



Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HG0152

Client Sample ID: 8211-15-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-15

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 10:23

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 1950	RVV

Client Sample ID: 8211-16-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-16

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 10:25

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 1953	RVV

Client Sample ID: 8211-17-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-17

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 10:29

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 2002	RVV

Client Sample ID: 8211-18-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-18

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 10:32

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	46.9	0.4	ppb	2		08/05/24 1620	08/06/24 2005	RVV

Client Sample ID: 8211-19-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-19

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 10:34

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 2008	RVV

Microbac Laboratories, Inc., Lenexa

8857 Long Street | Lenexa, KS 66215 | 913-321-7856 p | www.microbac.com



Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HG0152

Client Sample ID: 8211-20-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-20

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 10:37

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 2011	RVV

Client Sample ID: 8211-21-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-21

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 10:39

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 2014	RVV

Client Sample ID: 8211-22-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-22

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 10:46

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 2017	RVV

Client Sample ID: 8211-23-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-23

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 10:49

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 2020	RVV

Client Sample ID: 8211-24-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-24

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 11:02

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	1.0	0.4	ppb	2		08/05/24 1620	08/06/24 2023	RVV

Microbac Laboratories, Inc., Lenexa

8857 Long Street | Lenexa, KS 66215 | 913-321-7856 p | www.microbac.com



Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HG0152

Client Sample ID: 8211-25-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-25

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 11:06

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	4.1	0.4	ppb	2		08/05/24 1620	08/06/24 2026	RVV

Client Sample ID: 8211-26-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-26

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 11:08

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.9	0.4	ppb	2		08/05/24 1620	08/06/24 2029	RVV

Client Sample ID: 8211-27-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-27

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 11:13

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.9	0.4	ppb	2		08/05/24 1620	08/06/24 2038	RVV

Client Sample ID: 8211-28-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-28

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 11:16

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 2041	RVV

Client Sample ID: 8211-29-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-29

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 11:19

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.8	0.4	ppb	2		08/05/24 1620	08/06/24 2050	RVV

Microbac Laboratories, Inc., Lenexa

8857 Long Street | Lenexa, KS 66215 | 913-321-7856 p | www.microbac.com



Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HG0152

Client Sample ID: 8211-30-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-30

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 11:22

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	18.4	0.4	ppb	2		08/05/24 1620	08/06/24 2059	RVV

Client Sample ID: 8211-31-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-31

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 11:25

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	19.1	0.4	ppb	2		08/05/24 1620	08/06/24 2102	RVV

Client Sample ID: 8211-32-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-32

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 11:26

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.9	0.4	ppb	2		08/05/24 1620	08/06/24 2105	RVV

Client Sample ID: 8211-33-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-33

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 11:30

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 2114	RVV

Client Sample ID: 8211-34-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-34

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 11:31

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 2117	RVV

Microbac Laboratories, Inc., Lenexa

8857 Long Street | Lenexa, KS 66215 | 913-321-7856 p | www.microbac.com





Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HG0152

Client Sample ID: 8211-35-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-35

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 11:37

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	2.4	0.4	ppb	2		08/05/24 1620	08/06/24 2120	RVV

Client Sample ID: 8211-36-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-36

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 11:38

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.5	0.4	ppb	2		08/05/24 1620	08/06/24 2123	RVV

Client Sample ID: 8211-37-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-37

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 11:39

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.6	0.4	ppb	2		08/05/24 1620	08/06/24 2126	RVV

Client Sample ID: 8211-38-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-38

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 11:39

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.7	0.4	ppb	2		08/05/24 1620	08/06/24 2129	RVV

Client Sample ID: 8211-39-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-39

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 11:39

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.7	0.4	ppb	2		08/05/24 1620	08/06/24 2132	RVV

Microbac Laboratories, Inc., Lenexa

8857 Long Street | Lenexa, KS 66215 | 913-321-7856 p | www.microbac.com



Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HG0152

Client Sample ID: 8211-40-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-40

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 11:42

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 2135	RVV

Client Sample ID: 8211-41-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-41

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 11:48

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 2138	RVV

Client Sample ID: 8211-42-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-42

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 11:51

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 2141	RVV

Client Sample ID: 8211-43-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-43

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 11:54

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	54.6	0.4	ppb	2		08/05/24 1620	08/06/24 2150	RVV

Client Sample ID: 8211-44-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-44

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 11:55

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	17.8	0.4	ppb	2		08/05/24 1620	08/06/24 2153	RVV

Microbac Laboratories, Inc., Lenexa

8857 Long Street | Lenexa, KS 66215 | 913-321-7856 p | www.microbac.com



Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HG0152

Client Sample ID: 8211-45-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-45

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 11:58

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	3.2	0.4	ppb	2		08/05/24 1620	08/06/24 2156	RVV

Client Sample ID: 8211-46-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-46

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 12:02

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.5	0.4	ppb	2		08/05/24 1620	08/06/24 2159	RVV

Client Sample ID: 8211-47-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-47

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 12:07

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 2202	RVV

Client Sample ID: 8211-48-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-48

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 12:08

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 2205	RVV

Client Sample ID: 8211-49-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-49

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 12:11

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		08/05/24 1620	08/06/24 2214	RVV

Microbac Laboratories, Inc., Lenexa

8857 Long Street | Lenexa, KS 66215 | 913-321-7856 p | www.microbac.com



Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3HG0152

Client Sample ID: 8211-50-FD  
Sample Matrix: Drinking Water  
Lab Sample ID: 3HG0152-50

Collected By: Hurst, Jeff  
Collection Date: 07/09/2024 12:20

Analyses Performed by: Microbac Laboratories, Inc., Newton

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	4.6	0.4	ppb	2		08/05/24 1620	08/06/24 2229	RVV

Definitions

RL: Reporting Limit

Report Comments

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.

Reviewed and Approved By:

Carolyn Jackson  
Project Manager  
carolyn.jackson@microbac.com  
08/07/24 13:05



600 E. 17th St. S  
Newton, IA 50208  
Phone: 641-792-8451

3012 Ansborough Ave  
Waterloo, IA 50701  
Phone: 319-235-4440

835 S St. Paul  
Kansas City, KS 66105  
Phone: 913-321-7856

205 E Van Buren St  
Centerville, IA 52544  
Phone: 641-437-7023

X

<b>PRINT OR TYPE INFO BELOW:</b>		<b>REPORT TO:</b>		<b>BILL TO:</b>	
<b>SAMPLER:</b> Jeff Hurst		<b>NAME:</b> Jeff Hurst		<b>NAME:</b> Jeff Hurst	
<b>SITE NAME:</b>		<b>CO. NAME:</b>		<b>CO. NAME:</b>	
<b>ADDRESS:</b> 8211 Sterling Avenue		<b>ADDRESS:</b> PO Box 47166		<b>ADDRESS:</b> PO Box 47166	
<b>CITY/ST/ZIP:</b> Raytown, Missouri 64133		<b>CITY/ST/ZIP:</b> Kansas City, Missouri 64188		<b>CITY/ST/ZIP:</b> Kansas City, Missouri 64188	
<b>PHONE:</b>		<b>PHONE:</b> 816-678-7894		<b>PHONE:</b> 816-678-7894	
		<b>EMAIL:</b> jeffh@axiomservicepros.com		<b>EMAIL:</b> jeffh@axiomservicepros.com	

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED								LAB USE ONLY	
							Lead								Wk Order #:	
															Short Hold:	
															Rush:	
															Temp: oC	21.2
															Sample Condition	Sample #
8211-1-FD	7/9/2024	09:24	Raytown South High - Sink Tap - Clinic	1	Water	Grab	X									3HG0152-01
8211-2-FD	7/9/2024	09:45	Raytown South High - Drinking Fountain - Near Room 1	1	Water	Grab	X									02
8211-3-FD	7/9/2024	09:47	Raytown South High - Drinking Fountain - Near Room 8	1	Water	Grab	X									03
8211-4-FD	7/9/2024	09:49	Raytown South High - Drinking Fountain - Near Room 11	1	Water	Grab	X									04
8211-5-FD	7/9/2024	09:54	Raytown South High - Drinking Fountain - Near Little Theater - Left	1	Water	Grab	X									05
8211-6-FD	7/9/2024	09:57	Raytown South High - Drinking Fountain - Near Little Theater - Right	1	Water	Grab	X									06
8211-7-FD	7/9/2024	09:58	Raytown South High - Bottle Filler - Across Room 122	1	Water	Grab	X									07

Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:	07/18/24	
	Time:		<i>Carolyn Jackson</i>	Time:	16:00	



3 H G 0 1 5 2

AXIOM Service Professionals

PM: Carolyn Jackson





600 E. 17th St. S  
Newton, IA 50208  
Phone: 641-792-8451

3012 Ansborough Ave  
Waterloo, IA 50701  
Phone: 319-235-4440

X

835 S St. Paul  
Kansas City, KS 66105  
Phone: 913-321-7856

205 E Van Buren St  
Centerville, IA 52544  
Phone: 641-437-7023

<b>PRINT OR TYPE INFO BELOW:</b>		<b>REPORT TO:</b>		<b>BILL TO:</b>	
<b>SAMPLER:</b> Jeff Hurst		<b>NAME:</b> Jeff Hurst		<b>NAME:</b> Jeff Hurst	
<b>SITE NAME:</b>		<b>CO. NAME:</b>		<b>CO. NAME:</b>	
<b>ADDRESS:</b> 8211 Sterling Avenue		<b>ADDRESS:</b> PO Box 47166		<b>ADDRESS:</b> PO Box 47166	
<b>CITY/ST/ZIP:</b> Raytown, Missouri 64133		<b>CITY/ST/ZIP:</b> Kansas City, Missouri 64188		<b>CITY/ST/ZIP:</b> Kansas City, Missouri 64188	
<b>PHONE:</b>		<b>PHONE:</b> 816-678-7894		<b>PHONE:</b> 816-678-7894	
		<b>EMAIL:</b> jeffh@axiomservicepros.com		<b>EMAIL:</b> jeffh@axiomservicepros.com	

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED								LAB USE ONLY	
							Lead								Wk Order #:	3HGD152
															Short Hold:	
															Rush:	
															Temp: oC	
															Sample Condition	Sample #
8211-8-FD	7/9/2024	10:02	Raytown South High - Drinking Fountain - Outside Room 128 - Left	1	Water	Grab	X									3HGD152-08
8211-9-FD	7/9/2024	10:07	Raytown South High - Drinking Fountain - Across Room 114A	1	Water	Grab	X									09
8211-10-FD	7/9/2024	10:11	Raytown South High - Drinking Fountain - Near Room 109 - Left	1	Water	Grab	X									10
8211-11-FD	7/9/2024	10:14	Raytown South High - Drinking Fountain - Near Room 109 - Right	1	Water	Grab	X									11
8211-12-FD	7/9/2024	10:16	Raytown South High - Drinking Fountain - Outside Office - Left	1	Water	Grab	X									12
8211-13-FD	7/9/2024	10:18	Raytown South High - Drinking Fountain - Outside Office - Right	1	Water	Grab	X									13
8211-14-FD	7/9/2024	10:19	Raytown South High - Drinking Fountain - Across From E5	1	Water	Grab	X									14

Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:	07/18/24	
	Time:		<i>Carolyn L. Jackson</i>	Time:	16:00	



3 H G 0 1 5 2

AXIOM Service Professionals

PM: Carolyn Jackson



600 E. 17th St. S  
Newton, IA 50208  
Phone: 641-792-8451

3012 Ansborough Ave  
Waterloo, IA 50701  
Phone: 319-235-4440

X

835 S St. Paul  
Kansas City, KS 66105  
Phone: 913-321-7856

205 E Van Buren St  
Centerville, IA 52544  
Phone: 641-437-7023

## PRINT OR TYPE INFO BELOW:

**SAMPLER:** Jeff Hurst  
**SITE NAME:**  
**ADDRESS:** 8211 Sterling Avenue  
**CITY/ST/ZIP:** Raytown, Missouri 64133  
**PHONE:**

## REPORT TO:

**NAME:** Jeff Hurst  
**CO. NAME:**  
**ADDRESS:** PO Box 47166  
**CITY/ST/ZIP:** Kansas City, Missouri 64188  
**PHONE:** 816-678-7894  
**EMAIL:** jeffh@axiomservicepros.com

## BILL TO:

**NAME:** Jeff Hurst  
**CO. NAME:**  
**ADDRESS:** PO Box 47166  
**CITY/ST/ZIP:** Kansas City, Missouri 64188  
**PHONE:** 816-678-7894  
**EMAIL:** jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED							LAB USE ONLY	
							Lead							Wk Order #:	
														Short Hold:	
														Rush:	
														Temp: oC	
														Sample Condition	Sample #
8211-15-FD	7/9/2024	10:23	Raytown South High - Drinking Fountain - Near Room 111 - Left	1	Water	Grab	X								3HGO152-15
8211-16-FD	7/9/2024	10:25	Raytown South High - Drinking Fountain - Outside Room 111 - Right	1	Water	Grab	X								16
8211-17-FD	7/9/2024	10:29	Raytown South High - Drinking Fountain - Near Room 218	1	Water	Grab	X								17
8211-18-FD	7/9/2024	10:32	Raytown South High - Bottle Filler - Outside Room 218	1	Water	Grab	X								18
8211-19-FD	7/9/2024	10:34	Raytown South High - Bottle Filler - Near Room 210	1	Water	Grab	X								09
8211-20-FD	7/9/2024	10:37	Raytown South High - Drinking Fountain - Near Room 200 - Left	1	Water	Grab	X								20
8211-21-FD	7/9/2024	10:39	Raytown South High - Drinking Fountain - Outside Room 200 - Right	1	Water	Grab	X								21

Relinquished by: (Signature)	Date:	Received by: (Signature)	Date:	Remarks:
	Time:		Time:	
Relinquished by: (Signature)	Date:	Received by: (Signature)	Date:	
	Time:		Time:	

07/18/24

16:00



3 H G 0 1 5 2

AXIOM Service Professionals

PM: Carolyn Jackson



600 E. 17th St. S  
Newton, IA 50208  
Phone: 641-792-8451

3012 Ansborough Ave  
Waterloo, IA 50701  
Phone: 319-235-4440

X

835 S St. Paul  
Kansas City, KS 66105  
Phone: 913-321-7856

205 E Van Buren St  
Centerville, IA 52544  
Phone: 641-437-7023

<b>PRINT OR TYPE INFO BELOW:</b>		<b>REPORT TO:</b>		<b>BILL TO:</b>	
<b>SAMPLER:</b> Jeff Hurst		<b>NAME:</b> Jeff Hurst		<b>NAME:</b> Jeff Hurst	
<b>SITE NAME:</b>		<b>CO. NAME:</b>		<b>CO. NAME:</b>	
<b>ADDRESS:</b> 8211 Sterling Avenue		<b>ADDRESS:</b> PO Box 47166		<b>ADDRESS:</b> PO Box 47166	
<b>CITY/ST/ZIP:</b> Raytown, Missouri 64133		<b>CITY/ST/ZIP:</b> Kansas City, Missouri 64188		<b>CITY/ST/ZIP:</b> Kansas City, Missouri 64188	
<b>PHONE:</b>		<b>PHONE:</b> 816-678-7894		<b>PHONE:</b> 816-678-7894	
		<b>EMAIL:</b> jeffh@axiomservicepros.com		<b>EMAIL:</b> jeffh@axiomservicepros.com	

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED							LAB USE ONLY	
							Lead							Wk Order #:	3HG0152
														Short Hold:	
														Rush:	
														Temp: oC	
														Sample Condition	Sample #
8211-22-FD	7/9/2024	10:46	Raytown South High - Sink Tap - Counselor's Lounge	1	Water	Grab	X								3HG0152-22
8211-23-FD	7/9/2024	10:49	Raytown South High - Sink Tap - Room 136	1	Water	Grab	X								23
8211-24-FD	7/9/2024	11:02	Raytown South High - Sink Tap - Room 115	1	Water	Grab	X								24
8211-25-FD	7/9/2024	11:06	Raytown South High - Sink Tap - Concession Stand - Left	1	Water	Grab	X								25
8211-26-FD	7/9/2024	11:08	Raytown South High - Sink Tap - Concession Stand - Right	1	Water	Grab	X								26
8211-27-FD	7/9/2024	11:13	Raytown South High - Sink Tap - Prep Sink Near Serving Line	1	Water	Grab	X								27
8211-28-FD	7/9/2024	11:16	Raytown South High - Sink Tap - Triple Sink - Left	1	Water	Grab	X								28

Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:	07/10/24	
	Time:		<i>Carolyn Jackson</i>	Time:	16:00	



3 H G 0 1 5 2

AXIOM Service Professionals

PM: Carolyn Jackson

**Keystone**  
LABORATORIES  
A Microbac Company

600 E. 17th St. S  
Newton, IA 50208  
Phone: 641-792-8451

3012 Ansborough Ave  
Waterloo, IA 50701  
Phone: 319-235-4440

X

835 S St. Paul  
Kansas City, KS 66105  
Phone: 913-321-7856

205 E Van Buren St  
Centerville, IA 52544  
Phone: 641-437-7023

<b>PRINT OR TYPE INFO BELOW:</b>		<b>REPORT TO:</b>		<b>BILL TO:</b>	
<b>SAMPLER:</b> Jeff Hurst		<b>NAME:</b> Jeff Hurst		<b>NAME:</b> Jeff Hurst	
<b>SITE NAME:</b>		<b>CO. NAME:</b>		<b>CO. NAME:</b>	
<b>ADDRESS:</b> 8211 Sterling Avenue		<b>ADDRESS:</b> PO Box 47166		<b>ADDRESS:</b> PO Box 47166	
<b>CITY/ST/ZIP:</b> Raytown, Missouri 64133		<b>CITY/ST/ZIP:</b> Kansas City, Missouri 64188		<b>CITY/ST/ZIP:</b> Kansas City, Missouri 64188	
<b>PHONE:</b>		<b>PHONE:</b> 816-678-7894		<b>PHONE:</b> 816-678-7894	
		<b>EMAIL:</b> jeffh@axiomservicepros.com		<b>EMAIL:</b> jeffh@axiomservicepros.com	

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED							LAB USE ONLY	
							Lead							Wk Order #:	3HG0152
														Short Hold:	
														Rush:	
														Temp: oC	
														Sample Condition	Sample #
8211-29-FD	7/9/2024	11:19	Raytown South High - Sink Tap - Triple Sink - Right	1	Water	Grab	X								3HG0152-29
8211-30-FD	7/9/2024	11:22	Raytown South High - Sink Tap - Tilt Skillet - Left	1	Water	Grab	X								30
8211-31-FD	7/9/2024	11:25	Raytown South High - Sink Tap - Tilt Skillet - Right	1	Water	Grab	X								31
8211-32-FD	7/9/2024	11:26	Raytown South High - Sink Tap - Prep Sink Near Serving Line	1	Water	Grab	X								32
8211-33-FD	7/9/2024	11:30	Raytown South High - Sink Tap - FACS Teacher's	1	Water	Grab	X								33
8211-34-FD	7/9/2024	11:31	Raytown South High - Sink Tap - FACS 1	1	Water	Grab	X								34
8211-35-FD	7/9/2024	11:37	Raytown South High - Sink Tap - FACS 2	1	Water	Grab	X								35

Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:		<i>Carolyn Jackson</i>	Time:	07/18/24	
					16:00	



3 H G 0 1 5 2

AXIOM Service Professionals

PM: Carolyn Jackson

**Keystone**  
LABORATORIES  
A Microbac Company

600 E. 17th St. S  
Newton, IA 50208  
Phone: 641-792-8451

3012 Ansborough Ave  
Waterloo, IA 50701  
Phone: 319-235-4440

X

835 S St. Paul  
Kansas City, KS 66105  
Phone: 913-321-7856

205 E Van Buren St  
Centerville, IA 52544  
Phone: 641-437-7023

## PRINT OR TYPE INFO BELOW:

**SAMPLER:** Jeff Hurst  
**SITE NAME:**  
**ADDRESS:** 8211 Sterling Avenue  
**CITY/ST/ZIP:** Raytown, Missouri 64133  
**PHONE:**

## REPORT TO:

**NAME:** Jeff Hurst  
**CO. NAME:**  
**ADDRESS:** PO Box 47166  
**CITY/ST/ZIP:** Kansas City, Missouri 64188  
**PHONE:** 816-678-7894  
**EMAIL:** jeffh@axiomservicepros.com

## BILL TO:

**NAME:** Jeff Hurst  
**CO. NAME:**  
**ADDRESS:** PO Box 47166  
**CITY/ST/ZIP:** Kansas City, Missouri 64188  
**PHONE:** 816-678-7894  
**EMAIL:** jeffh@axiomservicepros.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED							LAB USE ONLY	
							Lead							Wk Order #:	3HG0152
														Short Hold:	
														Rush:	
														Temp:	oC
														Sample Condition	Sample #
8211-36-FD	7/9/2024	11:38	Raytown South High - Sink Tap - FACS 3	1	Water	Grab	X								31HG0152-36
8211-37-FD	7/9/2024	11:39	Raytown South High - Sink Tap - FACS 4	1	Water	Grab	X								37
8211-38-FD	7/9/2024	11:39	Raytown South High - Sink Tap - FACS 5	1	Water	Grab	X								38
8211-39-FD	7/9/2024	11:39	Raytown South High - Sink Tap - FACS 6	1	Water	Grab	X								39
8211-40-FD	7/9/2024	11:42	Raytown South High - Drinking Fountain - Cafeteria	1	Water	Grab	X								40
8211-41-FD	7/9/2024	11:48	Raytown South High - Sink Tap - Concession Stand Triple Sink - Left	1	Water	Grab	X								41
8211-42-FD	7/9/2024	11:51	Raytown South High - Sink Tap - Concession Stand Triple Sink - Right	1	Water	Grab	X								42

Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		
	Time:		<i>Carolyn Jackson</i>	Time:	07/18/24 16:00	



3 H G 0 1 5 2

AXIOM Service Professionals

PM: Carolyn Jackson



600 E. 17th St. S  
Newton, IA 50208  
Phone: 641-792-8451

3012 Ansborough Ave  
Waterloo, IA 50701  
Phone: 319-235-4440

X

835 S St. Paul  
Kansas City, KS 66105  
Phone: 913-321-7856

205 E Van Buren St  
Centerville, IA 52544  
Phone: 641-437-7023

<b>PRINT OR TYPE INFO BELOW:</b>		<b>REPORT TO:</b>		<b>BILL TO:</b>	
<b>SAMPLER:</b> Jeff Hurst		<b>NAME:</b> Jeff Hurst		<b>NAME:</b> Jeff Hurst	
<b>SITE NAME:</b>		<b>CO. NAME:</b>		<b>CO. NAME:</b>	
<b>ADDRESS:</b> 8211 Sterling Avenue		<b>ADDRESS:</b> PO Box 47166		<b>ADDRESS:</b> PO Box 47166	
<b>CITY/ST/ZIP:</b> Raytown, Missouri 64133		<b>CITY/ST/ZIP:</b> Kansas City, Missouri 64188		<b>CITY/ST/ZIP:</b> Kansas City, Missouri 64188	
<b>PHONE:</b>		<b>PHONE:</b> 816-678-7894		<b>PHONE:</b> 816-678-7894	
		<b>EMAIL:</b> jeffh@axiomservicepros.com		<b>EMAIL:</b> jeffh@axiomservicepros.com	

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED								LAB USE ONLY	
							Lead								Wk Order #:	3HG0152
															Short Hold:	
															Rush:	
															Temp:	oC
Sample Condition									Sample #							
8211-43-FD	7/9/2024	11:54	Raytown South High - Sink Tap - Coffee Maker Tap - North	1	Water	Grab	X								3HG0152-43	
8211-44-FD	7/9/2024	11:55	Raytown South High - Sink Tap - Coffee Tap - South	1	Water	Grab	X								44	
8211-45-FD	7/9/2024	11:58	Raytown South High - Ice Machine - Outside Concession Stand	1	Water	Grab	X								45	
8211-46-FD	7/9/2024	12:02	Raytown South High - Drinking Fountain - Concession Stand - South	1	Water	Grab	X								46	
8211-47-FD	7/9/2024	12:07	Raytown South High - Drinking Fountain - Concession Stand - North	1	Water	Grab	X								47	
8211-48-FD	7/9/2024	12:08	Raytown South High - Drinking Fountain - Concession Stand Between Restrooms	1	Water	Grab	X								48	
8211-49-FD	7/9/2024	12:11	Raytown South High - Spigot - Concession Stand	1	Water	Grab	X								49	

Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:	07/16/24	
	Time:			Time:	16:00	



3 H G 0 1 5 2

AXIOM Service Professionals

PM: Carolyn Jackson



600 E. 17th St. S  
Newton, IA 50208  
Phone: 641-792-8451

3012 Ansborough Ave  
Waterloo, IA 50701  
Phone: 319-235-4440

835 S St. Paul  
Kansas City, KS 66105  
Phone: 913-321-7856

205 E Van Buren St  
Centerville, IA 52544  
Phone: 641-437-7023

X

<b>PRINT OR TYPE INFO BELOW:</b>		<b>REPORT TO:</b>		<b>BILL TO:</b>	
<b>SAMPLER:</b> Jeff Hurst		<b>NAME:</b> Jeff Hurst		<b>NAME:</b> Jeff Hurst	
<b>SITE NAME:</b>		<b>CO. NAME:</b>		<b>CO. NAME:</b>	
<b>ADDRESS:</b> 8211 Sterling Avenue		<b>ADDRESS:</b> PO Box 47166		<b>ADDRESS:</b> PO Box 47166	
<b>CITY/ST/ZIP:</b> Raytown, Missouri 64133		<b>CITY/ST/ZIP:</b> Kansas City, Missouri 64188		<b>CITY/ST/ZIP:</b> Kansas City, Missouri 64188	
<b>PHONE:</b>		<b>PHONE:</b> 816-678-7894		<b>PHONE:</b> 816-678-7894	
		<b>EMAIL:</b> jeffh@axiomservicepros.com		<b>EMAIL:</b> jeffh@axiomservicepros.com	

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	Lead	ANALYSES REQUIRED						LAB USE ONLY	
														Wk Order #:	3H60152
														Short Hold:	
														Rush:	
														Temp: oC	
														Sample Condition	Sample #
8211-50-FD	7/9/2024	12:20	Raytown South High - Ice Machine - Concession - Small	1	Water	Grab	X								3H60152-50

Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:		Remarks:
	Time:			Time:		
Relinquished by: (Signature)	Date:		Received by: (Signature)	Date:	07/18/24	
	Time:		<i>Carolyn Jackson</i>	Time:	16:00	



3 H G 0 1 5 2


AXIOM Service Professionals

PM: Carolyn Jackson

## Appendix D

### Photo Log





7/9/2024 - 8211-1 - Raytown South High - Clinic



7/9/2024 - 8211-2 - Raytown South High - Near Room 1



7/9/2024 - 8211-3 - Raytown South High - Near Room 8



7/9/2024 - 8211-4 - Raytown South High - Near Room 11






7/9/2024 - 8211-5 - Raytown South High - Near Little Theater - Left



7/9/2024 - 8211-6 - Raytown South High - Near Little Theater - Right



7/9/2024 - 8211-7 - Raytown South High - Across from Room 122



7/9/2024 - 8211-8 - Raytown South High - Outside Room 128 - Left





7/9/2024 - 8211-9 - Raytown South High - Across from Room 114A



7/9/2024 - 8211-10 - Raytown South High - Near Room 109 - Left



7/9/2024 - 8211-11 - Raytown South High - Near Room 109 - Right



7/9/2024 - 8211-12 - Raytown South High - Outside Office - Left





7/9/2024 - 8211-13 - Raytown South High - Outside Office - Right



7/9/2024 - 8211-14 - Raytown South High - Across from E5



7/9/2024 - 8211-15 - Raytown South High - Near Room 111 - Left



7/9/2024 - 8211-16 - Raytown South High - Outside Room 111 - Right





7/9/2024 - 8211-17 - Raytown South High - Near Room 218



7/9/2024 - 8211-18 - Raytown South High - Outside Room 218



7/9/2024 - 8211-19 - Raytown South High - Near Room 210




7/9/2024 - 8211-20 - Raytown South High - Outside Room 200 - Left







7/9/2024 - 8211-21 - Raytown South High -  
Outside Room 200 - Right



7/9/2024 - 8211-22 - Raytown South High -  
Counselor's Lounge




7/9/2024 - 8211-23 - Raytown South High - Room  
136




7/9/2024 - 8211-24 - Raytown South High - Room  
115





7/9/2024 - 8211-25 - Raytown South High - Concession Stand - Left



7/9/2024 - 8211-26 - Raytown South High - Concession Stand - Right



7/9/2024 - 8211-27 - Raytown South High - Prep Sink Near Serving Line



7/9/2024 - 8211-28 - Raytown South High - Triple Sink - Left





7/9/2024 - 8211-29 - Raytown South High - Triple Sink - Right



7/9/2024 - 8211-30 - Raytown South High - Tilt Skillet - Left



7/9/2024 - 8211-31 - Raytown South High - Tilt Skillet - Right



7/9/2024 - 8211-32 - Raytown South High - Prep Double Sink Near Serving Line






7/9/2024 - 8211-33 - Raytown South High - FACS  
Teacher's Station



7/9/2024 - 8211-34 - Raytown South High - FACS  
1



7/9/2024 - 8211-35 - Raytown South High - FACS  
2



7/9/2024 - 8211-36 - Raytown South High - FACS  
3





7/9/2024 - 8211-37 - Raytown South High - FACS  
4



7/9/2024 - 8211-38 - Raytown South High - FACS  
5



7/9/2024 - 8211-39 - Raytown South High - FACS  
6



7/9/2024 - 8211-40 - Raytown South High - Cafeteria






7/9/2024 - 8211-41 - Raytown South High - Concession Stand Triple Sink - Left



7/9/2024 - 8211-42 - Raytown South High - Concession Stand Triple Sink - Right



7/9/2024 - 8211-43 - Raytown South High - Coffee Maker Tap - North



7/9/2024 - 8211-44 - Raytown South High - Coffee Maker Tap - South





7/9/2024 - 8211-45 - Raytown South High -  
Outside Concession Stand



7/9/2024 - 8211-46 - Raytown South High -  
Concession Stand - South



7/9/2024 - 8211-47 - Raytown South High -  
Concession Stand - North




7/9/2024 - 8211-48 - Raytown South High -  
Concession Stand between Restrooms





7/9/2024 - 8211-49 - Raytown South High -  
Concession Stand



7/9/2024 - 8211-50 - Raytown South High -  
Concession - Small

## **Appendix E**

### **Source Identification Diagram**

**ASP was provided sample locations by  
Raytown School District**

(Please note that no sampling location maps are included in this report as floor plans were not supplied to ASP for this sampling event.)