



Customer Name: Derry Township
Address: 30C East Granada Ave
City, State, Zip: Hershey PA 17033
Attn:
email:
Date: August 19, 2024
RE: Early Childhood Center Water Sampling Results

Sample Date: 07/25/24
Lab ID AC24663:

Table with 6 columns: Lab Sample Number, Client Sample ID/ Sample Location, Copper, EPA Action Level Copper, Lead, EPA Action Level Lead. Rows 1-6 show sampling data for various locations like 'Right Ftn outside gym' and 'Left Ftn @ 042'.

* ND- None Detected
** ppb- Parts per Billion

Comments / Recommendations:

ACIA has found all locations sampled on July 26, 2024 to be within EPA limits. There are no further recommendations at this time.

Regards,

AIRBORNE CONTAMINATION IDENTIFICATION ASSOCIATES, LTD.

Randall R. Leaman

Our Certifications:

- WBENC: Certified Women Owned Business (WBE)
Pennsylvania Home Improvement Contractor Registration Number: PA 059333
NADCA Certified Ventilation Systems Mold Remediators (CVSMR)
NADCA Certified Air Systems Cleaning Specialists (ASCS)
AEE - Certified Indoor Air Quality Professional (CIAQP)
ACAC: Certified Mold Remediation Supervisor (Required by Maryland Law) (CMRS)
Anabec: Certified Microbial Remediator Supervisor and Product Distributor (CMRS)
Co-Stars Number: 008-002



Customer Name: Derry Township
Address: 30C East Granada Ave
City, State, Zip: Hershey PA 17033
Attn:
email:
Date: August 19, 2024
RE: Hershey Elem. Water Sampling Results

Sample Date: 07/25/24
Lab ID AC24836:

Table with 6 columns: Lab Sample Number, Client Sample ID/ Sample Location, Copper, EPA Action Level Copper, Lead, EPA Action Level Lead. Rows 1-6 show sampling data for various locations like Left Ftn @ 7, Right Ftn @ 26, etc.

* ND- None Detected
** ppb- Parts per Billion

Comments / Recommendations:

ACIA has found all locations sampled on July 26, 2024 to be within EPA limits. There are no further recommendations at this time.

Regards,

AIRBORNE CONTAMINATION IDENTIFICATION ASSOCIATES, LTD.

Randall R. Leaman

Our Certifications:

- WBENC: Certified Women Owned Business (WBE)
Pennsylvania Home Improvement Contractor Registration Number: PA 059333
NADCA Certified Ventilation Systems Mold Remediators (CVSMR)
NADCA Certified Air Systems Cleaning Specialists (ASCS)
AEE - Certified Indoor Air Quality Professional (CIAQP)
ACAC: Certified Mold Remediation Supervisor (Required by Maryland Law) (CMRS)
Anabec: Certified Microbial Remediator Supervisor and Product Distributor (CMRS)
Co-Stars Number: 008-002



Customer Name: Derry Township
Address: 30C East Granada Ave
City, State, Zip: Hershey PA 17033
Attn:
email:
Date: August 19, 2024
RE: Hershey Middle School Water Sampling Results

Sample Date: 07/25/24
Lab ID AC24720:

Table with 6 columns: Lab Sample Number, Client Sample ID/ Sample Location, Copper, EPA Action Level Copper, Lead, EPA Action Level Lead. Rows 1-6 show sampling data for various locations like Boys Locker Rm Ftn, Ftn @ G14, etc.

* ND- None Detected
** ppb- Parts per Billion

Comments / Recommendations:

ACIA has found all locations sampled on July 26, 2024 to be within EPA limits. There are no further recommendations at this time.

Regards,

AIRBORNE CONTAMINATION IDENTIFICATION ASSOCIATES, LTD.

Randall R. Leaman

Our Certifications:

- WBENC: Certified Women Owned Business (WBE)
Pennsylvania Home Improvement Contractor Registration Number: PA 059333
NADCA Certified Ventilation Systems Mold Remediators (CVSMR)
NADCA Certified Air Systems Cleaning Specialists (ASCS)
AEE - Certified Indoor Air Quality Professional (CIAQP)
ACAC: Certified Mold Remediation Supervisor (Required by Maryland Law) (CMRS)
Anabec: Certified Microbial Remediation Supervisor and Product Distributor (CMRS)
Co-Stars Number: 008-002



Customer Name: Derry Township
Address: 30C East Granada Ave
City, State, Zip: Hershey PA 17033
Attn:
email:
Date: August 19, 2024
RE: Hershey High School Water Sampling Results

Sample Date: 07/25/24
Lab ID AC24832:

Table with 6 columns: Lab Sample Number, Client Sample ID/ Sample Location, Copper, EPA Action Level Copper, Lead, EPA Action Level Lead. Rows 1-6 show sampling data for various locations like Gym, Café, F129, A021A, D209, and F227.

* ND- None Detected
** ppb- Parts per Billion

Comments / Recommendations:

ACIA has found all locations sampled on July 26, 2024 to be within EPA limits. There are no further recommendations at this time.

Regards,

AIRBORNE CONTAMINATION IDENTIFICATION ASSOCIATES, LTD.

Randall R. Leaman

Our Certifications:

- WBENC: Certified Women Owned Business (WBE)
Pennsylvania Home Improvement Contractor Registration Number: PA 059333
NADCA Certified Ventilation Systems Mold Remediators (CVSMR)
NADCA Certified Air Systems Cleaning Specialists (ASCS)
AEE - Certified Indoor Air Quality Professional (CIAQP)
ACAC: Certified Mold Remediation Supervisor (Required by Maryland Law) (CMRS)
Anabec: Certified Microbial Remediator Supervisor and Product Distributor (CMRS)
Co-Stars Number: 008-002