

February 10, 2021

Mr. Jim Schneider
Supervisor of Buildings & Grounds
Belfast Central School District
1 King Street
Belfast, NY 14711

RE: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Schneider:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Belfast Central School District, including:

- Belfast Central School – 1 King Street, Belfast, New York.

This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on December 17, 2020. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 1 source of potable water in the Belfast Central School has been identified as having a lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Belfast Central School District.

Sincerely,
Stohl Environmental, LLC.



Eric Henderson Jr.
Senior Project Manager

**Investigation and Sampling
Of Sources of Potable Water
For Lead Concentrations**

Prepared for:

Belfast Central School District

Prepared by:



3860 California Road, Orchard Park, New York 14127

PHONE (716) 312-0070 FAX (716) 312-8092

WWW.STOHLENVIRONMENTAL.COM

Conditions as of December 17, 2020

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Belfast Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- Belfast Central School – 1 King Street, Belfast, New York.

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within Belfast Central School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, **Subpart 67-4: Lead Testing in School Drinking Water**, and the EPA guidance document, **‘3Ts for Reducing Lead in Drinking Water in Schools’**, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Belfast Central School	12/17/2020	73	72	1	N/A	N/A

** Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listing of Outlets Requiring Remediation

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples:

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
147-83	Bus Garage – Women's Lav	Sink	19.9

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports by Building

Analysis ID	Analysis Name	Concentration and units	Collection Location	Collection Date	Client Name/ID	Reference Number
01-08-2021		2.15	ELEMENTARY ART ROOM FAT LEFT	12/11/2020	147-1	20-12-02708-001
01-08-2021		1.00	ELEMENTARY ART ROOM FAT RIGHT	12/11/2020	147-2	20-12-02708-002
01-08-2021		2.10	GENDER NEUTRAL LEFT LAV	12/11/2020	147-3	20-12-02708-003
01-08-2021		1.94	GENDER NEUTRAL RIGHT LAV	12/11/2020	147-4	20-12-02708-004
01-08-2021		41.00	HS ART ROOM 142 LEFT	12/11/2020	147-5	20-12-02708-005
01-08-2021		1.00	HS ART ROOM 142 RIGHT	12/11/2020	147-6	20-12-02708-006
01-08-2021		< 1.00	MAIN OFFICE KITCHENETTE	12/11/2020	147-7	20-12-02708-007
01-08-2021		41.00	SINGLE LAV ACROSS FROM GYM LEFT	12/11/2020	147-8	20-12-02708-008
01-08-2021		41.00	SINGLE LAV ACROSS FROM GYM LEFT CENTER	12/11/2020	147-9	20-12-02708-009
01-08-2021		< 1.00	SINGLE LAV ACROSS FROM GYM RIGHT CENTER	12/11/2020	147-10	20-12-02708-010
01-08-2021		< 1.00	SINGLE LAV ACROSS FROM GYM RIGHT	12/11/2020	147-11	20-12-02708-011
01-08-2021		4.05	SINGLE FITNESS ROOM LAV	12/11/2020	147-12	20-12-02708-012
01-08-2021		41.00	DT ACROSS FROM LOCKER ROOMS	12/11/2020	147-13	20-12-02708-013



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Report Number: 20-12-02709

Received Date: 12/21/2020

Reported Date: 01/06/2021

Sampled By: Christine Schultz

Tech Certification #:

Client: Stohl Environmental
 3860 California Road
 Orchard Park, NY 14127

Project/Test Address: 2020L-147; Belfast Central School; 1 King St; Belfast, NY 14711

Client Number:
 33-5980

Fax Number:
 716-312-8092

Laboratory Results

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-12-02709-001	147-1	12/17/2020	ELEMENTARY ART ROOM 141 LEFT	2.48	01/06/2021	
20-12-02709-002	147-2	12/17/2020	ELEMENTARY ART ROOM 141 RIGHT	1.70	01/06/2021	
20-12-02709-003	147-3	12/17/2020	GENDER NEUTRAL LEFT LAV	2.10	01/06/2021	
20-12-02709-004	147-4	12/17/2020	GENDER NEUTRAL RIGHT LAV	1.93	01/06/2021	
20-12-02709-005	147-5	12/17/2020	HS ART ROOM 142 LEFT	<1.00	01/06/2021	
20-12-02709-006	147-6	12/17/2020	HS ART ROOM 142 RIGHT	1.06	01/06/2021	
20-12-02709-007	147-7	12/17/2020	MAIN OFFICE KITCHENETTE	<1.00	01/06/2021	
20-12-02709-008	147-8	12/17/2020	SINGLE LAV ACROSS FROM GYM LEFT	<1.00	01/06/2021	
20-12-02709-009	147-9	12/17/2020	SINGLE LAV ACROSS FROM GYM LEFT CENTER	<1.00	01/06/2021	
20-12-02709-010	147-10	12/17/2020	SINGLE LAV ACROSS FROM GYM RIGHT CENTER	<1.00	01/06/2021	
20-12-02709-011	147-11	12/17/2020	SINGLE LAV ACROSS FROM GYM RIGHT	<1.00	01/06/2021	
20-12-02709-012	147-12	12/17/2020	SINGLE FITNESS ROOM LAV	1.08	01/06/2021	
20-12-02709-013	147-13B	12/17/2020	DF ACROSS FROM LOCKER ROOMS	<1.00	01/06/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-12-02709

Project/Test Address: 2020L-147; Belfast Central School; 1 King St; Belfast, NY 14711

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-12-02709-014	147-14	12/17/2020	122 BOYS PHYS ED OFFICE	2.93	01/06/2021	
20-12-02709-015	147-15	12/17/2020	116 GIRLS PHYS ED OFFICE	2.92	01/06/2021	
20-12-02709-016	147-16	12/17/2020	308 BOYS LAV LEFT	<1.00	01/06/2021	
20-12-02709-017	147-17	12/17/2020	308 BOYS LAV RIGHT	<1.00	01/06/2021	
20-12-02709-018	147-18B	12/17/2020	DF NEXT TO 307	<1.00	01/06/2021	
20-12-02709-019	147-19	12/17/2020	GIRLS LAV NEXT TO 303 LEFT	<1.00	01/06/2021	
20-12-02709-020	147-20	12/17/2020	GIRLS LAV NEXT TO 303 RIGHT	<1.00	01/06/2021	
20-12-02709-021	147-21B	12/17/2020	DF NEXT TO 301	<1.00	01/06/2021	
20-12-02709-022	147-22	12/17/2020	HOME EC 301 BACK LEFT	7.44	01/06/2021	
20-12-02709-023	147-23	12/17/2020	HOME EC 301 BACK RIGHT	6.86	01/06/2021	
20-12-02709-024	147-24	12/17/2020	HOME EC 301 FRONT LEFT	7.70	01/06/2021	
20-12-02709-025	147-25	12/17/2020	HOME EC 301 FRONT RIGHT	7.93	01/06/2021	
20-12-02709-026	147-26	12/17/2020	207 NURSE EXAM ROOM	8.29	01/06/2021	
20-12-02709-027	147-27	12/17/2020	207 NURSE LAV	<1.00	01/06/2021	
20-12-02709-028	147-28	12/17/2020	BOYS LAV NEXT TO NURSE LEFT	<1.00	01/06/2021	
20-12-02709-029	147-29	12/17/2020	BOYS LAV NEXT TO NURSE RIGHT	<1.00	01/06/2021	
20-12-02709-030	147-30B	12/17/2020	DF NEXT TO 203	<1.00	01/06/2021	
20-12-02709-031	147-31	12/17/2020	GIRLS LAV ACROSS 202 LEFT	<1.00	01/06/2021	
20-12-02709-032	147-32	12/17/2020	GIRLS LAV ACROSS 202 RIGHT	<1.00	01/06/2021	
20-12-02709-033	147-33	12/17/2020	201 HOME EC LEFT	3.27	01/06/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-12-02709

Project/Test Address: 2020L-147; Belfast Central School; 1 King St; Belfast,
NY 14711

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-12-02709-034	147-34	12/17/2020	201 HOME EC RIGHT	<1.00	01/06/2021	
20-12-02709-035	147-35	12/17/2020	GIRLS LAV NEXT TO 108	2.76	01/06/2021	
20-12-02709-036	147-36	12/17/2020	FAC LAV ACROSS 108	4.18	01/06/2021	
20-12-02709-037	147-37	12/17/2020	BOYS LAV NEXT TO 109 MAINTENANCE	3.18	01/06/2021	
20-12-02709-038	147-38B	12/17/2020	DF NEAR 109 MAINTENANCE	<1.00	01/06/2021	
20-12-02709-039	147-39	12/17/2020	104 LAV	2.01	01/06/2021	
20-12-02709-040	147-40	12/17/2020	104 MAIN	1.97	01/06/2021	
20-12-02709-041	147-42	12/17/2020	105 LAV	1.66	01/06/2021	
20-12-02709-042	147-43	12/17/2020	105 MAIN	2.22	01/06/2021	
20-12-02709-043	147-45	12/17/2020	103 LAV	4.86	01/06/2021	
20-12-02709-044	147-46	12/17/2020	103 MAIN	3.67	01/06/2021	
20-12-02709-045	147-47	12/17/2020	102 LAV	2.63	01/06/2021	
20-12-02709-046	147-48	12/17/2020	102 MAIN	3.36	01/06/2021	
20-12-02709-047	147-51	12/17/2020	101 MAIN	1.16	01/06/2021	
20-12-02709-048	147-53	12/17/2020	100 LAV	2.87	01/06/2021	
20-12-02709-049	147-54	12/17/2020	100 MAIN	4.45	01/06/2021	
20-12-02709-050	147-56	12/17/2020	106D FACULTY ROOM	3.52	01/06/2021	
20-12-02709-051	147-57	12/17/2020	CAFE ICE WATER MACHINE	1.39	01/06/2021	
20-12-02709-052	147-58	12/17/2020	KITCHEN BACK CORNER HANDWASH	4.76	01/06/2021	
20-12-02709-053	147-59	12/17/2020	KITCHEN CENTER 2 BAY	2.93	01/06/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-12-02709

Project/Test Address: 2020L-147; Belfast Central School; 1 King St; Belfast,
NY 14711

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-12-02709-054	147-60	12/17/2020	KITCHEN CENTER 2 BAY SPRAYER	1.72	01/06/2021	
20-12-02709-055	147-61	12/17/2020	KITCHEN 3 BAY LEFT	3.07	01/06/2021	
20-12-02709-056	147-62	12/17/2020	KITCHEN 3 BAY SPRAYER	1.48	01/06/2021	
20-12-02709-057	147-63	12/17/2020	KITCHEN 3 BAY RIGHT	8.91	01/06/2021	
20-12-02709-058	147-64	12/17/2020	KITCHEN HAND WASH BY CAFE ENTRANCE	4.04	01/06/2021	
20-12-02709-059	147-65	12/17/2020	KITCHEN LAV	2.95	01/06/2021	
20-12-02709-060	147-66	12/17/2020	AUDITORIUM WOMENS LAV LEFT	5.31	01/06/2021	
20-12-02709-061	147-67	12/17/2020	AUDITORIUM WOMENS LAV CENTER	2.83	01/06/2021	
20-12-02709-062	147-68	12/17/2020	AUDITORIUM WOMENS LAV RIGHT	2.40	01/06/2021	
20-12-02709-063	147-70	12/17/2020	AUDITORIUM MENS LAV CENTER	3.35	01/06/2021	
20-12-02709-064	147-71	12/17/2020	AUDITORIUM MENS LAV RIGHT	2.27	01/06/2021	
20-12-02709-065	147-72	12/17/2020	150 KICHENETTE SINK	<1.00	01/06/2021	
20-12-02709-066	147-73	12/17/2020	150 LEFT LAV	2.06	01/06/2021	
20-12-02709-067	147-74	12/17/2020	150 LEFT LOW SINK	<1.00	01/06/2021	
20-12-02709-068	147-75	12/17/2020	150 RIGHT LOW SINK	<1.00	01/06/2021	
20-12-02709-069	147-76	12/17/2020	150 RIGHT LAV	1.44	01/06/2021	
20-12-02709-070	147-79B	12/17/2020	AUD DF LEFT	<1.00	01/06/2021	
20-12-02709-071	147-81	12/17/2020	BUS GARAGE KITCHENETTE	2.69	01/06/2021	
20-12-02709-072	147-82	12/17/2020	BUS GARAGE MENS LAV	5.47	01/06/2021	
20-12-02709-073	147-83	12/17/2020	BUS GARAGE WOMENS LAV	19.9	01/06/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980
 Project/Test Address: 2020L-147; Belfast Central School; 1 King St; Belfast, NY 14711

Report Number: 20-12-02709

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
-------------------	------------------	-----------------	---------------------	--------------------------	---------------	--------------

Method: SM 3113B-2010
 Analyst: Jennalee Hertzler
 Accreditation #: NY 11714

Reviewed By Authorized Signatory: Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2021
Issued April 01, 2020

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. JULIE DICKERSON
ENVIRONMENTAL HAZARDS SERVICES, LLC
7469 WHITEPINE ROAD
N. CHESTERFIELD, VA 23237

NY Lab Id No: 11714

is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2003) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:

Metals I

Copper, Total	SM 19, 21-23 3113B (-04,-10)
Lead, Total	SM 19, 21-23 3113B (-04,-10)



Department
of Health

Serial No.: 61514

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



1.6 Chains of Custody

Sample ID	Location	Container Type	Time	Order No.	Lot ID
147-1	Boiler Room	20L	10:30	2020	
147-2	Boiler Room	20L	10:30	2020	
147-3	Boiler Room	20L	10:30	2020	
147-4	Boiler Room	20L	10:30	2020	
147-5	Boiler Room	20L	10:30	2020	
147-6	Boiler Room	20L	10:30	2020	
147-7	Boiler Room	20L	10:30	2020	
147-8	Boiler Room	20L	10:30	2020	
147-9	Boiler Room	20L	10:30	2020	
147-10	Boiler Room	20L	10:30	2020	
147-11	Boiler Room	20L	10:30	2020	
147-12	Boiler Room	20L	10:30	2020	
147-13	Boiler Room	20L	10:30	2020	
147-14	Boiler Room	20L	10:30	2020	
147-15	Boiler Room	20L	10:30	2020	
147-16	Boiler Room	20L	10:30	2020	
147-17	Boiler Room	20L	10:30	2020	
147-18	Boiler Room	20L	10:30	2020	
147-19	Boiler Room	20L	10:30	2020	
147-20	Boiler Room	20L	10:30	2020	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-147

Client: Belfast CSD Contact: Wendy Butler

Building: Belfast Central School Location: 1 King St Belfast, NY 14711

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround
20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
147-1	Elementary Art Room 141 Left	Sink	23:20			
147-2	Elementary Art Room 141 Right	Sink	23:22			
147-3	Gender Neutral Left Lav	Sink	23:24			
147-4	Gender Neutral Right Lav	Sink	23:26			
147-5	HS Art Room 142 Left	Sink	23:28			
147-6	HS Art Room 142 Right	Sink	23:30			
147-7	Main Office Kitchenette	Sink	23:32			
147-8	Single Lav Across from Gym Left	Sink	23:34			
147-9	Single Lav Across from Gym Left Center	Sink	23:36			
147-10	Single Lav Across from Gym Right Center	Sink	23:38			
147-11	Single Lav Across from Gym Right	Sink	23:40			
147-12	Single Fitness Room Lav	Sink	23:42			
147-13B	DF Across from Locker Rooms	DFB	23:44			
147-14	122 Boys Phys Ed Office	Sink	23:46			
147-15	116 Girls Phys Ed Office	Sink	23:48			
147-16	308 Boys Lav Left	Sink	23:50			
147-17	308 Boys Lav Right	Sink	23:52			
147-18B	DF Next to 307	DFB	23:54			

20-12-02709

Due Date:
01/20/2021
(Wednesday)
AE

Notes:

Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to: Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Christine Schultz Stohl Env: Christine Schultz Date: 12/17/2020

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 12/17/2020

Received (Name / Lab): K. HARRIS Date: 12.21.20 Time: 9:47 AM

Sample Login (Name / Lab): T. Johnson Date: 12/29/20 Time: 3p

Analysis (Name / Lab): G. Hertzler Date: 1/6/21 Time: 1:46 pm

QA/QC Review (Name / Lab): M. Smith Date: 1/6/21 Time: 4pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-147

Client: Belfast CSD

Contact: Wendy Butler

Building: Belfast Central School

Location: 1 King St Belfast, NY 14711

LEAD
 Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround
20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
147-19	Girls Lav Next to 303 Left	Sink	23:56			
147-20	Girls Lav Next to 303 Right	Sink	23:58			
147-21B	DF Next to 301	DFB	0:00			
147-22	Home Ec 301 Back Left	Sink	0:02			
147-23	Home Ec 301 Back Right	Sink	0:04			
147-24	Home Ec 301 Front Left	Sink	0:06			
147-25	Home Ec 301 Front Right	Sink	0:08			
147-26	207 Nurse Exam Room	Sink	0:10			
147-27	207 Nurse Lav	Sink	0:12			
147-28	Boys Lav Next to Nurse Left	Sink	0:14			
147-29	Boys Lav Next to Nurse Right	Sink	0:16			
147-30B	DF Next to 203	DFB	0:18			
147-31	Girls Lav Across 202 Left	Sink	0:20			
147-32	Girls Lav Across 202 Right	Sink	0:22			
147-33	201 Home Ec Left	Sink	0:24			
147-34	201 Home Ec Right	Sink	0:26			
147-35	Girls Lav Next to 108	Sink	0:28			
147-36	Fac Lav Across 108	Sink	0:30			

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Christine Schultz Stohl Env: Christine Schultz Date: 12/17/2020

Relinquished By: E. Henderson Jr Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 12/17/2020

Received (Name / Lab): K. Harris Date: 12-21-20 Time: 9:47 AM

Sample Login (Name / Lab): J. Adnan Date: 12/29/20 Time: 3

Analysis (Name / Lab): J. Kertaylor Date: 1/6/21 Time: 1:46 pm

QA/QC Review (Name / Lab): M. [Signature] Date: 1/6/21 Time: 4pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-147

Client: Belfast CSD Contact: Wendy Butler

Building: Belfast Central School Location: 1 King St Belfast, NY 14711

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround
20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
147-37	Boys Lav Next to 109 Maintenance	Sink	0:32			
147-38B	DF Near 109 Maintenance	DFB	0:34			
147-39	104 Lav	Sink	0:36			
147-40	104 Main	Sink	0:38			
147-42	105 Lav	Sink	0:40			
147-43	105 Main	Sink	0:42			
147-45	103 Lav	Sink	0:44			
147-46	103 Main	Sink	0:48			
147-47	102 Lav	Sink	0:50			
147-48	102 Main	Sink	0:52			
147-51	101 Main	Sink	0:54			
147-53	100 Lav	Sink	0:56			
147-54	100 Main	Sink	0:58			
147-56	106D Faculty Room	Sink	1:00			
147-57	Cafe Ice Water Machine	DF/IM	1:02			
147-58	Kitchen Back Corner Handwash	Sink	1:04			
147-59	Kitchen Center 2 Bay	Sink	1:06			
147-60	Kitchen Center 2 Bay Sprayer	Sink	1:08			

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 12/17/2020

Relinquished By: E. Henderson Jr Print Name Stohl Env: Eric Henderson Jr. Date: 12/17/2020

Received (Name / Lab): K. THARRIS Date: 12-21-20 Time: 9:47 AM
R. OL

Sample Login (Name / Lab): T. Thomas Date: 12/29/20 Time: 3p

Analysis (Name / Lab): J. Kestylor Date: 1/6/21 Time: 1:46 pm

QA/QC Review (Name / Lab): M. ... Date: 1/6/21 Time: 4pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS
 STOHL Job # 2020L-147

Client: Belfast CSD Contact: Wendy Butler
 Building: Belfast Central School Location: 1 King St Belfast, NY 14711

LEAD
 Water by SM 19, 21 - 23 3113B (-04, -10) X Turnaround
20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
147-61	Kitchen 3 Bay Left	Sink	1:10			
147-62	Kitchen 3 Bay Sprayer	Sink	1:12			
147-63	Kitchen 3 Bay Right	Sink	1:14			
147-64	Kitchnen Hand Wash by Cafe Entrance	Sink	1:16			
147-65	Kitchen Lav	Sink	1:18			
147-66	Auditorium Women's Lav Left	Sink	1:20			
147-67	Auditorium Women's Lav Center	Sink	1:22			
147-68	Auditorium Women's Lav Right	Sink	1:24			
147-70	Auditorium Men's Lav Center	Sink	1:26			
147-71	Auditorium Men's Lav Right	Sink	1:28			
147-72	150 Kitchenette Sink	Sink	1:30			
147-73	150 Left Lav	Sink	1:32			
147-74	150 Left Low Sink	Sink	1:34			
147-75	150 Right Low Sink	Sink	1:36			
147-76	150 Right Lav	Sink	1:37			
147-79B	Aud DF Left	DFB	1:38			
147-81	Bus Garage Kitchenette	Sink	1:40			
147-82	Bus Garage Men's Lav	Sink	1:42			

Notes:
 Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Christine Schultz Stohl Env: Christine Schultz Date: 12/17/2020
 Relinquished By: Eric Henderson Jr Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 12/17/2020
 Received (Name / Lab): KT HARRIS Date: 12-21-20 Time: 9:47 AM
 Sample Login (Name / Lab): T Adams Date: 12/29/20 Time: 3
 Analysis (Name / Lab): J. Hertigler Date: 1/6/21 Time: 1:46 pm
 QA/QC Review (Name / Lab): Melinda Date: 1/6/21 Time: 4pm
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

BLANK

Stohl

ENVIRONMENTAL

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM