

School	Location	Trigger		Trigger	
		1st Draw Lead Count	5.00 pbb fixture	2nd Draw Lead Count	5.00 pbb piping
Clay	Sink - 1, PreK/K	0	N	0.00	N
Clay	Sink - 3, Kitchen	1.6	N	0.00	N
Clay	Sink - 4, Nurse	0	N	0.00	N
Clay	DF - 1, Café	0	N	0.00	N
Clay	DF - 2, Gym	0	N	0.00	N
Clay	DF - 3, 1st fl hall	0	N	0.00	N
Clay	DF - 5, 2nd fl hall	0	N	0.00	N
Clay	DF - 6, 2nd fl elevator	0	N	0.00	N
Clay	DF - 7, PDC bathrooms	0	N	0.00	N