

School	Location	Trigger		Trigger	
		1st Draw Lead Count	5.00 pbb flxture	2nd Draw Lead Count	5.00 pbb piping
Dean	DF - 1, Café BR	0	N	0.00	N
Dean	DF - 2, Café	0	N	0.00	N
Dean	DF - 3, Library Br	0	N	0.00	N
Dean	DF - 4, Library	0	N	0.00	N
Dean	DF - 5, Room 205 hall	0	N	0.00	N
Dean	DF - 6, Room 203 hall	0	N	0.00	N
Dean	DF - 7, Room 405 hall	0	N	0.00	N
Dean	DF - 8, Room 403 hall	0	N	0.00	N
Dean	Sink - 1, Room 102	0	N	2.00	N
Dean	Sink - 2, Room 103	0	N	1.20	N
Dean	Sink - 3, Kitchen	1.14	N	0.00	N
Dean	Sink - 5, Nurse	0	N	0.00	N