

School	Location	Trigger		Trigger	
		1st Draw Lead Count	5.00 pbb fixture	2nd Draw Lead Count	5.00 pbb piping
Westwood	DF-1, Hall by room 13	0	N	0	N
Westwood	DF - 2, Kitchen Hall right	0	N	0	N
Westwood	DF - 3, Kitchen Hall left	0	N	0	N
Westwood	DF - 4, Hall by room 37	0	N	1.12	N
Westwood	DF - 5, Hall by room 7	0	N	0	N
Westwood	DF - 7, Hall lower level	0	N	0	N
Westwood	Sink - 1, office (nurse)	2.17	N	1.4	N
Westwood	Sink - 3, Kitchen	1.74	N	0	N