

School	Location	Trigger		Trigger	
		1st Draw Lead Count	5.00 pbb fixture	2nd Draw Lead Count	5.00 pbb piping
WHS	DF - 1, Commons stairway right	0.00	N	0.00	N
WHS	DF - 2, Commons Stairway left	0.00	N	0.00	N
WHS	DF - 5, Commons bathrooms left	0.00	N	3.83	N
WHS	DF - 6, Commons bathrooms right	0.00	N	3.55	N
WHS	DF - 7, Cafeterial Hall	0.00	N	0.00	N
WHS	DF - 8, Wrestling room	0.00	N	0.00	N
WHS	DF - 9, Pool	0.00	N	1.30	N
WHS	DF - 10, Main gym	2.36	N	1.90	N
WHS	DF - 11, Main gym entrance	0.00	N	0.00	N
WHS	DF - 13, Hall by room 103 left	0.00	N	1.13	N
WHS	DF - 14, Room by room 103 right	0.00	N	1.64	N
WHS	DF - 15, hall by B121 left	0.00	N	0.00	N
WHS	DF - 16, hall by B121 right	0.00	N	0.00	N
WHS	DF - 17, Hall by B129 left	0.00	N	0.00	N
WHS	DF - 18, Hall by B 129 right	0.00	N	0.00	N
WHS	DF - 19, west Auditorium left	0.00	N	0.00	N
WHS	DF - 20, west auditorium right	0.00	N	0.00	N
WHS	DF - 21, Room D267	4.05	N	2.18	N
WHS	DF - 22, D273 left	0.00	N	0.00	N
WHS	DF - 23, D273 right	0.00	N	0.00	N
WHS	DF - 24, upper track	0.00	N	0.00	N
WHS	DF - 25, E291	0.00	N	0.00	N
WHS	DF - 26, E 293	0.00	N	0.00	N
WHS	DF - 27, E 288	0.00	N	1.54	N
WHS	DF - 28, A 204	0.00	N	1.56	N
WHS	DF - 29, A205	0.00	N	1.80	N
WHS	DF - 30, A219 left	0.00	N	0.00	N
WHS	DF - 31, A219 right	0.00	N	0.00	N
WHS	DF - 32, B229 left	0.00	N	2.47	N
WHS	DF - 33, D229 right	0.00	N	4.70	N
WHS	DF - 34, Balcony left	0.00	N	2.38	N
WHS	DF - 35, Balcony right	0.00	N	1.20	N
WHS	DF - 36, B329 left	0.00	N	1.36	N
WHS	DF - 37, B329 right	0.00	N	1.10	N
WHS	DF - 38, C451 left	0.00	N	0.00	N
WHS	DF - 39, C451 right	0.00	N	0.00	N
WHS	Sink - 1, Kithchen	2.19	N	0.00	N
WHS	Sink - 11, B121	0.00	N	0.00	N
WHS	Sink - 2, Kitchen	3.01	N	1.57	N
WHS	Sink - 8, Nurse	0.00	N	0.00	N
WHS	Sink 6, Room B121	0.00	N	0.00	N