

School	Location	1st Draw	Trigger	2nd Draw	Trigger
		Lead Count	5.00 pbb fixture	Lead Count	5.00 pbb piping
Northwood	DF - 2, Room 138	0.00	N	1.24	#REF!
Northwood	DF - 3, North hall bathroom	0.00	N	0.00	N
Northwood	DF - 5, Hall room 120 left	0.00	N	1.26	N
Northwood	DF - 6, Hall room 120 right	0.00	N	0.00	N
Northwood	DF - 7, Hall room 117 left	0.00	N	0.00	N
Northwood	DF - 8, Hall room 117 right	0.00	N	0.00	N
Northwood	Sink 1, Nurse	0.00	N	1.48	N
Northwood	DF 10, Hall by Locker Rm	0.00	N	0.00	N
Northwood	DF 11, Gym BR	0.00	N	0.00	N
Northwood	DF 12, Gym BR	0.00	N	0.00	N
Northwood	DF 15, Hall Rm 104	0.00	N	0.00	N
Northwood	DF 16, Hall Rm 102	0.00	N	0.00	N
Northwood	DF - 9, Hall room 143	1.11	N	3.58	N
Northwood	Sink 14, Nurse	1.30	N	0.00	N
Northwood	Sink 2, Kitchen	1.31	N	1.81	N
Northwood	Sink 13, Rm 103 hall	1.40	N	1.06	N
Northwood	Sink 4, Kitchen	3.06	N	4.17	N
Northwood	Sink 12, Rm 101	3.31	N	1.39	N