

Brookfield Central School

Achieving Academic Excellence

Superintendent

James Plows, Jr.

Principal

Carrie Smith

District Treasurer

Suzanne Scully



Board Members

Bernard C. Whitacre, President

Jeffrey Beehm, Vice President

Dawn Brean

Sean Karn

Valerie Nolan

District Clerk

Christa Case

P.O Box 60, 1910 Fairground Road, Brookfield, NY 13314

Telephone: (315) 899-3323

Fax: (315)-899-8902

October 5, 2016

Dear Brookfield School Community:

Our school system is committed to protecting student, teacher, and staff health. One aspect of our environmental control system is periodic sampling of our drinking water for contaminants, including lead. To comply with recent changes in New York State law we recently expanded our sampling for lead to include all water outlet locations. In our most recent tests forty eight total water sources were tested for lead. Forty six of these samples had traces of lead below the allowable level of 15 parts per billion (ppb). All drinking fountains were well below the allowable level of lead 15 (ppb). Two samples exceeded the acceptable level for lead.

One sample, from a utility sink in the photography dark room, exceeded the acceptable level of lead. This likely occurred because the sink is seldom used, resulting in the water sitting in the sink's plumbing for an extended period of time. The water to this utility sink has been shut off.

A second sample from a hand washing station in the boy's locker room tested equivalent to the 15ppb limit. Because lead is not absorbed through the skin, water from this location is acceptable for hand washing. In accordance with state regulations appropriate signage has been placed at this location indicating that the water is non-potable.

All of our lead testing results are available on the district's website or may be inspected at the District Office.

Sincerely

A large, stylized handwritten signature in black ink, appearing to read "Jim Plows".

Jim Plows
Superintendent



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6F0795

Oneida-Herkimer-Madison BOCES

Project Name: Brookfield K-12 Building

Joseph T. Muller II
4747 Middle Settlement Road
New Hartford, NY 13413

Project / PO Number: N/A
Received: 06/15/2016 12:00
Reported: 07/05/2016 16:40

Analytical Testing Parameters

Client Sample ID: 1 A1
Lab Sample ID: J6F0795-01
Sample Type: Grab

Collected By: Tina Simmons-Client
Collection Date: 06/08/16
Collection Time: 05:11

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00400		0.00100	mg/L		06/29/16 1245	06/30/16 1632

Analytical Testing Parameters

Client Sample ID: 1 B1
Lab Sample ID: J6F0795-02
Sample Type: Grab

Collected By: Tina Simmons-Client
Collection Date: 06/08/16
Collection Time: 05:15

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00424		0.00100	mg/L		06/29/16 1245	06/30/16 1646

Analytical Testing Parameters

Client Sample ID: 1 B2
Lab Sample ID: J6F0795-03
Sample Type: Grab

Collected By: Tina Simmons-Client
Collection Date: 06/08/16
Collection Time: 05:17

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00380		0.00100	mg/L		06/29/16 1245	06/30/16 1650



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6F0795

Analytical Testing Parameters			
Client Sample ID:	2 A1	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-04	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	05:22

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00259		0.00100	mg/L		06/29/16 1245	06/30/16 1653

Analytical Testing Parameters			
Client Sample ID:	3 B1	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-05	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	05:26

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00831		0.00100	mg/L		06/29/16 1245	06/30/16 1657

Analytical Testing Parameters			
Client Sample ID:	4 B1	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-06	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	05:30

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00895		0.00100	mg/L		06/29/16 1245	06/30/16 1700



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6F0795

Analytical Testing Parameters

Client Sample ID: 5 A1
Lab Sample ID: J6F0795-07
Sample Type: Grab

Collected By: Tina Simmons-Client
Collection Date: 06/08/16
Collection Time: 05:37

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 8 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00278, 0.00100, mg/L, 06/29/16 1245, 06/30/16 1711

Analytical Testing Parameters

Client Sample ID: 5 A2
Lab Sample ID: J6F0795-08
Sample Type: Grab

Collected By: Tina Simmons-Client
Collection Date: 06/08/16
Collection Time: 05:38

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 8 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00185, 0.00100, mg/L, 06/29/16 1245, 06/30/16 1714

Analytical Testing Parameters

Client Sample ID: 6 A1
Lab Sample ID: J6F0795-09
Sample Type: Grab

Collected By: Tina Simmons-Client
Collection Date: 06/08/16
Collection Time: 05:41

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 8 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00257, 0.00100, mg/L, 06/29/16 1245, 06/30/16 1718



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6F0795

Analytical Testing Parameters			
Client Sample ID:	6 A2	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-10	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	05:43

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00225		0.00100	mg/L		06/29/16 1245	06/30/16 1721

Analytical Testing Parameters			
Client Sample ID:	7 B1	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-11	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	05:47

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00108		0.00100	mg/L		06/29/16 1245	06/30/16 1725

Analytical Testing Parameters			
Client Sample ID:	7 B2	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-12	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	05:50

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00155		0.00100	mg/L		06/29/16 1245	06/30/16 1728



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6F0795

Analytical Testing Parameters

Client Sample ID: 8 B1
Lab Sample ID: J6F0795-13
Sample Type: Grab

Collected By: Tina Simmons-Client
Collection Date: 06/08/16
Collection Time: 05:51

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 8 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.203, 0.00100, mg/L, g, 06/29/16 1555, 07/01/16 0537

Analytical Testing Parameters

Client Sample ID: 9 A1
Lab Sample ID: J6F0795-14
Sample Type: Grab

Collected By: Tina Simmons-Client
Collection Date: 06/08/16
Collection Time: 05:58

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 8 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0149, 0.00100, mg/L, 06/29/16 1245, 06/30/16 1732

Analytical Testing Parameters

Client Sample ID: 10 A1
Lab Sample ID: J6F0795-15
Sample Type: Grab

Collected By: Tina Simmons-Client
Collection Date: 06/08/16
Collection Time: 06:04

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 8 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0119, 0.00100, mg/L, 06/29/16 1245, 06/30/16 1735



Microbac Laboratories, Inc., New York Division
 CERTIFICATE OF ANALYSIS
 J6F0795

Analytical Testing Parameters			
Client Sample ID:	11 F1	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-16	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	06:40

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	<0.00100		0.00100	mg/L		06/29/16 1245	06/30/16 1739

Analytical Testing Parameters			
Client Sample ID:	11 F2	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-17	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	06:14

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	<0.00100		0.00100	mg/L		06/29/16 1245	06/30/16 1742

Analytical Testing Parameters			
Client Sample ID:	12 B1	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-18	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	06:20

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00464		0.00100	mg/L		06/29/16 1245	06/30/16 1753



Microbac Laboratories, Inc., New York Division
 CERTIFICATE OF ANALYSIS
 J6F0795

Analytical Testing Parameters

Client Sample ID: 12 F1
 Lab Sample ID: J6F0795-19
 Sample Type: Grab

Collected By: Tina Simmons-Client
 Collection Date: 06/08/16
 Collection Time: 06:17

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00227		0.00100	mg/L		06/29/16 1245	06/30/16 1756

Analytical Testing Parameters

Client Sample ID: 13 A1
 Lab Sample ID: J6F0795-20
 Sample Type: Grab

Collected By: Tina Simmons-Client
 Collection Date: 06/08/16
 Collection Time: 06:24

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00148		0.00100	mg/L		06/29/16 1245	06/30/16 1800

Analytical Testing Parameters

Client Sample ID: 13 A2
 Lab Sample ID: J6F0795-21
 Sample Type: Grab

Collected By: Tina Simmons-Client
 Collection Date: 06/08/16
 Collection Time: 06:28

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00154		0.00100	mg/L		06/29/16 1245	06/30/16 1803



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6F0795

Analytical Testing Parameters			
Client Sample ID:	14 E1	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-22	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	06:31

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00108		0.00100	mg/L		06/29/16 1245	06/30/16 1807

Analytical Testing Parameters			
Client Sample ID:	15 A1	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-23	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	06:37

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00146		0.00100	mg/L		06/29/16 1245	06/30/16 1821

Analytical Testing Parameters			
Client Sample ID:	15 A2	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-24	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	06:38

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00231		0.00100	mg/L		06/29/16 1245	06/30/16 1824



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6F0795

Analytical Testing Parameters			
Client Sample ID:	17 A1	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-25	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	07:32

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	<0.00100		0.00100	mg/L		06/29/16 1245	06/30/16 1835

Analytical Testing Parameters			
Client Sample ID:	17 B1	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-26	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	07:31

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00260		0.00100	mg/L		06/29/16 1245	06/30/16 1838

Analytical Testing Parameters			
Client Sample ID:	17 F1	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-27	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	07:29

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00185		0.00100	mg/L		06/29/16 1245	06/30/16 1842



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6F0795

Analytical Testing Parameters			
Client Sample ID:	18 B1	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-28	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	07:24

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00258		0.00100	mg/L		06/29/16 1245	06/30/16 1845

Analytical Testing Parameters			
Client Sample ID:	18 F1	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-29	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	07:22

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	<0.00100		0.00100	mg/L		06/29/16 1245	06/30/16 1849

Analytical Testing Parameters			
Client Sample ID:	19.F1	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-30	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	08:03

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	<0.00100		0.00100	mg/L		06/29/16 1245	06/30/16 1852



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6F0795

Analytical Testing Parameters

Client Sample ID: 19 F2
Lab Sample ID: J6F0795-31
Sample Type: Grab

Collected By: Tina Simmons-Client
Collection Date: 06/08/16
Collection Time: 08:05

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 8 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 06/29/16 1245, 06/30/16 1856

Analytical Testing Parameters

Client Sample ID: 20 B1
Lab Sample ID: J6F0795-32
Sample Type: Grab

Collected By: Tina Simmons-Client
Collection Date: 06/08/16
Collection Time: 07:39

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 8 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00787, 0.00100, mg/L, 06/29/16 1245, 06/30/16 1859

Analytical Testing Parameters

Client Sample ID: 20 B2
Lab Sample ID: J6F0795-33
Sample Type: Grab

Collected By: Tina Simmons-Client
Collection Date: 06/08/16
Collection Time: 07:40

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 8 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00687, 0.00100, mg/L, 06/29/16 1245, 06/30/16 1903



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6F0795

Analytical Testing Parameters			
Client Sample ID:	21 A1	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-34	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	07:59

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00119		0.00100	mg/L		06/29/16 1245	06/30/16 1906

Analytical Testing Parameters			
Client Sample ID:	22 A1	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-35	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	07:46

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00229		0.00100	mg/L		06/29/16 1245	06/30/16 1917

Analytical Testing Parameters			
Client Sample ID:	22 A2	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-36	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	07:48

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00229		0.00100	mg/L		06/29/16 1245	06/30/16 1920



Microbac Laboratories, Inc., New York Division
 CERTIFICATE OF ANALYSIS
 J6F0795

Analytical Testing Parameters		Collected By:	Tina Simmons-Client
Client Sample ID:	23 A1	Collection Date:	06/08/16
Lab Sample ID:	J6F0795-37	Collection Time:	07:51
Sample Type:	Grab		

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00186		0.00100	mg/L		06/29/16 1245	06/30/16 1924

Analytical Testing Parameters		Collected By:	Tina Simmons-Client
Client Sample ID:	23 A2	Collection Date:	06/08/16
Lab Sample ID:	J6F0795-38	Collection Time:	07:52
Sample Type:	Grab		

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00148		0.00100	mg/L		06/29/16 1245	06/30/16 1927

Analytical Testing Parameters		Collected By:	Tina Simmons-Client
Client Sample ID:	25 F1	Collection Date:	06/08/16
Lab Sample ID:	J6F0795-39	Collection Time:	07:54
Sample Type:	Grab		

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	<0.00100		0.00100	mg/L		06/29/16 1245	06/30/16 1931



Microbac Laboratories, Inc., New York Division
 CERTIFICATE OF ANALYSIS
 J6F0795

Analytical Testing Parameters			
Client Sample ID:	25 F2	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-40	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	07:56

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	<0.00100		0.00100	mg/L		06/29/16 1245	06/30/16 1934

Analytical Testing Parameters			
Client Sample ID:	29 C1	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-41	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	06:48

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00173		0.00100	mg/L		06/29/16 1245	06/30/16 1938

Analytical Testing Parameters			
Client Sample ID:	29 C2	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-42	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	06:50

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00321		0.00100	mg/L		06/29/16 1245	06/30/16 1942



Microbac Laboratories, Inc., New York Division
 CERTIFICATE OF ANALYSIS
 J6F0795

Analytical Testing Parameters		Collected By:	Tina Simmons-Client
Client Sample ID:	29 C3	Collection Date:	06/08/16
Lab Sample ID:	J6F0795-43	Collection Time:	06:52
Sample Type:	Grab		

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00373		0.00100	mg/L		06/29/16 1555	07/01/16 1225

Analytical Testing Parameters		Collected By:	Tina Simmons-Client
Client Sample ID:	30 A1	Collection Date:	06/08/16
Lab Sample ID:	J6F0795-44	Collection Time:	07:13
Sample Type:	Grab		

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00153		0.00100	mg/L		06/29/16 1245	06/30/16 2003

Analytical Testing Parameters		Collected By:	Tina Simmons-Client
Client Sample ID:	31 A1	Collection Date:	06/08/16
Lab Sample ID:	J6F0795-45	Collection Time:	07:15
Sample Type:	Grab		

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00121		0.00100	mg/L		06/29/16 1245	06/30/16 2006



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6F0795

Analytical Testing Parameters			
Client Sample ID:	33 F1	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-46	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	06:57

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	<0.00100		0.00100	mg/L		06/29/16 1245	06/30/16 2010

Analytical Testing Parameters			
Client Sample ID:	33 F2	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-47	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	06:58

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	<0.00100		0.00100	mg/L		06/29/16 1245	06/30/16 2013

Analytical Testing Parameters			
Client Sample ID:	34 A	Collected By:	Tina Simmons-Client
Lab Sample ID:	J6F0795-48	Collection Date:	06/08/16
Sample Type:	Grab	Collection Time:	08:10

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4							
Lead	0.00851		0.00100	mg/L		06/29/16 1245	06/30/16 2017

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
- g: Result fails applicable NYS drinking water standards
- PQL: Practical Quantitation Limit



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6F0795

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	Yes	Containers Intact	Yes
COC/Labels Agree	Yes	Preservation Correct (or not required)	Yes
Received on Ice (or not required)	Yes		

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Michael Fifield
Division Manager
07/05/2016 16:40

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at michael.fifield@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.