



617 13th Ave S.,
Hopkins, MN 55343
(952) 935-3556
tcwaterclinic@gmail.com

Drinking Water Laboratory Test Report

CLIENT INFORMATION

REPORT ISSUE DATE: 11/14/2023	CLIENT/CLIENT ADDRESS MacNeil Environmental Inc. P.O. Box 826 Grand Rapids, MN 55744	SCHOOL/ADDRESS Lumen Christi School 1668 Montreal Ave St. Paul, MN
REPORT #: 23-11866		

SAMPLE INFORMATION

RECEIPT DATE/TIME: 11/7/2023 - 9:30	TEMP OF SAMPLE UPON RECEIPT: 19° C	COLLECTED BY: <input type="checkbox"/> TCWC <input checked="" type="checkbox"/> CLIENT <input type="checkbox"/> Other
----------------------------------------	---------------------------------------	--------------------------------------------------------------------------------------------------------------------------

LABORATORY		SAMPLE COLLECTION			SAMPLE ANALYSIS				SAMPLE RESULTS
SAMPLE ID	ANALYTE	LOCATION	DATE	TIME	DATE	TIME	METHOD	MCL	RESULT
23-11866	Lead	Old Building - Basement DF	11/7/2023	7:00	11/14/2023	11:08	SM3113B-93	15 µg/L	<2.0 µg/L
23-11867	Lead	Old Building - 1st Floor DF North	11/7/2023	7:05	11/14/2023	11:14	SM3113B-93	15 µg/L	8.74 µg/L
23-11868	Lead	Old Building - 1st Floor DF South	11/7/2023	7:10	11/14/2023	11:20	SM3113B-93	15 µg/L	<2.0 µg/L
23-11869	Lead	Quanset - West DF	11/7/2023	7:15	11/14/2023	11:26	SM3113B-93	15 µg/L	<2.0 µg/L
23-11870	Lead	Quanset - Center DF	11/7/2023	7:20	11/14/2023	11:44	SM3113B-93	15 µg/L	<2.0 µg/L
23-11871	Lead	Quanset - East DF	11/7/2023	7:25	11/14/2023	12:02	SM3113B-93	15 µg/L	<2.0 µg/L
23-11872	Lead	New Addition - By Kitchen	11/7/2023	7:30	11/14/2023	12:09	SM3113B-93	15 µg/L	<2.0 µg/L
23-11873	Lead	New Addition - By Women's	11/7/2023	7:30	11/14/2023	12:15	SM3113B-93	15 µg/L	<2.0 µg/L

*The analyte(s) reported for the above listed sample(s) pass if the result is at or below the MCL (maximum contaminant level) and fail if the result is above the MCL. The MCL is set by the U.S. EPA and followed by the Minnesota Department of Health for safe drinking water.

NOTES

DF = Drinking Fountain

APPROVED BY:

Bill VanArsdale - Lab Manager

Minnesota Laboratory ID # 027-053-119

The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.