



P.O. Box 167, Hammonton, NJ 08037
609-685-9984 Fax: 609-625-2644
coastalenvironmental@hotmail.com

August 21, 2024

Mr. Josh Stow
Swedesboro-Woolrich Township School District
15 Fredrick Boulevard
Woolwich Township, NJ 08085

Re:Informational Lead in Water Testing Results – All Schools

Dear Mr. Stow,

Background

Coastal Environmental Compliance, LLC (Coastal Environmental) was contacted by the Swedesboro-Woolrich Township School District, to conduct informational Lead in Water testing at schools.

Approach

On July 19, 2024, samples were taken in the morning, using a one liter-first draw sample at each selected location within each of the Schools. Once collected, the samples were transported to EMSL Analytical, Cinnaminson, New Jersey for analysis.

SAMPLE LOCATION	Results
STRATTON SCHOOL	ALL ACCEPTABLE LEVELS
HARKER SCHOOL	ALL ACCEPTABLE LEVELS
CLIFFORD SCHOOL	KITCHEN POT FILLER 23.1 ppb REMAINDER OF LOCATIONS ACCEPTABLE LEVELS
WALTER HILL SCHOOL	SINK IN ROOM 225 41.9 ppb REMAINDER OF LOCATIONS ACCEPTABLE LEVELS

Findings and Observations

Laboratory results indicate that all above locations sampled at the Swedesboro Township Stratton and Harker Schools did not exceed the Environmental Protection Agency established 15 ppb action level for lead in water concentration. All locations were within acceptable levels.

One location listed above in each Clifford and Walter Hill Schools did exceed the 15ppm limit for lead in water. These locations have been taken out of operation and have been disconnected. All remaining locations in the Clifford and Walter Hill Schools were within acceptable levels.

If you have any further questions or need additional information, please do not hesitate to call me at 609.685.9984.

Sincerely,
Coastal Environmental Compliance, LLC

Marylee K. Morinelli

Marylee K. Morinelli
President/Member

