

November 20, 2020

Mr. Scott Christ
Director of Operations
Holland Central School District
103 Canada Street
Holland, New York 14080

RE: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Christ:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Holland Central School District, including:

- Holland Elementary School, 173 Canada Street, Holland, New York 14080

This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on September 12, 2020. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 12 sources of potable water in Holland Elementary School have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Holland Central School District.

Sincerely,
Stohl Environmental, LLC.



Eric Henderson Jr.
Senior Project Manager

**Investigation and Sampling
Of Sources of Potable Water
For Lead Concentrations**

Prepared for:

Holland Central School District

Prepared by:



**3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM**

Conditions as of September 12, 2020

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Holland Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- Holland Elementary School, 173 Canada Street, Holland, New York 14080

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets in Holland Elementary School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, *Subpart 67-4: Lead Testing in School Drinking Water*, and the EPA guidance document, *‘3Ts for Reducing Lead in Drinking Water in Schools’*, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below the NYS Action level of 15 ppb	Number of Samples Above the NYS Action Level of 15 ppb	Number of Samples at or Below the NYS Action level of 15 ppb	Number of Samples Above the NYS Action Level of 15 ppb
Holland Elementary	9/12/2020	81	69	12	N/A	N/A

** Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listing of Outlets Requiring Remediation

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples:

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
105.3-7	Room 2 – Classroom	Sink	15.7
105.3-34	Room 12 – Bathroom	Sink	19.3
105.3-39	Room 13 – Classroom	Sink	37.3
105.3-52	Room 18 – Classroom	Sink	23.5
105.3-67	Room 21	Sink	17.5
105.3-69	Room 22	Sink	18.9
105.3-98	Boys Locker Room	Sink	30.9
105.3-101	Music Room 56	Sink	55.5
105.3-105	Room 74 – Bathroom	Sink	23.7
105.3-106	Room 74 – Classroom	Sink	15.2
105.3-112	Laundry Room	Sink	15.8
105.3-115	Kitchen – Sink near Corner	Sink	334

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports by Building



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
 3860 California Road
 Orchard Park, NY 14127

Report Number: 20-09-02690
 Received Date: 09/17/2020
 Reported Date: 10/13/2020
 Sampled By: Paul Nichols
 Tech Certification #:

Project/Test Address: 2020L-105; Holland Elementary; 173 Canada Street; Holland, NY

Client Number:
 33-5980

Laboratory Results

Fax Number:
 716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-09-02690-001	105.3-3	09/12/2020	RM 1	<1.00	10/09/2020	
20-09-02690-002	105.3-4	09/12/2020	RM 1	3.13	10/09/2020	
20-09-02690-003	105.3-6	09/12/2020	RM 2	4.17	10/09/2020	
20-09-02690-004	105.3-7	09/12/2020	RM 2	15.7	10/09/2020	
20-09-02690-005	105.3-9	09/12/2020	RM 3	5.90	10/09/2020	
20-09-02690-006	105.3-12	09/12/2020	RM 4	4.73	10/09/2020	
20-09-02690-007	105.3-13	09/12/2020	RM 4	4.07	10/09/2020	
20-09-02690-008	105.3-15	09/12/2020	RM 5	5.78	10/09/2020	
20-09-02690-009	105.3-16	09/12/2020	RM 5	4.47	10/09/2020	
20-09-02690-010	105.3-17	09/12/2020	RM 6	4.50	10/09/2020	
20-09-02690-011	105.3-18	09/12/2020	RM 6	4.60	10/09/2020	
20-09-02690-012	105.3-20	09/12/2020	RM 7	10.0	10/09/2020	
20-09-02690-013	105.3-21	09/12/2020	RM 7	4.50	10/09/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-09-02690

Project/Test Address: 2020L-105; Holland Elementary; 173 Canada Street;
Holland, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-09-02690-014	105.3-23	09/12/2020	RM 8	3.30	10/09/2020	
20-09-02690-015	105.3-24	09/12/2020	RM 8	4.16	10/09/2020	
20-09-02690-016	105.3-26	09/12/2020	RM 9	10.9	10/09/2020	
20-09-02690-017	105.3-27	09/12/2020	RM 9	3.45	10/09/2020	
20-09-02690-018	105.3-28	09/12/2020	RM 10	3.44	10/09/2020	
20-09-02690-019	105.3-29	09/12/2020	RM 10	4.20	10/09/2020	
20-09-02690-020	105.3-31	09/12/2020	RM 11	5.21	10/09/2020	
20-09-02690-021	105.3-34	09/12/2020	RM 12	19.3	10/09/2020	
20-09-02690-022	105.3-35	09/12/2020	RM 12	2.01	10/09/2020	
20-09-02690-023	105.3-38	09/12/2020	RM 13	8.35	10/09/2020	
20-09-02690-024	105.3-39	09/12/2020	RM 13	37.3	10/09/2020	
20-09-02690-025	105.3-43	09/12/2020	RM 14	5.96	10/09/2020	
20-09-02690-026	105.3-44	09/12/2020	RM 14	5.56	10/09/2020	
20-09-02690-027	105.3-45	09/12/2020	RM 15	4.87	10/09/2020	
20-09-02690-028	105.3-46	09/12/2020	RM 15	7.10	10/09/2020	
20-09-02690-029	105.3-48	09/12/2020	RM 16	9.46	10/09/2020	
20-09-02690-030	105.3-49	09/12/2020	RM 17	4.13	10/09/2020	
20-09-02690-031	105.3-51	09/12/2020	RM 17	3.97	10/09/2020	
20-09-02690-032	105.3-52	09/12/2020	RM 18	23.5	10/09/2020	
20-09-02690-033	105.3-54	09/12/2020	UNISEX RESTROOM	7.76	10/09/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-09-02690

Project/Test Address: 2020L-105; Holland Elementary; 173 Canada Street;
Holland, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-09-02690-034	105.3-55	09/12/2020	UNISEX RESTROOM	10.5	10/09/2020	
20-09-02690-035	105.3-56	09/12/2020	MENS ROOM	5.38	10/09/2020	
20-09-02690-036	105.3-58	09/12/2020	MENS ROOM	5.14	10/09/2020	
20-09-02690-037	105.3-59	09/12/2020	DRINKING FOUNTAIN	<1.00	10/09/2020	
20-09-02690-038	105.3-60	09/12/2020	WOMENS ROOM	<1.00	10/09/2020	
20-09-02690-039	105.3-62	09/12/2020	WOMENS ROOM	<1.00	10/09/2020	
20-09-02690-040	105.3-63	09/12/2020	RM 19	10.2	10/09/2020	
20-09-02690-041	105.3-65	09/12/2020	RM 20	4.96	10/09/2020	
20-09-02690-042	105.3-67	09/12/2020	RM 21	17.5	10/09/2020	
20-09-02690-043	105.3-69	09/12/2020	RM 22	18.9	10/09/2020	
20-09-02690-044	105.3-73	09/12/2020	RM 23	1.01	10/09/2020	
20-09-02690-045	105.3-75	09/12/2020	RM 25	<1.00	10/09/2020	
20-09-02690-046	105.3-77	09/12/2020	RM 26	14.0	10/09/2020	
20-09-02690-047	105.3-78	09/12/2020	RM 27	3.61	10/09/2020	
20-09-02690-048	105.3-79	09/12/2020	RM 28	11.3	10/09/2020	
20-09-02690-049	105.3-80	09/12/2020	RM 29	1.62	10/09/2020	
20-09-02690-050	105.3-81	09/12/2020	RM 29	1.57	10/09/2020	
20-09-02690-051	105.3-82	09/12/2020	RM 30	1.80	10/09/2020	
20-09-02690-052	105.3-83	09/12/2020	RM 31	6.41	10/09/2020	
20-09-02690-053	105.3-84	09/12/2020	RM 32	7.54	10/09/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-09-02690

Project/Test Address: 2020L-105; Holland Elementary; 173 Canada Street;
Holland, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-09-02690-054	105.3-85	09/12/2020	RM 33	9.83	10/09/2020	
20-09-02690-055	105.3-86	09/12/2020	RM 34	14.6	10/09/2020	
20-09-02690-056	105.3-87	09/12/2020	RM 35	12.1	10/09/2020	
20-09-02690-057	105.3-89	09/12/2020	GIRLS LAV	6.97	10/09/2020	
20-09-02690-058	105.3-91	09/12/2020	GIRLS LAV	4.16	10/09/2020	
20-09-02690-059	105.3-92	09/12/2020	BOYS LAV	5.92	10/09/2020	
20-09-02690-060	105.3-94	09/12/2020	BOYS LAV	3.68	10/09/2020	
20-09-02690-061	105.3-97	09/12/2020	UNISEX BATHROOM	9.14	10/09/2020	
20-09-02690-062	105.3-98	09/12/2020	BOYS LOCKER ROOM	30.9	10/09/2020	
20-09-02690-063	105.3-99	09/12/2020	GIRLS LOCKER ROOM	3.64	10/09/2020	
20-09-02690-064	105.3-100	09/12/2020	CUSTODIANS OFFICE	1.81	10/09/2020	
20-09-02690-065	105.3-101	09/12/2020	MUSIC RM 56	55.5	10/12/2020	
20-09-02690-066	105.3-102	09/12/2020	DRINKING FOUNTAIN	1.42	10/12/2020	
20-09-02690-067	105.3-103	09/12/2020	FACULTY ROOM	1.88	10/12/2020	
20-09-02690-068	105.3-104	09/12/2020	DRINKING FOUNTAIN	<1.00	10/12/2020	
20-09-02690-069	105.3-105	09/12/2020	RM 74	23.7	10/12/2020	
20-09-02690-070	105.3-106	09/12/2020	RM 74	15.2	10/12/2020	
20-09-02690-071	105.3-107	09/12/2020	UNISEX BATHROOM	1.43	10/12/2020	
20-09-02690-072	105.3-108	09/12/2020	UNISEX BATHROOM	9.62	10/12/2020	
20-09-02690-073	105.3-109	09/12/2020	NURSE SINK	<1.00	10/12/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980
 Project/Test Address: 2020L-105; Holland Elementary; 173 Canada Street;
 Holland, NY

Report Number: 20-09-02690

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-09-02690-074	105.3-110	09/12/2020	NURSE BATHROOM	1.14	10/12/2020	
20-09-02690-075	105.3-112	09/12/2020	LAUNDRY RM	15.8	10/12/2020	
20-09-02690-076	105.3-113	09/12/2020	KITCHEN	5.24	10/12/2020	
20-09-02690-077	105.3-114	09/12/2020	KITCHEN	8.35	10/12/2020	
20-09-02690-078	105.3-115	09/12/2020	KITCHEN	334	10/12/2020	
20-09-02690-079	105.3-116	09/12/2020	KITCHEN	3.72	10/12/2020	
20-09-02690-080	105.3-125	09/12/2020	DRINKING FOUNTAIN BOTTLE	<1.00	10/12/2020	
20-09-02690-081	105.3-126	09/12/2020	DRINKING FOUNTAIN BOTTLE	<1.00	10/12/2020	

Method: SM 3113B-2010
 Analyst: Jennalee Hertzler
 Accreditation #: NY 11714

Reviewed By Authorized Signatory: *Melissa Kanode*

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2021
Issued April 01, 2020

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. JULIE DICKERSON
ENVIRONMENTAL HAZARDS SERVICES, LLC
7469 WHITEPINE ROAD
N. CHESTERFIELD, VA 23237

NY Lab Id No: 11714

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2003) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Metals I

Copper, Total	SM 19, 21-23 3113B (-04,-10)
Lead, Total	SM 19, 21-23 3113B (-04,-10)



Department
of Health

Serial No.: 61514

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



1.6 Chains of Custody



Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
 ☎ (716) 312-0070 ■ (716) 312-8092
 www.stohlenvironmental.com

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-105

Client: Holland CSD

Contact: Scott Christ

Building: Holland Elementary

Location: 173 Canada Street Holland NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

20 Days

SAMPLE 105.3-10 NOT ACVD. (RH)

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
105.3-3	RM 1	S	2:50	NA		
105.3-4	RM 1	S	2:52	NA		
105.3-6	RM 2	S	2:54	NA		
105.3-7	RM 2	S	2:56	NA		
105.3-9	RM 3	S	2:58	NA		
105.3-10	RM 3	S	3:00	NA		
105.3-12	RM 4	S	3:02	NA		
105.3-13	RM 4	S	3:04	NA		
105.3-15	RM 5	S	3:06	NA		
105.3-16	RM 5	S	3:08	NA		
105.3-17	RM 6	S	3:10	NA		
105.3-18	RM 6	S	3:12	NA		
105.3-20	RM 7	S	3:14	NA		
105.3-21	RM 7	S	3:16	NA		
105.3-23	RM 8	S	3:18	NA		
105.3-24	RM 8	S	3:20	NA		
105.3-26	RM 9	S	3:22	NA		
105.3-27	RM 9	S	3:24	NA		

20-09-02690



Due Date:
10/15/2020
 (Thursday)
 AE

Notes:

Please e-mail lab results to labs@stohlenv.com

If checked, also e-mail results to: _____

Sampled By: Paul Nichols Print Name Paul Nichols Stohl Env: Paul Nichols Date: 9/12/2020

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 9/14/2020

Received (Name / Lab): K. Harris Date: 9-17-20 Time: 11:50 AM

Sample Login (Name / Lab): A. Glasser Date: 10/13/20 Time: 10:11 AM

Analysis (Name / Lab): A. Herting Date: 10/9 + 10/12/20 Time: 10 am

QA/QC Review (Name / Lab): M. Smith Date: 10/13/20 Time: noon

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-105

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
☎ (716) 312-0070 ■ (716) 312-8092
www.stohlenvironmental.com

Client: Holland CSD Contact: Scott Christ

Building: Holland Elementary Location: 173 Canada Street Holland NY

LEAD
Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround
20 Days

SAMPLE 105.3-32 NOT RCVD. KH

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
105.3-28	RM 10	S	3:26	NA		
105.3-29	RM 10	S	3:28	NA		
105.3-31	RM 11	S	3:30	NA		
105.3-32	RM 11	S	3:32	NA		
105.3-34	RM 12	S	3:34	NA		
105.3-35	RM 12	S	3:36	NA		
105.3-38	RM 13	S	3:38	NA		
105.3-39	RM 13	S	3:40	NA		
105.3-43	RM 14	S	3:42	NA		
105.3-44	RM 14	S	3:44	NA		
105.3-45	RM 15	S	3:46	NA		
105.3-46	RM 15	S	3:48	NA		
105.3-48	RM 16	S	3:50	NA		
105.3-49	RM 17	S	3:52	NA		
105.3-51	RM 17	S	3:54	NA		
105.3-52	RM 18	S	3:56	NA		
105.3-54	Unisex Restroom	S	3:58	NA		
105.3-55	Unisex Bathroom	S	4:00	NA		

Notes:
Please e-mail lab results to labs@stohlenv.com

* 20.09.02690

Sampled By: Paul Nichols Print Name Paul Nichols Date: 9/12/2020

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 9/14/2020

Received (Name / Lab): KTHARRIS O. Klaus Date: 9.17.20 Time: 11:50 AM

Sample Login (Name / Lab): O. Klaus Date: 10.13.20 Time: 10:11 AM

Analysis (Name / Lab): J. Hertzler Date: 10/9 + 10/12/20 Time: 10 am

QA/QC Review (Name / Lab): Melinda Date: 10/13/20 Time: noon

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
 ☎ (716) 312-0070 📠 (716) 312-8092
 www.stohlenvironmental.com

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-105

Client: Holland CSD

Contact: Scott Christ

Building: Holland Elementary

Location: 173 Canada Street Holland NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

20 Days

SAMPLE 105.3-71 NOT PROVIDED

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
105.3-56	Men's Room	S	4:02	NA		
105.3-58	Mens Room	S	4:04	NA		
105.3-59	Drinking Fountain	DF	4:06	NA		
105.3-60	Womens Room	S	4:08	NA		
105.3-62	Womens Room	S	4:10	NA		
105.3-63	RM 19	S	4:12	NA		
105.3-65	RM 20	S	4:14	NA		
105.3-67	RM 21	S	4:16	NA		
105.3-69	RM 22	S	4:18	NA		
105.3-71	RM 24	S	4:20	NA		
105.3-73	RM 23	S	4:22	NA		
105.3-75	RM 25	S	4:24	NA		
105.3-77	RM 26	S	4:26	NA		
105.3-78	RM 27	S	4:28	NA		
105.3-79	RM 28	S	4:30	NA		
105.3-80	RM 29	S	4:32	NA		
105.3-81	RM 29	S	4:34	NA		
105.3-82	RM 30	S	4:36	NA		

Notes:

Please e-mail lab results to labs@stohlenv.com

*20-09-02690

Sampled By: Paul Nichols Print Name Stohl Env: Paul Nichols Date: 9/12/2020

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 9/14/2020

Received (Name / Lab): K. HARRIS K. HARRIS Date: 9.17.20 Time: 11:50 AM

Sample Login (Name / Lab): K. HARRIS Date: 10.13.20 Time: 10:11 AM

Analysis (Name / Lab): J. Kozlowski Date: 10/9 + 10/12/20 Time: 10 am

QA/QC Review (Name / Lab): M. Kozlowski Date: 10/13/20 Time: nan

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
 (716) 312-0070 (716) 312-8092
 www.stohlenvironmental.com

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-105

Client: Holland CSD

Contact: Scott Christ

Building: Holland Elementary

Location: 173 Canada Street Holland NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
105.3-83	RM 31	S	4:38	NA		
105.3-84	RM 32	S	4:40	NA		
105.3-85	RM 33	S	4:42	NA		
105.3-86	RM 34	S	4:44	NA		
105.3-87	RM 35	S	4:46	NA		
105.3-89	Girls Lav	S	4:48	NA		
105.3-91	Girls Lav	S	4:50	NA		
105.3-92	Boys Lav	S	4:52	NA		
105.3-94	Boys Lav	S	4:54	NA		
105.3-97	Unisex Bathroom	S	4:56	NA		
105.3-98	Boys Locker Room	S	4:58	NA		
105.3-99	Girls Locker Room	S	5:00	NA		
105.3-100	Custodians Office	S	5:02	NA		
105.3-101	Music Room RM 56	S	5:04	NA		
105.3-102	Drinking Fountain	DF	5:06	NA		
105.3-103	Faculty Room	S	5:08	NA		
105.3-104	Drinking Fountain	DF	5:10	NA		
105.3-105	RM 74	S	5:12	NA		

Notes:

Please e-mail lab results to labs@stohlenv.com

20-09-02690

Sampled By: Paul Nichols Print Name Paul Nichols Stohl Env: Paul Nichols Date: 9/12/2020

Relinquished By: E. Henderson Jr Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 9/14/2020

Received (Name / Lab): K. Harris / K. Harris Date: 9.17.20 Time: 11:50 AM

Sample Login (Name / Lab): K. Harris Date: 10.13.20 Time: 10:11 AM

Analysis (Name / Lab): J. Hartigan Date: 10/9 + 10/12/20 Time: 10 am

QA/QC Review (Name / Lab): Melissa Date: 10/13/20 Time: noon

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
 ☎ (716) 312-0070 ■ (716) 312-8092
 www.stohlenvironmental.com

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-105

Client: Holland CSD Contact: Scott Christ

Building: Holland Elementary Location: 173 Canada Street Holland NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
105.3-106	RM 74	S	5:14	NA		
105.3-107	Unisex Bathroom	S	5:16	NA		
105.3-108	Unisex Bathroom	S	5:18	NA		
105.3-109	Nurse Sink	S	5:20	NA		
105.3-110	Nurse Bathroom	S	5:22	NA		
105.3-112	Laundry RM	S	5:24	NA		
105.3-113	Kitchen	S	5:26	NA		
105.3-114	Kitchen	S	5:28	NA		
105.3-115	Kitchen	S	5:30	NA		
105.3-116	Kitchen	S	5:32	NA		
105.3-125	Drinking Fountain Bottle	DFB	5:34	NA		
105.3-126	Drinking Fountain Bottle	DFB	5:36	NA		

Notes: Please e-mail lab results to labs@stohlenv.com #20-09-02690

Sampled By: Paul Nichols Print Name Stohl Env: Paul Nichols Date: 9/12/2020
 Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 9/14/2020
 Received (Name / Lab): K. Harris / K. Harris Date: 9.17.20 Time: 11:50 AM
 Sample Login (Name / Lab): M. Harris Date: 10.13.20 Time: 10:11 AM
 Analysis (Name / Lab): G. Heston Date: 10/9 + 10/12/20 Time: 10 am
 QA/QC Review (Name): M. Harris Date: 10/12/20 Time: noon
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____