

November 20, 2020

Mr. Scott Christ  
Director of Operations  
Holland Central School District  
103 Canada Street  
Holland, New York 14080

**RE: Investigation and Sampling of Drinking Water for Lead Concentrations**

Dear Mr. Christ:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Holland Central School District, including:

- Holland Middle School, 11720 Partridge Street, Holland, New York 14080

This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on September 12, 2020. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 6 sources of potable water in Holland Middle School have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Holland Central School District.

Sincerely,  
Stohl Environmental, LLC.



Eric Henderson Jr.  
Senior Project Manager

**Investigation and Sampling  
Of Sources of Potable Water  
For Lead Concentrations**

**Prepared for:**

**Holland Central School District**

**Prepared by:**



---

**3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
[WWW.STOHLENVIRONMENTAL.COM](http://WWW.STOHLENVIRONMENTAL.COM)**

**Conditions as of September 12, 2020**

## **Summary Tabulation**

### **Lead in Drinking Water Investigation**

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

## 1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Holland Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- Holland Middle School, 11720 Partridge Street, Holland, New York 14080

### Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets in Holland Middle School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

### Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***‘3Ts for Reducing Lead in Drinking Water in Schools’***, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

## 1.2 Executive Summary of Sampling and Analysis:

### Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below the NYS Action level of 15 ppb	Number of Samples Above the NYS Action Level of 15 ppb	Number of Samples at or Below the NYS Action level of 15 ppb	Number of Samples Above the NYS Action Level of 15 ppb
Holland CSD	9/12/2020	63	57	6	N/A	N/A

\*\* Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

### Listing of Outlets Requiring Remediation

#### Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples:

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
105.2-5	Concessions Boys Bathroom	Sink	90.2
105.2-6	Concession Stand Left	Sink	22.1
105.2-22	Kitchen Dish Wash	Sink	19.1
105.2-33	Girls Lav – Across from Office	Sink	17.3
105.2-37	Nurses Office	Sink	20.4
105.2-62	Room 204	Sink	22.5

### **1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:**

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
  - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
  - (2) test results indicate that the lead levels are at or below the action level;
- (b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

#### 1.4 Laboratory Analytical Reports by Building



Environmental Hazards Services, L.L.C.  
7469 Whitepine Rd  
Richmond, VA 23237  
Telephone: 800.347.4010

## Lead in Drinking Water Analysis Report

Client: Stohl Environmental  
3860 California Road  
Orchard Park, NY 14127

Report Number: 20-09-02650

Received Date: 09/17/2020  
Reported Date: 09/23/2020  
Sampled By: Paul Nichols  
Tech Certification #:

Project/Test Address: 2020L-105; Holland Middle School; 11720 Partridge Rd; Holland, NY

Client Number:  
33-5980

# Laboratory Results

Fax Number:  
716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-09-02650-001	105.2-3	09/12/2020	CO AUD	<1.00	09/21/2020	
20-09-02650-002	105.2-4	09/12/2020	CONCESSION GIRLS BR	3.95	09/21/2020	
20-09-02650-003	105.2-5	09/12/2020	CONCESSIONS BOYS BR	90.2	09/21/2020	
20-09-02650-004	105.2-6	09/12/2020	CONCESSION STAND L	22.1	09/21/2020	
20-09-02650-005	105.2-7	09/12/2020	CONCESSION STAND R	3.90	09/21/2020	
20-09-02650-006	105.2-9	09/12/2020	GIRLS LOCKER	6.77	09/21/2020	
20-09-02650-007	105.2-10	09/12/2020	GIRLS LOCKER	4.26	09/21/2020	
20-09-02650-008	105.2-12	09/12/2020	BOYS LOCKER	2.69	09/21/2020	
20-09-02650-009	105.2-14	09/12/2020	BOYS LOCKER	3.10	09/21/2020	
20-09-02650-010	105.2-15	09/12/2020	RECEIVING MENS LAV	4.07	09/21/2020	
20-09-02650-011	105.2-16	09/12/2020	RECEIVING WOMENS LAV	6.99	09/21/2020	
20-09-02650-012	105.2-17	09/12/2020	KITCHEN	2.43	09/21/2020	
20-09-02650-013	105.2-18	09/12/2020	KITCHEN	3.81	09/21/2020	



# Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-09-02650

Project/Test Address: 2020L-105; Holland Middle School; 11720 Partridge Rd;  
Holland, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-09-02650-014	105.2-19	09/12/2020	KITCHEN	4.08	09/21/2020	
20-09-02650-015	105.2-20	09/12/2020	KITCHEN SPRAYER	5.06	09/21/2020	
20-09-02650-016	105.2-21	09/12/2020	KITCHEN	10.7	09/21/2020	
20-09-02650-017	105.2-22	09/12/2020	KITCHEN DISH WASH	19.1	09/21/2020	
20-09-02650-018	105.2-23	09/12/2020	BOYS LAV	5.55	09/21/2020	
20-09-02650-019	105.2-24	09/12/2020	BOYS LAV	6.05	09/21/2020	
20-09-02650-020	105.2-25	09/12/2020	BOYS LAV	6.40	09/21/2020	
20-09-02650-021	105.2-26	09/12/2020	BOYS LAV	4.12	09/21/2020	
20-09-02650-022	105.2-28	09/12/2020	BREAK ROOM	1.56	09/21/2020	
20-09-02650-023	105.2-29	09/12/2020	LOBBY WOMENS LAV	4.11	09/21/2020	
20-09-02650-024	105.2-30	09/12/2020	LOBBY WOMENS LAV	6.43	09/21/2020	
20-09-02650-025	105.2-31	09/12/2020	GIRLS LAV	4.03	09/21/2020	
20-09-02650-026	105.2-33	09/12/2020	GIRLS LAV	17.3	09/21/2020	
20-09-02650-027	105.2-34	09/12/2020	MENS LAV	3.82	09/21/2020	
20-09-02650-028	105.2-35	09/12/2020	LIBRARY OFFICE	14.5	09/21/2020	
20-09-02650-029	105.2-37	09/12/2020	NURSES OFFICE	20.4	09/21/2020	
20-09-02650-030	105.2-38	09/12/2020	NURSES OFFICE	1.07	09/21/2020	
20-09-02650-031	105.2-39	09/12/2020	ROOM 108	5.51	09/21/2020	
20-09-02650-032	105.2-40	09/12/2020	5TH WING GIRLS LAV	5.08	09/21/2020	
20-09-02650-033	105.2-42	09/12/2020	5TH WING GIRLS LAV	5.59	09/21/2020	

# Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-09-02650

Project/Test Address: 2020L-105; Holland Middle School; 11720 Partridge Rd;  
Holland, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-09-02650-034	105.2-43	09/12/2020	5TH WING BOYS LAV	4.19	09/21/2020	
20-09-02650-035	105.2-44	09/12/2020	5TH WING BOYS LAV	3.80	09/21/2020	
20-09-02650-036	105.2-45	09/12/2020	5TH WING WOMENS LAV	4.44	09/21/2020	
20-09-02650-037	105.2-46	09/12/2020	5TH WING MENS LAV	1.80	09/21/2020	
20-09-02650-038	105.2-47	09/12/2020	ROOM 109	5.59	09/21/2020	
20-09-02650-039	105.2-48	09/12/2020	ROOM 110	3.64	09/21/2020	
20-09-02650-040	105.2-49	09/12/2020	ROOM 111	2.58	09/21/2020	
20-09-02650-041	105.2-50	09/12/2020	ROOM 113	2.05	09/21/2020	
20-09-02650-042	105.2-51	09/12/2020	ROOM 201	4.65	09/21/2020	
20-09-02650-043	105.2-52	09/12/2020	ROOM 201	1.09	09/21/2020	
20-09-02650-044	105.2-53	09/12/2020	ROOM 201	1.54	09/21/2020	
20-09-02650-045	105.2-54	09/12/2020	ROOM 201	3.06	09/21/2020	
20-09-02650-046	105.2-55	09/12/2020	ROOM 201	5.66	09/21/2020	
20-09-02650-047	105.2-61	09/12/2020	ROOM 204	13.8	09/21/2020	
20-09-02650-048	105.2-62	09/12/2020	ROOM 204	22.5	09/21/2020	
20-09-02650-049	105.2-63	09/12/2020	ROOM 204	12.9	09/21/2020	
20-09-02650-050	105.2-65	09/12/2020	2ND FLOOR GIRLS LAV	10.3	09/22/2020	
20-09-02650-051	105.2-67	09/12/2020	2ND FLOOR GIRLS LAV	6.02	09/22/2020	
20-09-02650-052	105.2-69	09/12/2020	2ND FLOOR GIRLS LAV	8.38	09/22/2020	
20-09-02650-053	105.2-70	09/12/2020	2ND FLOOR BOYS LAV	6.40	09/22/2020	

# Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-09-02650


Project/Test Address: 2020L-105; Holland Middle School; 11720 Partridge Rd;  
Holland, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-09-02650-054	105.2-73	09/12/2020	2ND FLOOR WOMENS LAV	5.68	09/22/2020	
20-09-02650-055	105.2-74	09/12/2020	2ND FLOOR MENS LAV	5.27	09/22/2020	
20-09-02650-056	105.2-75	09/12/2020	AUX GYM LAV	4.24	09/22/2020	
20-09-02650-057	105.2-80	09/12/2020	CO AUD BOTTLE	3.16	09/22/2020	
20-09-02650-058	105.2-81	09/12/2020	GIRLS LOCKER BOTTLE	<1.00	09/22/2020	
20-09-02650-059	105.2-82	09/12/2020	BOYS LOCKER BOTTLE	<1.00	09/22/2020	
20-09-02650-060	105.2-83	09/12/2020	LOBBY FOUNTAIN BOTTLE	<1.00	09/22/2020	
20-09-02650-061	105.2-84	09/12/2020	NURSES BATHROOM	6.88	09/22/2020	
20-09-02650-062	105.2-85	09/12/2020	5TH WIND DF	<1.00	09/22/2020	
20-09-02650-063	105.2-86	09/12/2020	BREAK ROOM	<1.00	09/22/2020	

Method: SM 3113B-2010

Analyst: Jennalee Hertzler

Accreditation #: NY 11714

Reviewed By Authorized Signatory: 

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

## 1.5 Laboratory Certifications



NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2021  
Issued April 01, 2020

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MS. JULIE DICKERSON  
ENVIRONMENTAL HAZARDS SERVICES, LLC  
7469 WHITEPINE ROAD  
N. CHESTERFIELD, VA 23237

NY Lab Id No: 11714

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2003) for the category  
ENVIRONMENTAL ANALYSES POTABLE WATER  
All approved analytes are listed below:*

**Metals I**

Copper, Total	SM 19, 21-23 3113B (-04,-10)
Lead, Total	SM 19, 21-23 3113B (-04,-10)



Department  
of Health

Serial No.: 61514

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.





**1.6 Chains of Custody**



## Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
☎ (716) 312-0070 ■ (716) 312-8092  
www.stohlenvironmental.com

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-105

Client: Holland CSD

Contact: Scott Christ

Building: Holland Middle School

Location: 11720 Partridge Rd, Holland NY

### LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
105.2-3	CO Aud	DF	4:50	NA		
105.2-4	Concession girls br	S	4:52	NA		
105.2-5	Concession boys br	S	4:54	NA		
105.2-6	Concession stand - L	S	4:56	NA		
105.2-7	Concession stand - R	S	4:58	NA		
105.2-9	Girls Locker	S	5:00	NA		
105.2-10	Girls Locker	S	5:00	NA		
105.2-12	Boys Locker	S	5:02	NA		
105.2-14	Boys Locker	S	5:02	NA		
105.2-15	Receiving Mens Lav	S	5:04	NA		
105.2-16	Receiving Womans Lav	S	5:06	NA		
105.2-17	Kitchen	S	5:08	NA		
105.2-18	Kitchen	S	5:08	NA		
105.2-19	Kitchen	S	5:10	NA		
105.2-20	Kitchen - Sprayer	S	5:10	NA		
105.2-21	Kitchen	S	5:12	NA		
105.2-22	Kitchen - Dish Wash	S	5:12	NA		
105.2-23	Boys Lav	S	5:14	NA		

20-09-02650



Due Date:  
10/15/2020  
(Thursday)  
AE

### Notes:

Please e-mail lab results to labs@stohlenv.com

☐ If checked, also e-mail results to: \_\_\_\_\_

Sampled By: Paul Nichols Print Name Stohl Env: Paul Nichols Date: 9/12/2020

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 9/14/2016

Received (Name / Lab): KTHARRIS K. Glauco Date: 9-17-20 Time: 11:14 AM

Sample Login (Name / Lab): KTHARRIS K. Glauco Date: 9-17-20 Time: 1:15 PM

Analysis (Name / Lab): J. Berthel Date: 9/21/20 + 9/22/20 Time: 10 am

QA/QC Review (Name / Lab): Melinda Date: 9/22/20 Tien Time: 7:20 PM

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



## Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
☎ (716) 312-0070 ■ (716) 312-8092  
www.stohlenvironmental.com

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-105

Client: Holland CSD Contact: Scott Christ

Building: Holland Middle School Location: 11720 Partridge Rd, Holland NY

### LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
105.2-24	Boys Lav	S	5:14	NA		
105.2-25	Boys Lav	S	5:16	NA		
105.2-26	Boys Lav	S	5:16	NA		
105.2-28	Break Room	S	5:18	NA		
105.2-29	Lobby Womans Lav	S	5:20	NA		
105.2-30	Lobby Womans Lav	S	5:22	NA		
105.2-31	Girls Lav	S	5:24	NA		
105.2-33	Girls Lav	S	5:24	NA		
105.2-34	Mens Lav	S	5:26	NA		
105.2-35	Library Office	S	5:28	NA		
105.2-37	Nurses Office	S	5:30	NA		
105.2-38	Nurses Office	S	5:30	NA		
105.2-39	Room 108	S	5:32	NA		
105.2-40	5th Wing Girls Lav	S	5:34	NA		
105.2-42	5th Wing Girls Lav	S	5:34	NA		
105.2-43	5th Wing Boys Lav	S	5:36	NA		
105.2-44	5th Wing Boys Lav	S	5:36	NA		
105.2-45	5th Wing Womans Lav	S	5:38	NA		

### Notes:

Please e-mail lab results to labs@stohlenv.com

20-09-02650

Sampled By: Paul Nichols Print Name Stohl Env: Paul Nichols Date: 9/12/2020

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 9/14/2016

Received (Name / Lab): RTHARRIS Date: 9-17-20 Time: 11:14 AM

Sample Login (Name / Lab): RTHARRIS Date: 9-17-20 Time: 1:15 PM

Analysis (Name / Lab): J. Bortolero Date: 9/21/20 + 9/22/20 Time: 10 am

QA/QC Review (Name / Lab): Melinda Date: 9/23/20 Time: 7:00 PM

Archived / Released: QA/QC InterLAB Use: Date:  Time:





## Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
☎ (716) 312-0070 ■ (716) 312-8092  
www.stohlenvironmental.com

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-105

Client: Holland CSD

Contact: Scott Christ

Building: Holland Middle School

Location: 11720 Partridge Rd, Holland NY

### LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
105.2-46	5th Wing Mens Lav	S	5:38	NA		
105.2-47	Room 109	S	5:40	NA		
105.2-48	Room 110	S	5:42	NA		
105.2-49	Room 111	S	5:44	NA		
105.2-50	Room 113	S	5:46	NA		
105.2-51	Room 201	S	5:48	NA		
105.2-52	Room 201	S	5:48	NA		
105.2-53	Room 201	S	5:50	NA		
105.2-54	Room 201	S	5:50	NA		
105.2-55	Room 201	S	5:52	NA		
105.2-61	Room 204	S	5:54	NA		
105.2-62	Room 204	S	5:54	NA		
105.2-63	Room 204	S	5:56	NA		
105.2-65	2nd Floor Girls Lav	S	5:58	NA		
105.2-67	2nd Floor Girls Lav	S	5:58	NA		
105.2-69	2nd Floor Girls Lav	S	6:00	NA		
105.2-70	2nd Floor Boys Lav	S	6:02	NA		
105.2-73	2nd Floor Womens Lav	S	6:04	NA		

### Notes:

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

20-09-02650

Sampled By: Paul Nichols Print Name Stohl Env: Paul Nichols Date: 9/12/2020

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 9/14/2016

Received (Name / Lab): RTHARRIS R. Olano Date: 9.17.20 Time: 11:14 AM

Sample Login (Name / Lab): RTHARRIS R. Olano Date: 9.17.20 Time: 1:15 PM

Analysis (Name / Lab): G. Hedges Date: 9/21/20 - 9/22/20 Time: 10 am

QA/QC Review (Name / Lab): Melissas Date: 9/23/20 Time: 7:20 am

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

## Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-105

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
☎ (716) 312-0070 ■ (716) 312-8092  
[www.stohlenvironmental.com](http://www.stohlenvironmental.com)

Client: Holland CSD

Contact: Scott Christ

Building: Holland Middle School

Location: 11720 Partridge Rd. Holland NY

**LEAD**

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9	X
---	---

## Turnaround

20 Days

[illegible]

Notes:

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

20.09.02650

Sampled By: Paul Nichols      Print Name      Stohl Env: Paul Nichols      Date: 9/12/2020

Relinquished By:  Print Name Stohl Env: Eric Henderson Jr. Date: 9/14/2016

Received (Name / Lab): REHMAN R. H. H. H. Date: 9.17.20 Time: 11:14 AM

Sample Login (Name / Lab): RTHARRIS K. Harris Date: 9.17.20 Time: 1:15 PM

Analysis (Name / Lab): Dr. Hestrich Date: 9/21/20 + 9/22/20 Time: 10 am

QA/QC Review (Name / Lab): Nelson, L Date: 9/23/20 Time: 7:20a

Archived / Released:                      QA/QC InterLAB Use:                      Date:                      Time:

BLANK



**3860 California Road, Orchard Park, New York 14127**

**PHONE (716) 312-0070 FAX (716) 312-8092**

**[WWW.STOHLENVIRONMENTAL.COM](http://WWW.STOHLENVIRONMENTAL.COM)**