Stohl BUFFALO ROCHESTER ENVIRONMENTAL

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

August 14, 2024

Michael Bryniarski
Director of Facilities
Lancaster Central School District
177 Central Avenue
Lancaster, New York 14086

Re: Lead Testing in School Drinking Water

Dear Mr. Bryniarski:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Lancaster Central School District, including:

- Hillview Elementary – 11 Pleasant View Drive, Lancaster, New York

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: *Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on June 7, 2024. As detailed in Section 1.2 *(Executive Summary)* of the accompanying report, based upon the sampling and analysis performed, 17 sources of potable water in Hillview Elementary have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion. To comply with NYS regulations, response actions by the district are required. Response actions are outlined in Section 1.3 *(Response Actions Required Under NYS Regulations).*

Thank you for the opportunity to be of service to Lancaster Central School District.

Sincerely,
Stohl Environmental, LLC.

M. Scinta

Michael Scinta
EPA Lead Risk Assessor

Lead Testing in School Drinking Water

Prepared for:

Lancaster Central School District

Prepared by:

3860 California Road
Orchard Park, New York 14127

Conditions as of June 7, 2024

Stohl BUFFALO ROCHESTER ENVIRONMENTAL

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

Summary Tabulation

Lead in Drinking Water Investigation

1.1. Scope of Work and Sampling Protocol

1.2. Executive Summary of Sampling and Analysis

1.3. Response Actions Required Under NYS Regulations

1.4. Laboratory Analytical Reports and Chain of Custody Documents

1.5. Laboratory Certifications

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Lancaster Central School District to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- Hillview Elementary – 11 Pleasant View Drive, Lancaster, New York

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within Hillview Elementary. Outlets are defined in NYS regulations as: "a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets".

Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***3Ts for Reducing Lead in Drinking Water in Schools***, Stohl Environmental's protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.

- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health's Environmental Laboratory Approval Program (ELAP).

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at Hillview Elementary:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Hillview Elementary	June 7, 2024	88	71	17

**NYS Action Level is 5 parts per billion*

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
104.6-1	Kitchen 3 Bay Left	Sink	7.2
104.6-3	Kitchen Lavatory	Sink	5.5
104.6-5	Cafeteria Fountain	Drinking Fountain	6.6
104.6-11	Principal's Office Lavatory	Sink	17.6
104.6-14	Room 1 Lavatory	Sink	29.4
104.6-26	Room 5 Lavatory	Sink	18.8
104.6-29	Room 4 Lavatory	Sink	5.4
104.6-33	Room 9 Main	Bubbler	6.3
104.6-36	Nurse Exam	Sink	7.5
104.6-43	Room 32 Art Office Right	Sink	5.3
104.6-52	Room 11	Sink	7.7
104.6-53	Room 11	Bubbler	6
104.6-63	Girls Locker Coach Office	Sink	7.3
104.6-64	Girls Locker Room	Sink	24.2
104.6-67	Boys Gym Office	Sink	5.3
104.6-74	Room 17	Sink	5.6
104.6-98	Basement	Sink	10.4

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration more than the NYS Action Level, regulations require:

(a) Prohibit use of the outlet until:

(1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and

(2) test results indicate that the lead levels are at or below the action level;

(b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;

(c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and

(d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.4 Laboratory Analytical Reports and Chain of Custody Documents

July 10, 2024 Service Request No:R2405408

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Lancaster CSD - Hillview Elementary

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory June 12, 2024
For your reference, these analyses have been assigned our service request number **R2405408.**

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental



Meghan Pedro
Project Manager

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | FAX +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental

Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Lancaster CSD - Hillview Elementary
Sample Matrix: Drinking Water

Service Request: R2405408
Date Received: 06/12/2024

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 06/12/2024. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

Approved by _____ Date 07/10/2024

SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 104.6-1			Lab ID: R2405408-001			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	7.2			1.0	ug/L	200.8

CLIENT ID: 104.6-2			Lab ID: R2405408-002			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	3.3			1.0	ug/L	200.8

CLIENT ID: 104.6-3			Lab ID: R2405408-003			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	5.5			1.0	ug/L	200.8

CLIENT ID: 104.6-4			Lab ID: R2405408-004			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	3.0			1.0	ug/L	200.8

CLIENT ID: 104.6-5			Lab ID: R2405408-005			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	6.6			1.0	ug/L	200.8

CLIENT ID: 104.6-11			Lab ID: R2405408-012			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	17.6			1.0	ug/L	200.8

CLIENT ID: 104.6-14			Lab ID: R2405408-015			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	29.4			1.0	ug/L	200.8

CLIENT ID: 104.6-19			Lab ID: R2405408-020			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.7			1.0	ug/L	200.8

CLIENT ID: 104.6-21			Lab ID: R2405408-022			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.7			1.0	ug/L	200.8

CLIENT ID: 104.6-24			Lab ID: R2405408-025			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	2.6			1.0	ug/L	200.8

CLIENT ID: 104.6-25			Lab ID: R2405408-026			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	2.7			1.0	ug/L	200.8

CLIENT ID: 104.6-26			Lab ID: R2405408-027			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	18.8			1.0	ug/L	200.8

SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 104.6-27			Lab ID: R2405408-028			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	2.7			1.0	ug/L	200.8

CLIENT ID: 104.6-28			Lab ID: R2405408-029			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.8			1.0	ug/L	200.8

CLIENT ID: 104.6-29			Lab ID: R2405408-030			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	5.4			1.0	ug/L	200.8

CLIENT ID: 104.6-30			Lab ID: R2405408-031			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	3.2			1.0	ug/L	200.8

CLIENT ID: 104.6-31			Lab ID: R2405408-032			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	2.6			1.0	ug/L	200.8

CLIENT ID: 104.6-32			Lab ID: R2405408-033			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	3.9			1.0	ug/L	200.8

CLIENT ID: 104.6-33			Lab ID: R2405408-034			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	6.3			1.0	ug/L	200.8

CLIENT ID: 104.6-35			Lab ID: R2405408-036			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	3.6			1.0	ug/L	200.8

Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental **Service Request:**R2405408
Project: Lancaster CSD - Hillview Elementary/2023-104.6

SAMPLE CROSS-REFERENCE

SAMPLE #	CLIENT SAMPLE ID	DATE	TIME
R2405408-001	104.6-1	6/7/2024	2300
R2405408-002	104.6-2	6/7/2024	2301
R2405408-003	104.6-3	6/7/2024	2302
R2405408-004	104.6-4	6/7/2024	2303
R2405408-005	104.6-5	6/7/2024	2304
R2405408-006	104.6-6	6/7/2024	2305
R2405408-007	104.6-7	6/7/2024	2306
R2405408-008	104.6-8A	6/7/2024	2307
R2405408-009	104.6-8B	6/7/2024	2308
R2405408-010	104.6-9	6/7/2024	2309
R2405408-011	104.6-10	6/7/2024	2310
R2405408-012	104.6-11	6/7/2024	2311
R2405408-013	104.6-12	6/7/2024	2312
R2405408-014	104.6-13	6/7/2024	2313
R2405408-015	104.6-14	6/7/2024	2314
R2405408-016	104.6-15	6/7/2024	2315
R2405408-017	104.6-16	6/7/2024	2316
R2405408-018	104.6-17	6/7/2024	2317
R2405408-019	104.6-18	6/7/2024	2318
R2405408-020	104.6-19	6/7/2024	2319
R2405408-021	104.6-20	6/7/2024	2320
R2405408-022	104.6-21	6/7/2024	2321
R2405408-023	104.6-22	6/7/2024	2322
R2405408-024	104.6-23	6/7/2024	2323
R2405408-025	104.6-24	6/7/2024	2324
R2405408-026	104.6-25	6/7/2024	2325
R2405408-027	104.6-26	6/7/2024	2326
R2405408-028	104.6-27	6/7/2024	2327
R2405408-029	104.6-28	6/7/2024	2328
R2405408-030	104.6-29	6/7/2024	2329
R2405408-031	104.6-30	6/7/2024	2330
R2405408-032	104.6-31	6/7/2024	2331
R2405408-033	104.6-32	6/7/2024	2332
R2405408-034	104.6-33	6/7/2024	2333
R2405408-035	104.6-34	6/7/2024	2334
R2405408-036	104.6-35	6/7/2024	2335

Stohl ENVIRONMENTAL
3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) ALS

STOHL Job # 2023-104.6

Client: Lancaster CSD Contact: Michael Bryniarski

Building: Hillview Elementary Location: 11 Pleasantview Dr Lancaster, NY 14086

LEAD		Turnaround
Water by 200.8	X	10 Days

Sample #	Location	Outlet Type	Time
104.6-1	Kitchen 3 bay Left	Sink	23:00
104.6-2	Kitchen 3 Bay Right	Sink	23:01
104.6-3	Kitchen Lav	Sink	23:02
104.6-4	Kitchen Dish Sprayer	Sink	23:03
104.6-5	Cafeteria Fountain	Drinking Fountain	23:04
104.6-6	1st Wing Girls Lav Left	Sink	23:05
104.6-7	1st Wing Girls Lav Right	Sink	23:06
104.6-8A	1st Wing Fountain	Drinking Fountain	23:07
104.6-8B	1st Wing Fountain	Bottle Fill	23:08
104.6-9	1st Wing Boys Lav Left	Sink	23:09
104.6-10	1st Wing Boys Lav Right	Sink	23:10
104.6-11	Principals Office Lav	Sink	23:11
104.6-12	Room 1 Main	Sink	23:12
104.6-13	Room 1 Main	Bubbler	23:13
104.6-14	Room 1 Lav	Sink	23:14
104.6-15	Room 8 Main	Sink	23:15
104.6-16	Room 8 Main	Bubbler	23:16
104.6-17	Room 7 Main	Sink	23:17

Notes:
Please e-mail lab results to labs@stohlenv.com ☑ If checked, also e-mail results to: Rfranjoine@stohlenvironmental.com

Sampled By: Drew Theal Print Name Stohl Env: Drew Theal Date: 6/7/2024

Relinquished By: Rebecca Franjoine Print Name Stohl Env: Rebecca Franjoine Date: 6/12/2024

Received (Name / Lab): Date: Time: 1300

Sample Login (Name / Lab): Date: Time:

Analysis (Name / Lab): Date: Time:

QA/QC Review (Name / Lab): Date: Time:

Archived / Released: QA/QC InterLAB Use: Date: Time:

Page 1 of 5

R2405408 5
Stohl Environmental
Lancaster CSD - Hillview Elementary

Stohl ENVIRONMENTAL

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) ALS

STOHL Job # 2023-104.6

Client: Lancaster CSD Contact: Michael Bryniarski

Building: Hillview Elementary Location: 11 Pleasantview Dr Lancaster, NY 14086

LEAD		Turnaround
Water by 200.8	X	10 Days

Sample #	Location	Outlet Type	Time
104.6-18	Room 7 Main	Bubbler	23:18
104.6-19	Room 3 Main	Sink	23:19
104.6-20	Room 3 Main	Bubbler	23:20
104.6-21	Room 3 Lav	Sink	23:21
104.6-22	Room 6 Main	Sink	23:22
104.6-23	Room 6 Main	Bubbler	23:23
104.6-24	Room 5 Main	Sink	23:24
104.6-25	Room 5 Main	Bubbler	23:25
104.6-26	Room 5 Lav	Sink	23:26
104.6-27	Room 4 Main	Sink	23:27
104.6-28	Room 4 Main	Bubbler	23:28
104.6-29	Room 4 Lav	Sink	23:29
104.6-30	Room 44 Fac Lav Right	Sink	23:30
104.6-31	Room 44 Fac Lav Left	Sink	23:31
104.6-32	Room 9 Main	Sink	23:32
104.6-33	Room 9 Main	Bubbler	23:33
104.6-34	Room 9 Lav	Sink	23:34
104.6-35	Nurse Main	Sink	23:35

Notes:
Please e-mail lab results to labs@stohlenv.com Rfranjoine@stohlenvironmental.com

Sampled By: Drew Theal Print Name Stohl Env: Drew Theal Date: 6/7/2024

Relinquished By: Rebecca Franjoine Print Name Stohl Env: Rebecca Franjoine Date: 6/12/2024

Received (Name / Lab): Date: Time: 6/12/24 1300

Sample Login (Name / Lab): Date: Time:

Analysis (Name / Lab): Date: Time:

QA/QC Review (Name / Lab): Date: Time:

Archived / Released: QA/QC InterLAB Use: Date: Time:

Page 2 of 5

R2405408 5
Stohl Environmental
Lancaster CSD - Hillview Elementary

R2405408 5
Stohl Environmental
Lancaster CSD - Hillview Elementary

Cooler Receipt and Preservation Check Form

Project/Client STOHL Folder Number

Cooler received on 6/12/24 by: [illegible] COURIER: (ALS) UPS FEDEX VELOCITY CLIENT

1	Were **Custody seals** on outside of cooler?	Y (N)	5a	Did **VOA** vials have sig* **bubbles?**	Y N (NA)
2	**Custody papers** properly completed (ink, signed)?	(Y) N	5b	Sig* bubbles: **Alk?** Y N (NA) **Sulfide?**	Y N (NA)
3	Did all bottles arrive in good **condition** (unbroken)?	(Y) N	6	Where did the bottles originate?	(ALS/ROC) CLIENT
4	Circle: **Wet Ice Dry Ice Gel packs** present?	(Y) N	7	Soil VOA received as: Bulk Encore 5035set	(NA)

8. Temperature Readings Date: 6/12 Time: 1300 ID: IR#12 (IR#1) From: Temp Blank (Sample Bottle)

Temp (°C)	20.7						
Within 0-6°C?	Y (N)	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule

&Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SHO by [illegible] on 6/12 at 1315
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 6/18/24 Time: 1042 by: SES.

9. Were all bottle labels complete (*i.e.* analysis, preservation, etc.)? YES (NO) no date/time
10. Did all bottle labels and tags agree with custody papers? YES (NO)
11. Were correct containers used for the tests indicated? (YES) NO
12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO (N/A)
13. Were dissolved metals filtered in the field? YES NO (N/A)
14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated (N/A)

pH	Lot of test paper	Reagent	Preserved? Yes	Preserved? No	Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
≥12		NaOH								
≤2		HNO_3								
≤2		H_2SO_4								
<4		$NaHSO_4$								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add $Na_2S_2O_3$ (625, 608, CN), ascorbic (phenol).					
		$Na_2S_2O_3$								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 440522000
Explain all Discrepancies/ Other Comments:

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: SES *significant air bubbles: VOA > 5-6 mm : WC >1 in. diameter

P:\INTRANET\QAQC\Forms Controlled\Cooler Receipt r21.doc 05/17/2024

Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

REPORT QUALIFIERS AND DEFINITIONS

U	Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
J	Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Arclors).
B	Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
E	Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
E	Organics- Concentration has exceeded the calibration range for that specific analysis.
D	Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
*	Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
H	Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
#	Spike was diluted out.
+	Correlation coefficient for MSA is <0.995.
N	Inorganics- Matrix spike recovery was outside laboratory limits.
N	Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
S	Concentration has been determined using Method of Standard Additions (MSA).
W	Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
P	Concentration >40% difference between the two GC columns.
C	Confirmed by GC/MS
Q	DoD reports: indicates a pesticide/Aroclor is not confirmed (≥100% Difference between two GC columns).
X	See Case Narrative for discussion.
MRL LOQ	Method Reporting Limit. Also known as: Limit of Quantitation (LOQ) The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
MDL	Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
LOD	Limit of Detection. A value at or above the MDL which has been verified to be detectable.
ND	Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations[1]

NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

[1] Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

Client: Stohl Environmental **Service Request:** R2405408
Project: Lancaster CSD - Hillview Elementary/2023-104.6

Sample Name: 104.6-1 **Date Collected:** 06/7/24
Lab Code: R2405408-001 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-2 **Date Collected:** 06/7/24
Lab Code: R2405408-002 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-3 **Date Collected:** 06/7/24
Lab Code: R2405408-003 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-4 **Date Collected:** 06/7/24
Lab Code: R2405408-004 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-5 **Date Collected:** 06/7/24
Lab Code: R2405408-005 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Client: Stohl Environmental **Service Request:** R2405408
Project: Lancaster CSD - Hillview Elementary/2023-104.6

Sample Name: 104.6-6 **Date Collected:** 06/7/24
Lab Code: R2405408-006 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-7 **Date Collected:** 06/7/24
Lab Code: R2405408-007 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-8A **Date Collected:** 06/7/24
Lab Code: R2405408-008 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-8B **Date Collected:** 06/7/24
Lab Code: R2405408-009 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-9 **Date Collected:** 06/7/24
Lab Code: R2405408-010 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Client: Stohl Environmental **Service Request:** R2405408
Project: Lancaster CSD - Hillview Elementary/2023-104.6

Sample Name: 104.6-10 **Date Collected:** 06/7/24
Lab Code: R2405408-011 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-11 **Date Collected:** 06/7/24
Lab Code: R2405408-012 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-12 **Date Collected:** 06/7/24
Lab Code: R2405408-013 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-13 **Date Collected:** 06/7/24
Lab Code: R2405408-014 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-14 **Date Collected:** 06/7/24
Lab Code: R2405408-015 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Client: Stohl Environmental **Service Request:** R2405408
Project: Lancaster CSD - Hillview Elementary/2023-104.6

Sample Name: 104.6-15 **Date Collected:** 06/7/24
Lab Code: R2405408-016 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-16 **Date Collected:** 06/7/24
Lab Code: R2405408-017 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-17 **Date Collected:** 06/7/24
Lab Code: R2405408-018 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-18 **Date Collected:** 06/7/24
Lab Code: R2405408-019 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-19 **Date Collected:** 06/7/24
Lab Code: R2405408-020 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Client: Stohl Environmental **Service Request:** R2405408
Project: Lancaster CSD - Hillview Elementary/2023-104.6

Sample Name: 104.6-20 **Date Collected:** 06/7/24
Lab Code: R2405408-021 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-21 **Date Collected:** 06/7/24
Lab Code: R2405408-022 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-22 **Date Collected:** 06/7/24
Lab Code: R2405408-023 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-23 **Date Collected:** 06/7/24
Lab Code: R2405408-024 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-24 **Date Collected:** 06/7/24
Lab Code: R2405408-025 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Client: Stohl Environmental **Service Request:** R2405408
Project: Lancaster CSD - Hillview Elementary/2023-104.6

Sample Name: 104.6-25 **Date Collected:** 06/7/24
Lab Code: R2405408-026 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-26 **Date Collected:** 06/7/24
Lab Code: R2405408-027 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-27 **Date Collected:** 06/7/24
Lab Code: R2405408-028 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-28 **Date Collected:** 06/7/24
Lab Code: R2405408-029 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-29 **Date Collected:** 06/7/24
Lab Code: R2405408-030 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Client: Stohl Environmental **Service Request:** R2405408
Project: Lancaster CSD - Hillview Elementary/2023-104.6

Sample Name: 104.6-30 **Date Collected:** 06/7/24
Lab Code: R2405408-031 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-31 **Date Collected:** 06/7/24
Lab Code: R2405408-032 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-32 **Date Collected:** 06/7/24
Lab Code: R2405408-033 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-33 **Date Collected:** 06/7/24
Lab Code: R2405408-034 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-34 **Date Collected:** 06/7/24
Lab Code: R2405408-035 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Analyst Summary report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6		

Sample Name:	104.6-35	**Date Collected:**	06/7/24
Lab Code:	R2405408-036	**Date Received:**	06/12/24
Sample Matrix:	Drinking Water		

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7	200.2
200.8	200.2
6010C or 6010D	3005A/3010A
6020A or 6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010C or 6010D	3050B
6020A or 6020B	3050B
6010C or 6010D TCLP (1311) extract	3005A/3010A
6010C or 6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":
For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.

Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:00
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-1	**Basis:**	NA
Lab Code:	R2405408-001		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**7.2**	ug/L	1.0	1	07/08/24 20:00	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:01
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-2	**Basis:**	NA
Lab Code:	R2405408-002		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.3**	ug/L	1.0	1	07/08/24 20:02	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:02
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-3	**Basis:**	NA
Lab Code:	R2405408-003		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**5.5**	ug/L	1.0	1	07/08/24 20:08	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:03
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-4	**Basis:**	NA
Lab Code:	R2405408-004		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.0**	ug/L	1.0	1	07/08/24 20:10	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:04
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-5	**Basis:**	NA
Lab Code:	R2405408-005		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**6.6**	ug/L	1.0	1	07/08/24 20:12	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:05
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-6	**Basis:**	NA
Lab Code:	R2405408-006		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/08/24 20:14	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:06
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-7	**Basis:**	NA
Lab Code:	R2405408-007		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/08/24 20:32	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:07
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-8A	**Basis:**	NA
Lab Code:	R2405408-008		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/08/24 20:38	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:08
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-8B	**Basis:**	NA
Lab Code:	R2405408-009		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/08/24 20:40	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:09
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-9	**Basis:**	NA
Lab Code:	R2405408-010		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/08/24 20:42	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:10
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-10	**Basis:**	NA
Lab Code:	R2405408-011		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/08/24 20:44	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:11
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-11	**Basis:**	NA
Lab Code:	R2405408-012		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**17.6**	ug/L	1.0	1	07/08/24 20:46	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:12
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-12	**Basis:**	NA
Lab Code:	R2405408-013		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/08/24 20:51	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:13
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-13	**Basis:**	NA
Lab Code:	R2405408-014		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/08/24 20:53	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:14
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-14	**Basis:**	NA
Lab Code:	R2405408-015		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**29.4**	ug/L	1.0	1	07/08/24 20:55	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:15
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-15	**Basis:**	NA
Lab Code:	R2405408-016		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/08/24 20:57	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:16
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-16	**Basis:**	NA
Lab Code:	R2405408-017		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/08/24 20:59	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:17
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-17	**Basis:**	NA
Lab Code:	R2405408-018		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/08/24 21:01	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:18
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-18	**Basis:**	NA
Lab Code:	R2405408-019		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/08/24 21:03	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:19
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-19	**Basis:**	NA
Lab Code:	R2405408-020		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.7**	ug/L	1.0	1	07/08/24 21:05	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:20
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-20	**Basis:**	NA
Lab Code:	R2405408-021		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/08/24 21:07	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:21
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-21	**Basis:**	NA
Lab Code:	R2405408-022		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.7**	ug/L	1.0	1	07/08/24 21:09	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:22
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-22	**Basis:**	NA
Lab Code:	R2405408-023		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/08/24 21:14	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:23
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-23	**Basis:**	NA
Lab Code:	R2405408-024		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/08/24 21:16	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:24
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-24	**Basis:**	NA
Lab Code:	R2405408-025		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.6**	ug/L	1.0	1	07/08/24 21:18	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:25
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-25	**Basis:**	NA
Lab Code:	R2405408-026		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.7**	ug/L	1.0	1	07/08/24 21:20	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:26
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-26	**Basis:**	NA
Lab Code:	R2405408-027		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**18.8**	ug/L	1.0	1	07/09/24 17:05	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:27
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-27	**Basis:**	NA
Lab Code:	R2405408-028		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.7**	ug/L	1.0	1	07/09/24 17:07	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:28
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-28	**Basis:**	NA
Lab Code:	R2405408-029		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.8**	ug/L	1.0	1	07/09/24 17:09	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:29
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-29	**Basis:**	NA
Lab Code:	R2405408-030		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**5.4**	ug/L	1.0	1	07/09/24 17:11	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:30
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-30	**Basis:**	NA
Lab Code:	R2405408-031		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.2**	ug/L	1.0	1	07/09/24 17:12	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:31
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-31	**Basis:**	NA
Lab Code:	R2405408-032		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.6**	ug/L	1.0	1	07/09/24 17:14	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:32
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-32	**Basis:**	NA
Lab Code:	R2405408-033		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.9**	ug/L	1.0	1	07/09/24 17:20	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:33
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-33	**Basis:**	NA
Lab Code:	R2405408-034		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**6.3**	ug/L	1.0	1	07/09/24 17:22	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:34
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-34	**Basis:**	NA
Lab Code:	R2405408-035		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/09/24 17:24	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:35
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-35	**Basis:**	NA
Lab Code:	R2405408-036		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.6**	ug/L	1.0	1	07/09/24 17:26	

QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	NA
Sample Matrix:	Drinking Water	**Date Received:**	NA
Sample Name:	Method Blank	**Basis:**	NA
Lab Code:	R2405408-MB1		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/08/24 20:29	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	NA
Sample Matrix:	Drinking Water	**Date Received:**	NA
Sample Name:	Method Blank	**Basis:**	NA
Lab Code:	R2405408-MB2		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/08/24 19:22	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	NA
Sample Matrix:	Drinking Water	**Date Received:**	NA
Sample Name:	Method Blank	**Basis:**	NA
Lab Code:	R2405408-MB3		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/09/24 16:34	

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24
		Date Analyzed:	07/8/24

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	104.6-6	**Units:**	ug/L
Lab Code:	R2405408-006	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike			Duplicate Matrix Spike					
		R2405408-006MS			R2405408-006DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	ND U	21.1	20.0	106	20.8	20.0	104	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24
		Date Analyzed:	07/8/24

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	104.6-7	**Units:**	ug/L
Lab Code:	R2405408-007	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike			Duplicate Matrix Spike					
		R2405408-007MS			R2405408-007DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	ND U	19.8	20.0	99	20.9	20.0	105	70-130	6	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24
		Date Analyzed:	07/8/24

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	104.6-25	**Units:**	ug/L
Lab Code:	R2405408-026	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike			Duplicate Matrix Spike					
		R2405408-026MS			R2405408-026DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	2.7	22.9	20.0	101	23.2	20.0	102	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24
		Date Analyzed:	07/9/24

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	104.6-35	**Units:**	ug/L
Lab Code:	R2405408-036	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike			Duplicate Matrix Spike					
		R2405408-036MS			R2405408-036DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	3.6	24.5	20.0	105	23.4	20.0	99	70-130	5	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Analyzed:**	07/08/24
Sample Matrix:	Drinking Water		

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2405408-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.5	20.0	103	85-115

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Analyzed:**	07/08/24
Sample Matrix:	Drinking Water		

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2405408-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.3	20.0	101	85-115

Client:	Stohl Environmental	**Service Request:**	R2405408
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Analyzed:**	07/09/24
Sample Matrix:	Drinking Water		

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2405408-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.2	20.0	106	85-115

July 10, 2024 Service Request No:R2405409

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Lancaster CSD - Hillview Elementary

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory June 12, 2024
For your reference, these analyses have been assigned our service request number **R2405409.**

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental



Meghan Pedro
Project Manager

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | FAX +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental

Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Lancaster CSD - Hillview Elementary
Sample Matrix: Drinking Water

Service Request: R2405409
Date Received: 06/12/2024

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 06/12/2024. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

Approved by _____ Date 07/10/2024

SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 104.6-36			Lab ID: R2405409-001			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	7.5			1.0	ug/L	200.8

CLIENT ID: 104.6-37			Lab ID: R2405409-002			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.6			1.0	ug/L	200.8

CLIENT ID: 104.6-38			Lab ID: R2405409-003			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	2.1			1.0	ug/L	200.8

CLIENT ID: 104.6-39			Lab ID: R2405409-004			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.5			1.0	ug/L	200.8

CLIENT ID: 104.6-42			Lab ID: R2405409-007			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	2.7			1.0	ug/L	200.8

CLIENT ID: 104.6-43			Lab ID: R2405409-008			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	5.3			1.0	ug/L	200.8

CLIENT ID: 104.6-44			Lab ID: R2405409-009			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	3.2			1.0	ug/L	200.8

CLIENT ID: 104.6-45			Lab ID: R2405409-010			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.3			1.0	ug/L	200.8

CLIENT ID: 104.6-48			Lab ID: R2405409-013			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.7			1.0	ug/L	200.8

CLIENT ID: 104.6-49			Lab ID: R2405409-014			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.7			1.0	ug/L	200.8

CLIENT ID: 104.6-50			Lab ID: R2405409-015			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	2.6			1.0	ug/L	200.8

CLIENT ID: 104.6-51			Lab ID: R2405409-016			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	2.1			1.0	ug/L	200.8

SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 104.6-52			Lab ID: R2405409-017			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	7.7			1.0	ug/L	200.8

CLIENT ID: 104.6-53			Lab ID: R2405409-018			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	6.0			1.0	ug/L	200.8

CLIENT ID: 104.6-54			Lab ID: R2405409-019			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	3.7			1.0	ug/L	200.8

CLIENT ID: 104.6-55			Lab ID: R2405409-020			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.6			1.0	ug/L	200.8

CLIENT ID: 104.6-56			Lab ID: R2405409-021			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	3.2			1.0	ug/L	200.8

CLIENT ID: 104.6-57			Lab ID: R2405409-022			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.6			1.0	ug/L	200.8

CLIENT ID: 104.6-58			Lab ID: R2405409-023			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	3.8			1.0	ug/L	200.8

CLIENT ID: 104.6-59			Lab ID: R2405409-024			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	2.8			1.0	ug/L	200.8

CLIENT ID: 104.6-60			Lab ID: R2405409-025			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	3.6			1.0	ug/L	200.8

CLIENT ID: 104.6-61			Lab ID: R2405409-026			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	4.5			1.0	ug/L	200.8

CLIENT ID: 104.6-63			Lab ID: R2405409-029			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	7.3			1.0	ug/L	200.8

CLIENT ID: 104.6-64			Lab ID: R2405409-030			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	24.2			1.0	ug/L	200.8

SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 104.6-67			Lab ID: R2405409-031			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	5.3			1.0	ug/L	200.8

CLIENT ID: 104.6-70			Lab ID: R2405409-033			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	2.1			1.0	ug/L	200.8

CLIENT ID: 104.6-72			Lab ID: R2405409-035			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.0			1.0	ug/L	200.8

CLIENT ID: 104.6-74			Lab ID: R2405409-036			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	5.6			1.0	ug/L	200.8

Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental **Service Request:**R2405409
Project: Lancaster CSD - Hillview Elementary/2023-104.6

SAMPLE CROSS-REFERENCE

SAMPLE #	CLIENT SAMPLE ID	DATE	TIME
R2405409-001	104.6-36	6/7/2024	2336
R2405409-002	104.6-37	6/7/2024	2337
R2405409-003	104.6-38	6/7/2024	2338
R2405409-004	104.6-39	6/7/2024	2339
R2405409-005	104.6-40	6/7/2024	2340
R2405409-006	104.6-41	6/7/2024	2341
R2405409-007	104.6-42	6/7/2024	2342
R2405409-008	104.6-43	6/7/2024	2343
R2405409-009	104.6-44	6/7/2024	2344
R2405409-010	104.6-45	6/7/2024	2345
R2405409-011	104.6-46A	6/7/2024	2346
R2405409-012	104.6-46B	6/7/2024	2347
R2405409-013	104.6-48	6/7/2024	2348
R2405409-014	104.6-49	6/7/2024	2349
R2405409-015	104.6-50	6/7/2024	2350
R2405409-016	104.6-51	6/7/2024	2351
R2405409-017	104.6-52	6/7/2024	2352
R2405409-018	104.6-53	6/7/2024	2353
R2405409-019	104.6-54	6/7/2024	2354
R2405409-020	104.6-55	6/7/2024	2355
R2405409-021	104.6-56	6/7/2024	2356
R2405409-022	104.6-57	6/7/2024	2357
R2405409-023	104.6-58	6/7/2024	2358
R2405409-024	104.6-59	6/7/2024	2359
R2405409-025	104.6-60	6/7/2024	0000
R2405409-026	104.6-61	6/7/2024	0001
R2405409-027	104.6-62A	6/7/2024	0002
R2405409-028	104.6-62B	6/7/2024	0003
R2405409-029	104.6-63	6/7/2024	0004
R2405409-030	104.6-64	6/7/2024	0005
R2405409-031	104.6-67	6/7/2024	0006
R2405409-032	104.6-69	6/7/2024	0007
R2405409-033	104.6-70	6/7/2024	0008
R2405409-034	104.6-71	6/7/2024	0009
R2405409-035	104.6-72	6/7/2024	0010
R2405409-036	104.6-74	6/7/2024	0011

Stohl ENVIRONMENTAL
3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) ALS

STOHL Job # 2023-104.6

Client: Lancaster CSD Contact: Michael Bryniarski

Building: Hillview Elementary Location: 11 Pleasantview Dr Lancaster, NY 14086

LEAD		Turnaround
Water by 200.8	X	10 Days

Sample #	Location	Outlet Type	Time
104.6-36	Nurse Exam	Sink	23:36
104.6-37	Nurse Lav	Sink	23:37
104.6-38	Room 10	Sink	23:38
104.6-39	Room 10	Bubbler	23:39
104.6-40	Room 32 Art Main Left	Sink	23:40
104.6-41	Room 32 Art Main Right	Sink	23:41
104.6-42	Room 32 Art Office Left	Sink	23:42
104.6-43	Room 32 Art Office Right	Sink	23:43
104.6-44	Main Hallway Boys Lav Left	Sink	23:44
104.6-45	Main Hallway Boys Lav Right	Sink	23:45
104.6-46A	Main Hallway Fountain	Drinking Fountain	23:46
104.6-46B	Main Hallway Fountain	Bottle Fill	23:47
104.6-48	2nd Wing Girls Lav Center	Sink	23:48
104.6-49	2nd Wing Girls Lav Right	Sink	23:49
104.6-50	Room 16 Main	Sink	23:50
104.6-51	Room 16 Main	Bubbler	23:51
104.6-52	Room 11	Sink	23:52
104.6-53	Room 11	Bubbler	23:53

Notes:
Please e-mail lab results to labs@stohlenv.com

Rfranjoine@stohlenvironmental.com

Sampled By: Drew Theal Print Name Stohl Env: Drew Theal Date: 6/7/2024

Relinquished By: Rebecca Franjoine Print Name Stohl Env: Rebecca Franjoine Date: 6/12/2024

Received (Name / Lab): Date: Time:

Sample Login (Name / Lab): Date: Time:

Analysis (Name / Lab): Date: Time:

QA/QC Review (Name / Lab): Date: Time:

Archived / Released: QA/QC InterLAB Use: Date: Time:

R2405409 5
Stohl Environmental
Lancaster CSD - Hillview Elementary

Stohl ENVIRONMENTAL
3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) ALS

STOHL Job # 2023-104.6

Client: Lancaster CSD Contact: Michael Bryniarski

Building: Hillview Elementary Location: 11 Pleasantview Dr Lancaster, NY 14086

LEAD		Turnaround
Water by 200.8	X	10 Days

Sample #	Location	Outlet Type	Time
104.6-54	Room 15	Sink	23:54
104.6-55	Room 15	Bubbler	23:55
104.6-56	Room 12	Sink	23:56
104.6-57	Room 12	Bubbler	23:57
104.6-58	Room 14	Sink	23:58
104.6-59	Room 14	Bubbler	23:59
104.6-60	Room 13	Sink	0:00
104.6-61	Room 13	Bubbler	0:01
104.6-62A	Gym Hall Fountain	Drinking Fountain	0:02
104.6-62B	Gym Hall Fountain	Bottle Fill	0:03
104.6-63	Girls Locker Coach Office	Sink	0:04
104.6-64	Girls Locker Room	Sink	0:05
104.6-67	Boys Gym Office	Sink	0:06
104.6-69	Fac Lav by Media Center	Sink	0:07
104.6-70	Fountain by Media Center	Drinking Fountain	0:08
104.6-71	Media Center	Sink	0:09
104.6-72	Room 26	Sink	0:10
104.6-74	Room 17	Sink	0:11

Notes:
Please e-mail lab results to labs@stohlenv.com Rfranjoine@stohlenvironmental.com

Sampled By: Drew Theal Print Name Stohl Env: Drew Theal Date: 6/7/2024

Relinquished By: Rebecca Franjoine Print Name Stohl Env: Rebecca Franjoine Date: 6/12/2024

Received (Name / Lab): Date: Time:

Sample Login (Name / Lab): Date: Time:

Analysis (Name / Lab): Date: Time:

QA/QC Review (Name / Lab): Date: Time:

Archived / Released: QA/QC InterLAB Use: Date: Time:

R2405409 5
Stohl Environmental
Lancaster CSD - Hillview Elementary

R2405409 5
Stohl Environmental
Lancaster CSD - Hillview Elementary

Cooler Receipt and Preservation Check Form

Project/Client STOHL Folder Number

Cooler received on 6/12/24 by: [illegible] COURIER: (ALS) UPS FEDEX VELOCITY CLIENT

1	Were **Custody seals** on outside of cooler?	Y (N)	5a	Did **VOA** vials have sig* **bubbles?**		Y N (NA)
2	**Custody papers** properly completed (ink, signed)?	(Y) N	5b	Sig* bubbles: **Alk?**	Y N (NA)	**Sulfide?** Y N (NA)
3	Did all bottles arrive in good **condition** (unbroken)?	(Y) N	6	Where did the bottles originate?	(ALS/ROC) CLIENT	
4	Circle: **Wet Ice Dry Ice Gel packs** present?	(Y) N	7	Soil VOA received as:	Bulk Encore 5035set (NA)	

8. Temperature Readings Date: 6/12 Time: 1300 ID: IR#12 (IR#1) From: Temp Blank (Sample Bottle)

Temp (°C)	20.7						
Within 0-6°C?	Y (N)	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule

&Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SR0 by [illegible] on 6/12 at 1315
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 6/18/24 Time: 1133 by: SES

9. Were all bottle labels complete (*i.e.* analysis, preservation, etc.)? YES (NO) no date/time
10. Did all bottle labels and tags agree with custody papers? YES (NO)
11. Were correct containers used for the tests indicated? (YES) NO
12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO (N/A)
13. Were dissolved metals filtered in the field? YES NO (N/A)
14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated (N/A)

pH	Lot of test paper	Reagent	Preserved? Yes	Preserved? No	Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
≥12		NaOH								
≤2		HNO_3								
≤2		H_2SO_4								
<4		$NaHSO_4$								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add $Na_2S_2O_3$ (625, 608, CN), ascorbic (phenol).					
		$Na_2S_2O_3$								
		ZnAcetate	-	-			**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).			
		HCl	**	**						

Bottle lot numbers: 440522300

Explain all Discrepancies/ Other Comments:

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: SES *significant air bubbles: VOA > 5-6 mm : WC >1 in. diameter

P:\INTRANET\QAQC\Forms Controlled\Cooler Receipt r21.doc 05/17/2024

Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

REPORT QUALIFIERS AND DEFINITIONS

U	Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
J	Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Arclors).
B	Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
E	Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
E	Organics- Concentration has exceeded the calibration range for that specific analysis.
D	Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
*	Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
H	Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
#	Spike was diluted out.
+	Correlation coefficient for MSA is <0.995.
N	Inorganics- Matrix spike recovery was outside laboratory limits.
N	Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
S	Concentration has been determined using Method of Standard Additions (MSA).
W	Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
P	Concentration >40% difference between the two GC columns.
C	Confirmed by GC/MS
Q	DoD reports: indicates a pesticide/Aroclor is not confirmed (≥100% Difference between two GC columns).
X	See Case Narrative for discussion.
MRL LOQ	Method Reporting Limit. Also known as: Limit of Quantitation (LOQ) The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
MDL	Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
LOD	Limit of Detection. A value at or above the MDL which has been verified to be detectable.
ND	Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations[1]

NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

[1] Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

Client: Stohl Environmental **Service Request:** R2405409
Project: Lancaster CSD - Hillview Elementary/2023-104.6

Sample Name: 104.6-36 **Date Collected:** 06/7/24
Lab Code: R2405409-001 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-37 **Date Collected:** 06/7/24
Lab Code: R2405409-002 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-38 **Date Collected:** 06/7/24
Lab Code: R2405409-003 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-39 **Date Collected:** 06/7/24
Lab Code: R2405409-004 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-40 **Date Collected:** 06/7/24
Lab Code: R2405409-005 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Client: Stohl Environmental **Service Request:** R2405409
Project: Lancaster CSD - Hillview Elementary/2023-104.6

Sample Name: 104.6-41 **Date Collected:** 06/7/24
Lab Code: R2405409-006 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-42 **Date Collected:** 06/7/24
Lab Code: R2405409-007 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-43 **Date Collected:** 06/7/24
Lab Code: R2405409-008 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-44 **Date Collected:** 06/7/24
Lab Code: R2405409-009 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-45 **Date Collected:** 06/7/24
Lab Code: R2405409-010 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Client: Stohl Environmental **Service Request:** R2405409
Project: Lancaster CSD - Hillview Elementary/2023-104.6

Sample Name: 104.6-46A **Date Collected:** 06/7/24
Lab Code: R2405409-011 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-46B **Date Collected:** 06/7/24
Lab Code: R2405409-012 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-48 **Date Collected:** 06/7/24
Lab Code: R2405409-013 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-49 **Date Collected:** 06/7/24
Lab Code: R2405409-014 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-50 **Date Collected:** 06/7/24
Lab Code: R2405409-015 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Client: Stohl Environmental **Service Request:** R2405409
Project: Lancaster CSD - Hillview Elementary/2023-104.6

Sample Name: 104.6-51 **Date Collected:** 06/7/24
Lab Code: R2405409-016 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-52 **Date Collected:** 06/7/24
Lab Code: R2405409-017 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-53 **Date Collected:** 06/7/24
Lab Code: R2405409-018 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-54 **Date Collected:** 06/7/24
Lab Code: R2405409-019 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-55 **Date Collected:** 06/7/24
Lab Code: R2405409-020 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6		

Sample Name:	104.6-56	**Date Collected:**	06/7/24
Lab Code:	R2405409-021	**Date Received:**	06/12/24
Sample Matrix:	Drinking Water		

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name:	104.6-57	**Date Collected:**	06/7/24
Lab Code:	R2405409-022	**Date Received:**	06/12/24
Sample Matrix:	Drinking Water		

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name:	104.6-58	**Date Collected:**	06/7/24
Lab Code:	R2405409-023	**Date Received:**	06/12/24
Sample Matrix:	Drinking Water		

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name:	104.6-59	**Date Collected:**	06/7/24
Lab Code:	R2405409-024	**Date Received:**	06/12/24
Sample Matrix:	Drinking Water		

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name:	104.6-60	**Date Collected:**	06/7/24
Lab Code:	R2405409-025	**Date Received:**	06/12/24
Sample Matrix:	Drinking Water		

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Client: Stohl Environmental **Service Request:** R2405409
Project: Lancaster CSD - Hillview Elementary/2023-104.6

Sample Name: 104.6-61 **Date Collected:** 06/7/24
Lab Code: R2405409-026 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-62A **Date Collected:** 06/7/24
Lab Code: R2405409-027 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-62B **Date Collected:** 06/7/24
Lab Code: R2405409-028 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-63 **Date Collected:** 06/7/24
Lab Code: R2405409-029 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-64 **Date Collected:** 06/7/24
Lab Code: R2405409-030 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Client: Stohl Environmental **Service Request:** R2405409
Project: Lancaster CSD - Hillview Elementary/2023-104.6

Sample Name: 104.6-67 **Date Collected:** 06/7/24
Lab Code: R2405409-031 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-69 **Date Collected:** 06/7/24
Lab Code: R2405409-032 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-70 **Date Collected:** 06/7/24
Lab Code: R2405409-033 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-71 **Date Collected:** 06/7/24
Lab Code: R2405409-034 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-72 **Date Collected:** 06/7/24
Lab Code: R2405409-035 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6		

Sample Name:	104.6-74	**Date Collected:**	06/7/24
Lab Code:	R2405409-036	**Date Received:**	06/12/24
Sample Matrix:	Drinking Water		

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7	200.2
200.8	200.2
6010C or 6010D	3005A/3010A
6020A or 6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010C or 6010D	3050B
6020A or 6020B	3050B
6010C or 6010D TCLP (1311) extract	3005A/3010A
6010C or 6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":
For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.

Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:36
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-36	**Basis:**	NA
Lab Code:	R2405409-001		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**7.5**	ug/L	1.0	1	07/09/24 17:44	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:37
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-37	**Basis:**	NA
Lab Code:	R2405409-002		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.6**	ug/L	1.0	1	07/09/24 17:50	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:38
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-38	**Basis:**	NA
Lab Code:	R2405409-003		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.1**	ug/L	1.0	1	07/09/24 17:52	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:39
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-39	**Basis:**	NA
Lab Code:	R2405409-004		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.5**	ug/L	1.0	1	07/09/24 17:54	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:40
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-40	**Basis:**	NA
Lab Code:	R2405409-005		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/09/24 17:56	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:41
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-41	**Basis:**	NA
Lab Code:	R2405409-006		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/09/24 17:58	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:42
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-42	**Basis:**	NA
Lab Code:	R2405409-007		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.7**	ug/L	1.0	1	07/09/24 18:03	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:43
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-43	**Basis:**	NA
Lab Code:	R2405409-008		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**5.3**	ug/L	1.0	1	07/09/24 18:05	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:44
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-44	**Basis:**	NA
Lab Code:	R2405409-009		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.2**	ug/L	1.0	1	07/09/24 18:07	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:45
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-45	**Basis:**	NA
Lab Code:	R2405409-010		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.3**	ug/L	1.0	1	07/09/24 18:09	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:46
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-46A	**Basis:**	NA
Lab Code:	R2405409-011		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/09/24 18:11	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:47
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-46B	**Basis:**	NA
Lab Code:	R2405409-012		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/09/24 18:13	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:48
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-48	**Basis:**	NA
Lab Code:	R2405409-013		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.7**	ug/L	1.0	1	07/09/24 18:15	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:49
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-49	**Basis:**	NA
Lab Code:	R2405409-014		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.7**	ug/L	1.0	1	07/09/24 18:16	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:50
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-50	**Basis:**	NA
Lab Code:	R2405409-015		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.6**	ug/L	1.0	1	07/09/24 18:18	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:51
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-51	**Basis:**	NA
Lab Code:	R2405409-016		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.1**	ug/L	1.0	1	07/09/24 18:20	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:52
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-52	**Basis:**	NA
Lab Code:	R2405409-017		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**7.7**	ug/L	1.0	1	07/09/24 18:26	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:53
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-53	**Basis:**	NA
Lab Code:	R2405409-018		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**6.0**	ug/L	1.0	1	07/09/24 18:28	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:54
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-54	**Basis:**	NA
Lab Code:	R2405409-019		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.7**	ug/L	1.0	1	07/09/24 18:30	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:55
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-55	**Basis:**	NA
Lab Code:	R2405409-020		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.6**	ug/L	1.0	1	07/09/24 18:32	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:56
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-56	**Basis:**	NA
Lab Code:	R2405409-021		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.2**	ug/L	1.0	1	07/09/24 18:51	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:57
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-57	**Basis:**	NA
Lab Code:	R2405409-022		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.6**	ug/L	1.0	1	07/09/24 18:56	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:58
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-58	**Basis:**	NA
Lab Code:	R2405409-023		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.8**	ug/L	1.0	1	07/09/24 18:58	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 23:59
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-59	**Basis:**	NA
Lab Code:	R2405409-024		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.8**	ug/L	1.0	1	07/09/24 19:00	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:00
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-60	**Basis:**	NA
Lab Code:	R2405409-025		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.6**	ug/L	1.0	1	07/09/24 19:02	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:01
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-61	**Basis:**	NA
Lab Code:	R2405409-026		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**4.5**	ug/L	1.0	1	07/09/24 19:04	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:02
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-62A	**Basis:**	NA
Lab Code:	R2405409-027		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/09/24 19:10	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:03
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-62B	**Basis:**	NA
Lab Code:	R2405409-028		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/09/24 19:11	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:04
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-63	**Basis:**	NA
Lab Code:	R2405409-029		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**7.3**	ug/L	1.0	1	07/09/24 19:13	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:05
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-64	**Basis:**	NA
Lab Code:	R2405409-030		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**24.2**	ug/L	1.0	1	07/09/24 19:15	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:06
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-67	**Basis:**	NA
Lab Code:	R2405409-031		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**5.3**	ug/L	1.0	1	07/09/24 19:17	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:07
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-69	**Basis:**	NA
Lab Code:	R2405409-032		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/09/24 19:19	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:08
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-70	**Basis:**	NA
Lab Code:	R2405409-033		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.1**	ug/L	1.0	1	07/09/24 19:21	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:09
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-71	**Basis:**	NA
Lab Code:	R2405409-034		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/09/24 19:23	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:10
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-72	**Basis:**	NA
Lab Code:	R2405409-035		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.0**	ug/L	1.0	1	07/09/24 19:25	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:11
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-74	**Basis:**	NA
Lab Code:	R2405409-036		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**5.6**	ug/L	1.0	1	07/09/24 19:27	

QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	NA
Sample Matrix:	Drinking Water	**Date Received:**	NA
Sample Name:	Method Blank	**Basis:**	NA
Lab Code:	R2405409-MB1		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/09/24 18:47	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	NA
Sample Matrix:	Drinking Water	**Date Received:**	NA
Sample Name:	Method Blank	**Basis:**	NA
Lab Code:	R2405409-MB2		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/09/24 17:41	

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24
		Date Analyzed:	07/9/24

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	104.6-36	**Units:**	ug/L
Lab Code:	R2405409-001	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike			Duplicate Matrix Spike					
		R2405409-001MS			R2405409-001DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	7.5	28.7	20.0	106	28.2	20.0	104	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24
		Date Analyzed:	07/9/24

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	104.6-55	**Units:**	ug/L
Lab Code:	R2405409-020	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike			Duplicate Matrix Spike					
		R2405409-020MS			R2405409-020DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	1.6	21.5	20.0	100	21.9	20.0	102	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24
		Date Analyzed:	07/9/24

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	104.6-56	**Units:**	ug/L
Lab Code:	R2405409-021	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike			Duplicate Matrix Spike					
		R2405409-021MS			R2405409-021DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	3.2	23.9	20.0	103	25.5	20.0	112	70-130	7	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Analyzed:**	07/09/24
Sample Matrix:	Drinking Water		

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2405409-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.5	20.0	107	85-115

Client:	Stohl Environmental	**Service Request:**	R2405409
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Analyzed:**	07/09/24
Sample Matrix:	Drinking Water		

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2405409-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.8	20.0	104	85-115

July 10, 2024 Service Request No:R2405410

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Lancaster CSD - Hillview Elementary

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory June 12, 2024
For your reference, these analyses have been assigned our service request number **R2405410.**

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental



Meghan Pedro
Project Manager

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | FAX +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental

Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Lancaster CSD - Hillview Elementary
Sample Matrix: Drinking Water

Service Request: R2405410
Date Received: 06/12/2024

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Sixteen drinking water samples were received for analysis at ALS Environmental on 06/12/2024. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

Approved by _____ Date 07/10/2024

SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 104.6-76			Lab ID: R2405410-001			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	2.0			1.0	ug/L	200.8

CLIENT ID: 104.6-78			Lab ID: R2405410-002			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	2.3			1.0	ug/L	200.8

CLIENT ID: 104.6-80			Lab ID: R2405410-003			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.7			1.0	ug/L	200.8

CLIENT ID: 104.6-81			Lab ID: R2405410-004			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.3			1.0	ug/L	200.8

CLIENT ID: 104.6-83			Lab ID: R2405410-007			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.2			1.0	ug/L	200.8

CLIENT ID: 104.6-86			Lab ID: R2405410-010			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	3.0			1.0	ug/L	200.8

CLIENT ID: 104.6-88			Lab ID: R2405410-011			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	2.3			1.0	ug/L	200.8

CLIENT ID: 104.6-90			Lab ID: R2405410-012			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	2.7			1.0	ug/L	200.8

CLIENT ID: 104.6-92			Lab ID: R2405410-013			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	3.7			1.0	ug/L	200.8

CLIENT ID: 104.6-94			Lab ID: R2405410-014			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.8			1.0	ug/L	200.8

CLIENT ID: 104.6-96			Lab ID: R2405410-015			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	3.7			1.0	ug/L	200.8

CLIENT ID: 104.6-98			Lab ID: R2405410-016			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	10.4			1.0	ug/L	200.8

Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental **Service Request:**R2405410

Project: Lancaster CSD - Hillview Elementary/2023-104.6

SAMPLE CROSS-REFERENCE

SAMPLE #	CLIENT SAMPLE ID	DATE	TIME
R2405410-001	104.6-76	6/7/2024	0012
R2405410-002	104.6-78	6/7/2024	0013
R2405410-003	104.6-80	6/7/2024	0014
R2405410-004	104.6-81	6/7/2024	0015
R2405410-005	104.6-82A	6/7/2024	0016
R2405410-006	104.6-82B	6/7/2024	0017
R2405410-007	104.6-83	6/7/2024	0018
R2405410-008	104.6-84	6/7/2024	0019
R2405410-009	104.6-85	6/7/2024	0020
R2405410-010	104.6-86	6/7/2024	0021
R2405410-011	104.6-88	6/7/2024	0022
R2405410-012	104.6-90	6/7/2024	0023
R2405410-013	104.6-92	6/7/2024	0024
R2405410-014	104.6-94	6/7/2024	0025
R2405410-015	104.6-96	6/7/2024	0026
R2405410-016	104.6-98	6/7/2024	0027

Stohl ENVIRONMENTAL

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) ALS

STOHL Job # 2023-104.6

Client: Lancaster CSD Contact: Michael Bryniarski

Building: Hillview Elementary Location: 11 Pleasantview Dr Lancaster, NY 14086

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
104.6-76	Room 25	Sink	0:12
104.6-78	Room 18	Sink	0:13
104.6-80	3rd Wing Girls Lav Left	Sink	0:14
104.6-81	3rd Wing Girls Lav Right	Sink	0:15
104.6-82A	3rd Wing Fountain	Drinking Fountain	0:16
104.6-82B	3rd Wing Fountain	Bottle Fill	0:17
104.6-83	3rd Wing Boys Lav Left	Sink	0:18
104.6-84	3rd Wing Boys Lav center	Sink	0:19
104.6-85	3rd Wing Boys Lav Right	Sink	0:20
104.6-86	Room 24	Sink	0:21
104.6-88	Room 19	Sink	0:22
104.6-90	Room 23	Sink	0:23
104.6-92	Room 20	Sink	0:24
104.6-94	Room 22	Sink	0:25
104.6-96	Room 21	Sink	0:26
104.6-98	Basement	Sink	0:27

Notes:
Please e-mail lab results to labs@stohlenv.com Rfranjoine@stohlenvironmental.com

Sampled By: Drew Theal Print Name Stohl Env: Drew Theal Date: 6/7/2024

Relinquished By: Rebecca Franjoine Print Name Stohl Env: Rebecca Franjoine Date: 6/12/2024

Received (Name / Lab): Date: Time: 6/12/24 1300

Sample Login (Name / Lab): Date: Time:

Analysis (Name / Lab): Date: Time:

QA/QC Review (Name / Lab): Date: Time:

Archived / Released: QA/QC InterLAB Use: Date: Time:

Page 5 of 5

R2405410 5
Stohl Environmental
Lancaster CSD - Hillview Elementary

R2405410 5
Stohl Environmental
Lancaster CSD - Hillview Elementary

Cooler Receipt and Preservation Check Form

Project/Client STOHL Folder Number

Cooler received on 6/12/24 by: [illegible] COURIER: (ALS) UPS FEDEX VELOCITY CLIENT

1	Were **Custody seals** on outside of cooler?	Y (N)	5a	Did **VOA** vials have sig* **bubbles?**	Y N (NA)
2	**Custody papers** properly completed (ink, signed)?	(Y) N	5b	Sig* bubbles: **Alk?** Y N (NA) **Sulfide?**	Y N (NA)
3	Did all bottles arrive in good **condition** (unbroken)?	(Y) N	6	Where did the bottles originate?	(ALS/ROC) CLIENT
4	Circle: **Wet Ice Dry Ice Gel packs** present?	(Y) N	7	Soil VOA received as: Bulk Encore 5035set	(NA)

8. Temperature Readings Date: 6/12 Time: 1300 ID: IR#12 (IR#1) From: Temp Blank (Sample Bottle)

Temp (°C)	20.7						
Within 0-6°C?	Y (N)	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: Ice melted Poorly Packed (described below) Same Day Rule

&Client Approval to Run Samples: Standing Approval Client aware at drop-off Client notified by:

All samples held in storage location: SR0 by [illegible] on 6/12 at 1315
5035 samples placed in storage location: by on at within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 6/18/24 Time: 1140 by: SES

9. Were all bottle labels complete (*i.e.* analysis, preservation, etc.)? YES (NO) no date/times
10. Did all bottle labels and tags agree with custody papers? YES (NO)
11. Were correct containers used for the tests indicated? (YES) NO
12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO (N/A)
13. Were dissolved metals filtered in the field? YES NO (N/A)
14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated (N/A)

pH	Lot of test paper	Reagent	Preserved? Yes	Preserved? No	Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
≥12		NaOH								
≤2		HNO_3								
≤2		H_2SO_4								
<4		$NaHSO_4$								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add $Na_2S_2O_3$ (625, 608, CN), ascorbic (phenol).					
		$Na_2S_2O_3$								
		ZnAcetate	-	-			**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).			
		HCl	**	**						

Bottle lot numbers: 4405220000
Explain all Discrepancies/ Other Comments:

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: SES *significant air bubbles: VOA > 5-6 mm : WC >1 in. diameter

P:\INTRANET\QAQC\Forms Controlled\Cooler Receipt r21.doc 05/17/2024

Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

REPORT QUALIFIERS AND DEFINITIONS

U	Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
J	Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Arclors).
B	Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
E	Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
E	Organics- Concentration has exceeded the calibration range for that specific analysis.
D	Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
*	Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
H	Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
#	Spike was diluted out.
+	Correlation coefficient for MSA is <0.995.
N	Inorganics- Matrix spike recovery was outside laboratory limits.
N	Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
S	Concentration has been determined using Method of Standard Additions (MSA).
W	Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
P	Concentration >40% difference between the two GC columns.
C	Confirmed by GC/MS
Q	DoD reports: indicates a pesticide/Aroclor is not confirmed (≥100% Difference between two GC columns).
X	See Case Narrative for discussion.
MRL LOQ	Method Reporting Limit. Also known as: Limit of Quantitation (LOQ) The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
MDL	Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
LOD	Limit of Detection. A value at or above the MDL which has been verified to be detectable.
ND	Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations[1]

NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

[1] Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

Client: Stohl Environmental **Service Request:** R2405410
Project: Lancaster CSD - Hillview Elementary/2023-104.6

Sample Name: 104.6-76 **Date Collected:** 06/7/24
Lab Code: R2405410-001 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-78 **Date Collected:** 06/7/24
Lab Code: R2405410-002 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-80 **Date Collected:** 06/7/24
Lab Code: R2405410-003 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-81 **Date Collected:** 06/7/24
Lab Code: R2405410-004 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-82A **Date Collected:** 06/7/24
Lab Code: R2405410-005 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Client: Stohl Environmental **Service Request:** R2405410
Project: Lancaster CSD - Hillview Elementary/2023-104.6

Sample Name: 104.6-82B **Date Collected:** 06/7/24
Lab Code: R2405410-006 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-83 **Date Collected:** 06/7/24
Lab Code: R2405410-007 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-84 **Date Collected:** 06/7/24
Lab Code: R2405410-008 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-85 **Date Collected:** 06/7/24
Lab Code: R2405410-009 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-86 **Date Collected:** 06/7/24
Lab Code: R2405410-010 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Client: Stohl Environmental **Service Request:** R2405410
Project: Lancaster CSD - Hillview Elementary/2023-104.6

Sample Name: 104.6-88 **Date Collected:** 06/7/24
Lab Code: R2405410-011 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-90 **Date Collected:** 06/7/24
Lab Code: R2405410-012 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-92 **Date Collected:** 06/7/24
Lab Code: R2405410-013 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-94 **Date Collected:** 06/7/24
Lab Code: R2405410-014 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Sample Name: 104.6-96 **Date Collected:** 06/7/24
Lab Code: R2405410-015 **Date Received:** 06/12/24
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6		

Sample Name:	104.6-98	**Date Collected:**	06/7/24
Lab Code:	R2405410-016	**Date Received:**	06/12/24
Sample Matrix:	Drinking Water		

Analysis Method	Extracted/Digested By	Analyzed By
200.8		NMANSEN

PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7	200.2
200.8	200.2
6010C or 6010D	3005A/3010A
6020A or 6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010C or 6010D	3050B
6020A or 6020B	3050B
6010C or 6010D TCLP (1311) extract	3005A/3010A
6010C or 6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":
For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.

Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:12
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-76	**Basis:**	NA
Lab Code:	R2405410-001		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.0**	ug/L	1.0	1	07/09/24 19:33	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:13
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-78	**Basis:**	NA
Lab Code:	R2405410-002		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.3**	ug/L	1.0	1	07/09/24 19:34	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:14
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-80	**Basis:**	NA
Lab Code:	R2405410-003		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.7**	ug/L	1.0	1	07/09/24 19:36	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:15
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-81	**Basis:**	NA
Lab Code:	R2405410-004		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.3**	ug/L	1.0	1	07/09/24 19:38	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:16
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-82A	**Basis:**	NA
Lab Code:	R2405410-005		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/09/24 19:57	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:17
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-82B	**Basis:**	NA
Lab Code:	R2405410-006		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/09/24 20:03	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:18
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-83	**Basis:**	NA
Lab Code:	R2405410-007		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.2**	ug/L	1.0	1	07/09/24 20:05	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:19
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-84	**Basis:**	NA
Lab Code:	R2405410-008		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/09/24 20:07	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:20
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-85	**Basis:**	NA
Lab Code:	R2405410-009		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/09/24 20:09	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:21
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-86	**Basis:**	NA
Lab Code:	R2405410-010		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.0**	ug/L	1.0	1	07/09/24 20:11	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:22
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-88	**Basis:**	NA
Lab Code:	R2405410-011		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.3**	ug/L	1.0	1	07/09/24 20:17	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:23
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-90	**Basis:**	NA
Lab Code:	R2405410-012		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.7**	ug/L	1.0	1	07/09/24 20:18	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:24
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-92	**Basis:**	NA
Lab Code:	R2405410-013		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.7**	ug/L	1.0	1	07/09/24 20:20	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:25
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-94	**Basis:**	NA
Lab Code:	R2405410-014		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.8**	ug/L	1.0	1	07/09/24 20:22	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:26
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-96	**Basis:**	NA
Lab Code:	R2405410-015		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**3.7**	ug/L	1.0	1	07/09/24 20:24	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24 00:27
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24 13:00
Sample Name:	104.6-98	**Basis:**	NA
Lab Code:	R2405410-016		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**10.4**	ug/L	1.0	1	07/09/24 20:26	

QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	NA
Sample Matrix:	Drinking Water	**Date Received:**	NA
Sample Name:	Method Blank	**Basis:**	NA
Lab Code:	R2405410-MB1		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/09/24 19:53	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	NA
Sample Matrix:	Drinking Water	**Date Received:**	NA
Sample Name:	Method Blank	**Basis:**	NA
Lab Code:	R2405410-MB2		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/09/24 18:47	

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24
		Date Analyzed:	07/9/24

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	104.6-81	**Units:**	ug/L
Lab Code:	R2405410-004	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike			Duplicate Matrix Spike					
		R2405410-004MS			R2405410-004DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	1.3	21.9	20.0	103	22.3	20.0	105	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Collected:**	06/07/24
Sample Matrix:	Drinking Water	**Date Received:**	06/12/24
		Date Analyzed:	07/9/24

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	104.6-82A	**Units:**	ug/L
Lab Code:	R2405410-005	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike			Duplicate Matrix Spike					
		R2405410-005MS			R2405410-005DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	ND U	21.0	20.0	105	20.8	20.0	104	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Analyzed:**	07/09/24
Sample Matrix:	Drinking Water		

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2405410-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.6	20.0	103	85-115

Client:	Stohl Environmental	**Service Request:**	R2405410
Project:	Lancaster CSD - Hillview Elementary/2023-104.6	**Date Analyzed:**	07/09/24
Sample Matrix:	Drinking Water		

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2405410-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.5	20.0	107	85-115

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER

Expires 12:01 AM April 01, 2025
Issued April 01, 2024

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE
Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. CHRISTINE KUTZER
ALS ENVIRONMENTAL - ROCHESTER
1565 JEFFERSON ROAD BUILDING 300, SUITE 360
ROCHESTER, NY 14623

NY Lab Id No: 10145

is hereby APPROVED as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2016) for the category ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:

Bacteriology	
Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Colilert)
Disinfection By-products	
Bromide	EPA 300.0 Rev. 2.1
Dissolved Gases	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
Fuel Additives	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
Metals I	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4

Serial No.: 68402

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/, by phone (518) 485-5570 or by email to elap@health.ny.gov.

Page 1 of 5