



Environmental and Laboratory Services

Dover Location:

90 1/2 West Blackwell St., Dover, NJ 07801
Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:

8A Railroad Ave, Marlboro, NJ 07746
Phone: (732) 308-3500, Fax (732) 308-3503

Date: June 23, 2022
Client: Stillwater Twp Elementary School
Address: 904 Stillwater Rd
Stillwater Township, NJ 07875

Analytical Results

PWSID#:
Project Location:

Sample Matrix:	Drinking Water	Lab Sample Number:	220606012-001		
Sample Location:	Field Blank	Customer Sample Number:			
Sampled By:	V. Cervantes				
Sample Date/Time:	6/7/2022 6:06				

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/22/2022	16:36	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220606012-002		
Sample Location:	B112-TL	Customer Sample Number:			
Sampled By:	V. Cervantes				
Sample Date/Time:	6/7/2022 5:49				

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	12.7	µg/L	15	6/22/2022	16:14	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220606012-003								
Sample Location: B110 Sink		Customer Sample Number:								
Sampled By: V. Cervantes										
Sample Date/Time: 6/7/2022 5:51										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	6.45	µg/L	15	6/22/2022	16:20	JGW	2	1	

Sample Matrix: Drinking Water		Lab Sample Number: 220606012-004								
Sample Location: B110 3xKC		Customer Sample Number:								
Sampled By: V. Cervantes										
Sample Date/Time: 6/7/2022 5:52										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	7.46	µg/L	15	6/22/2022	16:25	JGW	2	1	

Sample Matrix: Drinking Water		Lab Sample Number: 220606012-005								
Sample Location: B110 1FP		Customer Sample Number:								
Sampled By: V. Cervantes										
Sample Date/Time: 6/7/2022 5:53										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	24.3 **	µg/L	15	6/22/2022	17:01	JGW	4	2	

Sample Matrix: Drinking Water		Lab Sample Number: 220606012-006								
Sample Location: C110 Sink DS		Customer Sample Number:								
Sampled By: V. Cervantes										
Sample Date/Time: 6/7/2022 5:59										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	2.51	µg/L	15	6/22/2022	17:18	JGW	2	1	

Sample Matrix: Drinking Water		Lab Sample Number: 220606012-007								
Sample Location: C110 Water Ftn DS		Customer Sample Number:								
Sampled By: V. Cervantes										
Sample Date/Time: 6/7/2022 6:00										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/22/2022	17:23	JGW	2	1	

Sample Matrix: Drinking Water		Lab Sample Number: 220606012-008								
Sample Location: C111 Sink DS		Customer Sample Number:								
Sampled By: V. Cervantes										
Sample Date/Time: 6/7/2022 5:56										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/22/2022	17:29	JGW	2	1	

Sample Matrix: Drinking Water		Lab Sample Number: 220606012-009								
Sample Location: C111 Water Ftn DS		Customer Sample Number:								
Sampled By: V. Cervantes										
Sample Date/Time: 6/7/2022 5:57										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/22/2022	17:34	JGW	2	1	

Sample Matrix: Drinking Water		Lab Sample Number: 220606012-010								
Sample Location: C114 Water Ftn PBCU2		Customer Sample Number:								
Sampled By: V. Cervantes										
Sample Date/Time: 6/7/2022 5:55										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/22/2022	17:40	JGW	2	1	

Sample Matrix: Drinking Water		Lab Sample Number: 220606012-011							
Sample Location: A124 Water Ftn		Customer Sample Number:							
Sampled By: V. Cervantes									
Sample Date/Time: 6/7/2022 6:02									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/22/2022	17:45	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220606012-012							
Sample Location: A112 Water Ftn		Customer Sample Number:							
Sampled By: V. Cervantes									
Sample Date/Time: 6/7/2022 6:03									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/22/2022	17:51	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220606012-013							
Sample Location: A112 Sink 1 DS		Customer Sample Number:							
Sampled By: V. Cervantes									
Sample Date/Time: 6/7/2022 6:04									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.61	µg/L	15	6/22/2022	18:02	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220606012-014							
Sample Location: A112 Sink 2 DS		Customer Sample Number:							
Sampled By: V. Cervantes									
Sample Date/Time: 6/7/2022 6:05									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	27.8 **	µg/L	15	6/22/2022	18:10	JGW	4	2

Sample Matrix: Drinking Water Lab Sample Number: 220606012-015
 Sample Location: B23 Water Ftn Customer Sample Number:
 Sampled By: V. Cervantes
 Sample Date/Time: 6/7/2022 5:47

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/22/2022	18:32	JGW	2	1

Sample Matrix: Drinking Water Lab Sample Number: 220606012-016
 Sample Location: B&G Water Ftn Customer Sample Number:
 Sampled By: V. Cervantes
 Sample Date/Time: 6/7/2022 5:46

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/22/2022	18:38	JGW	2	1

Sample Matrix: Drinking Water Lab Sample Number: 220606012-017
 Sample Location: B10 Water Ftn Customer Sample Number:
 Sampled By: V. Cervantes
 Sample Date/Time: 6/7/2022 5:44

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	3.91	µg/L	15	6/22/2022	18:44	JGW	2	1

Sample Matrix: Drinking Water Lab Sample Number: 220606012-018
 Sample Location: B10 Sink Customer Sample Number:
 Sampled By: V. Cervantes
 Sample Date/Time: 6/7/2022 5:43

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.07	µg/L	15	6/22/2022	18:49	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220606012-019								
Sample Location: C11 Sink DS		Customer Sample Number:								
Sampled By: V. Cervantes										
Sample Date/Time: 6/7/2022 5:41										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	8.52	µg/L	15	6/22/2022	18:54	JGW	2	1	

Sample Matrix: Drinking Water		Lab Sample Number: 220606012-020								
Sample Location: C12 Sink		Customer Sample Number:								
Sampled By: V. Cervantes										
Sample Date/Time: 6/7/2022 5:38										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/22/2022	19:00	JGW	2	1	

Sample Matrix: Drinking Water		Lab Sample Number: 220606012-021								
Sample Location: C12 Water Ftn DS		Customer Sample Number:								
Sampled By: V. Cervantes										
Sample Date/Time: 6/7/2022 5:39										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/22/2022	19:05	JGW	2	1	

Sample Matrix: Drinking Water		Lab Sample Number: 220606012-022								
Sample Location: C16 Water Ftn DS		Customer Sample Number:								
Sampled By: V. Cervantes										
Sample Date/Time: 6/7/2022 5:36										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/22/2022	19:11	JGW	2	1	

Stillwater Twp Elementary School

Sample Matrix:	Drinking Water	Lab Sample Number:	220606012-023
Sample Location:	C16 Sink DS	Customer Sample Number:	
Sampled By:	V. Cervantes		
Sample Date/Time:	6/7/2022 5:35		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/22/2022	19:55	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220606012-024
Sample Location:	A23 Sink	Customer Sample Number:	
Sampled By:	V. Cervantes		
Sample Date/Time:	6/7/2022 5:34		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/22/2022	20:00	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220606012-025
Sample Location:	A23 Water Ftn	Customer Sample Number:	
Sampled By:	V. Cervantes		
Sample Date/Time:	6/7/2022 5:33		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	59.9 **	µg/L	15	6/22/2022	20:11	JGW	8	4

Sample Matrix:	Drinking Water	Lab Sample Number:	220606012-026
Sample Location:	A20 Hall Water Ftn	Customer Sample Number:	
Sampled By:	V. Cervantes		
Sample Date/Time:	6/7/2022 5:32		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/22/2022	20:16	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220606012-027
Sample Location:	A17 Copy Rm Sink DS	Customer Sample Number:	
Sampled By:	V. Cervantes		
Sample Date/Time:	6/7/2022 5:31		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	3.48	µg/L	15	6/22/2022	20:22	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220606012-028
Sample Location:	A14 Girls Water Ftn	Customer Sample Number:	
Sampled By:	V. Cervantes		
Sample Date/Time:	6/7/2022 5:30		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/22/2022	20:27	JGW	2	1

NJ Lab ID# 14013 (Dover)
 NJ Lab ID# 13033 (Marlboro)

** Result does not meet NJDEP Limits.
 NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.
 Any method followed by an asterisk (*) was analyzed by the Agra-Marlboro laboratory.
 All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen
 Susan VanVeen, Laboratory Manager

June 23, 2022



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

22060612
220606012

Customer Name:	Stillwater Twp Elementary School	Report to:	Rene Metzgar	Agra Environmental Services	# Asc./HCl Vials	pH: _____
Location:			rene.metzgar@stillwaterschool.net	90 1/2 West Blackwell Street	# HCl Vials	pH: _____
Address:	904 Stillwater Rd			Dover, NJ 07801	# Na ₂ S ₂ O ₃	Cl ₂ : _____
	Stillwater Township, NJ, 07875			Phone: (973) 989-0010	# HNO ₃ 250ml	pH: _____
Customer Contact:	Mike			Fax: (973) 989-0156	# H ₂ SO ₄	pH: _____
Phone: Work/Cell	973-383-6171 / 862-268-1777	973-383-8954			# NaOH	pH: _____
					# unpreserved	_____
					# other	_____
					# other	_____

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake Page 1 of 3

Project: BOE Lead Testing		Collection		PWSID# NJ1920317					for laboratory use only		Field Analysis	
Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl ₂ or PO ₄	
220606012-001	Field Blank	6-7-22	0606	X		DW	1	HNO3	Lead-1st Draw			
220606012-002	B112-TL		0549	X		DW	1	HNO3	Lead-1st Draw			
220606012-003	B110 Sink		0551	X		DW	1	HNO3	Lead-1st Draw			
220606012-004	B110 3xKC		0552	X		DW	1	HNO3	Lead-1st Draw			
220606012-005	B110 1FP		0553	X		DW	1	HNO3	Lead-1st Draw			
220606012-006	C110 Sink		0559	X		DW	1	HNO3	Lead-1st Draw			
220606012-007	C110 Water Ftn		0557	X		DW	1	HNO3	Lead-1st Draw			
220606012-008	C111 Sink		0556	X		DW	1	HNO3	Lead-1st Draw			
220606012-009	C111 Water Ftn		0557	X		DW	1	HNO3	Lead-1st Draw			
220606012-010	C114 Water Ftn		0555	X		DW	1	HNO3	Lead-1st Draw			

Sampled By (name/company):	Are these samples for compliance? (circle one): Yes or No		Indicate laboratory location where analysis request was performed	
<i>Vicki Cervantes/Agra</i>	NJDEP Laboratory Certification (Dover, NJ) #14013			
	NJDEP Laboratory Certification (Marlboro, NJ) #13033			
Reporting Requirements (Check Box):	Standard	NJ Reduced	Other (Specify)	Cooler Temperature Upon Receipt at lab: NA

Sample Custody Exchanges (Please use full legal signature)						Comments:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	<i>Preserved at lab with HNO3 @ 155. VC</i>
<i>Vicki Cervantes</i>	6-7-22	1145	<i>Sherry Stup</i>	6/7/22	1212	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____
						Invoice Number _____
						Is sample known to be hazardous? (circle one) Yes or No



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

22060612
220606012

Customer Name:	Stillwater Twp Elementary School	Report to:	Rene Metzgar	Agra Environmental Services	# _____ Asc./HCl Vials	pH: _____
Location:			rene.metzgar@stillwaterschool.net	90 1/2 West Blackwell Street	# _____ HCl Vials	pH: _____
Address:	904 Stillwater Rd			Dover, NJ 07801	# _____ Na ₂ S ₂ O ₃	Cl ₂ : _____
	Stillwater Township, NJ, 07875			Phone: (973) 989-0010	# _____ HNO ₃	pH: _____
Customer Contact:	Mike			Fax: (973) 989-0156	# _____ H ₂ SO ₄	pH: _____
Phone: Work/Cell	973-383-6171 / 862-268-1777		973-383-8954		# _____ NaOH	pH: _____
					# _____ unpreserved	_____
					# _____ other	_____
					# _____ other	_____

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake Page 2 of 3

Project: BOE Lead Testing		Collection		PWSID# NJ1920317						for laboratory use only	Field Analysis	
Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl ₂ or PO ₄	
220606012-011	A124 Water Ftn	6-7-22	0602	X		DW	1	HNO ₃	Lead-1st Draw			
220606012-012	A112 Water Ftn		0603	X		DW	1	HNO ₃	Lead-1st Draw			
220606012-013	A112 Sink 1		0604	X		DW	1	HNO ₃	Lead-1st Draw			
220606012-014	A112 Sink 2		0605	X		DW	1	HNO ₃	Lead-1st Draw			
220606012-015	B23 Water Ftn		0547	X		DW	1	HNO ₃	Lead-1st Draw			
220606012-016	B&G Water Ftn		0546	X		DW	1	HNO ₃	Lead-1st Draw			
220606012-017	B10 Water Ftn		0544	X		DW	1	HNO ₃	Lead-1st Draw			
220606012-018	B10 Sink		0543	X		DW	1	HNO ₃	Lead-1st Draw			
220606012-019	C11 Sink		0541	X		DW	1	HNO ₃	Lead-1st Draw			
220606012-020	C12 Sink		0539	X		DW	1	HNO ₃	Lead-1st Draw			

Sampled By (name/company): <i>Victor Leonardo/Agra</i>	Are these samples for compliance? (circle one): Yes or No	Indicate laboratory location where analysis request was performed
	NJDEP Laboratory Certification (Dover, NJ) #14013 NJDEP Laboratory Certification (Marlboro, NJ) #13033	
Reporting Requirements (Check Box):	<input type="checkbox"/> Standard <input checked="" type="checkbox"/> NJ Reduced <input type="checkbox"/> Other (Specify)	Cooler Temperature Upon Receipt at lab: <i>NA</i>

Sample Custody Exchanges (Please use full legal signature)						Comments:
Relinquished By: <i>Victor Leonardo</i>	Date: 6-7-22	Time: 11:45	Received By: <i>Sherry Huf</i>	Date: 6/7/22	Time: 12:12	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____ Invoice Number _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one) Yes or No



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

220606012
220606012

Customer Name:	Stillwater Twp Elementary School	Report to:	Rene Metzgar	Agra Environmental Services	# _____ Asc./HCl Vials	pH: _____
Location:				90 1/2 West Blackwell Street	# _____ HCl Vials	pH: _____
Address:	904 Stillwater Rd			Dover, NJ 07801	# _____ Na ₂ S ₂ O ₃	Cl ₂ : _____
	Stillwater Township, NJ, 07875			Phone: (973) 989-0010	# _____ HNO ₃	pH: _____
Customer Contact:	Mike			Fax: (973) 989-0156	# _____ H ₂ SO ₄	pH: _____
Phone: Work/Cell	973-383-6171 / 862-268-1777	973-383-8954			# _____ NaOH	pH: _____
					# _____ unpreserved	_____
					# _____ other	_____
					# _____ other	_____

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake

Project: BOE Lead Testing		Collection		PWSID# NJ1920317		for laboratory use only		Field Analysis			
Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl ₂ or PO ₄
220606012-021	C12 Water Ftn	6-7-22	0539	X		DW	1	HNO3	Lead-1st Draw		
220606012-022	C16 Water Ftn		0536	X		DW	1	HNO3	Lead-1st Draw		
220606012-023	C16 Sink		0535	X		DW	1	HNO3	Lead-1st Draw		
220606012-024	A23 Sink		0534	X		DW	1	HNO3	Lead-1st Draw		
220606012-025	A23 Water Ftn		0533	X		DW	1	HNO3	Lead-1st Draw		
220606012-026	A20 Hall Water Ftn		0532	X		DW	1	HNO3	Lead-1st Draw		
220606012-027	A17 Copy Rm Sink		0531	X		DW	1	HNO3	Lead-1st Draw		
220606012-028	A14 Girls Water Ftn		0530	X		DW	1	HNO3	Lead-1st Draw		

Sampled By (name/company): <i>Victor Puentes/Agra</i>	Are these samples for compliance? (circle one): Yes or No	Indicate laboratory location where analysis request was performed
	NJDEP Laboratory Certification (Dover, NJ) #14013 NJDEP Laboratory Certification (Marlboro, NJ) #13033	
Reporting Requirements (Check Box):	Standard <input type="checkbox"/> NJ Reduced <input type="checkbox"/> Other (Specify) <input type="checkbox"/>	Cooler Temperature Upon Receipt at lab: <i>NA</i>

Sample Custody Exchanges (Please use full legal signature)						Comments:	
Relinquished By:	<i>Chad Lamb</i>	Date:	6-7-22	Time:	1145	Received By:	<i>Sherry G...</i>
		Date:		Time:		Received By:	
Relinquished By:		Date:		Time:		Received By:	
Relinquished By:		Date:		Time:		Received By:	
Relinquished By:		Date:		Time:		Received By:	
							Date Faxed _____ Invoice Number _____
							Is sample known to be hazardous? (circle one) Yes or No