

August 2024

CLEAN

SAFE

HEALTHY

SCHOOLS

Amity Regional School
District No. 5

25 Newton Road

Woodbridge, CT 06525

Phone: 203-397-4817

Fax: 203-397-4864



Amity Regional School District No. 5

Facilities Department Monthly Report

Completed Projects:

- All parking lot light fixtures at ARHS have been replaced by our in house maintenance staff.
- The sinkhole in the ARHS parking lot was repaired by an outside contractor.
- Concrete repairs to the sidewalk, curbing, and loading dock at AMSO have been completed.
- The Athletic Department ticket booth has been finished.
- The gym floor at AMSO has been refinished by Dalene Flooring.
- The canopy at AMSB has been repainted.
- All kitchen equipment District-wide has been serviced for the start of school.

Projects in Process:

- Roof work at ARHS is in progress to repair the loose capstones and refurbish the metal roof portion over student street.
- The canopy at AMSO is being scheduled for repainting.
- The burglar alarms at all three schools and District office are being upgraded.
- The District is working with the Town of Woodbridge to address concerns with the fuel cell and microgrid. District met with the Town of Woodbridge on May 25th to discuss the report from UI and will continue to work together to resolve the ongoing concerns.
- One of the two automatic transfer switches for generator power at ARHS needs to be replaced. The switch is on order with an expected delivery date of late August. Once it arrives, it will be installed by our in house building electrician.
- The fire pump in Bethany needs to be replaced. The District is working with Van Zelm engineers to draft specifications so the project can go out to bid.

Outstanding issues to be addressed: