

CLEAN

SAFE

HEALTHY

SCHOOLS

Amity Regional School
District No. 5

25 Newton Road

Woodbridge, CT 06525

Phone: 203-397-4817

Fax: 203-397-4864



Amity Regional School District No. 5

Facilities Department Monthly Report

Completed Projects:

- The burglar alarm upgrades were completed at the three schools.
- A fan motor for one of the roof top air handlers at AMSO was replaced by our in house HVAC technician.
- A few electrical outlets in some classrooms at ARHS were not working at the start of school and were repaired by our in house electrician.
- A few rooftop exhaust fans District Wide were repaired by our in house HVAC technician.

Projects in Process:

- Roof work at ARHS is in progress to refurbish the metal roof portion over student street.
- The capstone repairs at ARHS are 90% complete and will be finished shortly.
- The canopy repainting at AMSO is underway, work will be completed over the next few weekends.
- The burglar alarm system at the District Office is scheduled to be upgraded.
- The District is working with the Town of Woodbridge to address concerns with the fuel cell and microgrid. District met with the Town of Woodbridge on May 25th to discuss the report from UI and will continue to work together to resolve the ongoing concerns.
- One of the two automatic transfer switches for generator power at ARHS needs to be replaced. The switch is on order. Once it arrives, it will be installed by our in house building electrician.
- The fire pump in Bethany needs to be replaced. The District is working with Van Zelm engineers to draft specifications so the project can go out to bid.
- Cleaning of ductwork at AMSO is being scheduled with a state contract vendor.

Outstanding issues to be addressed: