

Building	Lab ELAP I	Lab ID #	School Sample ID	Collection Date	Outlet Description	Initial/Post Remediation	Lead Result mcg/L (ppb)	Action Taken
Community Center	2406470	10248	2406470-049A	6/5/2024	CC Drinking Fountain East	Initial	<0.0010	N/A
Community Center	2406470	10248	2406470-050A	6/5/2024	CC B East	Initial	<0.0010	N/A
Community Center	2406470	10248	2406470-051A	6/5/2024	CC Drinking Fountain West	Initial	<0.0010	N/A
Community Center	2406470	10248	2406470-052A	6/5/2024	CC B West	Initial	<0.0010	N/A
Cuyler	2406470	10248	2406470-001	6/5/2024	Cuyler Kitchen Dish Wash Sink	Initial	0.0270	Replacement
Cuyler	2406470	10248	2406470-002A	6/5/2024	Cuyler Kitchen Food Prep	Initial	0.0074	Remove from Service
Cuyler	2406470	10248	2406470-003A	6/5/2024	Cuyler Kitchen Food Prep C	Initial	0.0039	N/A
Cuyler	2406470	10248	2406470-004A	6/5/2024	Cuyler Kitchen Food Prep R	Initial	0.0044	N/A
Cuyler	2406470	10248	2406470-005A	6/5/2024	Cuyler 558 Drinking	Initial	0.0019	N/A
Cuyler	2406470	10248	2406470-006A	6/5/2024	Cuyler 557 Drinking	Initial	0.0030	N/A
Cuyler	2406470	10248	2406470-007A	6/5/2024	Cuyler 557 Sink	Initial	0.0020	N/A
Cuyler	2406470	10248	2406470-009A	6/5/2024	Cuyler 558 Sink	Initial	0.0066	Remove from Service
Cuyler	2406470	10248	2406470-010A	6/5/2024	Cuyler 556 Sink	Initial	0.0100	Remove from Service
Cuyler	2406470	10248	2406470-011A	6/5/2024	Cuyler 556 Drinking Fountain	Initial	0.0096	Remove from Service
Cuyler	2406470	10248	2406470-013A	6/5/2024	Cuyler 555 Sink	Initial	0.0029	N/A
Cuyler	2406470	10248	2406470-014A	6/5/2024	Cuyler 555 Bubbler	Initial	0.0030	N/A
Cuyler	2406470	10248	2406470-015A	6/5/2024	Cuyler 554 Sink	Initial	0.0052	Remove from Service
Cuyler	2406470	10248	2406470-016A	6/5/2024	Cuyler 556 Bubbler	Initial	0.0084	Remove from Service
Cuyler	2406470	10248	2406470-017A	6/5/2024	Cuyler 553 Sink	Initial	0.0042	N/A
Cuyler	2406470	10248	2406470-018A	6/5/2024	Cuyler 553 Bubbler	Initial	0.0075	Remove from Service
Cuyler	2406470	10248	2406470-019A	6/5/2024	Cuyler Bathroom Bubbler	Initial	<0.0010	N/A
Cuyler	2406470	10248	2406470-020A	6/5/2024	Cuyler Bathroom Bottle Fill	Initial	<0.0010	N/A
Cuyler	2406470	10248	2406470-021A	6/5/2024	Cuyler 549 Sink	Initial	0.0110	Remove from Service
Cuyler	2406470	10248	2406470-022A	6/5/2024	Cuyler 549 Bubbler	Initial	0.0120	Remove from Service
Cuyler	2406470	10248	2406470-023A	6/5/2024	Cuyler 548 Sink	Initial	0.0067	Remove from Service
Cuyler	2406470	10248	2406470-024A	6/5/2024	Cuyler 548 Bubbler	Initial	0.0990	Remove from Service
Cuyler	2406470	10248	2406470-025A	6/5/2024	Cuyler 547 Sink	Initial	0.0040	N/A
Cuyler	2406470	10248	2406470-026A	6/5/2024	Cuyler 547 Bubbler	Initial	0.0050	Remove from Service
Cuyler	2406470	10248	2406470-027A	6/5/2024	Cuyler 546 Bubbler	Initial	0.0037	N/A
Cuyler	2406470	10248	2406470-028A	6/5/2024	Cuyler 546 Sink	Initial	0.0037	N/A
Cuyler	2406470	10248	2406470-029A	6/5/2024	Cuyler 544 Sink	Initial	0.0034	N/A
Cuyler	2406470	10248	2406470-030A	6/5/2024	Cuyler 544 Bubbler	Initial	0.0030	N/A
Cuyler	2406470	10248	2406470-031A	6/5/2024	Cuyler 541 Sink	Initial	0.0041	N/A
Cuyler	2406470	10248	2406470-032A	6/5/2024	Cuyler 541 Bubbler	Initial	0.0052	Remove from Service
Cuyler	2406470	10248	2406470-033A	6/5/2024	Cuyler 540 Sink	Initial	0.0063	Remove from Service
Cuyler	2406470	10248	2406470-034A	6/5/2024	Cuyler 540 Bubbler	Initial	0.0036	N/A
Cuyler	2406470	10248	2406470-035A	6/5/2024	Cuyler 539 Sink	Initial	0.0055	Remove from Service
Cuyler	2406470	10248	2406470-036A	6/5/2024	Cuyler 539 Bubbler	Initial	0.0046	N/A
Cuyler	2406470	10248	2406470-037A	6/5/2024	Cuyler 545 Sink	Initial	0.0110	Remove from Service
Cuyler	2406470	10248	2406470-038A	6/5/2024	Cuyler 545 Bubbler	Initial	0.0056	Remove from Service
Cuyler	2406470	10248	2406470-039A	6/5/2024	Cuyler 509 Sink	Initial	0.0041	N/A

Building	Lab ELAP ID	Lab ID #	School Sample ID	Collection Date	Outlet Description	Initial/Post Remediation	Lead Result mcg/L (ppb)	Action Taken
Cuyler	2406470	10248	2406470-040A	6/5/2024	Cuyler 509 Bubbler	Initial	0.0042	N/A
Cuyler	2406470	10248	2406470-041A	6/5/2024	Cuyler 508 Sink	Initial	0.0011	N/A
Cuyler	2406470	10248	2406470-042A	6/5/2024	Cuyler 508 Bubbler	Initial	<0.0010	N/A
Cuyler	2406470	10248	2406470-043A	6/5/2024	Cuyler 507 Sink	Initial	0.0066	Remove from Service
Cuyler	2406470	10248	2406470-044A	6/5/2024	Cuyler 507 Bubbler	Initial	0.0073	Remove from Service
Cuyler	2406470	10248	2406470-045A	6/5/2024	Cuyler 532 Sink	Initial	0.0013	N/A
Cuyler	2406470	10248	2406470-046A	6/5/2024	Cuyler 532 Bubbler	Initial	0.0024	N/A
Cuyler	2406470	10248	2406470-090A	6/5/2024	Room 538 Sink	Initial	0.025	Remove from Service
Cuyler	2406470	10248	2406470-091A	6/5/2024	Room 537 Sink	Initial	0.0018	N/A
Cuyler	2406470	10248	2406470-092A	6/5/2024	ES Library Sink	Initial	0.0065	Remove from Service
Cuyler	2406470	10248	2406470-093A	6/5/2024	ES Library Bubbler	Initial	0.0036	N/A
Cuyler	2406470	10248	2406470-094A	6/5/2024	ES Cafeteria Bubbler	Initial	<0.0010	N/A
Cuyler	2406470	10248	2406470-095A	6/5/2024	ES Cafeteria B	Initial	<0.0010	N/A
Cuyler	2406470	10248	2406470-096A	6/5/2024	Room 513 Sink 1	Initial	0.0029	N/A
Cuyler	2406470	10248	2406470-097A	6/5/2024	Room 513 Sink 2	Initial	0.0041	N/A
Cuyler	2406470	10248	2406470-098A	6/5/2024	Room 533 Sink	Initial	0.0013	N/A
Cuyler	2406470	10248	2406470-099A	6/5/2024	Room 533 Bubbler	Initial	0.0014	N/A
Cuyler	2406470	10248	2406470-100A	6/5/2024	Room 514 Sink	Initial	0.0041	N/A
Cuyler	2406470	10248	2406470-101A	6/5/2024	Room 514 Bubbler	Initial	0.0013	N/A
Cuyler	2407031	10248	2407031-001A	6/13/2024	Room 532 Sink	Initial	0.0021	N/A
Cuyler	2407031	10248	2407031-002A	6/13/2024	Room 532 Bubbler	Initial	0.0016	N/A
Cuyler	2407031	10248	2407031-003A	6/13/2024	Room 531 Sink	Initial	0.0013	N/A
Cuyler	2407031	10248	2407031-004A	6/13/2024	Room 531 Bubbler	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-005A	6/13/2024	Room 530 Sink	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-006A	6/13/2024	Room 530 Bubbler	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-007A	6/13/2024	Room 529 Sink	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-008A	6/13/2024	Room 529 Bubbler	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-009A	6/13/2024	Cuyler BR Drinking Fountain	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-010A	6/13/2024	Room 525 Sink	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-011A	6/13/2024	Room 525 Bubbler	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-012A	6/13/2024	Room 524 Sink	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-013A	6/13/2024	Room 524 Bubbler	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-014A	6/13/2024	Room 523 Sink	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-015A	6/13/2024	Room 523 Bubbler	Initial	0.0023	N/A
Cuyler	2407031	10248	2407031-016A	6/13/2024	Room 522 Sink	Initial	0.0012	N/A
Cuyler	2407031	10248	2407031-017A	6/13/2024	Room 522 Bubbler	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-018A	6/13/2024	Room 521 Sink	Initial	0.0011	N/A
Cuyler	2407031	10248	2407031-019A	6/13/2024	Room 521 Bubbler	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-020A	6/13/2024	Room 520 Sink	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-021A	6/13/2024	Room 520 Bubbler	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-022A	6/13/2024	Room 519 Sink	Initial	0.0022	N/A

Building	Lab ELAP I	Lab ID #	School Sample ID	Collection Date	Outlet Description	Initial/Post Remediation	Lead Result mcg/L (ppb)	Action Taken
Cuyler	2407031	10248	2407031-023A	6/13/2024	Room 519 Bubblers	Initial	0.0013	N/A
Cuyler	2407031	10248	2407031-024A	6/13/2024	Room 518 Sink	Initial	0.0013	N/A
Cuyler	2407031	10248	2407031-025A	6/13/2024	Room 518 Bubblers	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-026A	6/13/2024	Room 517 Sink	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-027A	6/13/2024	Room 517 Bubblers	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-028A	6/13/2024	Room 516 Sink	Initial	0.0011	N/A
Cuyler	2407031	10248	2407031-029A	6/13/2024	Room 516 Bubblers	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-030A	6/13/2024	Room 514 Sink	Initial	0.0038	N/A
Cuyler	2407031	10248	2407031-031A	6/13/2024	Room 514 Bubblers	Initial	0.002	N/A
Cuyler	2407031	10248	2407031-032A	6/13/2024	Room 558 Bubblers	Initial	0.0022	N/A
Cuyler	2407031	10248	2407031-033A	6/13/2024	Playground drinking fountain	Initial	0.0021	N/A
Cuyler	2407031	10248	2407031-034A	6/13/2024	Room 423 Sink	Initial	0.0093	Remove from Service
Cuyler	2407031	10248	2407031-035A	6/13/2024	Room 414 Sink	Initial	0.014	Remove from Service
Cuyler	2407031	10248	2407031-036A	6/13/2024	Room 424 Bubblers	Initial	0.0058	Remove from Service
Cuyler	2407031	10248	2407031-037A	6/13/2024	Room 425 Bubblers	Initial	0.0069	Remove from Service
Cuyler	2407031	10248	2407031-038A	6/13/2024	Room 425 Sink	Initial	0.0044	N/A
Cuyler	2407031	10248	2407031-039A	6/13/2024	Room 426 Sink	Initial	0.025	Remove from Service
Cuyler	2407031	10248	2407031-040A	6/13/2024	Room 426 Bubblers	Initial	0.024	Remove from Service
Cuyler	2407031	10248	2407031-041A	6/13/2024	Room 410 Sink	Initial	0.0055	Remove from Service
Cuyler	2407031	10248	2407031-042A	6/13/2024	Room 410 Bubblers	Initial	0.0023	N/A
Cuyler	2407031	10248	2407031-043A	6/13/2024	Room 435 Bubblers	Initial	0.0034	N/A
Cuyler	2407031	10248	2407031-044A	6/13/2024	Room 409 Bubblers	Initial	0.0016	N/A
Cuyler	2407031	10248	2407031-045A	6/13/2024	Room 409 Sink	Initial	0.0083	Remove from Service
Cuyler	2407031	10248	2407031-046A	6/13/2024	Room 436 Sink	Initial	0.0091	Remove from Service
Cuyler	2407031	10248	2407031-047A	6/13/2024	Room 436 Bubblers	Initial	0.0018	N/A
Cuyler	2407031	10248	2407031-048A	6/13/2024	Room 408 Sink	Initial	0.0091	Remove from Service
Cuyler	2407031	10248	2407031-049A	6/13/2024	Room 408 Bubblers	Initial	0.0022	N/A
Cuyler	2407031	10248	2407031-050A	6/13/2024	Room 407 Bubblers	Initial	0.0023	N/A
Cuyler	2407031	10248	2407031-051A	6/13/2024	Room 407 Sink	Initial	0.008	Remove from Service
Cuyler	2407031	10248	2407031-052A	6/13/2024	Room 406 Sink	Initial	0.0087	Remove from Service
Cuyler	2407031	10248	2407031-053A	6/13/2024	Room 406 Bubblers	Initial	0.0036	N/A
Cuyler	2407031	10248	2407031-054A	6/13/2024	ES Gym Bubblers	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-055A	6/13/2024	ES Girls LR Bubblers	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-056A	6/13/2024	ES Boys LR Bubblers	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-057A	6/13/2024	ES Boys LR Bubblers 2	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-058A	6/13/2024	Room 445 Sink	Initial	<0.0010	N/A
Cuyler	2407031	10248	2407031-059A	6/13/2024	Room 443 Sink	Initial	0.0031	N/A
District Office	2406470	10248	2406470-012A	6/5/2024	DO Back Room	Initial	0.0027	N/A
High School	2406470	10248	2406470-047A	6/5/2024	High School Cafeteria Bubblers	Initial	0.0013	N/A
High School	2406470	10248	2406470-048A	6/5/2024	HS Cafeteria B	Initial	0.0018	N/A
High School	2406470	10248	2406470-053A	6/5/2024	High School Nurse Bubblers	Initial	<0.0010	N/A

Building	Lab ELAP I	Lab ID #	School Sample ID	Collection Date	Outlet Description	Initial/Post Remediation	Lead Result mcg/L (ppb)	Action Taken
High School	2406470	10248	2406470-054A	6/5/2024	High School Nurse B	Initial	<0.0010	N/A
High School	2406470	10248	2406470-055A	6/5/2024	HS 421 Sink 1	Initial	0.0014	N/A
High School	2406470	10248	2406470-056A	6/5/2024	HS 421 Sink 2	Initial	0.0016	N/A
High School	2406470	10248	2406470-057A	6/5/2024	HS 421 Sink 3	Initial	0.0012	N/A
High School	2406470	10248	2406470-058A	6/5/2024	HS 421 Sink 4	Initial	0.0013	N/A
High School	2406470	10248	2406470-059A	6/5/2024	HS 421 Sink 5	Initial	0.0016	N/A
High School	2406470	10248	2406470-060A	6/5/2024	HS Kitchen Sink 1	Initial	0.0029	N/A
High School	2406470	10248	2406470-061A	6/5/2024	HS Kitchen Sink 2	Initial	0.0022	N/A
High School	2406470	10248	2406470-062A	6/5/2024	HS Kitchen Sink 3	Initial	0.0018	N/A
High School	2406470	10248	2406470-063A	6/5/2024	HS Kitchen Sink 4	Initial	0.0054	Remove from Service
High School	2406470	10248	2406470-064A	6/5/2024	HS Kitchen Sink 5	Initial	0.0053	Remove from Service
High School	2406470	10248	2406470-065A	6/5/2024	HS Kitchen Sink 6	Initial	0.0019	N/A
High School	2406470	10248	2406470-066A	6/5/2024	HS Kitchen Sink 7	Initial	0.0014	N/A
High School	2406470	10248	2406470-067A	6/5/2024	HS Kit Kettle 1	Initial	0.0016	N/A
High School	2406470	10248	2406470-068A	6/5/2024	HS Kit Kettle 2	Initial	0.002	N/A
High School	2406470	10248	2406470-069A	6/5/2024	HS Foyer Drinking Fountain	Initial	<0.0010	N/A
High School	2406470	10248	2406470-070A	6/5/2024	HS Foyer Drinking Fountain Right	Initial	<0.0010	N/A
High School	2406470	10248	2406470-071A	6/5/2024	HS Foyer B	Initial	<0.0010	N/A
High School	2406470	10248	2406470-072A	6/5/2024	HS Office	Initial	0.0047	N/A
High School	2406470	10248	2406470-073A	6/5/2024	HS Rm 101M	Initial	00.040	N/A
High School	2406470	10248	2406470-074A	6/5/2024	HS East Hall Bubbler	Initial	<0.0010	N/A
High School	2406470	10248	2406470-075A	6/5/2024	HS East Hall DF	Initial	<0.0010	N/A
High School	2406470	10248	2406470-076A	6/5/2024	HS East Hall B	Initial	<0.0010	N/A
High School	2406470	10248	2406470-077A	6/5/2024	HS East Hall Bubbler Left	Initial	0.0023	N/A
High School	2406470	10248	2406470-078A	6/5/2024	HS West Hall Bubbler Right	Initial	<0.0010	N/A
High School	2406470	10248	2406470-079A	6/5/2024	HS West Hall B1	Initial	<0.0010	N/A
High School	2406470	10248	2406470-080A	6/5/2024	HS West Hall Bubbler M	Initial	0.0016	N/A
High School	2406470	10248	2406470-081A	6/5/2024	HS west Hall Bubbler Left	Initial	0.0014	N/A
High School	2406470	10248	2406470-082A	6/5/2024	HS West Hall B2	Initial	0.0014	N/A
High School	2406470	10248	2406470-083A	6/5/2024	HS Library Sink	Initial	<0.0010	N/A
High School	2406470	10248	2406470-084A	6/5/2024	HS North Bubbler Right	Initial	<0.0010	N/A
High School	2406470	10248	2406470-085A	6/5/2024	HS North B	Initial	<0.0010	N/A
High School	2406470	10248	2406470-086A	6/5/2024	HS North Bubbler Left	Initial	<0.0010	N/A
High School	2406470	10248	2406470-087A	6/5/2024	HS Nurse Sink	Initial	0.0012	N/A
High School	2407031	10248	2407031-070A	6/13/2024	Outside Gym Left	Initial	<0.0010	N/A
High School	2407031	10248	2407031-071A	6/13/2024	Outside Gym Right	Initial	<0.0010	N/A
Middle School	2406470	10248	2406470-088A	6/5/2024	MS Bubbler	Initial	<0.0010	N/A
Middle School	2406470	10248	2406470-089A	6/5/2024	MS B	Initial	<0.0010	N/A
Middle School	2407031	10248	2407031-060A	6/13/2024	MS Office Sink	Initial	0.0011	N/A
Middle School	2407031	10248	2407031-061A	6/13/2024	Room 403 Sink	Initial	0.012	Remove from Service
Middle School	2407031	10248	2407031-062A	6/13/2024	Bubbler Girls Right	Initial	<0.0010	N/A

Building	Lab ELAP I	Lab ID #	School Sample ID	Collection Date	Outlet Description	Initial/Post Remediation	Lead Result mcg/L (ppb)	Action Taken
Middle School	2407031	10248	2407031-063A	6/13/2024	Bubbler Girls Left	Initial	<0.0010	N/A
Middle School	2407031	10248	2407031-064A	6/13/2024	Bottle Filler Girls Locker Room	Initial	<0.0010	N/A
Middle School	2407031	10248	2407031-065A	6/13/2024	Bubbler Boys Left	Initial	<0.0010	N/A
Middle School	2407031	10248	2407031-066A	6/13/2024	Bubbler Boys Right	Initial	<0.0010	N/A
Middle School	2407031	10248	2407031-067A	6/13/2024	Bottle Filler Boys Locker Room	Initial	<0.0010	N/A
Middle School	2407031	10248	2407031-068A	6/13/2024	MS Hall 5th Grade Bubbler	Initial	<0.0010	N/A
Middle School	2407031	10248	2407031-069A	6/13/2024	MS Hall 5th Grade Bottle Filler	Initial	<0.0010	N/A
Sports Building	2407031	10248	2407031-072A	6/13/2024	Taj Drinking Fountain	Initial	0.0046	N/A