



12423 NE Whitaker Way
Portland, OR 97230
503-254-1794



Report Number: 24-009984/D001.R000
Report Date: 09/13/2024
ORELAP#: OR100028
Purchase Order:
Project Name: Sauvie Island
Project No:

Cover Letter

Scappoose School District
33589 SE High School Way
Scappoose Oregon 97056
United States of America (USA)

Dear Jeff Andrehsen,

Enclosed please find Columbia Laboratories analytical report for samples received as order number 24-009984 on 09/06/2024 at 13:36. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Thank you for allowing Columbia Laboratories to be of service to you, we appreciate your business.

Sincerely,

Derrick Tanner
General Manager



12423 NE Whitaker Way
 Portland, OR 97230
 503-254-1794



Report Number: 24-009984/D001.R000
Report Date: 09/13/2024
ORELAP#: OR100028
Purchase Order:
Project Name: Sauvie Island
Project No:

Sample Results

Sample: 1st grade DF
 Lab ID: 24-009984-0001
 Collected: 9/6/24 06:38
 Received: 9/6/24 13:36
 Temp: 22.9 °C
 Evidence of Cooling: N
 Matrix: Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead [±]	1.47	15.000	µg/l	0.2	1.00	2406972		09/11/24 10:39	

Sample Results

Sample: Kitchen Staff Bath
 Lab ID: 24-009984-0002
 Collected: 9/6/24 07:02
 Received: 9/6/24 13:36
 Temp: 22.9 °C
 Evidence of Cooling: N
 Matrix: Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead [±]	19.7	15.000	µg/l	0.2	1.00	2406972		09/11/24 10:40	

Sample Results

Sample: Staff Lounge faucet
 Lab ID: 24-009984-0003
 Collected: 9/6/24 07:00
 Received: 9/6/24 13:36
 Temp: 22.9 °C
 Evidence of Cooling: N
 Matrix: Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead [±]	3.45	15.000	µg/l	0.2	1.00	2406972		09/11/24 10:51	

Sample Results

Sample: Library office faucet
 Lab ID: 24-009984-0004
 Collected: 9/6/24 07:04
 Received: 9/6/24 13:36
 Temp: 22.9 °C
 Evidence of Cooling: N
 Matrix: Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead [±]	46.8	15.000	µg/l	1.0	5.00	2406972		09/11/24 11:17	

Sample Results

Sample: Workroom staff bath
 Lab ID: 24-009984-0005
 Collected: 9/6/24 06:58
 Received: 9/6/24 13:36
 Temp: 22.9 °C
 Evidence of Cooling: N
 Matrix: Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead [±]	1.96	15.000	µg/l	0.2	1.00	2406972		09/11/24 10:54	



12423 NE Whitaker Way
 Portland, OR 97230
 503-254-1794



Report Number: 24-009984/D001.R000
Report Date: 09/13/2024
ORELAP#: OR100028
Purchase Order:
Project Name: Sauvie Island
Project No:

Sample Results

Sample: Kitchen Sprayer
 Lab ID: 24-009984-0006
 Collected: 9/6/24 07:08
 Received: 9/6/24 13:36
 Temp: 22.9 °C
 Evidence of Cooling: N
 Matrix: Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead [±]	8.36	15.000	µg/l	0.2	1.00	2406972		09/11/24 10:56	

Sample Results

Sample: 5th grade DF
 Lab ID: 24-009984-0007
 Collected: 9/6/24 06:55
 Received: 9/6/24 13:36
 Temp: 22.9 °C
 Evidence of Cooling: N
 Matrix: Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead [±]	4.63	15.000	µg/l	0.2	1.00	2406972		09/11/24 10:57	

Sample Results

Sample: 5th grade faucet
 Lab ID: 24-009984-0008
 Collected: 9/6/24 06:56
 Received: 9/6/24 13:36
 Temp: 22.9 °C
 Evidence of Cooling: N
 Matrix: Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead [±]	18.3	15.000	µg/l	0.2	1.00	2406972		09/11/24 10:59	

Sample Results

Sample: 4th grade faucet
 Lab ID: 24-009984-0009
 Collected: 9/6/24 06:50
 Received: 9/6/24 13:36
 Temp: 22.9 °C
 Evidence of Cooling: N
 Matrix: Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead [±]	18.2	15.000	µg/l	0.2	1.00	2406972		09/11/24 11:04	

Sample Results

Sample: 4th grade DF
 Lab ID: 24-009984-0010
 Collected: 9/6/24 06:52
 Received: 9/6/24 13:36
 Temp: 22.9 °C
 Evidence of Cooling: N
 Matrix: Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead [±]	2.09	15.000	µg/l	0.2	1.00	2406972		09/11/24 11:05	

Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Columbia Laboratories quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be retained for a maximum of 30 days from the receipt date unless prior arrangements have been made.



12423 NE Whitaker Way
 Portland, OR 97230
 503-254-1794



Report Number: 24-009984/D001.R000
Report Date: 09/13/2024
ORELAP#: OR100028
Purchase Order:
Project Name: Sauvie Island
Project No:

Sample Results

Sample: 3rd grade faucet Collected: 9/6/24 06:45 Temp: 22.9 °C Matrix:
 Lab ID: 24-009984-0011 Received: 9/6/24 13:36 Evidence of Cooling: N Drinking Water

Method: EPA 200.8 in mg/l

Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead [±]	22.6	15.000	µg/l	0.2	1.00	2406972		09/11/24 11:07	

Sample Results

Sample: Kinder faucet Collected: 9/6/24 06:35 Temp: 22.9 °C Matrix:
 Lab ID: 24-009984-0012 Received: 9/6/24 13:36 Evidence of Cooling: N Drinking Water

Method: EPA 200.8 in mg/l

Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead [±]	19.5	15.000	µg/l	0.2	1.00	2406972		09/11/24 11:08	

Sample Results

Sample: 1st grade faucet Collected: 9/6/24 06:39 Temp: 22.9 °C Matrix:
 Lab ID: 24-009984-0013 Received: 9/6/24 13:36 Evidence of Cooling: N Drinking Water

Method: EPA 200.8 in mg/l

Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead [±]	14.3	15.000	µg/l	0.2	1.00	2407065		09/13/24 09:03	

Sample Results

Sample: 2nd grade faucet Collected: 9/6/24 06:42 Temp: 22.9 °C Matrix:
 Lab ID: 24-009984-0014 Received: 9/6/24 13:36 Evidence of Cooling: N Drinking Water

Method: EPA 200.8 in mg/l

Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead [±]	23.1	15.000	µg/l	0.2	1.00	2407065		09/13/24 09:05	

Units of Measure

µg/l = micrograms per liter

Abbreviations

LOQ Limit of quantification

[±] = TNI accredited analyte.



12423 NE Whitaker Way
 Portland, OR 97230
 503-254-1794



Report Number: 24-009984/D001.R000
Report Date: 09/13/2024
ORELAP#: OR100028
Purchase Order:
Project Name: Sauvie Island
Project No.:



Chain of Custody

Scappoose-School-District-1725647964

Company Details Company: <u>Scappoose School District</u> Contact: <u>Jeff Andrehsen</u> Street Address: <u>33589 SE High School Way</u> City, State, Zip: <u>Scappoose, OR 97056</u> Email: <u>jandrehsen@scappoose.k12.or.us</u> Contact Phone: <u>5034109805</u> Company Phone: <u>9712008000</u> Billing Information Billing Phone: <u>9712008000</u> Billing Email: <u>jandrehsen@scappoose.k12.or.us</u>				Project Details Compliance: <u>Compliance</u> Turnaround Time: <u>8 Business Days Standard</u> Sample Relinquishment Options: <u>Drop Off at Laboratory</u> Project Name / ID: <u>Sauvie Island</u> Sample(s) Collected By: <u>Rich Hoerauf</u> Receipt Information Prelog Storage: <u>R99</u> Sample Condition: <u>Satisfactory</u>				Testing	Bottles
				E2008PB- Lead in DW- Schools/ Childcare		250ml Poly HNC3			
#	Material	Sample Name Field ID	Collection Date	Collection Time					
1	Drinking Water	1st grade DF	09/06/2024	6:38 AM	✓	8468			
2	Drinking Water	Kitchen Staff Bath	09/06/2024	7:02 AM	✓	8468			
3	Drinking Water	Staff Lounge faucet	09/06/2024	7:00 AM	✓	8468			
4	Drinking Water	Library ceiling faucet	09/06/2024	7:04 AM	✓	8468			
5	Drinking Water	Workroom staff bath	09/06/2024	6:58 AM	✓	8468			
6	Drinking Water	Kitchen Sprayer	09/06/2024	7:08 AM	✓	8468			
7	Drinking Water	5th grade DF	09/06/2024	6:55 AM	✓	8468			
8	Drinking Water	5th grade faucet	09/06/2024	6:56 AM	✓	8468			
9	Drinking Water	4th grade faucet	09/06/2024	6:50 AM	✓	8468			
10	Drinking Water	4th grade DF	09/06/2024	6:52 AM	✓	8468			

Relinquished By	Date	Time	Received By	Date	Time	Received Temp., °C	Evidence of Cooling?
<i>Jeff Andrehsen</i>	<i>09/06/2024</i>	<i>11:39</i>	<i>ent</i>	<i>09/06/2024</i>	<i>13:36</i>	<i>22.90</i>	<i>No</i>

Samples submitted to Columbia Laboratories with testing requirements constitute an agreement for services in accordance with the [current terms of services](#) associated with this COC. By signing "Relinquished by" you are agreeing to these terms.

Columbia Laboratories
 12423 NE Whitaker Way
 Portland, OR 97230

P: (503) 254-1794
info@columbiaboratories.com

Page 1 of 2
www.columbiaboratories.com



12423 NE Whitaker Way
Portland, OR 97230
503-254-1794



Report Number: 24-009984/D001.R000
Report Date: 09/13/2024
ORELAP#: OR100028
Purchase Order:
Project Name: Sauvie Island
Project No:



Chain of Custody

Scappoose-School-District-1725647964

Company Details Company: <u>Scappoose School District</u> Contact: <u>Jeff Andrehsen</u> Street Address: <u>33589 SE High School Way</u> City, State, Zip: <u>Scappoose, OR 97056</u> Email: <u>jandrehsen@scappoose.k12.or.us</u> Contact Phone: <u>5034109805</u> Company Phone: <u>9712008000</u> Billing Information Billing Phone: <u>9712008000</u> Billing Email: <u>jandrehsen@scappoose.k12.or.us</u>				Project Details Compliance: <u>Compliance</u> Turnaround Time: <u>8 Business Days Standard</u> Sample Relinquishment Options: <u>Drop Off at Laboratory</u> Project Name / ID: <u>Sauvie Island</u> Sample(s) Collected By: <u>Rich Hoerauf</u> Receipt Information Prelog Storage: <u>R99</u> Sample Condition: <u>Satisfactory</u>		Testing E2008Pb - Lead in DW - Schools/ Childcare	Bottles 250ml Poly HNO3
#	Material	Sample Name Field ID	Collection Date	Collection Time			
11	Drinking Water	3rd grade faucet	09/06/2024	6:45 AM	✓	8468	
12	Drinking Water	Kinder faucet	09/06/2024	6:35 AM	✓	8468	
13	Drinking Water	1st grade faucet	09/06/2024	6:39 AM	✓	8468	
14	Drinking Water	2nd grade faucet	09/06/2024	6:42 AM	✓	8468	

Relinquished By	Date	Time	Received By	Date	Time	Received Temp., °C	Evidence of Cooling?
<i>Jeff Andrehsen</i>	<i>09/06/2024</i>	<i>11:39</i>	<i>ont</i>	<i>09/06/2024</i>	<i>13:36</i>	<i>22.90</i>	<i>No</i>

Samples submitted to Columbia Laboratories with testing requirements constitute an agreement for services in accordance with the [current terms of services](#) associated with this COC. By signing "Relinquished by" you are agreeing to these terms.

Columbia Laboratories
12423 NE Whitaker Way
Portland, OR 97230

P: (503) 254-1794
info@columbialaboratories.com

Page 2 of 2
www.columbialaboratories.com



12423 NE Whitaker Way
Portland, OR 97230
503-254-1794



Report Number: 24-009984/D001.R000
Report Date: 09/13/2024
ORELAP#: OR100028
Purchase Order:
Project Name: Sauvie Island
Project No:

Case Narrative

No Case Narrative notes to report.