

**Webster Groves School District  
Lead in Drinking Water  
Table for Tracking Elevated Sources**

0029-5660-2

School	Sample Location	Initial Results (PPB)	1st Follow Up Date (PPB)	1st Follow Up Results (PPB) Draw (R) / Flush (F)	2nd Follow Up Date	2nd Follow Up Results (PPB) First Draw (2R) / Flush (2F)	3rd Follow Up Date	3rd Follow Up Results (PPB) First Draw (3R) / Flush (3F)	Comments on Completion
Admin Building	AB-DF-HALL4-UL-3	14.8							Permanently Removed
Avery	AE-F-206-2-4	11.4	8/15/23	4.1 / <1.0					Completed/Passed on 8-15-23
	AE-F-105-1-7	16.8	8/15/23	1.4 / <1.0					Completed/Passed on 8-15-23
	AE-DF-101-1-11	24.7	8/15/23	4.1 / <1.0					Completed/Passed on 8-15-23
	AE-F-109-1-16	6.4	8/15/23	7.4 / <1.0	4/26/24	3.0 / <1.0			Completed/Passed on 4/26/24
	AE-DF-7-LL-20	6.9	8/15/23	8.1 / <1.0					Permanently Removed
	AE-F-205-2-27	8.2	8/15/23	2.5 / <1.0					Completed/Passed on 2-24-23
Bristol	BE-F-202-2-1	6.1	3/7/23	39.2 / <1.0	8/15/23	3.3 / <1.0			Completed/Passed on 8-15-23
	BE-F-206-2-3	5.3	3/7/23	27.5 / <1.0	8/15/23	4.9 / <1.0			Completed/Passed on 8-15-23
	BE-KF-KIT-LL-9	5.2	2/24/23	3.0 / <1.0					Completed/Passed on 2-24-23
Clark	CE-KF-KIT-1-3	21.4	2/24/23	42.5 / <1.0	8/15/23	2.7 / <1.0			Completed/Passed on 8-15-23
	CE-F-9-1-10	5.2	2/24/23	13.2 / <1.0	8/15/23	18.3 / <1.0	Water not on		Shut off until remediated
	CE-WF-KIT-1-29	5.1	2/24/23	14.2 / <1.0	8/15/23	1.5 / <1.0			Completed/Passed on 8-15-23
	CE-DF-11-1-32	10.8							Permanently Removed
Edgar Road	ER-KF-KIT-1-4	9.3	3/7/23	2.1 / <1.0					Completed/Passed on 3-7-23
	ER-F-100-1-14	5.3	3/7/23	1.9 / <1.0					Completed/Passed on 3-7-23
Givens	GE-F-105-1-3	6.6	8/13/24	1.7 / 1.0					Completed/Passed on 8-13-24
	GE-F-123-1-8	5.4	8/13/24	1.9 / 1.0					Completed/Passed on 8-13-24
	GE-KF-KIT-1-22	8.5							Handwash only - Labeled as Non-Potable
Hixson Middle	HM-F-206-2-8	12.8							Handwash only - Labeled as Non-Potable
	HM-TF-213-2-14	7.6	3/7/23	28.7 / <1.0	8/15/23	2.0 / <1.0			Completed/Passed on 8-15-23
	HM-F-226-2-20	6.5							Lab use only - Labeled as Non-Potable
	HM-F-010-1-35	13.6							Lab use only - Labeled as Non-Potable
	HM-F-010-1-36	16.6							Lab use only - Labeled as Non-Potable
	HM-F-010-1-37	10.9							Lab use only - Labeled as Non-Potable
	HM-F-010-1-38	22.5							Lab use only - Labeled as Non-Potable
	HM-F-010-1-39	10.7							Lab use only - Labeled as Non-Potable
	HM-F-010-1-40	8.7							Lab use only - Labeled as Non-Potable
	HM-F-009-1-41	5							Lab use only - Labeled as Non-Potable
	HM-F-009-1-44	10.8							Lab use only - Labeled as Non-Potable
	HM-DF-15-1-49	6.2							Permanently Removed
	HM-F-126-1-56	11.8							Handwash only - Labeled as Non-Potable
	HM-F-102-1-81	7.6	8/15/23	52.7 / <1.0	8/13/24	7.2 / <1.0	9/6/24	<1.0 / <1.0	Completed/Passed on 9/6/24
	HM-WF-KIT-1-86	53.4	8/15/23	11.1 / <1.0	4/26/24	4.8 / <1.0			Completed/Passed on 4/26/24
HM-WF-KIT-1-89	5.9	8/15/23	5.3 / <1.0	4/26/24	3.2 / <1.0			Completed/Passed on 4/26/24	
Hudson	HE-F-101-1-1	15.9	4/26/24	<1.0 / <1.0					Completed/Passed on 4/26/24
	HE-F-100-1-2	18.1	3/7/23	NA / <1.0	8/13/24	2.3 / <1.0			Completed/Passed on 8/13/24
	HE-F-99-1-5	9.4	4/26/24	5.8 / <1.0	8/13/24	2.3 / <1.0			Completed/Passed on 8/13/24
	HE-F-102-1-6	9.9	4/26/24	8.9 / <1.0	8/13/24	5.8 / <1.0	9/6/24	<1.0 / <1.0	Completed/Passed on 9/26/24
	HE-F-8-1-7	6.2	4/26/24	3.3 / <1.0					Completed/Passed on 4/26/24
	HE-F-104-1-9	5.3	4/26/24	3.5 / <1.0					Completed/Passed on 4/26/24
	HE-F-103-1-10	13.7	4/26/24	2.4 / <1.0					Completed/Passed on 4/26/24
	HE-F-106-1-11	8.2			8/13/24	<1.0 / <1.0			Completed/Passed on 8/13/24
	HE-F-107-1-13	14.9	3/7/23	NA / <1.0	4/26/24	2.3 / <1.0			Completed/Passed on 4/26/24
	HE-F-6-G-15	6.4			8/13/24	<1.0 / <1.0			Completed/Passed on 8/13/24
	HE-F-CAFÉ-G-18	13.2	3/7/23	NA / <1.0	8/13/24	<1.0 / <1.0			Completed/Passed on 8/13/24
	HE-F-3-G-21	11.8	3/7/23	NA / <1.0	8/13/24	7.1 / <1.0	9/6/24	5.2 / <1.0	Shut off until remediated
	HE-F-2-G-22	5.3	4/26/24	43.6 / 1.6	8/13/24	2.7 / <1.0			Completed/Passed on 8/13/24
	HE-F-ART-G-23	5.1	4/26/24	1.3 / <1.0					Completed/Passed on 4/26/24
	HE-SN-KIT-G-28	7.1	2/24/23	1.2 / <1.0					Completed/Passed on 2-24-23
	Warehouse	WP-WC-W-1-1	6.3	4/12/24	<1.0 / <1.0				
Webster Groves High School	WG-F-334F-3-1	19.4							Handwash only - Labeled as Non-Potable
	WG-F-334G-3-4	91							Handwash only - Labeled as Non-Potable
	WG-F-324-3-7	8.6	8/15/23	4.5 / 2.1					Completed/Passed on 8-15-23
	WG-TF-318-3-17	34	8/15/23	1.8 / <1.0					Completed/Passed on 8-15-23
	WG-HF-228C-2-24	5.5	8/15/23	3.0 / <1.0					Completed/Passed on 8-15-23
	WG-HF-228B-2-30	8.1	8/15/23	8.5 / <1.0	4/26/24	4.8 / 3.3			Completed/Passed on 4/26/24
	WG-DF-126-1-49	Altered	4/12/24	<1.0 / <1.0					Completed/Passed on 4/12/24
	WG-F-126-1-50	33.2	4/12/24	3.7 / <1.0					Completed/Passed on 4/12/24
	WG-F-PRS-1-51	23.3	4/12/24	<1.0 / <1.0					Completed/Passed on 4/12/24
	WG-F-SA-1-64	6.7	8/15/23	4.8 / <1.0					Completed/Passed on 8-15-23
	WG-F-157-1-72	8.7	8/15/23	9.5 / 1.5	4/26/24	3.9 / <1.0			Completed/Passed on 4/26/24
	WG-SN-KIT-1-90	12.3	2/24/23	<1.0 / <1.0					Completed/Passed on 2-24-23
	WG-WF-KIT-1-91	6.2	8/15/23	<1.0 / <1.0					Completed/Passed on 8-15-23
	WG-F-126-1-99	Altered	4/12/24	12.9 / <1.0	8/13/24	2.4 / <1.0			Completed/Passed on 8-13-24
	WG-F-126-1-100	Altered	4/12/24	2.5 / 1.0					Completed/Passed on 4/12/24