



Mount Vernon CSD - Graham ES 9/19/2024

Name: Test 1

Description: None

Location: Rooms 110 and 108

Instrument Name: SidePak Aerosol Monitor

Device Model Number: AM520

Device Serial Number: 5202327009

Firmware Version: B.01

Last Factory Calibration: 7/8/2024

Data Properties	
Start Date	9/19/2024
Start Time	7:12 AM
End Date	9/19/2024
End Time	1:59 PM
Test Length	00:06:47:00
Logging Interval	60 second(s)
Number of Data Points	407

Additional Information
There is no metadata related to this test

Test Statistics					
Channel	Average	Minimum	Maximum	Cal Factor	TWA
Aerosol (mg/m ³)	0.029	0.015 09/19/2024 10:43:35	0.053 09/19/2024 01:39:35	1 User1 09/09/2024	0.025

Name: Test 2

Description: None

Location: Rooms 206 and 209

Instrument Name: SidePak Aerosol Monitor

Device Model Number: AM520

Device Serial Number: 5201735009

Firmware Version: B.01

Last Factory Calibration: 4/1/2024

Data Properties	
Start Date	9/19/2024
Start Time	7:22 AM
End Date	9/19/2024
End Time	2:03 PM
Test Length	00:06:41:00
Logging Interval	60 second(s)
Number of Data Points	401

Additional Information
There is no metadata related to this test

Test Statistics					
Channel	Average	Minimum	Maximum	Cal Factor	TWA
Aerosol (mg/m ³)	0.029	0.018 09/19/2024 07:50:43	0.046 09/19/2024 01:47:43	1 Factory 09/09/2024	0.024

Name: Test 4

Description: None

Location: Rooms 323 to 320

Instrument Name: SidePak Aerosol Monitor

Device Model Number: AM520

Device Serial Number: 5202223004

Firmware Version: B.01

Last Factory Calibration: 9/25/2023

Data Properties	
Start Date	9/19/2024
Start Time	7:30 AM
End Date	9/19/2024
End Time	2:08 PM
Test Length	00:06:38:00
Logging Interval	60 second(s)
Number of Data Points	398

Additional Information
There is no metadata related to this test

Test Statistics					
Channel	Average	Minimum	Maximum	Cal Factor	TWA
Aerosol (mg/m ³)	0.029	0.022 09/19/2024 02:03:32	0.041 09/19/2024 09:34:32	1 Factory 06/17/2024	0.024

Name: Test 3

Description: None

Location: Rooms 225 and 222

Instrument Name: SidePak Aerosol Monitor

Device Model Number: AM520

Device Serial Number: 5202131010

Firmware Version: B.01

Last Factory Calibration: 10/18/2023

Data Properties	
Start Date	9/19/2024
Start Time	7:24 AM
End Date	9/19/2024
End Time	2:05 PM
Test Length	00:06:41:00
Logging Interval	60 second(s)
Number of Data Points	401

Additional Information
There is no metadata related to this test

Test Statistics					
Channel	Average	Minimum	Maximum	Cal Factor	TWA
Aerosol (mg/m ³)	0.029	0.013 09/19/2024 08:40:20	0.056 09/19/2024 01:48:20	1 Factory 07/11/2024	0.024