
CERTIFICATE OF ANALYSIS

Client: Eastampton B.O.E
1 Student Drive
Eastampton NJ 08060

Report Date: 4/19/2017
Report No.: 533911 - Lead Water
Project: LIDW Sampling Lead Drinking Water
Project No.:

Client: EAS001

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6204926 **Location:** **Result(ppb):** <2.00
Client No.: 100-WF-1

Lab No.:6204927 **Location:** **Result(ppb):** <2.00
Client No.: 100-WF-2

Lab No.:6204928 **Location:** **Result(ppb):** <2.00
Client No.: 200-WF-1

Lab No.:6204929 **Location:** **Result(ppb):** <2.00
Client No.: 200-WF-2

Lab No.:6204930 **Location:** **Result(ppb):** <2.00
Client No.: 300N-WF-1

Lab No.:6204931 **Location:** **Result(ppb):** <2.00
Client No.: 300N-WF-2


Lab No.:6204932 **Location:** **Result(ppb):** <2.00
Client No.: 300N-WF-3


Lab No.:6204933 **Location:** **Result(ppb):** <2.00
Client No.: 300S-WF-1

Lab No.:6204934 **Location:** **Result(ppb):** <2.00
Client No.: 300S-WF-2

Lab No.:6204935 **Location:** **Result(ppb):** <2.00
Client No.: 300E-WF-1

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 4/10/2017
Date Analyzed: 04/18/2017
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Eastampton B.O.E
1 Student Drive
Eastampton NJ 08060

Client: EAS001

Report Date: 4/19/2017
Report No.: 533911 - Lead Water
Project: LIDW Sampling Lead Drinking Water
Project No.:

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6204936 **Location:** **Result(ppb):** <2.00
Client No.: 300E-WF-2

Lab No.: 6204937 **Location:** **Result(ppb):** <2.00
Client No.: 321-SINK-1

Lab No.: 6204938 **Location:** **Result(ppb):** <2.00
Client No.: 400-WF-1

Lab No.: 6204939 **Location:** **Result(ppb):** <2.00
Client No.: 400-WF-2

Lab No.: 6204940 **Location:** **Result(ppb):** <2.00
Client No.: 500-WF-1

Lab No.: 6204941 **Location:** **Result(ppb):** <2.00
Client No.: 500-WF-2

Lab No.: 6204942 **Location:** **Result(ppb):** <2.00
Client No.: 600-WF-1

Lab No.: 6204943 **Location:** **Result(ppb):** <2.00
Client No.: 700-WF-1


Lab No.: 6204944 **Location:** **Result(ppb):** <2.00
Client No.: KIT-ICE-1

Lab No.: 6204945 **Location:** **Result(ppb):** 2.80
Client No.: KIT-SINK-1

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 4/10/2017

Date Analyzed: 04/18/2017

Signature: 

Analyst: Chad Shaffer

Approved By: 

Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Eastampton B.O.E
1 Student Drive
Eastampton NJ 08060

Report Date: 4/19/2017
Report No.: 533911 - Lead Water
Project: LIDW Sampling Lead Drinking Water
Project No.:

Client: EAS001

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6204947	Location:	Result(ppb): <2.00
Client No.: ART-WF-1		


Lab No.: 6204948	Location:	Result(ppb): <2.00
Client No.: ART-WF-2		


Lab No.: 6204949	Location:	Result(ppb): <2.00
Client No.: CAF-WF-1		

Lab No.: 6204950	Location:	Result(ppb): <2.00
Client No.: CAF-WF-2		

Lab No.: 6204951	Location:	Result(ppb): <2.00
Client No.: CENTRAL		

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 4/10/2017
Date Analyzed: 04/18/2017
Signature: 
Analyst: Chad Shaffer

Approved By: 
 Frank E. Ehrenfeld, III
 Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Eastampton B.O.E
1 Student Drive
Eastampton NJ 08060

Report Date: 5/10/2017
Report No.: 535496 - Lead Water
Project: Eastampton Community School
Project No.:

Client: EAS001


LEAD WATER SAMPLE ANALYSIS SUMMARY


Lab No.:6220706
Client No.:KIT-STEAM-1

Location:Kitchen Steamer, 1st Draw

Result(ppb):10.1

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 5/2/2017
Date Analyzed: 05/10/2017
Signature: 
Analyst: Mark Stewart

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director