

## **New Wave Engineering**

ENVIRONMENTAL ENGINEERING CONSULTANTS

September 13, 2024

North Caldwell Public School District  
132A Gould Avenue  
North Caldwell, New Jersey 07006  
Atten: Mr. Michael Halik, Business Administrator

Re: Lead in Drinking Water Regulations and Results  
North Caldwell Public School District

Dear Mr. Halik,

On July 13, 2016, the State Board of Education adopted regulations regarding the testing for lead in drinking water in public schools throughout New Jersey. The regulations were filed with the Office of Administrative Law and became effective on July 13, 2016.

The regulations required testing for lead in all outlets where water may be consumed within 365 days of the effective date of the regulations. All districts were directed to develop a lead sampling plan that governed the collection and analysis of drinking water samples.

In addition, public schools are required to test for lead in drinking water **every three years**, as described and amended in state regulations.

North Caldwell Public School District complied with the State Regulations and tested all potable water sources. Should an area tested surpass the Corrective Action Level (CAL) of 15 ppb, a corrective action must occur, (e.g. replace the fountain, add a filter system, discontinue use). At that point, the area of concern will be re-tested,

As of this date, all potable water outlets have passed the State Regulations and a full report is submitted to your office, both digitally and bound, for your review. As required by State mandate, please post the attached water report on your school website for all concerned parties.

Best Regards,

**NEW WAVE ENGINEERING, LLC**

*Nadine Bello*


Nadine Bello, MS, RPIH, CIEC, AST

PO Box 4124, Wayne, New Jersey 07474

973-616-4601 Fax: Scan to Email

[Newwaveenvironmental.com](http://Newwaveenvironmental.com)

*"Environmental Solutions for Tomorrows Problems"*




# *Lead in Drinking Water Report*

North Caldwell Board of Education  
132A Gould Avenue  
North Caldwell, NJ 07006

September 2024

Prepared for:  
North Caldwell Board of Education  
132A Gould Avenue  
North Caldwell, NJ 07006

Prepared by:  
***New Wave Engineering, LLC***  
**PO Box 4124**  
**Wayne, New Jersey 07474**



September 13, 2024

Mr. Michael Halik, Business Administrator  
North Caldwell Board of Education  
132A Gould Avenue  
North Caldwell, NJ 07006

Re: Lead in Drinking Water Services per NJAC 6A:26  
Gould School, 132/132A Gould Avenue, North Caldwell, NJ 07006  
Grandview School, 35 Hamilton Drive East, North Caldwell, NJ 07006

Dear Mr. Halik,

New Wave is pleased to submit this lead in drinking water report for the North Caldwell Board of Education. This report details the methods and findings of the comprehensive lead in drinking water services as per New Jersey state regulations (amendments to N.J.A.C 6A:26 Educational Facilities) performed at the various schools in the North Public Caldwell School District, located at the above referenced addresses on August 30, 2024.

Best Regards,

*Nadine Bello*

Nadine Bello, MS, RPIH, CIEC, AST *New  
Wave Engineering, LLC*

## Table of Content

EXECUTIVE SUMMARY.....	Page 1
1.0 PROJECT BACKGROUND.....	Page 2
2.0 LEAD IN DRINKING WATER.....	Page 2
3.0 DRINKING WATER SAMPLING METHODOLOGY.....	Page 3
4.0 DRINKING WATER ANALYSIS RESULTS.....	Page 4
5.0 CONCLUSIONS & RECOMMENDATIONS.....	Page 7
6.0 DISCLAIMER.....	Page 7
7.0 CLOSING.....	Page 8

APPENDIX A Chain of Custody and Lab Results



## Executive Summary of Lead in Drinking Water Services

August 2024

New Wave Engineering was retained to conduct a first draw “lead in drinking water sampling” at the district’s school buildings located within the North Caldwell Board of Education in August of 2024. Water samples were collected from designated drinking water outlets at the following schools:

All samples were collected according to the regulatory guidelines outlined in the amendments to the N.J.A.C. 6A:26: Educational Facilities (July 2016) and its supporting documentation.

- **Gould School**
- **Grandview School**

First draw sample results indicated that water sources sampled at locations from the schools, exhibited no lead levels above the Regulatory Action Level of .015mg/l, or its equivalent: 15 ppbs. With no potable water sources in exceedance of the Action Level, no remediation of the water outlets is required. Continue with the Districts plumbing maintenance plan and replace any water filters as required by the manufacture’s recommendations. All plumbing repairs and upgrades must be documented in the district’s “Lead in Drinking Water” plan. According to State regulations, the next scheduled lead in water testing shall occur in three years, during the school year 2027/2028.

## 1.0 PROJECT BACKGROUND

New Wave Engineering was contacted by the North Caldwell Board of Education (the "Client") to perform lead in drinking water sampling to determine the lead content of drinking water from sources throughout the school facilities. Additionally, as per State regulations, New Wave was contracted to update a Quality Assurance Project Plan (QAPP) and a Sampling Plan (SP), including: a Drinking Water Outlet Inventory, Filter Inventory, and Outlet Location Schematic in conjunction with the District's Buildings and Grounds Director.

The purpose of lead in drinking water sampling is to determine if any sampled drinking water sources exhibit lead levels exceeding the Regulatory Action Level of 15 parts per billion (ppb) which may also be designated as: .015mg/l. Drinking water concentration points included: any water sources from which a student, staff, or faculty may reasonably drink or from which the water may be used for cooking or beverage preparation, including, but not limited to, water coolers/bubblers, kitchen faucets, Nurse's Office faucets, and Faculty/Staff lounges.

For further information on guidance protocols and Action Levels that were followed please refer to: The EPA's Revised Technical Guidance - "3Ts for Reduced Lead in Drinking Water in Schools" and the Guidance Document from NJDEP Division of Water Supply and Geoscience — *"Lead in Drinking Water: Guidance for Schools and Child Care Facilities Served by Public Water"*.

## 2.0 LEAD IN DRINKING WATER

Lead is a toxic substance that can be harmful to human health. As compared to adults, children are more susceptible to the detrimental health effects of lead, as their nervous systems are not yet fully developed. Exposure to lead can occur in a variety of ways including through food, soil, deteriorating lead-based paint, and drinking water. Lead can leach into drinking water from plumbing materials such as pipes and solder, as well as brass plumbing fixtures. For this investigation, planning, preparation, methodology, sampling, and follow up actions were conducted according to the technical guidance provided by New Jersey following the adoption of amendments to N.J.A.C. 6A:26: *"Educational Facilities, requiring the sampling of drinking water for Lead in Schools"*

### 3.0 DRINKING WATER SAMPLING METHODOLOGY

New Wave collected drinking water samples from water outlets throughout each school building. At each collection point, New Wave filled a 250 milliliter (ml) wide-mouth high density polyethylene (HDPE) sample collection bottle from the designated water source. Samples were collected after the water in each building had not been used for at least 8 hours, but not more than 48 hours. The initial sample at each collection point represents the first draw sample. The first draw sample is representative of the water from the end point of the water source (i.e., the bubbler/bottle filler or tap).

A field blank using lead-free laboratory reagent water was also collected for each Facility during the sampling event to rule out contamination of samples during the collection and transportation process. All samples were recorded utilizing proper chain of custody documents and couriered to *Garden State Laboratory*, a New Jersey certified laboratory (NJ Lab ID #20044) located in Hillside, New Jersey for analysis via EPA method 200.80.

During the initial sampling event on August 30, 2024, New Wave collected the following number of samples at each School Building:

#### **Gould School**

132 Gould Building

- 1) 8 First draw samples
- 2) 1 Field Blank Sample

132A Gould Building

- 1) 4 First Draw Samples
- 2) 1 Field Blank Sample

#### **Grandview School**

- 1) 33 First draw samples
- 2) 1 Field Blank Sample

For a complete drinking water outlet inventory and sampling location diagram for each facility, please refer to the Sampling Plan, dated May 2017. Updates to this documentation can be found in the Field Log Book for each facility.



## 4.0 DRINKING WATER ANALYSIS RESULTS

The analytical “lead in drinking water results” for each first draw sample is listed in Tables below:

Table 1: Analytical Lead Results for First Draw Water Samples Collected from **Gould Street School** August 30, 2024

Sample I.D.	Type of Collection Point	Lead Concentration (mg/l)	Above Regulatory Action Level?
NC-Gould-24-01	Nurse’s Sink	< 0.00100	No
NC-Gould -24-02	Hallway by Main Office Bubbler	< 0.00100	No
NC-Gould -24-03	Hallway by Gym B/F	< 0.00100	No
NC-Gould -24-04	Kitchen Sink	< 0.01000	No
NC-Gould -24-05	Hallway by 123 B/F	< 0.00100	No
NC-Gould -24-06	Hallway by 115 Bubbler L	< 0.00100	No
NC-Gould -24-07	Hallway by 115 Bubbler R	< 0.00100	No
NC-Gould -24-08	Teacher’s Room Sink	< 0.00100	No
NC-Gould -24-09	Field Blank	< 0.00100	No
NC-Gould -24-01A	Hallway by Science B/F	< 0.00100	No
NC-Gould -24-02A	By Elevator Bubbler	< 0.00100	No
NC-Gould -24-03A	Teacher’s Room Sink	< 0.00100	No
NC-Gould -24-04A	Field Blank	< 0.00100	No

BF= Bottle Filler Station W/F= Water Fountain B= Bubbler S=Sink

Table 2: Analytical Lead Results for First Draw Water Samples  
 Collected from **Grandview School** taken on August 30, 2024

Sample ID.	Type of Collection Point	Lead Concentration (mg/l)	Above Regulatory Action Level?
NC-Grand-24-01	Room 207 Bubblers	< 0.00100	No
NC-Grand -24-02	Hallway by 207 Bubblers	< 0.00100	No
NC-Grand -24-03	Hallway by 207 B/F	< 0.00100	No
NC-Grand -24-04	Room 206 Bubblers	< 0.00100	No
NC-Grand -24-05	Room 205 Bubblers	< 0.00100	No
NC-Grand -24-06	Room 204 Bubblers	< 0.00100	No
NC-Grand -24-07	Room 203 Bubblers	< 0.00100	No
NC-Grand -24-08	Room 202 Bubblers	< 0.00100	No
NC-Grand -24-09	Nurse's Sink	< 0.00100	No
NC-Grand -24-10	Hallway by Nurse B/F	< 0.00100	No
NC-Grand -24-11	Teacher's Room Sink	< 0.00100	No
NC-Grand -24-12	Hallway by 310 B/F	< 0.00100	No
NC-Grand -24-13	Room 302 Bubblers	< 0.00100	No
NC-Grand -24-14	Room 309 Bubblers	< 0.00100	No
NC-Grand -24-15	Room 303 Bubblers	< 0.00100	No
NC-Grand -24-16	Room 308 Bubblers	< 0.00100	No
NC-Grand -24-17	Room 304 Bubblers	< 0.00100	No
NC-Grand -24-18	Room 307 Bubblers	< 0.00100	No

Sample ID.	Type of Collection Point	Lead Concentration (mg/l)	Above Regulatory Action Level!?
NC-Grand -24-19	Room 305 Bubblers	< 0.00100	No
NC-Grand -24-20	Room 306 Bubblers	< 0.00100	No
NC-Grand -24-21	Room 105 Bubblers	< 0.00100	No
NC-Grand -24-22	Art Room Bubblers	< 0.00100	No
NC-Grand -24-23	Room 107 Bubblers	< 0.00100	No
NC-Grand -24-24	Room 116 Bubblers	< 0.00100	No
NC-Grand -24-25	Room 108 Bubblers	< 0.00100	No
NC-Grand -24-26	Room 115 Bubblers	< 0.00100	No
NC-Grand -24-27	Room 109 Bubblers	< 0.00100	No
NC-Grand -24-28	Room 114 Bubblers	< 0.00100	No
NC-Grand -24-29	Room 113 Bubblers	< 0.00100	No
NC-Grand -24-30	Hallway by Library B/F L	< 0.00100	No
NC-Grand -24-31	Hallway by Library B/F R	< 0.00100	No
NC-Grand -24-32	Kitchen Sink Right	< 0.00100	No
NC-Grand -24-33	Kitchen Sink Left	< 0.00100	No
NC-Grand -24-34	Field Blank	< 0.00100	No

B/F= Bottle Filler B= Bubblers W/F= Water Fountain S= Sink

All laboratory analytical results of first-draw samples were compared to the NJDEP's Regulatory Action Level of 15.5 ppb or .015 mg/l for lead. Analysis of lead in the first draw drinking water samples indicated that, at the time of the sampling event, no water sources tested exceeded the action level.

## 5.0 CONCLUSIONS & RECOMMENDATIONS

New Wave collected first draw samples from drinking water sources throughout the North Caldwell Board of Education school facilities. First draw sample results indicated that no water outlet sources *exceeded* the regulatory action level of 15 ppb or .015mg/l. In conclusion of the comprehensive “lead in drinking water” services, New Wave offers the following recommendations:

- Continue to monitor lead in drinking water levels as part of a regular sampling and maintenance plan, per New Jersey State regulations.
- Implement an aerator cleaning maintenance program to prevent the build up of debris behind the aerator screen which may contribute to elevated lead levels.
- Enter all filter maintenance, aerator maintenance, plumbing repairs/changes and any other important information into the *Field Log Book* for each School.
- Use only cold water for food and beverage preparation, as hot water is more likely to contribute to the corrosion of plumbing materials and therefore may contain a greater level of water contaminants from the plumbing system.

## 6.0 Disclaimer

This investigation focused on lead in drinking water. No other heavy metals or additional contaminants were sampled for/or analyzed. Note: Lead concentrations in water can change as water continues to move through the water system.

Each sample taken was a “grab sample” and represents lead concentrations only at the specific time of collection and may vary based upon the water usage in the facility. Interpretation of these results is only valid if the facility is serviced by a municipal water supplier or water utility.

Our lead sampling event was in response to recent amendments to N.J.A.C. 6A:26i *Educational Facilities* dated July 13, 2016, which requires testing for lead in drinking water of public and charter school districts with retesting every three years.

The Lead Hazard Assessment has limitations with regards to identification of actual health and environmental issues. It is limited to only those items listed in the report and all items reflect conditions at the time of the assessment.

New Wave Engineering, LLC warrants only that the contents of this report constitute an informed discussion of the assessment at the subject property and is prepared exclusively for the above noted client. New Wave Engineering, LLC assumes no liability with regards to the use of this information or decisions which are made regarding the subject properties. It is at the discretion of the School District, given the results and information in this report, to use their own best judgment to determine any appropriate course of action.

## **7.0 Closing**

The drinking water in the North Caldwell Public Schools is below the action level of 15 ppb or .015 mg/l.

Thank you for utilizing New Wave to assist your District with this project. Please do not hesitate to call if you have any questions relating to this report or for any other environmental health and safety concerns.

APPENDIX A  
CHAIN OF CUSTODY  
AND  
LAB RESULTS



# Garden State Laboratories, Inc.

## Report of Analysis

410 Hillside Ave.  
Hillside, NJ 07205

Main Lab  
NJDEP Lab Cert. #20044

Jersey Shore Lab  
NJDEP Lab Cert. #15037

Lakehurst Lab  
NJDEP Lab Cert. #15041

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director  
Jordan B. Klein, B.A., Exec. Vice President  
Sharon Ercoliani, B.A. Laboratory Manager

Telephone: 800-273-8901  
Email: info@gsllabs.com  
Internet: www.gsllabs.com

For: North Caldwell BOE - NW  
132A Gould Avenue  
North Caldwell, NJ 07006

Laboratory Director:

Report Date: 09/12/2024

Attention: Jerry Bello

Client Number: NOR19

Sample ID: GRANDVIEW SCHOOL 35  
HAMILTON DR. EAST N.  
CALDWELL/ NC - GRAND-24-  
01 BUBBLER IN 207  
Lab Sample ID: 240830023-01

Site: Collection Date/Time: 08/30/2024 06:40

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	09/09/24 14:08	

Sample ID: GRANDVIEW SCHOOL 35  
HAMILTON DR. EAST N.  
CALDWELL/ NC - GRAND-24-  
02 BUBBLER HALL 207  
Lab Sample ID: 240830023-02

Site: Collection Date/Time: 08/30/2024 06:41

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	09/09/24 14:11	

Sample ID: GRANDVIEW SCHOOL 35  
HAMILTON DR. EAST N.  
CALDWELL/ NC - GRAND-24-  
03 B/F HALL BY 207  
Lab Sample ID: 240830023-03

Site: Collection Date/Time: 08/30/2024 06:41

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/09/24 11:23	

Sample ID: GRANDVIEW SCHOOL 35  
HAMILTON DR. EAST N.  
CALDWELL/ NC - GRAND-24-  
04 BUBBLER IN 206  
Lab Sample ID: 240830023-04

Site: Collection Date/Time: 08/30/2024 06:42

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/09/24 11:28	



Garden State Laboratories, Inc.

Sample ID: GRANDVIEW SCHOOL 35  
HAMILTON DR. EAST N.  
CALDWELL/ NC - GRAND-24-  
05 BUBBLER IN 205

Lab Sample ID: 240830023-05

Site: Collection Date/Time: 08/30/2024 06:42

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/09/24 11:42	

Sample ID: GRANDVIEW SCHOOL, 35  
HAMILTON DR. EAST  
NORTH CALDWELL/ NC-  
GRAND-24-06 BUBBLER IN  
204

Lab Sample ID: 240830023-06

Site: Collection Date/Time: 08/30/2024 06:43

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/09/24 11:47	

Sample ID: GRANDVIEW SCHOOL, 35  
HAMILTON DR. EAST  
NORTH CALDWELL/ NC-  
GRAND-24-07 BUBBLER IN  
203

Lab Sample ID: 240830023-07

Site: Collection Date/Time: 08/30/2024 06:44

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/09/24 11:57	

Sample ID: GRANDVIEW SCHOOL, 35  
HAMILTON DR. EAST  
NORTH CALDWELL/ NC-  
GRAND-24-08 BUBBLER IN  
202

Lab Sample ID: 240830023-08

Site: Collection Date/Time: 08/30/2024 06:45

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/09/24 12:02	





Garden State Laboratories, Inc.

Sample ID: GRANDVIEW SCHOOL, 35 HAMILTON DR. EAST NORTH CALDWELL/ NC- GRAND-24-09 NURSES SINK      Lab Sample ID: 240830023-09

Site:      Collection Date/Time: 08/30/2024 06:45

Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/09/24 12:07	

Sample ID: GRANDVIEW SCHOOL, 35 HAMILTON DR. EAST NORTH CALDWELL/ NC- GRAND-24-10 B/F BY NURSE      Lab Sample ID: 240830023-10

Site:      Collection Date/Time: 08/30/2024 06:47

Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/09/24 12:12	

Sample ID: GRANDVIEW SCHOOL 35 HAMILTON DR. EAST NORTH CALDWELL/ NC- GRAND-24-11 TEACHERS SINK      Lab Sample ID: 240830023-11

Site:      Collection Date/Time: 08/30/2024 06:47

Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/09/24 12:17	

Sample ID: GRANDVIEW SCHOOL 35 HAMILTON DR. EAST NORTH CALDWELL/ NC- GRAND-24-12 B/F HALL BY 310      Lab Sample ID: 240830023-12

Site:      Collection Date/Time: 08/30/2024 06:48

Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/09/24 12:21	



Garden State Laboratories, Inc.

Sample ID: GRANDVIEW SCHOOL 35  
 HAMILTON DR. EAST  
 NORTH CALDWELL/ NC-  
 GRAND-24-13 BUBBLER IN  
 302

Lab Sample ID: 240830023-13

Site: Collection Date/Time: 08/30/2024 06:49

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/09/24 12:26	

Sample ID: GRANDVIEW SCHOOL 35  
 HAMILTON DR. EAST  
 NORTH CALDWELL/ NC-  
 GRAND-24-14 BUBBLER IN  
 309

Lab Sample ID: 240830023-14

Site: Collection Date/Time: 08/30/2024 06:49

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/09/24 12:46	

Sample ID: GRANDVIEW SCHOOL 35  
 HAMILTON DR. EAST  
 NORTH CALDWELL/ NC-  
 GRAND-24-15 BUBBLER IN  
 303

Lab Sample ID: 240830023-15

Site: Collection Date/Time: 08/30/2024 06:50

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/09/24 12:51	

Sample ID: GRANDVIEW SCHOOL 35  
 HAMILTON DR. EAST  
 NORTH CLADWELL/ NC-  
 GRAND-24-16 BUBBLER IN  
 308

Lab Sample ID: 240830023-16

Site: Collection Date/Time: 08/30/2024 06:50

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/10/24 12:43	



Garden State Laboratories, Inc.

Sample ID: GRANDVIEW SCHOOL 35  
 HAMILTON DR. EAST  
 NORTH CLADWELL/ NC-  
 GRAND-24-17 BUBBLER IN  
 304

Lab Sample ID: 240830023-17

Site: Collection Date/Time: 08/30/2024 06:51

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/10/24 12:58	

Sample ID: GRANDVIEW SCHOOL 35  
 HAMILTON DR. EAST  
 NORTH CLADWELL/ NC-  
 GRAND-24-18 BUBBLER IN  
 307

Lab Sample ID: 240830023-18

Site: Collection Date/Time: 08/30/2024 06:51

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/10/24 13:03	

Sample ID: GRANDVIEW SCHOOL 35  
 HAMILTON DR. EAST  
 NORTH CLADWELL/ NC-  
 GRAND-24-19 BUBBLER IN  
 305

Lab Sample ID: 240830023-19

Site: Collection Date/Time: 08/30/2024 06:54

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/10/24 13:08	

Sample ID: GRANDVIEW SCHOOL 35  
 HAMILTON DR. EAST  
 NORTH CLADWELL/ NC-  
 GRAND-24-20 BUBBLER IN  
 306

Lab Sample ID: 240830023-20

Site: Collection Date/Time: 08/30/2024 06:55

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/10/24 13:13	



Garden State Laboratories, Inc.

Sample ID: GRANDVIEW SCHOOL 35  
HAMILTON DR EAST. NORTH  
CALDWELL/ NC GRAND-24-  
21 BUBBLER 105

Lab Sample ID: 240830023-21

Site: Collection Date/Time: 08/30/2024 06:57

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/10/24 13:17	

Sample ID: GRANDVIEW SCHOOL 35  
HAMILTON DR EAST. NORTH  
CALDWELL/ NC GRAND-24-  
22 BUBBLER ART RM

Lab Sample ID: 240830023-22

Site: Collection Date/Time: 08/30/2024 06:58

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/10/24 13:22	

Sample ID: GRANDVIEW SCHOOL 35  
HAMILTON DR EAST. NORTH  
CALDWELL/ NC GRAND-24-  
23 BUBBLER IN 107

Lab Sample ID: 240830023-23

Site: Collection Date/Time: 08/30/2024 06:58

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/10/24 13:47	

Sample ID: GRANDVIEW SCHOOL 35  
HAMILTON DR EAST. NORTH  
CALDWELL/ NC GRAND-24-  
24 BUBBLER IN 116

Lab Sample ID: 240830023-24

Site: Collection Date/Time: 08/30/2024 06:59

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/10/24 13:52	

Sample ID: GRANDVIEW SCHOOL 35  
HAMILTON DR EAST. NORTH  
CALDWELL/ NC GRAND-24-  
25 BUBBLER IN 108

Lab Sample ID: 240830023-25

Site: Collection Date/Time: 08/30/2024 07:00

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/10/24 13:57	



Garden State Laboratories, Inc.

Sample ID: GRANDVIEW SCHOOL 35  
 HAMILTON DRIVE EAST  
 NORTH CALDWELL/ NC  
 GRAND-24-26 BUBBLER IN  
 115

Lab Sample ID: 240830023-26

Site: Collection Date/Time: 08/30/2024 07:00

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/10/24 14:01	

Sample ID: GRANDVIEW SCHOOL 35  
 HAMILTON DRIVE EAST  
 NORTH CALDWELL/ NC  
 GRAND-24-27 BUBBLER IN  
 109

Lab Sample ID: 240830023-27

Site: Collection Date/Time: 08/30/2024 07:01

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/10/24 14:06	

Sample ID: GRANDVIEW SCHOOL 35  
 HAMILTON DRIVE EAST  
 NORTH CALDWELL/ NC  
 GRAND-24-28 BUBBLER IN  
 114

Lab Sample ID: 240830023-28

Site: Collection Date/Time: 08/30/2024 07:02

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/10/24 14:11	

Sample ID: GRANDVIEW SCHOOL 35  
 HAMILTON DRIVE EAST  
 NORTH CALDWELL/ NC  
 GRAND-24-29 BUBBLER IN  
 113

Lab Sample ID: 240830023-29

Site: Collection Date/Time: 08/30/2024 07:02

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/10/24 14:16	



Garden State Laboratories, Inc.

Sample ID: GRANDVIEW SCHOOL 35  
 HAMILTON DRIVE EAST  
 NORTH CALDWELL/ NC  
 GRAND-24-30 BUBBLER BY  
 LIBRARY LEFT

Lab Sample ID: 240830023-30

Site: Collection Date/Time: 08/30/2024 07:05

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/10/24 14:21	

Sample ID: GRANDVIEW SCHOOL 35  
 HAMILTON DR. EAST  
 NORTH CALDWELL/ NC  
 GRAND-24-31 BUBBLER  
 LIBRARY RIGHT

Lab Sample ID: 240830023-31

Site: Collection Date/Time: 08/30/2024 07:05

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/10/24 14:26	

Sample ID: GRANDVIEW SCHOOL 35  
 HAMILTON DR. EAST  
 NORTH CALDWELL/ NC  
 GRAND-24-32 KITCHEN SINK  
 R

Lab Sample ID: 240830023-32

Site: Collection Date/Time: 08/30/2024 07:06

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	09/10/24 14:46	

Sample ID: GRANDVIEW SCHOOL 35  
 HAMILTON DR. EAST  
 NORTH CALDWELL/ NC  
 GRAND-24-33 KITCHEN SINK  
 L

Lab Sample ID: 240830023-33

Site: Collection Date/Time: 08/30/2024 07:07

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	09/12/24 10:00	



Garden State Laboratories, Inc.

Sample ID: GRANDVIEW SCHOOL 35  
 HAMILTON DR. EAST  
 NORTH CALDWELL/ NC  
 GRAND-24-34 FIELD BLANK

Lab Sample ID: 240830023-34

Site: Collection Date/Time: 08/30/2024 07:08

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	09/12/24 10:09	

Sample ID: GOULD SCHOOL - 132  
 GOULD AVENUE NORTH  
 CALDWELL 07006/ NC-  
 GOULD-24-01 NURSE SINK

Lab Sample ID: 240830023-35

Site: Collection Date/Time: 08/30/2024 06:18

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	09/12/24 10:11	

Sample ID: GOULD SCHOOL - 132  
 GOULD AVENUE NORTH  
 CALDWELL 07006/ NC-  
 GOULD-24-02 BUBBLER  
 HALL BY MAIN OFFICE

Lab Sample ID: 240830023-36

Site: Collection Date/Time: 08/30/2024 06:18

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	09/12/24 10:14	

Sample ID: GOULD SCHOOL - 132  
 GOULD AVENUE NORTH  
 CALDWELL 07006/ NC-  
 GOULD-24-03 B/F HALL BY  
 GYM

Lab Sample ID: 240830023-37

Site: Collection Date/Time: 08/30/2024 06:18

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	09/12/24 10:17	

Sample ID: GOULD SCHOOL - 132  
 GOULD AVENUE NORTH  
 CALDWELL 07006/ NC-  
 GOULD-24-04 KITCHEN SINK

Lab Sample ID: 240830023-38

Site: Collection Date/Time: 08/30/2024 06:19

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	09/12/24 10:20	



Garden State Laboratories, Inc.

Sample ID: GOULD SCHOOL - 132 GOULD AVENUE NORTH CALDWELL 07006/ NC-GOULD-24-05 B/F BY 123  
 Lab Sample ID: 240830023-39

Site: Collection Date/Time: 08/30/2024 06:19

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	09/12/24 10:23	

Sample ID: GOULD SCHOOL 132 GOULD AVENUE NORTH CALDWELL, NJ/ NC-GOULD-24-06 BUBBLER BY 115 L  
 Lab Sample ID: 240830023-40

Site: Collection Date/Time: 08/30/2024 06:20

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	09/12/24 10:31	

Sample ID: GOULD SCHOOL 132 GOULD AVENUE NORTH CALDWELL, NJ/ NC-GOULD-24-07 BUBBLER BY 115 R  
 Lab Sample ID: 240830023-41

Site: Collection Date/Time: 08/30/2024 06:20

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	09/12/24 10:34	

Sample ID: GOULD SCHOOL 132 GOULD AVENUE NORTH CALDWELL, NJ/ NC-GOULD-24-08 TEACHERS SINK  
 Lab Sample ID: 240830023-42

Site: Collection Date/Time: 08/30/2024 06:21

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	09/12/24 10:37	

Sample ID: GOULD SCHOOL 132 GOULD AVENUE NORTH CALDWELL, NJ/ NC-GOULD-24-09 FIELD BLANK  
 Lab Sample ID: 240830023-43

Site: Collection Date/Time: 08/30/2024 06:21

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	09/12/24 10:40	





Garden State Laboratories, Inc.

Sample ID: GOULD SCHOOL - 132A  
GOULD AVENUE NORTH  
CALDWELL/ NC-GOULDA-24  
-01A B/F BY SCIENCE

Lab Sample ID: 240830023-44

Site: Collection Date/Time: 08/30/2024 06:15

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	09/12/24 10:42	

Sample ID: GOULD SCHOOL - 132A  
GOULD AVENUE NORTH  
CALDWELL/ NC-GOULDA-24  
-02A BUBBLER BY  
ELEVATOR

Lab Sample ID: 240830023-45

Site: Collection Date/Time: 08/30/2024 06:15

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	09/12/24 10:45	

Sample ID: GOULD SCHOOL - 132A  
GOULD AVENUE NORTH  
CALDWELL/ NC-GOULDA-24  
-03A TEACHERS SINK

Lab Sample ID: 240830023-46

Site: Collection Date/Time: 08/30/2024 06:16

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	09/12/24 10:48	

Sample ID: GOULD SCHOOL - 132A  
GOULD AVENUE NORTH  
CALDWELL/ NC-GOULDA-24  
-04A FIELD BLANK

Lab Sample ID: 240830023-47

Site: Collection Date/Time: 08/30/2024 06:17

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	09/12/24 10:51	

*DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit, MDL=Method Detection Limit, SM YR=Standard Methods Publication Year, and NC=Not Certified. The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice. Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.*

# Garden State Laboratories, Inc.

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**  
**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

### Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827  
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

8/30/24 12:33 27.6c

NO EC

Page \_\_\_\_\_ of \_\_\_\_\_

GSL CLIENT # **NOR 19**

MICRO#

CHEM. **210830023-01-**

SAMPLE REC'D BY: **CS**

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: **NORTH Caldwell Board of Ed** Contact/Authorized by: **JERRY Bello**  
 Mailing Address: **132 A Gould Avenue** Phone: **973-981-4856**  
 City/State/Zip: **NORTH Caldwell, NJ 07006** Email: **JERRY@newkme**  
**environmental.com**

### SAMPLE INFORMATION

SAMPLE TYPE: **DWI**  
 SAMPLE LOCATION: **GRANDVIEW school 35 Hamilton DR. EAST N. Caldwell**

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	<input type="checkbox"/> List attached	Total Pages _____	No.	Type*	Size	Pres.*
X		NC-Grand-24-01 bubbler in 207	8-30-24	6:40	X		LEAD FIRST DRAW 23-01	1	P	250mL	A	
X		NC-Grand-24-02 bubbler Hall 207	8-30-24	6:41	X		LEAD FIRST DRAW 23-02	1	P	250mL	A	
X		NC-Grand-24-03 B/P Hall by 207	8-30-24	6:41	X		LEAD FIRST DRAW 23-03	1	P	250mL	A	
X		NC-Grand-24-04 bubbler in 206	8-30-24	6:42	X		LEAD FIRST DRAW 23-04	1	P	250mL	A	
X		NC-Grand-24-05 bubbler in 205	8-30-24	6:42	X		LEAD FIRST DRAW 23-05	1	P	250mL	A	

\*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: \_\_\_\_\_  
 \*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: \_\_\_\_\_

TURNAROUND TIME:  Standard  Rush (if RUSH REQUESTED) Rush Due by: \_\_\_\_\_

REPORT FORMAT:  Standard Report  Other/Specify: \_\_\_\_\_

Standard Report + E2 PWS ID#: \_\_\_\_\_

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$

Payment Method:  Credit Card Type:  Check #  Other: See Quote

Note:

### SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): <b>NADINE Bello</b>	Signature: <i>Nadine Bello</i>	Date/Time: <b>08-30-24</b>
Client/Client's Representative (PRINT): <b>NADINE Bello</b>	Signature: <i>Nadine Bello</i>	Date/Time: <b>08-30-24</b>
1. Received/Relinquished by (PRINT):	Signature: _____	Date/Time: _____
2. Received/Relinquished by (PRINT): <i>Karen...</i>	Signature: <i>Bull...</i>	Date/Time: <b>8/30/24 12:33</b>

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

# Garden State Laboratories, Inc.

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**  
**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

### Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827  
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:  
 8/30/24 12:33 27.6c  
 NO EDC

Page of

GSL CLIENT # **NOR19**

MICRO #  
 CHEM. # **240820023-06-**

SAMPLE REC'D BY: **10**

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: **NORTH CALDWELL Board of Ed.** Contact/Authorized by: **JERRY Bello**  
 Mailing Address: **132A Gould Avenue** Phone: **973-981-4856**  
 City/State/Zip: **NORTH Caldwell, NJ 07006** Email: **JERRY@newwave**  
**environmental.com**

### SAMPLE INFORMATION

SAMPLE TYPE: **DW**  
 SAMPLE LOCATION: **GRANDVIEW School, 35 Hamilton DR. EAST NORTH Caldwell**

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION				
			Date	Time	AM	PM	<input type="checkbox"/> List attached	Total Pages _____	No.	Type*	Size	Pres.*	
X		NC-GRAND-24-06 bubble in 204	8-30-24	6:43	X		LEAD FIRST DRAW 23-06			1	P	250ML	A
X		NC-GRAND-24-07 bubble in 203	8-30-24	6:44	X		LEAD FIRST DRAW 23-07			1	P	250ML	A
X		NC-GRAND-24-08 bubble in 202	8-30-24	6:45	X		LEAD FIRST DRAW 23-08			1	P	250ML	A
X		NC-GRAND-24-09 nurse's sink	8-30-24	6:45	X		LEAD FIRST DRAW 23-09			1	P	250ML	A
X		NC-GRAND-24-10 B/F by nurse	8-30-24	6:47	X		LEAD FIRST DRAW 23-10			1	P	250ML	A

\*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: \_\_\_\_\_  
 \*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: \_\_\_\_\_

TURNAROUND TIME:  Standard  Rush (if RUSH REQUESTED) Rush Due by: \_\_\_\_\_

REPORT FORMAT:  Standard Report  Other/Specify: \_\_\_\_\_

Standard Report + E2 PWS ID#: \_\_\_\_\_

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$

Payment Method:  Credit Card Type: \_\_\_\_\_  Check # \_\_\_\_\_  Other: See Quote

Note: \_\_\_\_\_

### SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): <b>NADINE BELLO</b>	Signature: <i>Nadine Bello</i>	Date/Time: <b>8-30-24</b>
Client/Client's Representative (PRINT): <b>NADINE Bello</b>	Signature: <i>Nadine Bello</i>	Date/Time: <b>8-30-24</b>
1. Received/Relinquished by (PRINT): _____	Signature: _____	Date/Time: _____
2. Received/Relinquished by (PRINT): <i>[Signature]</i>	Signature: <i>[Signature]</i>	Date/Time: <b>8/30/24 12:33</b>

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

# Garden State Laboratories, Inc.

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**  
**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

### Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827  
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

8/30/24 12:33 27.6c  
 DW EOL

Page of

GSL CLIENT # NOR 19

MICRO #

CHEM. # 240830083-11-15

SAMPLE REC'D BY:

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: **NORTH CALDWELL Bd of Ed** Contact/Authorized by: **JERRY Bello**  
 Mailing Address: **132 A Gould Avenue** Phone: **973-981-4850**  
 City/State/Zip: **NORTH CALDWELL, NJ 07006** Email: **JERRY@newwaveenvironmental.com**

### SAMPLE INFORMATION

SAMPLE TYPE: **DW**  
 SAMPLE LOCATION: **GRANDVIEW School 35 HAMILTON DR EAST NORTH CALDWELL**

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	<input type="checkbox"/> List attached	Total Pages _____	No.	Type*	Size	Pres.*
X		NC-GRAND-24-11 Teacher's Smk	8-30-24	6:47	X		LEAD FIRST DRAW 23-11	1	P	250ML	A	
X		NC-GRAND-24-12 B/F Hall by 310	8-30-24	6:48	X		LEAD FIRST DRAW 23-12	1	P	250ML	A	
X		NC-GRAND-24-13 bubble in 302	8-30-24	6:49	X		LEAD FIRST DRAW 23-13	1	P	250ML	A	
X		NC-GRAND-24-14 bubble in 309	8-30-24	6:49	X		Lead First Draw 23-14	1	P	250ML	A	
X		NC-GRAND-24-15 bubble in 303	8-30-24	6:50	✓		Lead First Draw 23-15	1	P	250ML	A	

\*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: \_\_\_\_\_  
 \*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: \_\_\_\_\_

SUBCONTRACTED WORK

TURNAROUND TIME:  Standard  Rush (IF RUSH REQUESTED) Rush Due by:

SEND TO:

REPORT FORMAT:  Standard Report  Other/Specify:

DATE/TIME:

Standard Report + E2 PWS ID#:

METHOD OF SHIPMENT:

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$

Payment Method:  Credit Card Type:  Check #  Other: See Quote

Note:

### SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): <b>NADINE Bello</b>	Signature: <i>Nadine Bello</i>	Date/Time: <b>8-30-24</b>
Client/Client's Representative (PRINT): <b>NADINE Bello</b>	Signature: <i>Nadine Bello</i>	Date/Time: <b>8-30-24</b>
1. Received/Relinquished by (PRINT):	Signature: <i>[Signature]</i>	Date/Time:
2. Received/Relinquished by (PRINT):	Signature: <i>[Signature]</i>	Date/Time: <b>8/29/24 12:33</b>

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

# Garden State Laboratories, Inc.

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**  
**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

### Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827  
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

8/30/24 12:33 27.6  
 NJDEP

Page of

GSL CLIENT # **NOR19**

MICRO #

CHEM. # **240830023-16-**

SAMPLE REC'D BY: **20**

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: **NORTH CALDWELL Bd of Ed** Contact/Authorized by: **Jeely Bello**  
 Mailing Address: **132A GOULD AVENUE** Phone: **973 981-4850**  
 City/State/Zip: **NORTH CALDWELL, NJ 07006** Email: **Jeely@newwave**  
**environmental.com**

### SAMPLE INFORMATION

SAMPLE TYPE: **DW**  
 SAMPLE LOCATION: **GRANDVIEW School 35 Hamilton Dr. EAST NORTH CALDWELL**

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	<input type="checkbox"/> List attached	Total Pages _____	No.	Type*	Size	Pres.*
X		NG-Grand-24-16 bubbler in 308	8-30-24	6:50	X		LEAD FIRST DRAW 23-16		1	P	250ml	A
X		NG-Grand-24-17 bubbler in 304	8-30-24	6:51	X		LEAD FIRST DRAW 23-17		1	P	250ml	A
X		NG-Grand-24-18 bubbler in 307	8-30-24	6:51	X		LEAD FIRST DRAW 23-18		1	P	250ml	A
X		NG-Grand-24-19 bubbler in 305	8-30-24	6:54	X		LEAD FIRST DRAW 23-19		1	P	250ml	A
X		NG-Grand-24-20 bubbler in 306	8-30-24	6:55	X		LEAD FIRST DRAW 23-20		1	P	250ml	A

\*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: \_\_\_\_\_  
 \*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: \_\_\_\_\_

SUBCONTRACTED WORK

TURNAROUND TIME:  Standard  Rush (if RUSH REQUESTED) Rush Due by:

SEND TO:

REPORT FORMAT:  Standard Report  Other/Specify:

DATE/TIME:

Standard Report + E2 PWS ID#:

METHOD OF SHIPMENT:

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$

Payment Method:  Credit Card Type:  Check #  Other: See Quote

Note:

### SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): **NADINE Bello** Signature: *Nadine Bello* Date/Time: **8-30-24**

Client/Client's Representative (PRINT): **NADINE Bello** Signature: *Nadine Bello* Date/Time: **8-30-24**

1. Received/Relinquished by (PRINT): \_\_\_\_\_ Signature: \_\_\_\_\_ Date/Time: \_\_\_\_\_

2. Received/Relinquished by (PRINT): \_\_\_\_\_ Signature: *[Signature]* Date/Time: **8/30/24 12:33**

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

# Garden State Laboratories, Inc.

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**  
**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

### Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827  
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

8/30/24 12:33 27.6c  
 110500

Page \_\_\_\_\_ of \_\_\_\_\_

GSL CLIENT # **NOR 19**

MICRO#

CHEM. **240830023-21-25**

SAMPLE REC'D BY:

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: **NORTH CALDWELL Bd of Ed** Contact/Authorized by: **JERRY Bello**  
 Mailing Address: **132 A Gould Avenue** Phone: **973-981-4850**  
 City/State/Zip: **NORTH Caldwell, NJ 07006** Email: **JERRY@newwaveenvironmental.com**

### SAMPLE INFORMATION

SAMPLE TYPE: **DW**  
 SAMPLE LOCATION: **GRANDVIEW School 35 Hamilton DR EAST NORTH Caldwell**

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	<input type="checkbox"/> List attached	Total Pages _____	No.	Type*	Size	Pres.*
X		NC GRAND 24-21 Bubble 105	8-30-24	6:57	X		LEAD - FIRST DRAW 23-21	1	P	250ML A		
X		NC GRAND 24-22 Bubble ART 106	8-30-24	6:58	X		LEAD FIRST DRAW 23-22	1	P	250ML A		
X		NC GRAND 24-23 Bubble in 107	8-30-24	6:58	X		LEAD FIRST DRAW 23-23	1	P	250ML A		
X		NC GRAND 24-24 Bubble in 116	8-30-24	6:59	X		LEAD FIRST DRAW 23-24	1	P	250ML A		
X		NC GRAND 24-25 Bubble in 108	8-30-24	7:00	X		LEAD FIRST DRAW 23-25	1	P	250ML A		

\*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: \_\_\_\_\_  
 \*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: \_\_\_\_\_

SUBCONTRACTED WORK

TURNAROUND TIME:  Standard  Rush (if RUSH REQUESTED) Rush Due by: \_\_\_\_\_

SEND TO: \_\_\_\_\_

REPORT FORMAT:  Standard Report  Other/Specify: \_\_\_\_\_

DATE/TIME: \_\_\_\_\_

Standard Report + E2 PWS ID#: \_\_\_\_\_

METHOD OF SHIPMENT: \_\_\_\_\_

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$

Payment Method:  Credit Card Type: \_\_\_\_\_  Check # \_\_\_\_\_  Other: See Quote

Note: \_\_\_\_\_

### SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): <b>NADINE BELLO</b>	Signature: <i>Nadine Bello</i>	Date/Time: <b>8-30-24</b>
Client/Client's Representative (PRINT): <b>NADINE Bello</b>	Signature: <i>Nadine Bello</i>	Date/Time: <b>8-30-24</b>
1. Received/Relinquished by (PRINT): _____	Signature: _____	Date/Time: _____
2. Received/Relinquished by (PRINT): <i>Russell</i>	Signature: <i>Russell</i>	Date/Time: <b>8/30/24 12:33</b>

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

# Garden State Laboratories, Inc.

**Main Lab. - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**  
**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

### Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827  
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

8/30/24 12:33 27.6c  
 NJDEP

Page of

GSL CLIENT # **NOR19**

MICRO #

CHEM. # **240820023-26-**

SAMPLE REC'D BY: **30**

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: **NORTH Caldwell Bd of Ed** Contact/Authorized by: **JERRY Bello**

Mailing Address: **132A Gould Avenue** Phone: **973-981-4850**

City/State/Zip: **NORTH Caldwell, NJ 07006** Email: **JERRY@newwave**

**environmental.com**

### SAMPLE INFORMATION

SAMPLE TYPE: **DW**

SAMPLE LOCATION: **GRANDVIEW School 35 Hamilton Drive EAST NORTH Caldwell**

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	<input type="checkbox"/> List attached	Total Pages	No.	Type*	Size	Pres.*
X		NC GRAND 24-26 Bubbles in 115	8-30-24	7:00	X		LEAD FIRST DRAW	23-26	1	P	250mLA	
X		NC GRAND 24-27 Bubbles in 109	8-30-24	7:01	X		LEAD FIRST DRAW	23-27	1	P	250mLA	
X		NC GRAND 24-28 Bubbles in 114	8-30-24	7:02	X		LEAD FIRST DRAW	23-28	1	P	250mLA	
X		NC GRAND 24-29 Bubbles in 113	8-30-24	7:02	X		LEAD FIRST DRAW	23-29	1	P	250mLA	
X		NC GRAND 24-30 Bubbles in 114	8-30-24	7:05	X		LEAD FIRST DRAW	23-30	1	P	250mLA	

\*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: \_\_\_\_\_  
 \*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: \_\_\_\_\_

SUBCONTRACTED WORK

TURNAROUND TIME:  Standard  Rush (IF RUSH REQUESTED) Rush Due by:

REPORT FORMAT:  Standard Report  Other/Specify:

Standard Report + E2 PWS ID#:

SEND TO:

DATE/TIME:

METHOD OF SHIPMENT:

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$

Payment Method:  Credit Card Type:  Check #  Other: See Quote

Note:

### SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): <b>NADINE Bello</b>	Signature: <i>Nadine Bello</i>	Date/Time: <b>8-30-24</b>
Client/Client's Representative (PRINT): <b>NADINE Bello</b>	Signature: <i>Nadine Bello</i>	Date/Time: <b>8-30-24</b>
1. Received/Relinquished by (PRINT):	Signature: <i>[Signature]</i>	Date/Time:
2. Received/Relinquished by (PRINT):	Signature: <i>[Signature]</i>	Date/Time: <b>8/30/24 12:33</b>

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

# Garden State Laboratories, Inc.

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**  
**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

### Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827  
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

8/30/24 12:33 27.6c  
 NOEOL

Page of

GSL CLIENT # **NOR 19**

MICRO #

CHEM. # **240880022-31-**

SAMPLE REC'D BY: **34**

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: **NORTH Caldwell Bd of Ed** Contact/Authorized by: **JERRY Bello**  
 Mailing Address: **132A Gould Avenue** Phone: **973-981-4850**  
 City/State/Zip: **NORTH Caldwell, NJ 07006** Email: **JERRY@newwaveenvironmental.com**

### SAMPLE INFORMATION

SAMPLE TYPE: **DW**  
 SAMPLE LOCATION: **GRANDVIEW School 35 Hamilton DR. EAST NORTH Caldwell**

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION			
			Date	Time	AM	PM		No.	Type*	Size	Pres.*
X		NC GRAND 24-31 <sup>Upstairs</sup> <del>hubbler</del> <sup>Right</sup>	8-30-24	7:05	X		LEAD FIRST DRAW 23-31	1	P	250mLA	
X		NC GRAND 24-32 <sup>Kitchen</sup> <del>Sink</del>	8-30-24	7:06	X		LEAD FIRST DRAW 23-32	1	P	250mLA	
X		NC GRAND 24-33 <sup>Kitchen</sup> <del>Sink</del>	8-30-24	7:07	X		LEAD FIRST DRAW 23-33	1	P	250mLA	
X		NC GRAND 24-34 <sup>Field</sup> <del>Blank</del>	8-30-24	7:08	X		LEAD FIRST DRAW 23-34	1	P	250mLA	

\*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: \_\_\_\_\_  
 \*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: \_\_\_\_\_

SUBCONTRACTED WORK

TURNAROUND TIME:  Standard  Rush (if RUSH REQUESTED) Rush Due by:

SEND TO:

REPORT FORMAT:  Standard Report  Other/Specify:

DATE/TIME:

Standard Report + E2 PWS ID#:

METHOD OF SHIPMENT:

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$

Payment Method:  Credit Card Type:  Check #  Other: See Quote

Note:

### SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): <b>NADINE Bello</b>	Signature: <i>Nadine Bello</i>	Date/Time: <b>8-30-24</b>
Client/Client's Representative (PRINT): <b>NADINE BELLO</b>	Signature: <i>Nadine Bello</i>	Date/Time: <b>8-30-24</b>
1. Received/Relinquished by (PRINT):	Signature:	Date/Time:
2. Received/Relinquished by (PRINT):	Signature: <i>[Signature]</i>	Date/Time: <b>8/30/24 12:33</b>

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED



# Garden State Laboratories, Inc.

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**  
**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

### Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827  
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

8/30/24 12:33 276c  
 NREOC

Page of

GSL CLIENT # **NOR 19**

MICRO #

CHEM. # **240880023-25-**

SAMPLE REC'D BY: **39**

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

#### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: **NORTH Caldwell Board of Ed** Contact/Authorized by: **JERRY Bello**  
 Mailing Address: **132A Gould Ave** Phone: **973 981-4856**  
 City/State/Zip: **NORTH Caldwell, NJ 07006** Email: **JERRY@newwave**  
**environmental.com**

#### SAMPLE INFORMATION

SAMPLE TYPE: **DW**  
 SAMPLE LOCATION: **Gould School - 132 Gould Avenue North Caldwell 07006**

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	<input type="checkbox"/> List attached	Total Pages	No.	Type*	Size	Pres.*
X		NC Gould 24-01 - nurse sink	8-30-24	6:18	X		LEAD FIRST DRAW	23-25	1	P	250ml	A
X		NC Gould 24-02 bubbles Hall by main office	8-30-24	6:18	X		LEAD FIRST DRAW	23-36	1	P	250ml	A
X		NC Gould 24-03 B/F Hall by Gym	8-30-24	6:18	X		LEAD FIRST DRAW	23-37	1	P	250ml	A
X		NC Gould 24-04 Kitchen Sink	8-30-24	6:19	X		Lead First Draw	23-38	1	P	250ml	A
X		NC Gould 24-05 B/F by 123	8-30-24	6:19	X		Lead First Draw	23-39	1	P	250ml	A

\*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: \_\_\_\_\_  
 \*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: \_\_\_\_\_

TURNAROUND TIME:  Standard  Rush (if RUSH REQUESTED) Rush Due by:

REPORT FORMAT:  Standard Report  Other/Specify:

Standard Report + E2 PWS ID#:

SUBCONTRACTED WORK

SEND TO:

DATE/TIME:

METHOD OF SHIPMENT:

#### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$

Payment Method:  Credit Card Type:  Check #  Other: See Quote

Note: As per label on bottle it is Office for 23-36  
 8/30/24 Jan

**SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION**

**PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME**

Sampled by (PRINT): **NADINE Bello** Signature: *Nadine Bello* Date/Time: **8-30-24**

Client/Client's Representative (PRINT): **NADINE Bell** Signature: *Nadine Bello* Date/Time: **8-30-24**

1. Received/Relinquished by (PRINT): Signature: \_\_\_\_\_ Date/Time: \_\_\_\_\_

2. Received/Relinquished by (PRINT): *Ramon Bello* Signature: *Ramon Bello* Date/Time: **8/30/24 12:33**

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

# Garden State Laboratories, Inc.

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**  
**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

## Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827  
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

8/30/24 12:33 27.6c  
 DW/EC

Page of

GSL CLIENT # **NOR-19**

MICRO #

CHEM. # **240820083-40-**

SAMPLE REC'D BY: **43**

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: **NORTH CALDWELL Bd of Ed** Contact/Authorized by: **JERRY Bello**  
 Mailing Address: **132 A Gould Avenue** Phone: **973-981-4850**  
 City/State/Zip: **NORTH Caldwell, NJ 07006** Email: **JERRY@newwave**  
**environmental.com**

### SAMPLE INFORMATION

SAMPLE TYPE: **DW**  
 SAMPLE LOCATION: **Gould School 132 Gould Avenue NORTH Caldwell, NJ**

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
			Date	Time	AM	PM	<input type="checkbox"/> List attached	Total Pages	No.	Type*	Size	Pres.*
X		NC-Gould-24-06 Bubble by 115 L	8-30-24	6:20	X		LEAD FIRST DRAW	23-40	1	P	250ml	A
X		NC-Gould-24-07 Bubble by 115 R	8-30-24	6:20	X		LEAD FIRST DRAW	23-41	1	P	250ml	A
X		NC-Gould-24-08 Teachers Sink	8-30-24	6:21	X		LEAD FIRST DRAW	23-42	1	P	250ml	A
X		NC-Gould-24-09 Field Blank	8-30-24	6:21	X		LEAD FIRST DRAW	23-43	1	P	250ml	A

\*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: \_\_\_\_\_  
 \*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: \_\_\_\_\_

SUBCONTRACTED WORK

TURNAROUND TIME:  Standard  Rush (if RUSH REQUESTED) Rush Due by:

SEND TO:

REPORT FORMAT:  Standard Report  Other/Specify:

DATE/TIME:

Standard Report + E2 PWS ID#:

METHOD OF SHIPMENT:

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$  
 Payment Method:  Credit Card Type:  Check #  Other: See Quote

Note:

**SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION**  
**PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME**

Sampled by (PRINT): **NADINE Bello** Signature: *Nadine Bello* Date/Time: **8-30-24**

Client/Client's Representative (PRINT): **NADINE Bello** Signature: *Nadine Bello* Date/Time: **8-30-24**

1. Received/Relinquished by (PRINT): Signature: *[Signature]* Date/Time:

2. Received/Relinquished by (PRINT): Signature: *[Signature]* Date/Time: **8/30/24 12:33**

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

# Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044  
 Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

## Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827  
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

8/30/24 12:33 27.6  
 DW BOC

Page of

GSL CLIENT # **NOR-19**

MICRO #

CHEM. # **240820023-44-47**

SAMPLE REC'D BY:

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: **NORTH Caldwell Bd of Ed** Contact/Authorized by: **JERRY Bello**  
 Mailing Address: **132A Gould AVE** Phone: **973-981-4850**  
 City/State/Zip: **NORTH Caldwell, NJ 07006** Email: **JERRY@newwaveenvironmental.com**

### SAMPLE INFORMATION

SAMPLE TYPE: **DW**  
 SAMPLE LOCATION: **Gould School - 132A Gould Avenue NORTH Caldwell**

Grab	Comp.	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION				
			Date	Time	AM	PM	<input type="checkbox"/> List attached	Total Pages	No.	Type*	Size	Pres.*	
X		NC-GouldA-24-01A - B/Fby Sme	8-30-24	6:15	X		<input type="checkbox"/>		LEAD FIRST DRAW 23-44	1	P	250mL	A
X		NC-GouldA-24-02A Bubble by Ed	8-30-24	6:15	X		<input type="checkbox"/>		LEAD FIRST DRAW 23-45	1	P	250mL	A
X		NE-GouldA-24-03A Teachers Sme	8-30-24	6:16	X		<input type="checkbox"/>		LEAD FIRST DRAW 23-46	1	P	250mL	A
X		NE-GouldA-24-04A Field Blank	8-30-24	6:17	X		<input type="checkbox"/>		LEAD FIRST DRAW 23-47	1	P	250mL	A

\*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: \_\_\_\_\_  
 \*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: \_\_\_\_\_

SUBCONTRACTED WORK

TURNAROUND TIME:  Standard  Rush (if RUSH REQUESTED) Rush Due by: \_\_\_\_\_

REPORT FORMAT:  Standard Report  Other/Specify: \_\_\_\_\_

Standard Report + E2 PWS ID#: \_\_\_\_\_

SEND TO:

DATE/TIME:

METHOD OF SHIPMENT:

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$  
 Payment Method:  Credit Card Type:  Check #  Other: See Quote

Note:

**SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION  
 PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME**

Sampled by (PRINT): <b>NADINE Bello</b>	Signature: <i>Nadine Bello</i>	Date/Time: <b>8-30-24</b>
Client/Client's Representative (PRINT): <b>NADINE Bello</b>	Signature: <i>Nadine Bello</i>	Date/Time: <b>8-30-24</b>
1. Received/Relinquished by (PRINT):	Signature: _____	Date/Time: _____
2. Received/Relinquished by (PRINT):	Signature: <i>[Signature]</i>	Date/Time: <b>8/30/24 12:33</b>

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN  
 IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

# New Jersey Department of Health

*Having met the requirements of N.J.A.C. 8:50*

***New Wave Engineering, LLC***

***85 Redwood Avenue***

***WAYNE, NJ 07470***

***License Number: 1244***

*is licensed as an Indoor Environmental Consultant to conduct Indoor Environmental Health Assessments of Child Care Centers and Educational Facilities in New Jersey.*

9/4/2024

*Issue Date*

9/4/2026

*Expiration Date*



Christina Tan, MD, MPH, Assistant Commissioner  
Division of Epidemiology, Environmental and Occupational Health

*This License is non-transferable and only valid for the licensee as indicated above.*



# American Council for Accredited Certification

hereby certifies that

**Nadine Bello**

has met all the specific standards and qualifications of the re-certification process,  
including continued professional development, and is hereby re-certified as a



**Council-certified  
Indoor Environmental Consultant**

This certificate expires on June 30, 2025

A handwritten signature in black ink, appearing to read 'Charles F. Wiles'.

Charles F. Wiles, Executive Director

1506022

Certificate Number

This certificate remains the property of the American Council for Accredited Certification.