



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Mark Rampado
Amherst CSD
55 Kings Hwy
Amherst, NY 14226**

12/28/2016

Phone: (716) 362-8355

Fax: (716) 836-4972

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 11/9/2016. The results are tabulated on the attached data pages for the following client designated project:

**Project ID: PO Box 17-00954 NY State Component School Dist.
Amherst High School**

The reference number for these samples is EMSL Order #011607615. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.

NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 187

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607615

CustomerID: AMHE50

CustomerPO: 17-00954

ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
Fax: (716) 836-4972
Received: 11/09/16 9:30 AM

Project: **Amherst High School****Analytical Results****Client Sample Description** 001-HALL BY 301**Collected:****Lab ID:** 0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 002-WOMEN'S FAC LAV BY 301**Collected:****Lab ID:** 0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 003-RM. 301**Collected:****Lab ID:** 0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.76	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 004-BACK RM, RM 303**Collected:****Lab ID:** 0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.71	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 005-BACK RM, RM 303**Collected:****Lab ID:** 0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.45	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 006-BACK RM, RM 303**Collected:****Lab ID:** 0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.5	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 007-RM 304 CLASS SINK**Collected:****Lab ID:** 0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.46	1.00	µg/L	12/20/2016	CB	12/20/2016	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607615
 CustomerID: AMHE50
 CustomerPO: 17-00954
 ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 11/09/16 9:30 AM

Project: **Amherst High School****Analytical Results**

Client Sample Description 008-RM 304 INSTRUCTOR SINK **Collected:** **Lab ID:** 0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.46	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 009-BOYS LAV BY 304 **Collected:** **Lab ID:** 0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.79	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 010-BOYS LAV BY 304 **Collected:** **Lab ID:** 0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.06	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 011-GIRLS LAVE BY 304 **Collected:** **Lab ID:** 0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.03	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 012-GIRLS LAVE BY 304 **Collected:** **Lab ID:** 0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.01	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 013-HALL BY GIRLS LAV **Collected:** **Lab ID:** 0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.77	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 014-BACK RM RM 314 **Collected:** **Lab ID:** 0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.99	1.00	µg/L	12/20/2016	CB	12/20/2016	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607615
CustomerID: AMHE50
CustomerPO: 17-00954
ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
Fax: (716) 836-4972
Received: 11/09/16 9:30 AM

Project: **Amherst High School****Analytical Results**

Client Sample Description 015-RM 314 INSTRUCTOR SINK **Collected:** **Lab ID:** 0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.70	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 016-RM 318 INSRTUCTOR SINK **Collected:** **Lab ID:** 0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.60	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 017- HALL BY CHEM OFFICE **Collected:** **Lab ID:** 0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 018-WOMEN'S FAC LAV BY CHEM OFFICE **Collected:** **Lab ID:** 0018

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.64	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 019-MEN'S FAC LAV BY CHEM OFFICE **Collected:** **Lab ID:** 0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.62	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 020-RM 320 CLASS SINK **Collected:** **Lab ID:** 0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	29.7	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 021-RM 320 INSRTUCTOR SINK **Collected:** **Lab ID:** 0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	65.3	1.00	µg/L	12/20/2016	CB	12/20/2016	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607615
 CustomerID: AMHE50
 CustomerPO: 17-00954
 ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 11/09/16 9:30 AM

Project: **Amherst High School****Analytical Results**

Client Sample Description 022-RM 322 INSTRUCTOR SINK **Collected:** **Lab ID:** 0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	43.0	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 023-MIDDLE ROOM 322/329 **Collected:** **Lab ID:** 0023

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	54.2	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 024-MIDDLE ROOM 322/329 **Collected:** **Lab ID:** 0024

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	44.6	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 025-CHEM/STORAGE RM 322/329 **Collected:** **Lab ID:** 0025

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	39.4	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 026-RM 329 INSTRUCTOR SINK **Collected:** **Lab ID:** 0026

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	44.5	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 028-RM 327 CLASS SINK **Collected:** **Lab ID:** 0027

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	92.2	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 029-RM 327 INSTRUCTOR SINK **Collected:** **Lab ID:** 0028

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	36.9	1.00	µg/L	12/20/2016	CB	12/20/2016	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607615
CustomerID: AMHE50
CustomerPO: 17-00954
ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
Fax: (716) 836-4972
Received: 11/09/16 9:30 AM

Project: **Amherst High School****Analytical Results****Client Sample Description** 030-RM 317 CLASS SINK**Collected:****Lab ID:** 0029

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	51.8	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 031-RM 317 CLASS SINK**Collected:****Lab ID:** 0030

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	12.9	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 032-RM305 INSTRUCTOR SINK**Collected:****Lab ID:** 0031

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.34	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 033-RM 302 INSTRUCTOR SINK**Collected:****Lab ID:** 0032

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.33	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 034-RM 302 CLASS SINK**Collected:****Lab ID:** 0033

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.74	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 035-RM 306 CLASS SINK**Collected:****Lab ID:** 0034

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.97	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 036-RM 306 CLASS SINK**Collected:****Lab ID:** 0035

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.99	1.00	µg/L	12/20/2016	CB	12/20/2016	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607615
CustomerID: AMHE50
CustomerPO: 17-00954
ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
Fax: (716) 836-4972
Received: 11/09/16 9:30 AM

Project: **Amherst High School****Analytical Results****Client Sample Description** 037-RM 306 CLASS SINK**Collected:****Lab ID:** 0036

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.89	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 038-RM 306 INSTRUCTOR SINK**Collected:****Lab ID:** 0037

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.15	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 039-RM 310 CLASS SINK**Collected:****Lab ID:** 0038

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.46	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 040-RM 312 CLASS SINK**Collected:****Lab ID:** 0039

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.61	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 041-RM 312 INSTRUCTOR SINK**Collected:****Lab ID:** 0040

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.81	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 042-RM 312 INSTRUCTOR SINK**Collected:****Lab ID:** 0041

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.22	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 043-RM 316 CLASS SINK**Collected:****Lab ID:** 0042

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.97	1.00	µg/L	12/20/2016	CB	12/20/2016	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607615

CustomerID: AMHE50

CustomerPO: 17-00954

ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 11/09/16 9:30 AM

Project: **Amherst High School****Analytical Results****Client Sample Description** 044-RM 316 CLASS SINK**Collected:****Lab ID:** 0043

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.65	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 045-HALL BY RM 203**Collected:****Lab ID:** 0044

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 046-WOMEN'S FAC LAV BY 203**Collected:****Lab ID:** 0045

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 047-FAC LAV ACROSS FROM 202**Collected:****Lab ID:** 0046

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.07	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 048-BOY'S LAV ACROSS FROM 202**Collected:****Lab ID:** 0047

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 049-BOY'S LAV ACROSS FROM 202**Collected:****Lab ID:** 0048

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 050-GIRL'S LAV ACROSS FROM 202**Collected:****Lab ID:** 0049

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/20/2016	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607615
 CustomerID: AMHE50
 CustomerPO: 17-00954
 ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 11/09/16 9:30 AM

Project: **Amherst High School****Analytical Results**

Client Sample Description 051-GIRL'S LAV ACROSS FROM 202 **Collected:** **Lab ID:** 0050

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 052-HALL ACROSS FROM 200 **Collected:** **Lab ID:** 0051

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 053-HALLACROSS FROM 224A **Collected:** **Lab ID:** 0052

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 054-WOMAN'S FAC LAV BY 224A **Collected:** **Lab ID:** 0053

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.31	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 055-MEN'S FAC LAV BY 224A **Collected:** **Lab ID:** 0054

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.82	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 056-HALL BY 103 **Collected:** **Lab ID:** 0055

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 057-FAMILY RESTROOM ACROSS FROM HEALTH OFFICE **Collected:** **Lab ID:** 0056

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.63	1.00	µg/L	12/20/2016	CB	12/20/2016	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607615
 CustomerID: AMHE50
 CustomerPO: 17-00954
 ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 11/09/16 9:30 AM

Project: **Amherst High School****Analytical Results****Client Sample Description** 058-HEALTH OFFICE RESTROOM**Collected:****Lab ID:** 0057

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.74	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 059-HEALTH OFFICE MIDDLE EXAM ROOM**Collected:****Lab ID:** 0058

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 060-HEALTH OFFICE END EXAM ROOM**Collected:****Lab ID:** 0059

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.11	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 061-BOYS LAV ACROSS FROM MAIN OFFICE**Collected:****Lab ID:** 0060

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/20/2016	

Client Sample Description 062-GIRLS LAV ACROSS FROM MAIN OFFICE**Collected:****Lab ID:** 0061

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 063GIRLS LAV ACROSS FROM MAIN OFFICE**Collected:****Lab ID:** 0062

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 064-HALL ACROSS FROM MAIN OFFICE**Collected:****Lab ID:** 0063

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607615
 CustomerID: AMHE50
 CustomerPO: 17-00954
 ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 11/09/16 9:30 AM

Project: **Amherst High School****Analytical Results****Client Sample Description** 065-HALL BY 124**Collected:****Lab ID:** 0064

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 066-WOMEN'S FAC LAV BY 124**Collected:****Lab ID:** 0065

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.20	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 067-MEN'S FAC LAV BY 124**Collected:****Lab ID:** 0066

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.17	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 068-LIBRARY**Collected:****Lab ID:** 0067

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.05	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 069-COPY RM**Collected:****Lab ID:** 0068

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.82	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 070-PRINCIPAL'S OFFICE**Collected:****Lab ID:** 0069

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.19	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 071-PRINCIPAL'S OFFICE**Collected:****Lab ID:** 0070

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607615
 CustomerID: AMHE50
 CustomerPO: 17-00954
 ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 11/09/16 9:30 AM

Project: **Amherst High School****Analytical Results****Client Sample Description** 072-ASST. PRINCIPAL'S OFFICE**Collected:****Lab ID:** 0071

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.37	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 073-CUSTODIAL OFFICE**Collected:****Lab ID:** 0072

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 074-BOY'S LOCKER RM BY DOOR 27**Collected:****Lab ID:** 0073

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.90	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 075-GIRL'S LOCKER ROOM BY DOOR 29**Collected:****Lab ID:** 0074

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.32	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 076-GIRL'S LOCKER ROOM BY DOOR 29**Collected:****Lab ID:** 0075

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.17	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 077-OFFICE IN GIRL'S LOCKER RM BY DOOR 29**Collected:****Lab ID:** 0076

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.26	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 079-HALL S. GYM ATRIUM**Collected:****Lab ID:** 0077

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.43	1.00	µg/L	12/21/2016	CB	12/21/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607615
 CustomerID: AMHE50
 CustomerPO: 17-00954
 ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 11/09/16 9:30 AM

Project: **Amherst High School****Analytical Results**

Client Sample Description 080-LOWER BOY'S LOCKER RM S. GYM **Collected:** **Lab ID:** 0078

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 081-LOWER BOY'S LOCKER RM S. GYM **Collected:** **Lab ID:** 0079

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.77	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 082-LOWER BOY'S LOCKER RM S. GYM **Collected:** **Lab ID:** 0080

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.65	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 083-LOWER BOY'S LOCKER RM S. GYM **Collected:** **Lab ID:** 0081

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.14	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 106-GYM OFFICE LOWER BOY'S LOCKER RM **Collected:** **Lab ID:** 0082

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.33	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 107-TRAINER'S ROOM **Collected:** **Lab ID:** 0083

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.31	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 108-TRAINER'S ROOM **Collected:** **Lab ID:** 0084

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.17	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607615
CustomerID: AMHE50
CustomerPO: 17-00954
ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
Fax: (716) 836-4972
Received: 11/09/16 9:30 AM

Project: **Amherst High School****Analytical Results**

Client Sample Description 117-LOWER GIRL'S LOCKER RM S. GYM **Collected:** **Lab ID:** 0085

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.39	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 118-LOWER GIRL'S LOCKER RM S. GYM **Collected:** **Lab ID:** 0086

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.07	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 119-LOWER GIRL'S LOCKER RM S. GYM **Collected:** **Lab ID:** 0087

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.48	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 120-LOWER GIRL'S LOCKER RM S. GYM **Collected:** **Lab ID:** 0088

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.30	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 121-S. GYM MEN'S LAV **Collected:** **Lab ID:** 0089

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.85	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 122-S. GYM MEN'S LAV **Collected:** **Lab ID:** 0090

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.57	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 123-S. GYM MEN'S LAV **Collected:** **Lab ID:** 0091

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.11	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607615
CustomerID: AMHE50
CustomerPO: 17-00954
ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
Fax: (716) 836-4972
Received: 11/09/16 9:30 AM

Project: **Amherst High School****Analytical Results**

Client Sample Description 124-S. GYM WOMEN'S LAV **Collected:** **Lab ID:** 0092

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.53	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 125-S. GYM WOMEN'S LAV **Collected:** **Lab ID:** 0093

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.06	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 126-S. GYM WOMEN'S LAV **Collected:** **Lab ID:** 0094

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.03	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 127-UPPER FITNESS CENTER S.GYM
MEN'S LAV **Collected:** **Lab ID:** 0095

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.87	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 128-UPPER FITNESS CENTER S. GYM
WOMEN'S LAV **Collected:** **Lab ID:** 0096

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 129-UPPER FITNESS CENTER S. GYM **Collected:** **Lab ID:** 0097

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.45	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 130-UPPER BOY'S LOCKER RM S. GYM **Collected:** **Lab ID:** 0098

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.10	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607615
 CustomerID: AMHE50
 CustomerPO: 17-00954
 ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 11/09/16 9:30 AM

Project: **Amherst High School****Analytical Results**

Client Sample Description 131-UPPER BOY'S LOCKER RM S. GYM **Collected:** **Lab ID:** 0099

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.70	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 132-UPPER BOY'S LOCKER RM S. GYM **Collected:** **Lab ID:** 0100

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.50	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 141-UPPER GIRLS LOCKER RM S. GYM **Collected:** **Lab ID:** 0101

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.13	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 142-UPPER GIRLS LOCKER RM S. GYM **Collected:** **Lab ID:** 0102

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.78	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 143-UPPER GIRLS LOCKER RM S. GYM **Collected:** **Lab ID:** 0103

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.69	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 144-BOY'S LAV-AUD HALL BY DOOR 2 **Collected:** **Lab ID:** 0104

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.11	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 145-BOY'S LAV-AUD HALL BY DOOR 2 **Collected:** **Lab ID:** 0105

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.77	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607615
CustomerID: AMHE50
CustomerPO: 17-00954
ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
Fax: (716) 836-4972
Received: 11/09/16 9:30 AM

Project: **Amherst High School****Analytical Results**

Client Sample Description 146-BOY'S LAV-AUD HALL BY DOOR 2 **Collected:** **Lab ID:** 0106

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.44	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 147-AUD HALL BY BOYS LAV **Collected:** **Lab ID:** 0107

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 148-GIRL'S LAV-AUD HALL BY DOOR 3 **Collected:** **Lab ID:** 0108

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.54	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 149-GIRL'S LAV-AUD HALL BY DOOR 3 **Collected:** **Lab ID:** 0109

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.38	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 150-RM 10 **Collected:** **Lab ID:** 0110

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.41	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 151-WOMEN'S LAV ACROSS FROM RM 10 **Collected:** **Lab ID:** 0111

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 152-WOMEN'S LAV ACROSS FROM RM 10 **Collected:** **Lab ID:** 0112

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607615
 CustomerID: AMHE50
 CustomerPO: 17-00954
 ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 11/09/16 9:30 AM

Project: **Amherst High School****Analytical Results**

Client Sample Description 153-RM 14 **Collected:** **Lab ID:** 0113

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 154-RM 14 **Collected:** **Lab ID:** 0114

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.45	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 155-RM 16 **Collected:** **Lab ID:** 0115

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.62	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 156- RM 16 DARK ROOM **Collected:** **Lab ID:** 0116

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 157-MEN'S LAV BY RM 8 **Collected:** **Lab ID:** 0117

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.06	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 158-MEN'S LAV BY RM 8 **Collected:** **Lab ID:** 0118

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.00	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 159-WOMEN'S LAV BY RM 8 **Collected:** **Lab ID:** 0119

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.67	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607615

CustomerID: AMHE50

CustomerPO: 17-00954

ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 11/09/16 9:30 AM

Project: **Amherst High School****Analytical Results****Client Sample Description** 161-RM 8**Collected:****Lab ID:** 0120

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.84	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 162-RM 8**Collected:****Lab ID:** 0121

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	EG

Client Sample Description 163-RM 4**Collected:****Lab ID:** 0122

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

Client Sample Description 164-RM 4**Collected:****Lab ID:** 0123

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

Client Sample Description 165-RM 4**Collected:****Lab ID:** 0124

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

Client Sample Description 166-RM 4**Collected:****Lab ID:** 0125

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

Client Sample Description 167-RM 4**Collected:****Lab ID:** 0126

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.05	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607615
 CustomerID: AMHE50
 CustomerPO: 17-00954
 ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 11/09/16 9:30 AM

Project: **Amherst High School****Analytical Results****Client Sample Description** 168-CAFETERIA**Collected:****Lab ID:** 0127

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

Client Sample Description 169-KITCHEN BY STEAMER**Collected:****Lab ID:** 0128

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.21	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

Client Sample Description 170-KITCHEN**Collected:****Lab ID:** 0129

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

Client Sample Description 171-KITCHEN 2 BAY SINK BY FREEZER**Collected:****Lab ID:** 0130

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.98	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

Client Sample Description 172-KITCHEN 3 BAY SINK BY WINDOWS**Collected:****Lab ID:** 0131

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.80	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

Client Sample Description 173-KITCHEN 3 BAY SINK BY WINDOWS**Collected:****Lab ID:** 0132

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.45	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

Client Sample Description 174-KITCHEN MIDDLE WORK STATION**Collected:****Lab ID:** 0133

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.98	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607615
 CustomerID: AMHE50
 CustomerPO: 17-00954
 ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 11/09/16 9:30 AM

Project: **Amherst High School****Analytical Results****Client Sample Description** 175-KITCHEN FAR WORK STATION**Collected:****Lab ID:** 0134

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.14	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

Client Sample Description 176-KITCHEN LAV**Collected:****Lab ID:** 0135

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.72	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

Client Sample Description 177-BOILER RM**Collected:****Lab ID:** 0136

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.01	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

Client Sample Description 178-BACK RM OFFBOILER RM @ MAIN LINE**Collected:****Lab ID:** 0137

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.12	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

Client Sample Description 179-BOILER RM INSIDE DOOR 26**Collected:****Lab ID:** 0138

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

Client Sample Description 180-OUTDOORS LEFT FRONT OF BUILDING**Collected:****Lab ID:** 0139

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.19	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

Client Sample Description 181-RIGHT OF DOOR 1**Collected:****Lab ID:** 0140

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.44	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607615
CustomerID: AMHE50
CustomerPO: 17-00954
ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
Fax: (716) 836-4972
Received: 11/09/16 9:30 AM

Project: **Amherst High School****Analytical Results**

Client Sample Description 182-LEFT OF DOOR 1 **Collected:** **Lab ID:** 0141

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.76	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

Client Sample Description 183-BY GENERATOR AND DOOR 25 **Collected:** **Lab ID:** 0142

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.75	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

Client Sample Description 184-INNER COURT YARD **Collected:** **Lab ID:** 0143

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

Client Sample Description 185-WATER BOOSTER KITCHEN **Collected:** **Lab ID:** 0144

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1430	50.0	µg/L	12/21/2016	LY	12/22/2016	BB

Client Sample Description 186-FAC. DINING RM **Collected:** **Lab ID:** 0145

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/21/2016	BB

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)