



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Mark Rampado
Amherst CSD
55 Kings Hwy
Amherst, NY 14226**

3/22/2017

Phone: (716) 362-8355
Fax: (716) 836-4972

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/13/2017. The results are tabulated on the attached data pages for the following client designated project:

**Project ID: PO Box 17-00954 NY State Component School Dist.
Windermere Elementary**

The reference number for these samples is EMSL Order #011701879. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701879
 CustomerID: AMHE50
 CustomerPO: 17-00954
 ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 03/13/17 9:30 AM

Project: **Windermere Elementary****Analytical Results**

Client Sample Description		WE44FD Room106	Collected:		2/24/2017	Lab ID:		0001
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	25.8	1.00	µg/L	3/16/2017	AE	3/17/2017	EG
Client Sample Description		WE44FLD Room106	Collected:		2/24/2017	Lab ID:		0002
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.97	1.00	µg/L	3/16/2017	AE	3/17/2017	EG
Client Sample Description		WE45FD Room106	Collected:		2/24/2017	Lab ID:		0003
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	14.8	1.00	µg/L	3/16/2017	AE	3/17/2017	EG
Client Sample Description		WE45FLD Room106	Collected:		2/24/2017	Lab ID:		0004
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG
Client Sample Description		WE46FD Room109	Collected:		2/24/2017	Lab ID:		0005
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	21.1	1.00	µg/L	3/16/2017	AE	3/17/2017	EG
Client Sample Description		WE46FLD Room109	Collected:		2/24/2017	Lab ID:		0006
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG
Client Sample Description		WE47FD Room109	Collected:		2/24/2017	Lab ID:		0007
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	29.4	1.00	µg/L	3/16/2017	AE	3/17/2017	EG
Client Sample Description		WE47FLD Room109	Collected:		2/24/2017	Lab ID:		0008
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701879
 CustomerID: AMHE50
 CustomerPO: 17-00954
 ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 03/13/17 9:30 AM

Project: **Windermere Elementary****Analytical Results**

Client Sample Description		WE47FLD Room109		Collected:		2/24/2017	Lab ID:		0008
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	2.70	1.00	µg/L	3/16/2017	AE	3/17/2017	EG	
Client Sample Description		WE100FD Room226		Collected:		2/24/2017	Lab ID:		0009
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	7.90	1.00	µg/L	3/16/2017	AE	3/17/2017	EG	
Client Sample Description		WE100FLD Room226		Collected:		2/24/2017	Lab ID:		0010
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	1.72	1.00	µg/L	3/16/2017	AE	3/17/2017	EG	
Client Sample Description		WE104FD Room227		Collected:		2/24/2017	Lab ID:		0011
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	30.6	1.00	µg/L	3/16/2017	AE	3/17/2017	EG	
Client Sample Description		WE104FLD Room227		Collected:		2/24/2017	Lab ID:		0012
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	4.85	1.00	µg/L	3/16/2017	AE	3/17/2017	EG	
Client Sample Description		WE117FD Room222B		Collected:		2/24/2017	Lab ID:		0013
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	12.8	1.00	µg/L	3/16/2017	AE	3/17/2017	EG	
Client Sample Description		WE117FLD Room222B		Collected:		2/24/2017	Lab ID:		0014
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG	
Client Sample Description		WE123FD Room210		Collected:		2/24/2017	Lab ID:		0015
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701879
 CustomerID: AMHE50
 CustomerPO: 17-00954
 ProjectID: PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 03/13/17 9:30 AM

Project: **Windermere Elementary****Analytical Results**

Client Sample Description		WE123FD Room210	Collected:		2/24/2017	Lab ID:		0015
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	46.2	1.00	µg/L	3/16/2017	AE	3/17/2017	EG
Client Sample Description		WE123FLD Room210	Collected:		2/24/2017	Lab ID:		0016
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.15	1.00	µg/L	3/16/2017	AE	3/17/2017	EG
Client Sample Description		WE134FD Room203A	Collected:		2/24/2017	Lab ID:		0017
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG
Client Sample Description		WE134FLD Room203A	Collected:		2/24/2017	Lab ID:		0018
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG
Client Sample Description		WE144FD Room252B	Collected:		2/24/2017	Lab ID:		0019
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/17/2017	EG
Client Sample Description		WE144FLD Room252B	Collected:		2/24/2017	Lab ID:		0020
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.90	1.00	µg/L	3/16/2017	AE	3/17/2017	EG

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)