EMSL Analytical, Inc.
200 Route 130 North, Cinnaminson, NJ 08077
Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226
Phone: (716) 362-8355
Fax: (716) 836-4972

10/13/2021

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 9/29/2021. The results are tabulated on the attached data pages for the following client designated project:

Smallwood Elementary

The reference number for these samples is EMSL Order #012111255. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director

The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

Report amended 10/13/2021 09:58:15 Replaces initial report from 10/12/2021 15:40:53 Revised sample locations per client request.

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

EMSL Analytical, Inc.
200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (856) 303-2500 / (856) 858-4571
http://www.EMSL.com EnvChemistry2@emsl.com

EMSL Order:	012111255
CustomerID:	AMHE50
CustomerPO:	21-01422
ProjectID:	

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
Fax: (716) 836-4972
Received: 9/29/2021 01:40 PM

Project: **Smallwood Elementary**

Analytical Results

Client Sample Description SM01
Water Fountain Across From 226
Collected: 9/2/2021 5:06:00 AM
Lab ID: *012111255-0001*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date & Analyst*	*Analysis Date & Analyst*
METALS						
200.8	Lead	40.8	1.00	µg/L	10/5/2021 VD	10/5/2021 16:13 VD

Client Sample Description SM02
Water Fountain Across From 226 - Flush Draw
Collected: 9/2/2021 5:08:00 AM
Lab ID: *012111255-0002*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date & Analyst*	*Analysis Date & Analyst*
METALS						
200.8	Lead	26.4	1.00	µg/L	10/5/2021 VD	10/5/2021 16:21 VD

Client Sample Description SM03
Sink - Room 226
Collected: 9/2/2021 5:10:00 AM
Lab ID: *012111255-0003*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date & Analyst*	*Analysis Date & Analyst*
METALS						
200.8	Lead	1.74	1.00	µg/L	10/5/2021 VD	10/5/2021 16:22 VD

Client Sample Description SM04
Sink - Room 226 - Flush Draw
Collected: 9/2/2021 5:12:00 AM
Lab ID: *012111255-0004*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date & Analyst*	*Analysis Date & Analyst*
METALS						
200.8	Lead	ND	1.00	µg/L	10/5/2021 VD	10/5/2021 16:24 VD

Client Sample Description SM05
Water Fountain - Room 149
Collected: 9/2/2021 5:20:00 AM
Lab ID: *012111255-0005*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date & Analyst*	*Analysis Date & Analyst*
METALS						
200.8	Lead	2.74	1.00	µg/L	10/5/2021 VD	10/5/2021 16:25 VD

EMSL Analytical, Inc.
200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (856) 303-2500 / (856) 858-4571
http://www.EMSL.com EnvChemistry2@emsl.com

EMSL Order:	012111255
CustomerID:	AMHE50
CustomerPO:	21-01422
ProjectID:	

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
Fax: (716) 836-4972
Received: 9/29/2021 01:40 PM

Project: **Smallwood Elementary**

Analytical Results

Client Sample Description SM06
Water Fountain - Room 149 - Flush Draw
Collected: 9/2/2021 5:25:00 AM
Lab ID: *012111255-0006*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date & Analyst*	*Analysis Date & Analyst*
METALS						
200.8	Lead	1.38	1.00	µg/L	10/5/2021 VD	10/5/2021 16:26 VD

Client Sample Description SM07
Kitchen 3 Bay Sink Right Side
Collected: 9/2/2021 5:30:00 AM
Lab ID: *012111255-0007*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date & Analyst*	*Analysis Date & Analyst*
METALS						
200.8	Lead	4.83	1.00	µg/L	10/5/2021 VD	10/5/2021 16:28 VD

Client Sample Description SM08
Kitchen 3 Bay Sink Right Side - Flush Draw
Collected: 9/2/2021 5:32:00 AM
Lab ID: *012111255-0008*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date & Analyst*	*Analysis Date & Analyst*
METALS						
200.8	Lead	ND	1.00	µg/L	10/5/2021 VD	10/5/2021 16:29 VD

Definitions:
MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - indicates that the analyte was not detected at the reporting limit
RL - Reporting Limit (Analytical)
D - Dilution Sample required a dilution which was used to calculate final results