



Amherst Central School District

Anthony J. Panella
Superintendent

Lynn Shanahan, Ph.D
*Assistant Superintendent
Curriculum, Instruction & Technology*

Michael Belle-Isle
*Assistant Superintendent
Student & Staff Services*

August 12, 2021

Dear Windermere Boulevard Elementary Parent/Guardian,

As a district, we are committed to the safety and education of all our students and we also want to clearly communicate with parents about our learning environment.

The Amherst Central School District is in compliance with regulations issued by the New York State Department of Health (NYSDOH) requiring all school districts and Boards of Cooperative Educational Services (BOCES) to test potable water fixtures used for drinking or cooking purposes for lead contamination, to remediate contamination, and to notify parents of children and the public of test results. Levels of lead at any water outlet above 15 parts per billion (ppb) require action to remediate this issue and trigger notification requirements.

As required, the Amherst Central School District tested all water sources in every school building for lead. Consistent with regulatory requirements, first draw water samples were taken after letting the water remain motionless in pipes for a minimum of 8 hours and a maximum of 18 hours. I am writing to share the initial results we received for testing at Windermere Boulevard Elementary School.

In total, 121 samples were collected at Windermere Boulevard Elementary School with 12 samples exceeding the threshold of 15 ppb, as follows:

- Room 210 Sink
- Room 208 Sink
- Room 203 Sink B
- Room 256 Sink
- Room 110 Sink
- Kitchen – Pot Filler Over Stove
- Room 230 Bubbler
- Room 231 Bubbler
- Room 226 Bubbler
- Room 209 Bubbler
- Room 144 Bubbler
- Room 100 Bubbler

In response to the receipt of these test results, the water outlets that exceeded the testing level have immediately been taken out of service. The next step is to develop a remediation plan that will be approved and guided by the experts in the field of water remediation.

It is important to note that none of the sources will be put back into service and available for drinking or cooking until the sources are fully mitigated, re-tested and meet NYSDOH Standards.

The water testing results are available on the District website at www.amherstschoools.org under Departments / Facilities.

For more information about water quality and sampling for lead you may want to contact the Erie County Department of Health at 961-6800. Should you have any questions or concerns, please contact Mark Rampado, ACSD Director of Facilities, at 362-8151.

Sincerely,

A handwritten signature in black ink, appearing to read "Anthony J. Panella". The signature is fluid and cursive, with a long horizontal stroke at the end.

Anthony Panella
Superintendent of Schools