



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Mark Rampado
Amherst CSD
55 Kings Hwy
Amherst, NY 14226**

7/1/2021

Phone: (716) 362-8355
Fax: (716) 836-4972

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 6/21/2021. The results are tabulated on the attached data pages for the following client designated project:

Field House

The reference number for these samples is EMSL Order #012106715. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012106715

CustomerID: AMHE50

CustomerPO: 21-01422

ProjectID:

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 6/21/2021 03:20 PM

Project: **Field House****Analytical Results**

Client Sample Description FH001
Field House Sink
Collected: 5/20/2021 6:30:00 AM
Lab ID: 012106715-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.05	1.00 µg/L	6/28/2021 VD	6/28/2021 VD 17:23

Client Sample Description FH002
Field House Hose BIB
Collected: 5/20/2021 6:31:00 AM
Lab ID: 012106715-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.66	1.00 µg/L	6/28/2021 VD	6/28/2021 VD 17:24

Client Sample Description FH003
Field House Inside Rear Hose BIB
Collected: 5/20/2021 6:35:00 AM
Lab ID: 012106715-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	123 D	2.00 µg/L	6/24/2021 JD	6/25/2021 JW 12:57

Client Sample Description FH004
Field House Snack Shack Sink
Collected: 5/20/2021 6:36:00 AM
Lab ID: 012106715-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/28/2021 VD	6/28/2021 VD 17:26

Client Sample Description FH005
Field House Outside Bubbler
Collected: 5/20/2021 6:40:00 AM
Lab ID: 012106715-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	56.8	1.00 µg/L	6/28/2021 VD	6/28/2021 VD 17:27

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012106715

CustomerID: AMHE50

CustomerPO: 21-01422

ProjectID:

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
Fax: (716) 836-4972
Received: 6/21/2021 03:20 PM

Project: **Field House**

Analytical Results

Client Sample Description FH006 **Collected:** 5/20/2021 **Lab ID:** 012106715-0006
Field House Westside of Track Water Supply 6:45:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	52.5	1.00 µg/L	6/24/2021 JD	6/24/2021 JW 20:33

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results