

| School      | Item   | Item Description                           | Date       | Result                  | Action                            |
|-------------|--------|--------------------------------------------|------------|-------------------------|-----------------------------------|
|             |        |                                            |            |                         |                                   |
| High School | #FH006 | Field House Westside of Track Water Supply | 10/12/2021 | Retested Over Threshold | Replace Outlet/Retest             |
|             |        |                                            |            |                         |                                   |
| Smallwood   | #SM01  | Bubbler Across from 226 (220)              | 10/12/2021 | Retested Over Threshold | Outlet to be Taken Out of Service |
|             |        |                                            |            |                         |                                   |
| Windermere  | #WB1   | Room 210 Sink                              | 10/12/2021 | Retested Over Threshold | Outlet to be Taken Out of Service |
|             |        |                                            |            |                         |                                   |
|             |        |                                            |            |                         |                                   |
|             |        |                                            |            |                         |                                   |
|             |        |                                            |            |                         |                                   |
|             |        |                                            |            |                         |                                   |