

| Sample Identification # and Location | Date/Time Collected | Date/Time Analyzed | Container ID | Analyte | Results | NYSDOH Action Level | Units |
|--------------------------------------|---------------------|--------------------|--------------|---------|---------|---------------------|-------|
| 2ND FLOOR KITCHEN 1-DISH SPRAY | 4/23/2021 05:15 | 5/9/2021 16:58 | 70170848001 | Lead | 2.7 | 15 | ug/L |
| 2ND FLOOR KITCHEN 2-3 BAY R | 4/23/2021 05:16 | 5/9/2021 17:03 | 70170848002 | Lead | 8.8 | 15 | ug/L |
| 2ND FLOOR KITCHEN 3-3 BAY L | 4/23/2021 05:17 | 5/9/2021 17:04 | 70170848003 | Lead | 11.0 | 15 | ug/L |
| 2ND FLOOR KITCHEN 4 -HAND WASH | 4/23/2021 05:18 | 5/9/2021 17:05 | 70170848004 | Lead | 22.5 | 15 | ug/L |
| 2ND FLOOR KITCHEN 5-FOOD PREP | 4/23/2021 05:19 | 5/9/2021 17:06 | 70170848005 | Lead | 7.0 | 15 | ug/L |
| 2ND FLOOR CAFETREIA STORE ROOM | 4/23/2021 05:20 | 5/9/2021 17:07 | 70170848006 | Lead | 344 | 15 | ug/L |
| 2ND FLOOR 219 ART ROOM CLASS 1 | 4/23/2021 05:22 | 5/9/2021 17:08 | 70170848007 | Lead | 1.7 | 15 | ug/L |
| 2ND FLOOR 219 ART ROOM CLASS 2 | 4/23/2021 05:23 | 5/9/2021 17:11 | 70170848008 | Lead | <1.0 | 15 | ug/L |
| 2ND FLOOR 219 ART ROOM CLASS 3 | 4/23/2021 05:24 | 5/9/2021 17:12 | 70170848009 | Lead | 5.8 | 15 | ug/L |
| 2ND FLOOR 218TECH ROOM CLASS 1 | 4/23/2021 05:25 | 5/9/2021 17:13 | 70170848010 | Lead | 1.8 | 15 | ug/L |
| 2ND FLOOR 218TECH ROOM CLASS 2 | 4/23/2021 05:26 | 5/9/2021 17:14 | 70170848011 | Lead | 1.2 | 15 | ug/L |
| 2ND FLOOR 217 AG ROOM CLASS 1 | 4/23/2021 05:29 | 5/9/2021 17:17 | 70170848012 | Lead | <1.0 | 15 | ug/L |
| 2ND FLOOR 217 AG ROOM CLASS 2 | 4/23/2021 05:30 | 5/9/2021 17:18 | 70170848013 | Lead | <1.0 | 15 | ug/L |
| 2ND FLOOR 214 HOME/CAREERS KIT | 4/23/2021 05:33 | 5/9/2021 17:19 | 70170848014 | Lead | <1.0 | 15 | ug/L |
| 2ND FLOOR 214 HOME/CAREERS KIT | 4/23/2021 05:34 | 5/9/2021 17:20 | 70170848015 | Lead | <1.0 | 15 | ug/L |
| 2ND FLOOR GN BATHROOM CAFE LEF | 4/23/2021 05:36 | 5/9/2021 17:23 | 70170848016 | Lead | <1.0 | 15 | ug/L |
| 2ND FLOOR GN BATHROOM CAFE RIG | 4/23/2021 05:37 | 5/9/2021 17:24 | 70170848017 | Lead | <1.0 | 15 | ug/L |
| 2ND FLOOR DF MAIN OFFICE BOTTL | 4/23/2021 05:39 | 5/9/2021 17:25 | 70170848018 | Lead | <1.0 | 15 | ug/L |
| 2ND FLOOR GIRLS BATHROOM FRONT | 4/23/2021 05:40 | 5/9/2021 17:26 | 70170848019 | Lead | <1.0 | 15 | ug/L |
| 2ND FLOOR GIRLS BATHROOM FRONT | 4/23/2021 05:41 | 5/9/2021 17:27 | 70170848020 | Lead | <1.0 | 15 | ug/L |
| 2ND FLOOR NURSE OFFICE BATHROO | 4/23/2021 05:42 | 5/9/2021 17:30 | 70170848021 | Lead | 3.3 | 15 | ug/L |
| 2ND FLOOR BOY BATHROOM HALL 1 | 4/23/2021 05:34 | 5/9/2021 17:35 | 70170848022 | Lead | <1.0 | 15 | ug/L |
| 2ND FLOOR BOY BATHROOM HALL 2 | 4/23/2021 05:44 | 5/9/2021 17:36 | 70170848023 | Lead | <1.0 | 15 | ug/L |
| 2ND FLOOR CUSTODIAL CLOSET FRO | 4/23/2021 05:44 | 5/9/2021 17:37 | 70170848024 | Lead | 4.2 | 15 | ug/L |
| 2ND FLOOR LIBRARY OFFICE CLASS | 4/23/2021 05:47 | 5/9/2021 17:38 | 70170848025 | Lead | <1.0 | 15 | ug/L |
| 3RD FLOOR DF RM 312 BOTTLE | 4/23/2021 05:51 | 5/9/2021 17:39 | 70170848026 | Lead | 1.2 | 15 | ug/L |
| 3RD FLOOR GIRLS BATHROOM 308-1 | 4/23/2021 05:52 | 5/9/2021 17:40 | 70170848027 | Lead | 1.1 | 15 | ug/L |
| 3RD FLOOR GIRLS BATHROOM 308-2 | 4/23/2021 05:53 | 5/9/2021 17:41 | 70170848028 | Lead | <1.0 | 15 | ug/L |
| 3RD FLOOR BOYS BATHROOM 304-1 | 4/23/2021 05:54 | 5/9/2021 17:42 | 70170848029 | Lead | 1.9 | 15 | ug/L |
| 3RD FLOOR BOYS BATHROOM 304-2 | 4/23/2021 05:55 | 5/9/2021 17:43 | 70170848030 | Lead | 1.0 | 15 | ug/L |
| 3RD FLOOR CUSTODIAL BY 304 | 4/23/2021 05:56 | 5/9/2021 17:44 | 70170848031 | Lead | 1.1 | 15 | ug/L |
| 3RD FLOOR RM 303 FACULTY BATH | 4/23/2021 05:57 | 5/9/2021 17:49 | 70170848032 | Lead | <1.0 | 15 | ug/L |
| 3RD FLOOR RM 303 FACULTY CLASS | 4/23/2021 05:58 | 5/9/2021 17:50 | 70170848033 | Lead | 3.4 | 15 | ug/L |
| 3RD FLOOR FACULTY BATH RM 302 | 4/23/2021 05:59 | 5/9/2021 17:51 | 70170848034 | Lead | 1.2 | 15 | ug/L |
| 1ST FLOOR BANDROOM, CLASS | 4/23/2021 06:04 | 5/9/2021 17:52 | 70170848035 | Lead | 1.4 | 15 | ug/L |
| 1ST FLOOR LOBBY CUSTODIAL CLOS | 4/23/2021 06:06 | 5/9/2021 17:53 | 70170848036 | Lead | 1.0 | 15 | ug/L |
| 1ST FLOOR BOY COACHES OFFICE B | 4/23/2021 06:07 | 5/9/2021 17:54 | 70170848037 | Lead | 1.1 | 15 | ug/L |
| 1ST FLOOR BOY LOCKER RM BATH 1 | 4/23/2021 06:08 | 5/9/2021 17:55 | 70170848038 | Lead | 4.2 | 15 | ug/L |
| 1ST FLOOR BOY LOCKER RM BATH 2 | 4/23/2021 06:09 | 5/9/2021 17:56 | 70170848039 | Lead | 2.9 | 15 | ug/L |
| 1ST FLOOR DF BY GYM BOTTLE | 4/23/2021 06:10 | 5/9/2021 17:59 | 70170848040 | Lead | <1.0 | 15 | ug/L |
| 1ST FLOOR GYM STORAGE RM ICE | 4/23/2021 06:11 | 5/9/2021 18:02 | 70170848041 | Lead | <1.0 | 15 | ug/L |
| 1ST FLOOR GIRL LOBBY BATHROOM1 | 4/23/2021 06:14 | 5/9/2021 18:05 | 70170848042 | Lead | 7.4 | 15 | ug/L |
| 1ST FLOOR GIRL LOBBY BATHROOM2 | 4/23/2021 06:15 | 5/9/2021 18:06 | 70170848043 | Lead | 5.6 | 15 | ug/L |
| 1ST FLOOR GIRL LOBBY BATHROOM3 | 4/23/2021 06:16 | 5/9/2021 18:07 | 70170848044 | Lead | 13.3 | 15 | ug/L |
| 1ST FLOOR BOYS LOBBY BATHROOM1 | 4/23/2021 06:17 | 5/9/2021 18:08 | 70170848045 | Lead | 1.8 | 15 | ug/L |
| 1ST FLOOR BOYS LOBBY BATHROOM2 | 4/23/2021 06:18 | 5/9/2021 18:10 | 70170848046 | Lead | 1.6 | 15 | ug/L |
| 1ST FLOOR BOYS LOBBY BATHROOM3 | 4/23/2021 06:19 | 5/9/2021 18:12 | 70170848047 | Lead | 2.1 | 15 | ug/L |
| 1ST FLOOR GIRLS COACHES OFFICE | 4/23/2021 06:20 | 5/9/2021 18:13 | 70170848048 | Lead | <1.0 | 15 | ug/L |

| | | | | | | | |
|--------------------------------|-----------------|----------------|-------------|------|------|----|------|
| 1ST FLOOR GIRLS LOCKERRM BATH1 | 4/23/2021 06:21 | 5/9/2021 18:14 | 70170848049 | Lead | 2.1 | 15 | ug/L |
| 1ST FLOOR GIRLS LOCKERRM BATH2 | 4/23/2021 06:22 | 5/9/2021 18:15 | 70170848050 | Lead | 1.4 | 15 | ug/L |
| 1ST FLOOR BOILER RM CUSTODUAL | 4/23/2021 06:23 | 5/9/2021 18:16 | 70170848051 | Lead | 1.5 | 15 | ug/L |
| 1ST FLOOR MAINTENENCE OFFICE B | 4/23/2021 06:24 | 5/9/2021 18:19 | 70170848052 | Lead | 12.5 | 15 | ug/L |
| RHS 14 | 4/23/2021 05:32 | 5/9/2021 18:20 | 70170848053 | Lead | <1.0 | 15 | ug/L |

NYSDOH Action Level for Lead of 15 ppb