

# J.C. Broderick & Associates, Inc.

Environmental / Construction Consulting & Testing



1775 Expressway Drive North  
Hauppauge, NY 11788  
631.584.5492  
Fax: 631.584.3395  
www.jcbroderick.com

July 31, 2024

Mr. Paul Noonan  
Patchogue-Medford Union Free School District  
Administration Building  
241 South Ocean Avenue  
Patchogue, New York 11772

**Re: Lead Testing in School Drinking Water  
Remedial Action Plan  
2023-2025 Compliance 10 NYCRR Subpart 67-4**

**JCB#: 24-57728**

Dear Mr. Noonan:

J.C. Broderick & Associates, Inc. (JCB) was retained to perform lead testing and analysis of the outlets which service the above referenced school district in accordance with 10 NYCRR Subpart 67-4 (Subpart 67-4).

The outlets servicing each of the school buildings were inventoried and assigned unique identification numbers. The use and location of each outlet was reviewed to determine its applicability for testing under Subpart 67-4.

An initial first-draw sample was collected from each applicable outlet after the minimum 8-hour stagnation period. Samples were logged into a chain of custody document and delivered to an Environmental Laboratory Approval Program (ELAP) accredited laboratory for analysis.

Results from the laboratory analysis were compared with the Action Level as defined by Subpart 67-4 of 5 parts per billion (ppb). Any outlet which exceeded this level requires a remediation action plan be implemented (i.e. removal from service, placarding for non-drinking uses). Outlets which did not exceed the action level do not require further testing or remediation.

Please see the following attachments which detail the sampling and analysis performed and remediation actions taken to date.

Attachment 1: Lead in Water Remediation Plan  
Attachment 2: Outlet Inventory and Lead Testing Results  
Attachment 3: Laboratory Analytical Reports  
Attachment 4: Laboratory Certifications


If you have any questions, or if more information is needed, please contact our office.

Sincerely,

A handwritten signature in black ink, appearing to read 'Meghan Gwynn', is written over a light blue horizontal line.

Meghan Gwynn  
J C Broderick & Associates, Inc.

Attachment 1:  
  
Lead in Water  
Remediation Plan



**J.C. Broderick & Associates, Inc.**  
*Environmental Consulting & Testing*  
1775 Expressway Drive North  
Hauppauge, New York 11788  
631.584.5492 fax 631.584.3395

# Lead in Water Remediation Plan

Section 67-4.4 Response of the New York State Department of Health (NYS DOH) Title 10 of the Official Compilation of the Codes, Rules and Regulations of the State of New York requires:

*If the lead concentration of water at an outlet exceeds the action level, the school shall:*

*(a) prohibit use of the outlet until:*

- (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and*
- (2) test results indicate that the lead levels are at or below the action level;*

As historical sampling results have indicated, the concentrations of lead are more likely attributable to the individual fixtures and/or their immediately adjoining plumbing, and not with the building-wide plumbing. Based upon this information, the following remedial steps are recommended:

## **Step 1A: Potable Outlets** (Outlets intended to be used for drinking/cooking)

Immediately remove the fixture from service. If necessary, provide an adequate supply of potable water for drinking/cooking to this location at no cost to the occupants. If an outlet is seldomly used or is unnecessary, the district may consider permanent removal of the outlet and capping of its supply line.

## **Step 1B: Non-Potable Outlets** (Outlets not intended for drinking/cooking)


See Step 1A OR Placard the outlet for non-drinking use. Signs must be clearly visible and in close proximity to the affected outlet. Example signage is provided at: [https://www.health.ny.gov/environmental/water/drinking/lead/docs/donotdrinksigns\\_lead .pdf](https://www.health.ny.gov/environmental/water/drinking/lead/docs/donotdrinksigns_lead.pdf).



Do not use for drinking



Hand washing only




## **Step 2: Service & Repair or Outlet Replacement**

The school district's plumber should evaluate the outlet to determine if any components require service or repair. Depending on the extent of service/repair necessary, age of the fixture, and or overall costs, the district may consider replacing the outlet entirely. Any newly installed components shall be certified lead free. (i.e. NSF/ANSI 61, NSF/ANSI-273). If servicing involves installing/replacing a point-of-use filtration system, this filter shall be certified for its lead reduction capability (i.e. NSF/ANSI 53). Follow all manufacturer's instructions for all component installations. OUTLET RESTRICTIONS MUST REMAIN IN PLACE UNTIL SATISFACTORY TEST RESULTS ARE RECEIVED. See Step 3.

## **Step 3: Retesting & Return to Service**

Schedule a retest of the outlet. Outlet restrictions must remain in place until lead testing results at or below the action level are received. Once satisfactory results are received, the outlet may be returned to normal service. Note: It is recommended that "Do Not Drink" signage remain in place for all non-potable and non-applicable outlet types.

Attachment 2:  
  
Outlet Inventory and  
Lead Testing Results



**J.C. Broderick & Associates, Inc.**

*Environmental Consulting & Testing*

1775 Expressway Drive North

Hauppauge, New York 11788

631.584.5492 fax 631.584.3395



# Laboratory Lead in Water Results

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 24-57728

## Patchogue-Medford Union Free School District

### Medford Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0001	Bathroom	5000	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0002	Girls Bathroom	5001	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0004	Girls Bathroom	5001	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0005	Custodial Closet	5002	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0006	Corridor Near Main Office (5005)	5004	Water Cooler	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0007	Corridor Near Main Office (5005)	5004	Bottle Fill Station	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0008	Main Office Kitchenette	5005E	Kitchen Non Potable	Non-Applicable					Placarded for Non-Drinking Use
PMED-0009	Main Office Bathroom	5005D	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0010	Boys Bathroom	5003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0011	Boys Bathroom	5003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0012	Boys Bathroom	5003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0013	Art Room	5006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0014	Faculty Bathroom	4006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0015	Lower Level Hallway	4008	Water Cooler	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0016	Lower Level Hallway	4008	Bottle Fill Station	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0017	Student Bathroom	4007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Medford Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0018	Storage	4005	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0019	Nurse's Bathroom	5007C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0020	Nurse's Office	5007	Nurse's Office Sink	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0021	Room 1	1012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0022	Room 2	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0023	Room 2	1001	Water Fountain-No Chiller	Potable	5/29/2024	OOS			Testing Required Before Return to Service
PMED-0024	Room 2 Bathroom	1001A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0027	Room 4	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0028	Room 4	1002	Water Fountain-No Chiller	Potable	5/29/2024	OOS			Testing Required Before Return to Service
PMED-0029	Room 4 Bathroom	1002A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0030	Room 5	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0031	Room 5	1010	Water Fountain-No Chiller	Potable	5/29/2024	OOS			Testing Required Before Return to Service
PMED-0032	Room 6	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0033	Room 6	1003	Water Fountain-No Chiller	Potable	5/29/2024	OOS			Testing Required Before Return to Service
PMED-0034	Room 6 Bathroom	1003B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0035	Room 8	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0036	Room 8	1004	Water Fountain-No Chiller	Potable	5/29/2024	OOS			Testing Required Before Return to Service
PMED-0038	Corridor Near Library (1009)	1013	Water Cooler	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0039	Corridor Near Library (1009)	1013	Bottle Fill Station	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0040	Library Bathroom	1009B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Medford Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0041	Library Office	1009C	Office Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0042	Room 10	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0043	Room 7 Bathroom	1008B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0044	Room 12	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0045	Custodial Closet	1007	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0046	Boiler Room	1031	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-0047	Girls Bathroom	1019A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0048	Girls Bathroom	1019A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0049	Boys Bathroom	1021A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0050	Boys Bathroom	1021A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0051	Corridor Near Gymnasium (1028A)	1032	Water Cooler	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0052	Corridor Near Gymnasium (1028A)	1032	Bottle Fill Station	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0053	Custodial Closet	1027	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0054	Ladies Bathroom	1026	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0055	Faculty Room	1024	Kitchen Non Potable	Non-Applicable					Placarded for Non-Drinking Use
PMED-0056	Faculty Room	1024	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-0059	Custodial Closet	3016	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0060	Rear Bathroom	3004A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0061	Handicap Bathroom	3004B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0062	Boys Bathroom	3013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Medford Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0064	Corridor Near Room 37 (3012)	3020	Water Cooler	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0065	Corridor Near Room 37 (3012)	3020	Bottle Fill Station	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0066	Room 25	2002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0067	Corridor Near Room 23 (2003)	2018	Water Cooler	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0068	Corridor Near Room 23 (2003)	2018	Bottle Fill Station	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0069	Boys Bathroom	2004A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0071	Rear Bathroom	2013A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0072	Handicap Bathroom	2013B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0073	Room 22	2012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0074	Custodial Closet	2007	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0075	Girls Bathroom	2008A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0076	Girls Bathroom	2008A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0077	Kitchen	1033A	Kitchen Faucet (Cold)	Potable	5/29/2024	25.6			Removed From Service, Pending Remediation
PMED-0078	Kitchen	1033A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-0079	Kitchen	1033A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-0080	Kitchen Bathroom	1033A2A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0081	Bathroom	5019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0082	Outside (5001)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0083	Outside Library	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0084	Outside Boiler Room	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use



# Medford Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0086	Outside Faculty Room	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0089	Outside Room 17	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3076	Girls Bathroom	5001	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3077	Girls Bathroom	5001	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3078	Boys Bathroom	5003	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3079	Room 3	1011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3080	Room 8 Bathroom	1004B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3081	Storage	1014	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-3082	Girls Bathroom	1019A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3083	Boys Bathroom	1021A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3084	Boys Bathroom	2004A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3085	Girls Room	3017	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3086	Girls Room	3017	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3087	Boys Bathroom	3013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3088	Outside Boiler Room	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3089	Outside Cafeteria	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3090	Outside Room 12	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3091	Outside Room 8	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

# Bay Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0090	Kitchen	1002B	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-0091	Kitchen	1002B	Kitchen Faucet (Cold)	Potable	5/21/2024	<5.0			Result Below Action Level Continue O&M
PMED-0092	Kitchen	1002B	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-0093	Faculty Bathroom	1004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0094	Faculty Room	1005	Kitchen Faucet (Cold)	Potable	5/21/2024	3.1			Result Below Action Level Continue O&M
PMED-0095	Faculty Room	1005	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-0096	Hall To Music Room (Outside Music Room 1012A)	1012	Water Fountain-No Chiller	Potable	5/21/2024	OOS			Testing Required Before Return to Service
PMED-0097	Music Room Bathroom	1012A2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0098	Band Room	1011	Water Fountain-No Chiller	Potable	5/21/2024	OOS			Testing Required Before Return to Service
PMED-0099	Band Room Bathroom	1011A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0100	Gymnasium	1007	Water Fountain-No Chiller	Potable	5/21/2024	OOS			Testing Required Before Return to Service
PMED-0101	Gymnasium	1007	Water Fountain-No Chiller	Potable	5/21/2024	OOS			Testing Required Before Return to Service
PMED-0102	Custodial Closet	1015	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0103	Corridor Across from Gym (1007)	1023	Water Cooler	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0104	Corridor Across from Gym (1007)	1023	Bottle Fill Station	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0105	Girls Bathroom	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0106	Girls Bathroom	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0108	Boys Bathroom	1018	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0109	Main Office Storage/Kitchenette	1022A	Kitchen Non Potable	Non-Applicable					Placarded for Non-Drinking Use
PMED-0110	Nurse's Office	1038	Nurse's Office Sink	Potable	5/21/2024	5.0			Result Below Action Level Continue O&M

# Bay Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0111	Nurse's Bathroom	1038B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0112	Corridor Near Nurse's Office (1038)	1039	Water Cooler	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0113	Corridor Near Nurse's Office (1038)	1039	Bottle Fill Station	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0114	Room 101	1037	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0115	Room 102	1025	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0116	Room 103	1036	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0117	Room 104	1026	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0118	Room 105	1035	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0119	Room 106	1027	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0120	Room 107	1034	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0121	Room 108	1028	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0122	Faculty Bathroom	1029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0123	Art Room 109	1033	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0124	Art Room 109	1033	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0125	Room 110	1030	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0126	Unisex Bathroom	1032A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0127	Room 111	1048	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0128	Corridor Near Room 112 (1047)	1049	Water Cooler	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0129	Corridor Near Room 112 (1047)	1049	Bottle Fill Station	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0130	Custodial Closet	1045	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

# Bay Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0131	Room 112	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0132	Library Work Room	1046B	Kitchen Faucet (Cold)	Potable	5/21/2024	1.6			Result Below Action Level Continue O&M
PMED-0133	Library Bathroom	1046A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0134	Elevator Corridor Bathroom	1059A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0135	Elevator Corridor Bathroom	1059A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0136	Room 210	1058	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0140	Custodial Closet	1056	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0141	Corridor Near Custodial Closet (1056)	1066	Water Cooler	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0142	Corridor Near Custodial Closet (1056)	1066	Bottle Fill Station	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0143	Room 209	1060	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0145	Boys Bathroom	1055	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0147	Room 208	1053	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0148	Room 207	1061	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0149	Room 206	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0150	Room 205	1062	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0151	Room 204	1051	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0152	Room 203	1063	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0153	Room 202	1050	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0154	Room 201	1064	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1994	Girls Bathroom	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Bay Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1995	Exterior of (1048)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1996	Elevator Corridor Bathroom (Former ESL Room)	1059A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1997	Girls Bathroom	1057	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1998	Girls Bathroom	1057	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1999	Girls Bathroom	1057	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-2000	Boys Bathroom	1055	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3001	Boys Bathroom	1055	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3002	Exterior of (1008)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3003	Exterior of (1002B)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3004	Exterior of (1002B)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3005	Exterior of (1028)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3006	Exterior of (1046)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3007	Exterior of (1047)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

# Barton Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0162	Custodial Bathroom	1001A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0163	Kitchen	1002	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-0164	Kitchen	1002	Kitchen Faucet (Cold)	Potable	5/29/2024	1.4			Result Below Action Level Continue O&M
PMED-0165	Kitchen	1002	Kitchen Non Potable	Non-Applicable					Placarded for Non-Drinking Use
PMED-0167	Kitchen	1002	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-0168	Kitchen	1002	Kitchen Faucet (Cold)	Potable	5/29/2024	1.4			Result Below Action Level Continue O&M
PMED-0169	Cafeteria	1004	Water Cooler	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0170	Cafeteria	1004	Bottle Fill Station	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0171	Men's Bathroom	1017A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0172	Women's Bathroom	1016A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0173	Custodial Closet	1014	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0176	Girls Bathroom	1008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0177	Main Office Kitchen	1012A	Kitchen Faucet (Cold)	Potable	5/29/2024	3.8			Result Below Action Level Continue O&M
PMED-0178	Custodial Closet	1010	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0179	Women's Bathroom	1011	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0180	Room 107	1040	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0181	Outside 1040	1044	Water Cooler	Potable	5/29/2024	OOS			Testing Required Before Return to Service
PMED-0182	Principal's Bathroom	1012C1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0183	Nurse's Bathroom	1022A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0184	Nurse's Office	1022	Nurse's Office Sink	Potable	5/29/2024	1.1			Result Below Action Level Continue O&M

# Barton Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0185	Room 103	1020	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0186	Room 106 Bathroom	1041B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0187	Room 106	1041	Water Fountain-No Chiller	Potable	5/29/2024	OOS			Testing Required Before Return to Service
PMED-0188	Room 104	1019	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0189	Room 105 Bathroom	1042B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0191	Room 105	1042	Water Fountain-No Chiller	Potable	5/29/2024	OOS			Testing Required Before Return to Service
PMED-0192	Room 106	1041	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0194	Corridor Near Library (1023)	1044	Water Cooler	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0195	Corridor Near Library (1023)	1044	Bottle Fill Station	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0196	Room 110	1038	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0197	Library Bathroom	1023B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0198	Room 111	1037	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0199	Ladies Bathroom	1025A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0200	Ladies Bathroom	1025A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0201	Social Worker Office 113	1035	Office Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0202	Custodial Closet/Storage A	1026	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0203	Men's Bathroom	1027A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0204	Men's Bathroom	1027A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0205	Room 114	1034	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0206	Room 116	1028	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Barton Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0207	Room 118	1029	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0208	Room 117	1032	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0209	Room 120	1030	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0210	Room 119	1031	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0211	Corridor Near Room 121 (4001)	4012	Water Cooler	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0212	Corridor Near Room 121 (4001)	4012	Bottle Fill Station	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0213	Room 124	4007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0214	Room 123	4002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0215	Room 126/128	4006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0216	Room 125	4003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0217	Room 126/128	4006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0219	Corridor Near Room 126/128 (4006)	4012	Water Cooler	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0220	Corridor Near Room 126/128 (4006)	4012	Bottle Fill Station	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0221	Custodial Closet	4008	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0222	Men's Bathroom	4009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0223	Women's Bathroom	4010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0224	Men's Locker Room	1054A	Water Fountain-No Chiller	Potable	5/29/2024	OOS			Testing Required Before Return to Service
PMED-0227	Corridor Near Men's Bathroom (1054)	1058	Water Cooler	Potable	5/29/2024	1.1			Result Below Action Level Continue O&M
PMED-0228	Corridor Near Men's Bathroom (1054)	1058	Bottle Fill Station	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0229	Custodial Closet	1049	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use



# Barton Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0230	Women's Bathroom	1050	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0231	Women's Bathroom	1050	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0232	Girls Locker Room	1050A	Water Fountain-No Chiller	Potable	5/29/2024	OOS			Testing Required Before Return to Service
PMED-0234	Corridor Near Room 230 (5001)	5011	Water Cooler	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0235	Corridor Near Room 230 (5001)	5011	Bottle Fill Station	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0236	Room 231	5002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0237	Room 230	5001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0238	Room 229	5004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0239	Room 228	5003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0240	Room 240	5006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0241	Room 226	5005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0242	Corridor Near Faculty Bathroom (5008)	5011	Water Cooler	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0243	Corridor Near Faculty Bathroom (5008)	5011	Bottle Fill Station	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0244	Custodial Closet	5007	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0245	Faculty Bathroom	5008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0246	Room 223	2002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0247	Room 222	2034	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0248	Room 219/221	2003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0249	Room 219/221	2003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0250	Room 218	2032	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Barton Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0251	Room 220	2033	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0252	Men's Bathroom	2031A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0253	Men's Bathroom	2031A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0254	Room 217	2004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0255	Women's Bathroom	2029A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0256	Women's Bathroom	2029A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0257	Custodial Closet	2026	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0258	Room 214/201 Office	2027A	Kitchen Non Potable	Non-Applicable					Placarded for Non-Drinking Use
PMED-0259	Room 213	2007	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0260	Room 202	2024	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0261	Room 212	2008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0262	Room 203	2023	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0263	Room 211	2009	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0267	Women's Bathroom	2021	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0268	Custodial Closet	2020	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0269	Men's Bathroom	2019	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0275	Room 210	2010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0277	Room 209	2011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0278	Room 205	2015	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0279	Room 208	2012	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

# Barton Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0280	Room 206	2014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0281	Room 207	2013	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0284	Corridor Near Faculty Room (1017)	1018	Water Fountain-No Chiller	Potable	5/29/2024	OOS			Testing Required Before Return to Service
PMED-0285	Exterior of Band/Orchestra Rm (1013)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0286	Exterior of Custodial Office (1001)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0288	Kitchen Custodial Closet	1003A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0289	Kitchen Bathroom	1003C1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0291	Exterior of Room 128 (4006)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3092	Kitchen	1002	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-3093	Custodial Office	1001	Bottled Water Dispenser	Potable	5/29/2024	OOS			Testing Required Before Return to Service
PMED-3094	Custodial Office	1001	Bottled Water Dispenser	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3095	Conference Room 134	1013	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-3096	Conference Room 134	1013	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-3097	Boys Bathroom	1007	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3098	105	1042	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3099	109	1039	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3100	Ladies Bathroom	1025A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3101	Men's Bathroom	1027A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3102	Ladies Bathroom	1025A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3103	Room 127	4004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Barton Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-3104	Men's Bathroom	1054	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3105	Men's Bathroom	1054	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3106	Exterior of Men's Bathroom (1054)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3107	Exterior of Men's Locked Room (1054A)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3108	Exterior of Room 118 (1029)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3109	Men's Bathroom	2031A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3110	Men's Bathroom	2031A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3111	Women's Bathroom	2029A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3112	Women's Bathroom	2029A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3113	214	2027	Bottled Water Dispenser	Potable	5/29/2024	OOS			Testing Required Before Return to Service
PMED-3114	214	2027	Bottled Water Dispenser	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3115	203	2023	Bottled Water Dispenser	Potable	5/29/2024	OOS			Testing Required Before Return to Service
PMED-3116	Girls Bathroom	2022	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3117	Girls Bathroom	2022	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3118	Girls Bathroom	2022	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3119	Girls Bathroom	2022	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3120	Boys Bathroom	2018	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3121	Boys Bathroom	2018	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3122	Boys Bathroom	2018	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3123	Boys Bathroom	2018	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

# Barton Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-3124	Corridor 206 To 214	2036	Water Cooler	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3125	Corridor 206 To 214	2036	Bottle Fill Station	Potable	5/29/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3126	204	2016	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3127	Exterior of Cafeteria Storage (1004A)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3128	Exterior of Girls Locker Room (1050A)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3129	Exterior of Room 119 (1031)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3130	Exterior of Room 113	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3131	Exterior of Room 110	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3132	Exterior of Room 106 (1041)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

# River Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0298	Kitchen	1002	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-0299	Kitchen	1002	Kitchen Faucet (Cold)	Potable	5/22/2024	15.6	7/12/2024	2.9	Outlet Remediated and Returned to Service Continue O&M
PMED-0300	Kitchen	1002	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-0301	Kitchen	1002	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-0302	Nurse's Office	1024	Nurse's Office Sink	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0303	Nurse's Bathroom	1023B1A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0304	Custodial Closet	1022	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0305	Custodial Office Rm 7	1003	Office Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0306	Custodial Office Rm 7	1003	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-0307	Corridor Near Faculty Room (1020)	1027	Water Cooler	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0308	Corridor Near Faculty Room (1020)	1027	Bottle Fill Station	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0309	Boys Bathroom	1019B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0312	Compressor Room	1006	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0313	Kindergarten 3	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0314	Corridor Near Kindergarten 1 (1008)	1027	Water Cooler	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0316	Kindergarten 4	1014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0317	Kindergarten 4	1014	Water Fountain-No Chiller	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-0318	Kindergarten 4 Bathroom	1014A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0319	Kindergarten 2	1013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0320	Kindergarten 2	1013	Water Fountain-No Chiller	Potable	5/22/2024	OOS			Testing Required Before Return to Service

# River Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0322	Kindergarten 1 Vestibule Bathroom	1008A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0323	Kindergarten 1	1008B	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0324	Main Office Kitchen	1012D	Kitchen Faucet (Cold)	Potable	5/22/2024	1.3			Result Below Action Level Continue O&M
PMED-0325	Custodial Closet	1009	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0326	Art Room 28	2021	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0327	Room 25	2001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0328	Boys Bathroom	2002A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0329	Boys Bathroom	2002A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0330	Corridor Near Room 24A (2018)	2022	Water Cooler	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0331	Corridor Near Room 24A (2018)	2022	Bottle Fill Station	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0332	Room 24A Bathroom	2018B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0333	Custodial Closet	2004	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0334	Girls Bathroom	2005A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0335	Girls Bathroom	2005A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0336	Room 21	2007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0337	Room 20	2014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0338	Corridor Near Room 19 (2008)	2022	Water Cooler	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0339	Corridor Near Room 19 (2008)	2022	Bottle Fill Station	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0340	Room 19	2008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0341	Room 18	2013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# River Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0342	Room 17	2009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0343	Room 16	2012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0344	Boys Bathroom	3002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0345	Boys Bathroom	3002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0346	Corridor Near Room 32A (3011)	3014	Water Cooler	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0347	Corridor Near Room 32A (3011)	3014	Bottle Fill Station	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0348	Room 32A Bathroom	3011B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0349	Custodial Closet	3005	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0352	Faculty Room	1020	Kitchen Faucet (Cold)	Potable	5/22/2024	2.5			Result Below Action Level Continue O&M
PMED-0353	Exterior of Principal's Office (1012B)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0354	Exterior of Main Office (1012)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0355	Exterior of Girls Bathroom (1018A)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0358	Exterior of Compressor Room (1006)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1741	Art Room 28	2021	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1742	STEM Room 35	3003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1743	Room 31	3007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1980	Cafeteria	1001	Water Cooler	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1981	Cafeteria	1001	Bottle Fill Station	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1982	Boys Bathroom	1019B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1983	Girls Bathroom Vestibule	1018	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use



# River Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1984	Girls Bathroom Vestibule	1018	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1985	Girls Bathroom Vestibule	1018	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1986	Corridor Near Kindergarten 1 (1008)	1027	Bottle Fill Station	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1987	Kindergarten 2 Bathroom	1013B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1988	Room 24 A Bathroom	2018B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1989	Girls Bathroom	3006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1990	Girls Bathroom	3006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1991	Exterior of Nurse's Office (1023)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1992	Exterior of Fan Room (1004)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1993	Exteior of Kindergarten 1 (1008B)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

# Tremont Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0360	Room 18	1059	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0361	Room 18	1059	Water Fountain-No Chiller	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-0362	Room 18 Bathroom	1059A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0363	Room 19	1058	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0364	Room 19	1058	Water Fountain-No Chiller	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-0365	Room 19 Bathroom	1058B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0366	Room 1	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0367	Room 2	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0368	Room 3	1014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0369	Room 4	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0370	Room 6	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0371	Corridor Near Room 6 (1004)	1015	Water Cooler	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0372	Corridor Near Room 6 (1004)	1015	Bottle Fill Station	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-0373	Room 7	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0374	Library Work Room	1012	Kitchen Faucet (Cold)	Potable	5/22/2024	2.0			Result Below Action Level Continue O&M
PMED-0375	Boys Bathroom	1006A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0377	Boys Bathroom	1006A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0378	Boys Bathroom	1006A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0381	Custodial Closet	1007	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0382	Girls Bathroom	1008A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Tremont Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0383	Girls Bathroom	1008A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0385	Girls Bathroom	1008A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0386	Girls Bathroom	1008A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0387	Girls Bathroom	1008A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0388	Men's Bathroom	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0389	Women's Bathroom	1010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0390	Custodial Office	1009	Kitchen Faucet (Cold)	Potable	5/22/2024	3.5			Result Below Action Level Continue O&M
PMED-0391	Boiler Room	0001	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0392	Kitchen	1016	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-0393	Kitchen	1016	Kitchen Faucet (Cold)	Potable	5/22/2024	3.5			Result Below Action Level Continue O&M
PMED-0394	Kitchen	1016	Kitchen Faucet (Cold)	Potable	5/22/2024	3.5			Result Below Action Level Continue O&M
PMED-0395	Kitchen	1016	Kitchen Faucet (Cold)	Potable	5/22/2024	5.6	7/12/2024	12.2	Removed From Service, Pending Remediation
PMED-0396	Kitchen	1016	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-0397	Kitchen	1016	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-0398	Cafeteria	1017	Water Cooler	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0399	Cafeteria	1017	Bottle Fill Station	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0400	Room B Bathroom	1027A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0401	Corridor Near Gymnasium (1019)	1029	Water Cooler	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0402	Corridor Near Gymnasium (1019)	1029	Bottle Fill Station	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0403	Coach's Office Bathroom	1026B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Tremont Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0404	Faculty Bathroom	1024	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0405	Bathroom Adjacent Main Office	1022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0406	Principal's Bathroom	1021A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0407	Book Room 9	1041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0408	Book Room 9 Bathroom	1041A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0409	Room 10	1040	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0410	Room 10 Bathroom	1040A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0411	Room 11	1039	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0412	Room 11 Bathroom	1039A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0413	Nurse's Office	1031	Nurse's Office Sink	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0414	Nurse's Bathroom	1031B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0415	Custodial Closet	1032	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0416	Room 12	1038	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0417	Room 12 Bathroom	1038A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0418	Faculty Room	1033	Kitchen Faucet (Cold)	Potable	5/22/2024	2.4			Result Below Action Level Continue O&M
PMED-0419	Faculty Room Bathroom	1033A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0420	Corridor Near Faculty Room (1033)	1042	Water Cooler	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0421	Corridor Near Faculty Room (1033)	1042	Bottle Fill Station	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0422	Room 14 Bathroom	1037A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0423	Room 15	1034	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Tremont Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0424	Room 15 Bathroom	1034A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0425	Room 16	1036	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0426	Room 16 Bathroom	1036A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0427	Room 14	1037	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0428	Art Room 17	1035	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0429	Art Room 17 Bathroom	1035A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0430	Custodial Closet	1056	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0431	Room 20	1044	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0433	Room 21	1055	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0434	Room 21 Bathroom	1055B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0435	Room 21	1055	Water Fountain-No Chiller	RFI					Outlet Permanently Removed
PMED-0436	Room 22	1045	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0437	Room 22 Bathroom	1045A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0438	Room 23	1053	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0439	Room 23 Bathroom	1053A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0440	Room 24	1046	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0441	Room 24 Bathroom	1046A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0442	Corridor Near Room 23 (1053)	1060	Water Cooler	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0443	Corridor Near Room 23 (1053)	1060	Bottle Fill Station	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0444	Room 25	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Tremont Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0445	Room 25 Bathroom	1052A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0446	Room 26	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0448	Room 27	1051	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0449	Room 27 Bathroom	1051A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0450	Room 28	1048	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0451	Room 28 Bathroom	1048A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0452	Room 29	1050	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0453	Room 29 Bathroom	1050A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0454	Room 30	1049	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0456	Bathroom	2001	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0457	Boys Bathroom	2007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0458	Boys Bathroom	2007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0459	Boys Bathroom	2007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0460	Girls Bathroom	2010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0461	Girls Bathroom	2010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0462	Girls Bathroom	2010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0463	Room 38	2013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0464	Room 39	2014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0465	Room 40	2015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0466	Room 41	2016	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Tremont Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0467	Corridor Near New Gymnasium (2023)	2024	Water Cooler	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0468	Corridor Near New Gymnasium (2023)	2024	Bottle Fill Station	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0469	Custodial Closet	2009	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0470	Exterior Bathroom (Adj. 2018)	3000	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0473	Exterior of Kitchen (1016)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0474	Exterior of Room 32 (2003)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0475	Exterior of Room 38 (2013)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0477	Exterior of Room 1 (1001)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0481	Exterior of Room 16 (1036)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1961	Boys Bathroom	1006A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1962	Boys Bathroom	1006A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1963	Boys Bathroom	1006A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1964	Girls Bathroom	1008A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1965	Conference Room	1023	Bottled Water Dispenser	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-1966	Conference Room	1023	Bottled Water Dispenser	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-1967	Health Office	1031	Ice Machine	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1968	Room 20 Bathroom	1044A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1969	Room 26 Bathroom	1047A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1970	Room 30 Bathroom	1049A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1971	Boys Bathroom	2007	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

# Tremont Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1972	Girls Bathroom	2010	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1973	Exterior of Kitchen (1016)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1974	Exterior of Room 17 (1035)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1975	Exterior of Room 19 (1058)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1976	Exterior of Room 4 (1003)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1977	Exterior of Room 10 (1040)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1978	Exterior of Room Psychologists Office (1025B)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1979	Exterior of Library (1013)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use



# Eagle Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0482	Art Room 49	4000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0483	Art Room 49	4000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0484	Art Room 49	4000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0485	Room 12	1032	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0486	Room 12 Bathroom	1032A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0487	Room 13	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0488	Room 13 Bathroom	1001A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0489	Room 11	1031	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0491	Room 14	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0492	Room 14 Bathroom	1002A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0493	Room 10	1030	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0497	Room 9	1029	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0498	Room 9 Bathroom	1029A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0499	Corridor Near Room 8 (1028)	1033	Water Cooler	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0501	Room 16	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0502	Room 16 Bathroom	1004A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0503	Room 8	1028	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0504	Room 17	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0505	Room 17 Bathroom	1005A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0506	7	1027	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Eagle Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0507	7 Bathroom	1027A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0508	Men's Bathroom	1009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0509	Women's Bathroom	1010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0510	Women's Bathroom	1010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0511	Book Room 6	1026	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0512	Book Room 6 Bathroom	1026A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0513	Main Office Kitchen	1011B	Kitchen Faucet (Cold)	Potable	5/21/2024	2.1			Result Below Action Level Continue O&M
PMED-0514	Corridor Near Book Room 6 (1026)	1033	Water Cooler	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0515	Corridor Near Book Room 6 (1026)	1033	Bottle Fill Station	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0516	Nurse's Office	1012A	Nurse's Office Sink	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0517	Nurse's Bathroom	1012A2	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0518	Public Restroom	1024A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0519	Room 18	1014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0520	Room 18 Bathroom	1014A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0521	Room 4	1023	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0522	Room 4 Bathroom	1023A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0523	Room 3	1022	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0524	Room 3 Bathroom	1022B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0525	Corridor Near Room 3 (1022)	1033	Water Cooler	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0526	Corridor Near Room 3 (1022)	1033	Bottle Fill Station	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M

# Eagle Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0527	Room 19	1015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0528	Room 19 Bathroom	1015A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0529	Room 20	1016	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0530	Room 20 Bathroom	1016A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0531	Room 2	1021	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0532	Room 2 Bathroom	1021B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0533	Room 21	1017	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0534	Room 21 Bathroom	1017A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0535	Room 1	1020	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0537	Room 1 Bathroom	1020B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0538	Room 22	1018	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0539	Room 22	1018	Water Fountain-No Chiller	Potable	5/21/2024	OOS			Testing Required Before Return to Service
PMED-0540	Room 22 Bathroom	1018A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0541	OT/PT Bathroom	1038A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0542	Storage Room Custodial Closet	1040C	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0543	Storage Room Bathroom	1040B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0544	Room 44 Music Room	1051	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0545	Room 44 Music Room	1051	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0546	Room 44 Music Room	1051	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0547	Music Room 45	1050	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Eagle Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0548	Music Room 45 Bathroom	1050A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0549	Corridor Near Music Room 46 (1049)	1052	Water Cooler	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0550	Corridor Near Music Room 46 (1049)	1052	Bottle Fill Station	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0551	Music Room 46	1049	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0552	Custodial Closet	1048	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0553	Girls Bathroom	1047	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0554	Girls Bathroom	1047	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0555	Girls Bathroom	1047	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0556	Girls Bathroom	1047	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0557	Boys Bathroom	1046	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0558	Boys Bathroom	1046	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0559	Cafeteria	1042	Water Cooler	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0560	Cafeteria	1042	Bottle Fill Station	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0561	Kitchen	1043	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-0562	Kitchen	1043	Kitchen Non Potable	Non-Applicable	5/21/2024	274			Further Investigation Determined Outlet Function as Non-Applicable, Placarded for Non-Drinking Use
PMED-0563	Kitchen	1043	Kitchen Faucet (Cold)	Potable	5/21/2024	2.8			Result Below Action Level Continue O&M
PMED-0564	Kitchen	1043	Kitchen Faucet (Cold)	Potable	5/21/2024	1.1			Result Below Action Level Continue O&M
PMED-0565	Kitchen	1043	Kitchen Faucet (Cold)	Potable	5/21/2024	1.3			Result Below Action Level Continue O&M
PMED-0566	Kitchen	1043	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-0567	Kitchen Storage/Exit Vestibule	1043A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

# Eagle Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0568	Kitchen Storage/Exit Vestibule	1043A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0569	Kitchen Bathroom	1043D	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0570	Men's Bathroom	4006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0571	Women's Bathroom	4007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0572	Corridor Near Secondary Gym (4008)	4009	Water Cooler	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0573	Corridor Near Secondary Gym (4008)	4009	Bottle Fill Station	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0574	Custodial Office Bathroom	1055A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0575	Room 33	2033	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0576	Room 34	2001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0577	Room 32	2032	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0578	Room 35	2002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0579	Room 31	2031	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0580	Room 36	2003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0581	Girls Bathroom	2030A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0582	Girls Bathroom	2030A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0583	Girls Bathroom	2030A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0584	Girls Bathroom	2030A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0585	Corridor Near Girls Bathroom (2030)	2034	Water Cooler	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0586	Corridor Near Girls Bathroom (2030)	2034	Bottle Fill Station	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0587	Custodial Closet	2029	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

# Eagle Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0588	Boys Bathroom	2028A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0589	Boys Bathroom	2028A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0590	Boys Bathroom	2028A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0591	Boys Bathroom	2028A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0592	Room 37	2004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0593	Room 30	2026	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0594	Room 29	2025	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0596	Faculty Room	2005	Kitchen Faucet (Cold)	Potable	5/21/2024	3.4			Result Below Action Level Continue O&M
PMED-0597	Men's Bathroom	2007	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0598	Women's Bathroom	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0599	Women's Bathroom	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0600	Room 28	2024	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0601	Room 27	2023	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0602	Library Work Room	2010A	Kitchen Faucet (Cold)	Potable	5/21/2024	1.5			Result Below Action Level Continue O&M
PMED-0603	Room 26	2022	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0604	Boys Bathroom	2020A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0605	Boys Bathroom	2020A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0606	Boys Bathroom	2020A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0607	Boys Bathroom	2020A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0608	Custodial Closet	2019	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

# Eagle Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0609	Corridor Near Custodial Closet (2019)	2034	Water Cooler	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0610	Corridor Near Custodial Closet (2019)	2034	Bottle Fill Station	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0611	Girls Bathroom	2018A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0612	Girls Bathroom	2018A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0613	Girls Bathroom	2018A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0614	Girls Bathroom	2018A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0615	Room 25	2017	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0616	Room 40	2011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0617	Room 41	2012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0618	Room 24	2016	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0619	Room 42	2013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0620	Room 23	2015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0621	Room 43	2014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0622	Courtyard - Exterior of Rm 44 (1051)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0623	Exterior of Room 16 (1004)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1909	11 Bathroom	1031A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1910	10 Bathroom	1030A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1911	15	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1912	15 Bathroom	1003A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1913	Corridor 12 To Exit Adjacent To 22	1033	Bottle Fill Station	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M

# Eagle Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1914	OT/PT Bathroom	1038A1	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1915	Bathroom	1040B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1916	Exterior of Gym Storage (1040)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1917	Faculty Room	2005	Bottled Water Dispenser	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M



# Administration Building

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0626	Women's Bathroom	1006B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0627	Men's Bathroom	1004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0628	Custodial Closet	1011	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0630	Women's Bathroom Vestibule	2006A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0631	Superintendent's Bathroom	2004A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0632	Custodial Closet	2009	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0633	Basement Faculty Room	0008	Kitchen Non Potable	Non-Applicable					Placarded for Non-Drinking Use
PMED-0634	Basement Faculty Room	0008	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-0635	Exterior of Business Office (1012C)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3032	Exterior of Payroll Interior Office (1001C)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3033	Conference Room	1006	Bottled Water Dispenser	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3034	Conference Room	1006	Bottled Water Dispenser	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3035	Business Office 2 Inner Office Closet	1012C1	Kitchen Non Potable	Non-Applicable	5/30/2024	36.1			Further Investigation Determined Outlet Function as Non-Applicable, Placarded for Non-Drinking Use
PMED-3036	Business Office 2 Inner Office Closet	1012C1	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-3037	2nd Floor Corridor	2011	Bottled Water Dispenser	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3038	2nd Floor Corridor	2011	Bottled Water Dispenser	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M

# South Ocean Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0637	Director Office 100	1001	Bottled Water Dispenser	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0638	Director's Office Kitchenette	1002E	Kitchen Non Potable	Non-Applicable					Placarded for Non-Drinking Use
PMED-0639	Print Shop Printing Center	1003A	Kitchen Non Potable	Non-Applicable	5/30/2024	417			Further Investigation Determined Outlet Function as Non-Applicable, Placarded for Non-Drinking Use
PMED-0640	Custodial Office	1008B	Bottled Water Dispenser	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0641	Conference Room Kitchen	1006A	Kitchen Non Potable	Non-Applicable					Placarded for Non-Drinking Use
PMED-0644	Nurse's Office	1009	Nurse's Office Sink	Potable	5/30/2024	4.1			Result Below Action Level Continue O&M
PMED-0645	Nurse's Bathroom	1009B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0646	Women's Bathroom	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0647	Girls Bathroom	1012A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0649	Girls Bathroom	1012A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0651	Room 110 Technology	1025	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0652	Room 110 Technology	1025	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0653	Room 110 Technology	1025	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0654	Room 111 Technology	1030	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0655	Room 111 Technology	1030	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0656	Room 111 Technology	1030	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0657	Custodial Closet	1019	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0658	Boys Bathroom	1018A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0659	Boys Bathroom	1018A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0660	Corridor Near Kitchen (1017)	1024	Water Cooler	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M

# South Ocean Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0661	<b>Corridor Near Kitchen (1017)</b>	1024	Bottle Fill Station	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0662	<b>Kitchen</b>	1017	Kitchen Faucet (Cold)	Potable	5/30/2024	37.9	7/12/2024	5.6	Removed From Service, Pending Remediation
PMED-0663	<b>Kitchen</b>	1017	Kitchen Faucet (Cold)	Potable	5/30/2024	1.1			Result Below Action Level Continue O&M
PMED-0664	<b>Kitchen</b>	1017	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-0665	<b>Kitchen</b>	1017	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-0666	<b>Kitchen</b>	1017	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-0667	<b>Girls Locker Room</b>	1038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0668	<b>Girls Locker Room</b>	1038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0670	<b>Girls Coach's Office Bathroom</b>	1039A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0671	<b>Boys Coachs' Office Bathroom</b>	1040A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0672	<b>Boys Locker Room Custodial Closet</b>	1041A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0673	<b>Boys Locker Room Bathroom</b>	1041D	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0674	<b>Boys Locker Room Bathroom</b>	1041D	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0677	<b>Girls Bathroom</b>	1042A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0678	<b>Girls Bathroom</b>	1042A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0679	<b>Boys Bathroom</b>	1042B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0681	<b>Corridor Near Room 208 (2033)</b>	2034	Water Cooler	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0682	<b>Corridor Near Room 208 (2033)</b>	2034	Bottle Fill Station	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0683	<b>Men's Bathroom</b>	2028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0684	<b>Boys Bathroom</b>	2013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# South Ocean Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0685	Boys Bathroom	2013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0686	Faculty Bathroom	2014A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0687	Corridor Near Psychologist Office 205 (2016A)	2018	Water Cooler	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0688	Corridor Near Psychologist Office 205 (2016A)	2018	Bottle Fill Station	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0689	Psychologist Office 205	2016A	Office Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0690	Psychologist Office Bathroom	2016A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0691	Psychologist Office 205	2016A	Office Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0692	Library Work Room	2019A	Kitchen Non Potable	Non-Applicable					Placarded for Non-Drinking Use
PMED-0693	Girls Bathroom	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0694	Girls Bathroom	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0695	Girls Bathroom	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0696	Girls Bathroom	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0697	Custodial Closet	2006	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0698	Corridor Near Room 215 (2003)	2018	Water Cooler	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0699	Corridor Near Room 215 (2003)	2018	Bottle Fill Station	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0700	Art Room 317	3011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0701	Art Room 317	3011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0702	Art Room 318	3009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0703	Art Room 318	3009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0704	Art Room 318	3009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# South Ocean Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0705	Art Room 318	3009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0706	Art Room 318	3009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0707	Art Room 318	3009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0709	Men's Bathroom	3008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0710	Women's Bathroom	3013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0712	Boys Bathroom	3015	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0713	Boys Bathroom	3015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0714	Boys Bathroom	3015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0715	Custodial Closet	3016	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0719	Girls Bathroom	3004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0720	Girls Bathroom	3004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0721	Girls Bathroom	3004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0722	Corridor Near Room 323 (3001)	3007	Water Cooler	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0723	Corridor Near Room 323 (3001)	3007	Bottle Fill Station	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0725	Science Room 404	4006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0726	Science Room 404	4006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0727	Science Room 404	4006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0728	Science Room 404	4006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0729	Science Room 404	4006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0730	Science Room 405	4000	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

# South Ocean Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0731	Science Room 405	4000	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0732	Science Room 405	4000	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0733	Science Room 405	4000	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0734	Science Room 405	4000	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0735	Prep Room 405	4000A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0737	Science Room 402	4005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0738	Science Room 402	4005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0739	Science Room 402	4005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0740	Science Room 402	4005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0741	Science Room 402	4005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0742	Prep Room 400	4003B	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0743	Science Room 403	4001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0744	Science Room 403	4001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0745	Science Room 403	4001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0746	Science Room 403	4001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0747	Science Room 403	4001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0748	Science Room 403	4001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0749	Custodial Closet	4004	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0750	Science Room 400	4003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0751	Science Room 400	4003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

# South Ocean Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0752	Science Room 400	4003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0753	Science Room 400	4003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0755	Exterior of Guidance Office (1007)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0756	Exterior of Room 113 (1016)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0757	Exterior of Gymnasium (1043)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0759	Exterior of Printing Center (1003A)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3008	Directors Office 100	1001	Bottled Water Dispenser	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3009	Print Shop Printing Center	1003A	Bottled Water Dispenser	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3010	Custodial Office	1008B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3011	Corridor Between Guidance Office & Kitchen	1024	Water Cooler	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3012	Girls Bathroom	1012A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3013	Girls Bathroom	1012A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3014	Girls Bathroom	1012A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3015	Mens Bathroom	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3016	Corridor Between Guidance Office & Kitchen	1024	Bottle Fill Station	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3017	Girls Locker Room	1038	Water Cooler	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3018	Girls Locker Room	1038	Bottle Fill Station	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3019	Boys Locker Room	1041	Water Cooler	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3020	Boys Locker Room	1041	Bottle Fill Station	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3021	Boys Bathroom	1042B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# South Ocean Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-3022	Hallway From Men's Bathroom To Staircase (Near	3012	Water Cooler	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3023	Hallway From Men's Bathroom To Staircase (Near	3012	Bottle Fill Station	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3024	Girls Bathroom	3004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3025	Boys Bathroom	3015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3026	Room 405 Prep Room	4000A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3027	Room 404	4006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3028	4th Floor Corridor (Includes Stairwell Near Elevator)	4007	Water Cooler	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3029	4th Floor Corridor (Includes Stairwell Near Elevator)	4007	Bottle Fill Station	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3030	Exterior of Conference Room (1006)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3031	Exterior of Gymnasium (1043)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use



# Canaan Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0760	Room 1	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0761	Room 2	1012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0762	Room 3	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0763	Room 4	1009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0764	Room 5	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0765	Room 6	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0766	Corridor Near Room 7 (1006)	1013	Water Cooler	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0767	Corridor Near Room 7 (1006)	1013	Bottle Fill Station	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0768	Room 7	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0769	Room 14	1015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0770	Room 8	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0771	Room 13	3000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0772	Room 13	3000	Water Fountain-No Chiller	Potable	5/21/2024	OOS			Testing Required Before Return to Service
PMED-0773	Room 10	3001	Water Fountain-No Chiller	Potable	5/21/2024	OOS			Testing Required Before Return to Service
PMED-0774	Room 10	3001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0775	Room 11	3002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0776	Room 11	3002	Water Fountain-No Chiller	Potable	5/21/2024	OOS			Testing Required Before Return to Service
PMED-0777	Room 12	3003	Water Fountain-No Chiller	Potable	5/21/2024	OOS			Testing Required Before Return to Service
PMED-0778	Room 12	3003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0779	Room 17	3009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Canaan Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0780	Music Room 806	3010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0781	Women's Bathroom	3011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0782	Custodial Closet	3012	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0783	Corridor Near Music Room 807 (3014)	3018	Water Cooler	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0784	Corridor Near Music Room 807 (3014)	3018	Bottle Fill Station	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0785	Music Room 807	3014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0786	Art Room 808	3015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0787	Art Room 808	3015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0788	Art Room 808	3015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0789	Men's Bathroom	3016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0790	Girls Bathroom	3019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0791	Girls Bathroom	3019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0792	Girls Bathroom	3019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0793	Boys Bathroom	3020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0794	Boys Bathroom	3020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0795	Boys Bathroom	3020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0796	Corridor Near Gymnasium (3024)	3025	Water Cooler	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0797	Corridor Near Gymnasium (3024)	3025	Bottle Fill Station	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0800	Boys Bathroom	1031	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0801	Boys Bathroom	1031	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Canaan Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0802	Coach's Office	1030D	Water Fountain-No Chiller	Potable	5/21/2024	OOS			Testing Required Before Return to Service
PMED-0803	Gym Storage Bathroom	1030B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0804	Gym Storage	1030C1	Water Fountain-No Chiller	Potable	5/21/2024	OOS			Testing Required Before Return to Service
PMED-0805	Nurse's Office	1019A	Nurse's Office Sink	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0806	Nurse's Bathroom	1019A2	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0807	Custodial Closet	1020	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0808	Girls Bathroom	1029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0809	Girls Bathroom	1029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0810	Faculty Room	1022	Kitchen Faucet (Cold)	Potable	5/21/2024	2.2			Result Below Action Level Continue O&M
PMED-0812	Receiving Area Bathroom	1027A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0813	Receiving Area Custodial Closet	1027B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0814	Kitchen	1026	Kitchen Faucet (Cold)	Potable	5/21/2024	3.4			Result Below Action Level Continue O&M
PMED-0815	Kitchen	1026	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-0816	Kitchen	1026A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-0817	Kitchen	1026A	Kitchen Faucet (Cold)	Potable	5/21/2024	2.9			Result Below Action Level Continue O&M
PMED-0818	Kitchen	1026A	Kitchen Faucet (Cold)	Potable	5/21/2024	3.6			Result Below Action Level Continue O&M
PMED-0819	Kitchen	1026A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-0820	Cafeteria	1034	Water Cooler	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0821	Cafeteria	1034	Bottle Fill Station	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0822	Women's Bathroom	1023	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Canaan Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0823	Women's Bathroom	1023	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0824	Corridor Near Women's Bathroom (1023)	1032	Water Cooler	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0825	Corridor Near Women's Bathroom (1023)	1032	Bottle Fill Station	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0826	Men's Bathroom	1024	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0827	Men's Bathroom	1024	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0828	Main Office Copy Room	1035A	Office Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0829	Library Work Room	1037A	Kitchen Faucet (Cold)	Potable	5/21/2024	3.5			Result Below Action Level Continue O&M
PMED-0830	Library Bathroom	1037B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0831	Exterior of Library (1037) - Courtyard	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0832	Custodial Closet	1038	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0833	Exterior of Corridor (3022) - Courtyard	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0834	Exterior of Corridor (3018) - Courtyard	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0836	Room 600	2001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0837	Room 19	2017	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0838	Room 20	2003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0839	Room 21	2016	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0841	Girls Bathroom	2004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0843	Faculty Bathroom	2005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0844	Room 22	2015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0845	Art Room 25	2007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Canaan Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0846	Art Room 25	2007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0847	Art Room 25	2007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0848	Room 24	2014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0849	Custodial Closet	2008	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0850	Room 26	2013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0851	Boys Bathroom	2009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0852	Boys Bathroom	2009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0853	Boys Bathroom	2009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0854	Corridor Near Boys Bathroom (2009)	2020	Water Cooler	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0855	Corridor Near Boys Bathroom (2009)	2020	Bottle Fill Station	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0856	Room 30	2012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0857	Room 27	2010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0858	Room 31	4000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0859	Room 31	4000	Water Fountain-No Chiller	Potable	5/21/2024	OOS			Testing Required Before Return to Service
PMED-0860	Room 32	4001	Water Fountain-No Chiller	Potable	5/21/2024	OOS			Testing Required Before Return to Service
PMED-0861	Room 32	4001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0862	Room 34	4002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0863	Room 34	4002	Water Fountain-No Chiller	Potable	5/21/2024	OOS			Testing Required Before Return to Service
PMED-0864	Room 33	4003	Water Fountain-No Chiller	Potable	5/21/2024	OOS			Testing Required Before Return to Service
PMED-0866	Room 38	4009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Canaan Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0867	Room 39	4010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0868	Faculty Bathroom	4011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0869	Custodial Closet	4012	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0870	Room 40	4014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0871	Corridor Outside Room 40 (4014)	4017	Water Cooler	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0872	Corridor Outside Room 40 (4014)	4017	Bottle Fill Station	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0873	Room 41	4015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0875	Exterior of Stairwell (1039)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0876	Exterior of West Entrance (1041)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-0878	Exterior of Room 10 (3001)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1918	Girls Bathroom	3019	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1919	Boys Bathroom	3020	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1920	Corridor Child Care To Gym	1032	Water Cooler	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1921	Corridor Child Care To Gym	1032	Bottle Fill Station	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1922	Custodial Break Room Office	1028A	Bottled Water Dispenser	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1923	Custodial Break Room Office	1028A	Bottled Water Dispenser	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1924	Faculty Lounge	1022	Bottled Water Dispenser	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1925	Faculty Lounge	1022	Bottled Water Dispenser	Potable	5/21/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1926	Exterior of Room 13 (3000) - Courtyard	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1927	Girls Bathroom	2004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Canaan Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1928	Girls Bathroom	2004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1929	Room 33	4003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1930	Exterior of Custodial Closet (1027B)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1931	Exterior of Art Room 808 (3015)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1932	Exterior of Room 6 (1007)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

# Saxton Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0880	Science Room 221	2034	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0881	Science Room 221	2034	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0882	Science Room 221	2034	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0883	Prep Room 221	2034A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0884	Prep Room 221	2034A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0885	Science Room 222	2036	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0886	Science Room 222	2036	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0887	Science Room 222	2036	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0888	Science Room 219	2035	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0889	Prep Room 219	2035A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0890	Prep Room 223	2037	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0891	Prep Room 223	2037	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0892	Science Room 218	2038	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0893	Science Room 218	2038	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0894	Science Room 218	2038	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0895	Faculty Room	2039	Kitchen Faucet (Cold)	Potable	5/30/2024	4.7			Result Below Action Level Continue O&M
PMED-0896	Corridor Near Room 218 (2038)	2058	Water Cooler	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0897	Corridor Near Room 218 (2038)	2058	Bottle Fill Station	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0898	Library Break Room	2046C	Kitchen Non Potable	Non-Applicable					Placarded for Non-Drinking Use
PMED-0899	Men's Bathroom	2041	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use



# Saxton Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0901	Women's Bathroom	2045	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0902	Women's Bathroom	2045	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0904	Science Room 234	2048	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0905	Science Room 234	2048	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0906	Science Room 234	2048	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0907	Science Room 234	2048	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0908	Prep Room 234	2048A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0909	Corridor Near Room 230 (2055)	2058	Water Fountain-No Chiller	Potable	5/30/2024	OOS			Testing Required Before Return to Service
PMED-0910	Boys Bathroom	2029A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0911	Boys Bathroom	2029A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0912	Boys Bathroom	2029A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0913	Boys Bathroom	2029A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0914	Boys Bathroom	2029A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0915	Custodial Closet	2028	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0916	Girls Bathroom	2027A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0917	Girls Bathroom	2027A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0918	Girls Bathroom	2027A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0919	Girls Bathroom	2027A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0921	Corridor Near Room 217 (2026)	2032	Bottle Fill Station	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0924	Women's Bathroom	2005B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Saxton Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0925	Men's Bathroom	2005A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0926	Boys Bathroom	2007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0927	Boys Bathroom	2007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0928	Boys Bathroom	2007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0929	Corridor Near Room 203 (2008)	2015	Water Fountain-No Chiller	Potable	5/30/2024	OOS			Testing Required Before Return to Service
PMED-0930	Custodial Closet	2009	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0931	Girls Bathroom	2010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0932	Girls Bathroom	2010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0933	Girls Bathroom	2010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0934	Garage Storage Bathroom	1046A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0935	Girls Locker Room	1045	Water Fountain-No Chiller	Potable	5/30/2024	OOS			Testing Required Before Return to Service
PMED-0936	Girls Coach's Office Bathroom	1045A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0937	Girls Locker Room Custodial Closet	1045B1	Sports Cooler	Non-Potable	5/30/2024	45.9	7/12/2024	3.2	Outlet Remediated and Returned to Service Continue O&M
PMED-0938	Girls Locker Room	1045B	Water Fountain-No Chiller	Potable	5/30/2024	OOS			Testing Required Before Return to Service
PMED-0939	Girls Locker Room	1045B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0940	Girls Back Coach's Office Bathroom	1045B3B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0941	Girls Back Locker Room	1045B3	Water Fountain-No Chiller	Potable	5/30/2024	OOS			Testing Required Before Return to Service
PMED-0942	Girls Back Locker Room Bathroom	1045B7	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0943	Corridor Near Gymnasium (1044)	1051	Water Cooler	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0944	Corridor Near Gymnasium (1044)	1051	Bottle Fill Station	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M

# Saxton Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0945	Boiler Room	0004B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0946	Boys Locker Room	1050	Water Fountain-No Chiller	Potable	5/30/2024	OOS			Testing Required Before Return to Service
PMED-0947	Boys Coach's Office	1050A1	Ice Machine	Potable	5/30/2024	OOS			Testing Required Before Return to Service
PMED-0948	Boys Coach's Office Bathroom	1050A1A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0949	Boys Locker Room	1050B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0950	Boys Back Locker Room	1050C	Water Fountain-No Chiller	Potable	5/30/2024	OOS			Testing Required Before Return to Service
PMED-0951	Boys Back Coach's Office Bathroom	1050C4B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0952	Boys Locker Room Custodial Closet	1050B2	Slop Sink	Non-Applicable	5/30/2024	7.2	7/12/2024	12.0	Further Investigation Determined Outlet Function as Non-Applicable, Placarded for Non-Drinking Use
PMED-0953	Art Room 110	1055	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0955	Art Room 110	1055	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0956	Art Room 110	1055	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0958	Art Room 110	1055	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0960	Corridor Near Art Room 110 (1055)	1056	Bottle Fill Station	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0961	Art Room 109	1052	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0962	Art Room 109	1052	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0963	Corridor Near Room 108 (1006)	1008	Water Fountain-No Chiller	Potable	5/30/2024	OOS			Testing Required Before Return to Service
PMED-0964	Women's Bathroom	1005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0965	Women's Bathroom	1005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0966	Women's Bathroom	1005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0967	Custodial Closet	1009	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

# Saxton Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0968	Corridor Near Band Room 103 (1012)	1020	Water Fountain-No Chiller	Potable	5/30/2024	OOS			Testing Required Before Return to Service
PMED-0969	Women's Bathroom	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0970	Men's Bathroom	1017	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-0971	Men's Bathroom	1017	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0972	Nurse's Office	1019	Nurse's Office Sink	Potable	5/30/2024	2.0			Result Below Action Level Continue O&M
PMED-0973	Nurse's Bathroom	1019B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0974	Corridor Near Room 118 (1022)	1039	Water Fountain-No Chiller	Potable	5/30/2024	OOS			Testing Required Before Return to Service
PMED-0975	Room 118	1022	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0976	Room 117	1023	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0977	Custodial Closet	1024	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0978	Attendance Office Bathroom	1026A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0981	Office Across from Safe	1026K	Kitchen Faucet (Cold)	Potable	5/30/2024	7.5	7/12/2024	3.1	Outlet Remediated and Returned to Service Continue O&M
PMED-0982	Office Across from Safe	1026K	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-0983	Main Office Bathroom	1026N	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0984	Men's Bathroom	1029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0985	Women's Bathroom	1030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0988	Custodial Closet	1032	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-0989	Girls Bathroom	1033	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0990	Girls Bathroom	1033	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0991	Girls Bathroom	1033	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Saxton Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-0992	Girls Bathroom	1033	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0993	Girls Bathroom	1033	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0994	Corridor Near Room 114 (1034)	1040	Water Cooler	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0995	Corridor Near Room 114 (1034)	1040	Bottle Fill Station	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-0996	Room 114	1034	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0997	Room 114	1034	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-0999	Corridor Near Room 113 Hallway (1036)	1040	Water Fountain-No Chiller	Potable	5/30/2024	OOS			Testing Required Before Return to Service
PMED-1000	Boys Bathroom	1064	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1001	Boys Bathroom	1064	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1002	Girls Bathroom	1065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1003	Girls Bathroom	1065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1006	Kitchen	1063	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1007	Kitchen	1063	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1008	Kitchen	1063	Kitchen Non Potable	Non-Applicable					Placarded for Non-Drinking Use
PMED-1009	Kitchen	1063	Kitchen Non Potable	Non-Applicable	5/30/2024	7.6			Further Investigation Determined Outlet Function as Non-Applicable, Placarded for Non-Drinking Use
PMED-1010	Kitchen	1063	Kitchen Non Potable	Non-Applicable					Placarded for Non-Drinking Use
PMED-1011	Kitchen Laundry Room	1063C	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1012	Kitchen Bathroom	1063C1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1013	Kitchen	1063	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-1014	Kitchen	1063	Kitchen Non Potable	Non-Applicable					Placarded for Non-Drinking Use

# Saxton Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1015	Kitchen	1063	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1016	Kitchen	1063	Kitchen Faucet (Cold)	Potable	5/30/2024	1.8			Result Below Action Level Continue O&M
PMED-1017	Kitchen	1063	Kitchen Faucet (Cold)	Potable	5/30/2024	1.1			Result Below Action Level Continue O&M
PMED-1020	Corridor Near Room 125 (1079)	1080	Water Fountain-No Chiller	Potable	5/30/2024	OOS			Testing Required Before Return to Service
PMED-1021	Technology Room 126	1083	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1022	Men's Bathroom	1084	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1023	Men's Bathroom	1084	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1024	Plant & Facilities Faculty Room	1087C	Kitchen Non Potable	Non-Applicable	5/30/2024	28.1			Further Investigation Determined Outlet Function as Non-Applicable, Placarded for Non-Drinking Use
PMED-1025	Transportation Suite Bathroom	1086B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1026	Men's Bathroom	1093	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1027	Corridor Near Bathroom (1093)	1095	Water Cooler	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1028	Corridor Near Bathroom (1093)	1095	Bottle Fill Station	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1029	Women's Bathroom	1094	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1030	Women's Bathroom	3000	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1031	Women's Bathroom	3000	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1032	Custodial Closet	3001	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1033	Corridor Near Custodial Closet (3001)	3012	Water Cooler	Potable	5/30/2024	OOS			Testing Required Before Return to Service
PMED-1034	Men's Bathroom	3002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1035	Men's Bathroom	3002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1036	Faculty Room	3003	Kitchen Faucet (Cold)	Potable	5/30/2024	6.3			Removed From Service, Pending Remediation

# Saxton Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1037	Maintenance Area	0007	Water Cooler	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1038	Maintenance Area	0007	Bottle Fill Station	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1039	Maintenance Area	0007	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-1043	Boys Locker Room 2	0004C4	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1044	Custodial Closet (Sump Pump)	0004C1	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1045	Faculty Room	1077	Kitchen Faucet (Cold)	Potable	5/30/2024	3.7			Result Below Action Level Continue O&M
PMED-1046	ENL Women's Bathroom	1078B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1047	ENL Women's Bathroom	1078B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1048	ENL Room	1078	Kitchen Faucet (Cold)	Potable	5/30/2024	2.0			Result Below Action Level Continue O&M
PMED-1049	ENL Men's Bathroom	1078A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1050	Technology Room 125	1079	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1054	Courtyard - Exterior of Corridor (1020)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1060	Exterior of Kitchen Closet (1063B)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1061	Exterior of Room 106 (1001)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3039	Room 218 Prep	2038A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3040	Custodial Closet 3	2042	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-3041	Library Corridor	2058	Water Fountain-No Chiller	Potable	5/30/2024	OOS			Testing Required Before Return to Service
PMED-3042	Boys Bathroom	2029A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3043	Girls Bathroom	2027A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3044	Corridor From Storage 7 To Room 211	2032	Water Cooler	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M

# Saxton Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-3045	Corridor Between Room 200 & Room 206	2015	Water Cooler	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3046	Corridor Between Room 200 & Room 206	2015	Bottle Fill Station	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3047	Girls Locker Bathroom	1045B7	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3048	Boys Locker Room 1	0004C3	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3049	Boys Locker Room 1	0004C3	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3050	Corridor Between Room 109 & 110	1056	Water Cooler	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3051	Attendance Office Bathroom	1026A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3052	Main Lobby	1081	Water Cooler	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3053	Main Lobby	1081	Bottle Fill Station	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3054	Boys Bathroom	1031	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3055	Boys Bathroom	1031	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3056	Boys Bathroom	1031	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3057	Girls Bathroom	1033	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3058	Cafeteria North	1062	Water Cooler	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3059	Cafeteria North	1062	Bottle Fill Station	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3060	Cafeteria South	1066	Water Cooler	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3061	Cafeteria South	1066	Bottle Fill Station	Potable	5/30/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-3062	Men's Bathroom	1084	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-3063	Women's Bathroom	3000	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3064	Men's Bathroom	3002	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use



# Saxton Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-3065	Courtyard - Exterior of Room 115 (1027)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3066	Courtyard - Exterior of Room 112 (1054)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3067	Exterior of Faculty Room (1077)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3068	Exterior of Back Girls Locker Room (1045B3)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3069	Exterior of Back Boys Locker Room (1050C)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3070	Exterior of Room 110 (1055)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3071	Exterior of Room 105 (1022)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3072	Exterior of Chorus Room 102 (1013)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3073	Exterior of Room 100 (1015)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3074	Exterior of Technology Room 126 (1083)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-3075	Exterior of Plant & Facilities Kitchen (1087C)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

# Oregon Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1065	Corridor Near Band Room (4000)	1006	Water Cooler	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1066	Corridor Near Band Room (4000)	1006	Bottle Fill Station	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1067	Technology Room 2	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1068	Technology Room 2	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1069	Technology Room 2	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1070	Technology Room 1	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1071	Technology Room 1	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1072	Technology Room 1	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1073	Custodial Closet	1007	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1074	Faculty Room	1009	Kitchen Faucet (Cold)	Potable	5/31/2024	3.1			Result Below Action Level Continue O&M
PMED-1076	Kitchen Locker Room Bathroom	1011A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1077	Kitchen	1011	Kitchen Faucet (Cold)	Potable	5/31/2024	1.9			Result Below Action Level Continue O&M
PMED-1078	Kitchen	1011	Kitchen Faucet (Cold)	Potable	5/31/2024	6.4	7/12/2024	4.2	Outlet Remediated and Returned to Service Continue O&M
PMED-1079	Kitchen	1011	Kitchen Faucet (Cold)	Potable	5/31/2024	5.6			Removed From Service, Pending Remediation
PMED-1080	Kitchen	1011	Kitchen Faucet (Cold)	Potable	5/31/2024	2.1			Result Below Action Level Continue O&M
PMED-1081	Kitchen	1011	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-1082	Kitchen	1011	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1083	Kitchen	1011	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1084	Kitchen	1011	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1085	Kitchen	1011	Kitchen Non Potable	Non-Applicable					Placarded for Non-Drinking Use

# Oregon Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1086	Kitchen Serving Area	1011B	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1087	Kitchen Serving Area	1011B	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1088	Custodial Bathroom	1012D	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1090	Faculty Bathroom	1015A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1091	Women's Bathroom	1015B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1093	Principal's Bathroom	1017B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1094	Custodial Closet	1020	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1095	Corridor Near Room 100 (1031)	1033	Water Fountain-No Chiller	Potable	5/31/2024	OOS			Testing Required Before Return to Service
PMED-1096	Guidance Office Bathroom	1034A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1097	Girls Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1098	Girls Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1099	Girls Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1100	Girls Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1101	Girls Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1103	Boys Bathroom	1038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1104	Boys Bathroom	1038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1105	Men's Bathroom	1040	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1106	Room 111	1042	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1107	Home Economics Room 110	1041	Home Economics Faucet (Cold)	Potable	5/31/2024	1.7			Result Below Action Level Continue O&M
PMED-1108	Nurse's Office	1043	Nurse's Office Sink	Potable	5/31/2024	2.4			Result Below Action Level Continue O&M

# Oregon Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1109	Nurse's Office	1043	Nurse's Office Sink	Potable	5/31/2024	3.1			Result Below Action Level Continue O&M
PMED-1110	Nurse's Bathroom	1043A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1111	Office C Storage	1044A	Ice Machine	Potable	5/31/2024	OOS			Testing Required Before Return to Service
PMED-1112	Boys Locker Room	1061	Water Fountain-No Chiller	Potable	5/31/2024	OOS			Testing Required Before Return to Service
PMED-1113	Boys Locker Room Custodial Closet	1061A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1114	Boys Locker Room	1061	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1115	Boys Locker Room	1061	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1116	Boys Locker Room	1061	Water Fountain-No Chiller	Potable	5/31/2024	OOS			Testing Required Before Return to Service
PMED-1117	Boys Team Locker Room	1067	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1118	Boys Team Locker Room	1067	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1119	Custodial Closet	1067A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1120	Boys Locker Room Vestibule Bathroom	4002A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1121	Boys Locker Room Exterior Bathroom	4003A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1122	Boys Locker Room Exterior Bathroom	4003A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1123	Boys Locker Room (New)	4003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1124	Boys Locker Room (New)	4003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1125	Boys Locker Room Vestibule	4002	Water Cooler	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1126	Boys Locker Room Vestibule	4002	Bottle Fill Station	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1127	Girls Locker Room Vestibule	4006	Water Cooler	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1128	Girls Locker Room Vestibule	4006	Bottle Fill Station	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M

# Oregon Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1129	Girls Locker Room (New)	4007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1130	Girls Locker Room (New)	4007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1131	Girls Locker Room Exterior Bathroom	4007B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1132	Girls Locker Room Exterior Bathroom	4007B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1133	Girls Locker Room Vestibule Bathroom	4006B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1134	Girls Team Locker Room	1066	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1135	Girls Coach's Office Bathroom	1064A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1136	Girls Locker Room	1065	Water Fountain-No Chiller	Potable	5/31/2024	OOS			Testing Required Before Return to Service
PMED-1137	Girls Locker Room Custodial Closet	1065A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1138	Girls Locker Room	1065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1139	Girls Locker Room	1065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1140	Girls Locker Room	1065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1141	Girls Locker Room	1065	Water Fountain-No Chiller	Potable	5/31/2024	OOS			Testing Required Before Return to Service
PMED-1142	Corridor Near Nurse's Office (1043)	1069	Water Fountain-No Chiller	Potable	5/31/2024	OOS			Testing Required Before Return to Service
PMED-1143	Custodial Closet	1045	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1144	Corridor Near Book Storage B (1048)	1068	Water Cooler	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1145	Corridor Near Book Storage B (1048)	1068	Bottle Fill Station	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1146	Corridor Near Room 118 (1057)	1068	Bottle Fill Station	Potable	5/31/2024	OOS			Testing Required Before Return to Service
PMED-1147	Corridor Near Room 118 (1057)	1068	Water Fountain-No Chiller	Potable	5/31/2024	36.7			Removed From Service, Pending Remediation
PMED-1148	Corridor Near Room 125 (4008)	1059	Water Cooler	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M

# Oregon Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1149	<b>Corridor Near Room 125 (4008)</b>	1059	Bottle Fill Station	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1150	<b>Art Room 221</b>	2002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1152	<b>Art Room 221</b>	2002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1153	<b>Art Room 221</b>	2002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1155	<b>Art Room 221</b>	2002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1156	<b>Art Room 219</b>	2003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1158	<b>Art Room 219</b>	2003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1159	<b>Art Room 219</b>	2003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1161	<b>Art Room 219</b>	2003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1162	<b>Science Room 217</b>	2006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1163	<b>Science Room 217</b>	2006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1164	<b>Custodial Closet</b>	2008	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1165	<b>Science Room 212</b>	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1166	<b>Science Room 212</b>	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1167	<b>Prep Room 212</b>	2010A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1168	<b>Corridor Near Fan Room (2009)</b>	2011	Water Fountain-No Chiller	Potable	5/31/2024	OOS			Testing Required Before Return to Service
PMED-1169	<b>Men's Bathroom</b>	2014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1170	<b>Women's Bathroom</b>	2015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1171	<b>Women's Bathroom</b>	2015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1174	<b>Science Room 210</b>	2017	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Oregon Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1175	Science Room 210	2017	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1176	Science Room 211	2018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1177	Science Room 211	2018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1178	Prep Room 211	2018A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1179	Prep Room 211	2018A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1180	Boys Bathroom	2019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1181	Boys Bathroom	2019	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1182	Boys Bathroom	2019	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1183	Boys Bathroom	2019	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1184	Custodial Closet	2020	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1185	Girls Bathroom	2021	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1186	Girls Bathroom	2021	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1187	Girls Bathroom	2021	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1188	Girls Bathroom	2021	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1189	Girls Bathroom	2021	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1191	Science Room 209	2022	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1192	Science Room 209	2022	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1193	Library Office/Kitchenette	2026A	Kitchen Non Potable	Non-Applicable					Placarded for Non-Drinking Use
PMED-1194	Corridor Near Library (2026)	2036	Water Fountain-No Chiller	Potable	5/31/2024	OOS			Testing Required Before Return to Service
PMED-1195	Exterior of Boys Locker Room Storage (1061B)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

# Oregon Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1197	Exterior of Room 118 (1058)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1198	Exterior of Room 118 (1058)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1201	Exterior of Technology 2 Storage (1004B)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1933	Faculty Room	1009	Water Cooler	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1934	Faculty Room	1009	Bottle Fill Station	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1935	Main Office Storage Room	1016A1	Bottled Water Dispenser	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1936	Main Office Storage Room	1016A1	Bottled Water Dispenser	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1937	Corridor Between Room 100 And Main Office	1033	Water Cooler	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1938	Corridor Between Room 100 And Main Office	1033	Bottle Fill Station	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1939	Girls Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1940	Girls Bathroom	1037	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1941	Boys Bathroom	1038	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1942	Room 111	1042	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1943	Boys PE Office Bathroom	1062A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1944	Boys Locker Room (New)	4003	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1945	Girls Locker Room (New)	4007	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1946	Girls Locker Room	1065	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1947	Girls Locker Room	1065	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1948	Girls Locker Room	1065	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1949	Corridor Between Library & Room 215	2023	Water Cooler	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M



# Oregon Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1950	Corridor Between Library & Room 215	2023	Bottle Fill Station	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1951	Girls Bathroom	2021	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1952	Girls Bathroom	2021	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1953	Girls Bathroom	2021	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1954	Girls Bathroom	2021	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1955	Girls Bathroom	2021	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1956	Exterior of Boys Locker Room (1061)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1957	Exterior of Kitchen (1011)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1958	Exterior of Kitchen (1011)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1959	Exterior of Music Room (1008)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1960	Exterior of Technology 2 Storage (1004B)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1202	Men's Bathroom	1002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1203	Room 104 Multipurpose Room	1005B	Kitchen Non Potable	Non-Applicable					Placarded for Non-Drinking Use
PMED-1205	Cafeteria	1012	Water Cooler	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1206	Cafeteria	1012	Bottle Fill Station	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1207	Cafeteria Girls Bathroom	1012B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1208	Kitchen	1012C1	Kitchen Faucet (Cold)	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1209	Kitchen	1012C1	Kitchen Faucet (Cold)	Potable	5/22/2024	3.0			Result Below Action Level Continue O&M
PMED-1210	Kitchen	1012C1	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1211	Kitchen	1012C1	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-1212	Kitchen	1012C1	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1216	Kitchen	1012C1	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-1217	Kitchen	1012C1	Kitchen Faucet (Cold)	Potable	5/22/2024	1.1			Result Below Action Level Continue O&M
PMED-1218	Kitchen	1012C1	Kitchen Faucet (Cold)	Potable	5/22/2024	2.2			Result Below Action Level Continue O&M
PMED-1219	Kitchen	1012C1	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1220	Kitchen	1012C1	Water Cooler	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1222	Kitchen	1012C1	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1223	Kitchen	1012C1	Kitchen Faucet (Cold)	Potable	5/22/2024	3.9			Result Below Action Level Continue O&M
PMED-1224	Kitchen Line 2 Serving Area	1012C1A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1225	Kitchen Line 2 Serving Area	1012C1A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1226	Kitchen Line 2 Serving Area	1012C1A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1227	Kitchen	1012C1	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1228	Faculty Cafeteria	1013	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1229	Kitchen Bathroom	1012C111	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1230	Kitchen Bathroom	1012C111	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1231	Kitchen Bathroom	1012C111	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1232	Cafeteria/Kitchen Storage	1012D	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1233	Kitchen Line 1 Serving Area	1012C1L	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1234	Kitchen Line 1 Serving Area	1012C1L	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1235	Kitchen Line 1 Serving Area	1012C1L	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1236	Kitchen Line 1 Serving Area	1012C1L	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1237	Kitchen Line 1 Serving Area	1012C1L	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1238	Kitchen	1012C1	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-1239	Room 110 Office Suite	1018	Kitchen Non Potable	Non-Applicable					Placarded for Non-Drinking Use
PMED-1240	Corridor Near Room 111 Dean's Office (1017)	1020	Water Fountain-No Chiller	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-1241	Security Suite Bathroom	3004G	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1242	Security Suite Faculty Room	3004F	Kitchen Faucet (Cold)	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1246	Custodial Closet	3011	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1247	Girls Bathroom	3012	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1248	Girls Bathroom	3012	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1249	Girls Bathroom	3012	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1250	Men's Bathroom	3014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1251	Women's Bathroom	3016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1252	Corridor Near Room 163 (3015)	3009	Water Cooler	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1253	Corridor Near Room 163 (3015)	3009	Bottle Fill Station	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1254	Science Room 164	3010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1255	Science Room 164	3010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1256	Science Room 164	3010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1257	Science Room 164	3010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1258	Science Room 164	3010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1259	Science Room 164	3010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1260	Science Room 164	3010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1261	Science Room 164	3010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1262	Science Room 164	3010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1263	Science Room 164	3010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1264	Science Room 164	3010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1265	Science Room 164	3010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1266	Science Room 164	3010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1267	Science Room 164	3010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1268	Science Room 164	3010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1269	Science Room 164	3010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1270	Prep Room 164/166	3010A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1271	Science Room 166	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1272	Science Room 166	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1273	Science Room 166	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1274	Science Room 166	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1275	Science Room 166	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1276	Science Room 166	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1277	Science Room 166	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1278	Science Room 166	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1279	Science Room 166	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1280	Science Room 166	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1281	Science Room 166	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1282	Science Room 166	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1283	Science Room 166	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1284	Science Room 166	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1285	Science Room 166	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1286	Science Room 166	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1287	Science Room 168	3016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1288	Science Room 168	3016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1289	Science Room 168	3016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1290	Science Room 168	3016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1291	Science Room 168	3016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1292	Science Room 168	3016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1293	Science Room 168	3016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1294	Science Room 168	3016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1295	Science Room 168	3016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1296	Science Room 168	3016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1297	Science Room 168	3016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1298	Science Room 168	3016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1299	Science Room 168	3016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1300	Science Room 168	3016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1301	Science Room 168	3016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1302	Science Room 168	3016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1303	Prep Room 168/170	3016A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1304	Science Room 170	3018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1305	Science Room 170	3018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1306	Science Room 170	3018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1307	Science Room 170	3018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1308	Science Room 170	3018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1309	Science Room 170	3018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1310	Science Room 170	3018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1311	Science Room 170	3018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1312	Science Room 170	3018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1313	Science Room 170	3018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1314	Science Room 170	3018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1315	Science Room 170	3018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1316	Science Room 170	3018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1317	Science Room 170	3018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1318	Science Room 170	3018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1319	Science Room 170	3018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1320	Prep Room 170/172	3018A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1321	Science Room 172	3019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1322	Science Room 172	3019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1323	Science Room 172	3019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1324	Science Room 172	3019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1325	Science Room 172	3019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1326	Science Room 172	3019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1327	Science Room 172	3019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1328	Science Room 172	3019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1329	Science Room 172	3019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1330	Science Room 172	3019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1331	Science Room 172	3019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1332	Science Room 172	3019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1333	Science Room 172	3019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1334	Science Room 172	3019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1335	Science Room 172	3019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1336	Science Room 172	3019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1337	Corridor Near Room 175 (3024)	3030	Water Cooler	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1338	Corridor Near East Stairwell	4046	Bottle Fill Station	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1339	Women's Bathroom	3022	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1340	Men's Bathroom	3023	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1341	Girls Bathroom	3025	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1342	Girls Bathroom	3025	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1343	Girls Bathroom	3025	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1344	Custodial Closet	3026	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1350	Corridor Near Team Locker Room #1 (3040)	3046	Water Cooler	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-1351	Team Locker Room #1	3040	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1352	Team Locker Room #2	3041	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1353	Team Locker Room #3	3042	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1354	Team Locker Room #4	3043	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use



# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1355	Trainer's Office	3044	Ice Machine	Potable	5/22/2024	1.1			Result Below Action Level Continue O&M
PMED-1356	Trainer's Office	3044	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1357	Exterior Girls Bathroom	3045	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1358	Exterior Girls Bathroom	3045	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1359	Exterior Girls Bathroom	3045	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1360	Exterior Boys Bathroom	3049	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1361	Exterior Boys Bathroom	3049	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1362	Maintenance Office Bathroom	3050B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1363	Boys Bathroom	3052	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1364	Boys Bathroom	3052	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1365	Boys Bathroom	3052	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1366	Girls Bathroom	3053	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1367	Girls Bathroom	3053	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1368	Girls Bathroom	3053	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1369	Custodial Closet	1083	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1370	Custodial Closet	1092B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1371	Boys Locker Room Bathroom	1092C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1372	Boys Locker Room Bathroom	1092C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1373	Boys Locker Room Coach's Office	1092D	Ice Machine	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-1374	Girls Locker Room Bathroom	1090E	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1375	Girls Locker Room Bathroom	1090E	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1376	Girls Locker Room Custodial Closet	1090B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1377	Girls Locker Room Office	1090D	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1378	Room 137 Girls Team Room	1086	Ice Machine	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-1379	Corridor Near Girls Team Room (1086)	1093	Water Fountain-No Chiller	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-1380	Art Room 140	1081	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1381	Art Room 140	1081	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1382	Boys Locker Room Bathroom	1100B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1383	Boys Locker Room Bathroom	1100B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1384	Boys Locker Room Custodial Closet	1100B2	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1385	Boys Locker Room	1100B	Water Fountain-No Chiller	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-1386	Boys Coach's Office Bathroom	1100C1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1391	Art Studio 142	1079	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1393	Corridor Near Art Studio 142 (1084)	1084	Water Fountain-No Chiller	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-1394	Robotics Room 143	1078	Water Fountain-No Chiller	Potable	5/22/2024	2.0			Result Below Action Level Continue O&M
PMED-1395	Robotics Room 143	1078	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1396	Room 144 Wood Shop	1077	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1397	Technology Room 145	1076	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1398	Technology Room 145	1076	Water Fountain-No Chiller	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-1399	Room 142	1079	Office Faucet	Non-Applicable	5/22/2024	OOS			Further Investigation Determined Outlet Function as Non-Applicable, Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1400	Room 142	1079	Spray Nozzle	Non-Applicable	5/22/2024	OOS			Further Investigation Determined Outlet Function as Non-Applicable, Placarded for Non-Drinking Use
PMED-1402	Girls Coach's Office Bathroom	1099A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1403	Girls Locker Room	1099	Water Fountain-No Chiller	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-1404	Girls Locker Room Custodial Closet	1099C	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1405	Girls Locker Room Bathroom	1099D	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1406	Girls Locker Room Bathroom	1099D	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1418	Corridor Near Home Economics Room 134 (1095)	1097	Water Fountain-No Chiller	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-1419	Home Economics Room 134	1095	Home Economics Faucet (Cold)	Potable	5/22/2024	3.1			Result Below Action Level Continue O&M
PMED-1420	Home Economics Room 134	1095	Home Economics Faucet (Cold)	Potable	5/22/2024	4.0			Result Below Action Level Continue O&M
PMED-1421	Custodial Closet	1030	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1422	Science Room 120	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1423	Science Room 120	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1424	Science Room 120	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1425	Science Room 120	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1426	Science Room 120	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1427	Science Room 120	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1428	Science Room 120	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1429	Science Room 120	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1430	Science Room 120	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1431	Science Room 120	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1432	Science Room 120	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1433	Science Room 120	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1434	Science Room 120	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1435	Science Room 120	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1436	Science Room 120	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1437	Science Room 120	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1438	Science Room 120	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1439	Prep Room 119/120	1028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1440	Prep Room 119/120	1028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1441	Prep Room 119/120	1028	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1442	Science Room 119	1027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1443	Science Room 119	1027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1444	Science Room 119	1027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1445	Science Room 119	1027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1446	Science Room 119	1027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1447	Science Room 119	1027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1448	Science Room 119	1027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1449	Science Room 119	1027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1450	Science Room 119	1027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1451	Science Room 119	1027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1452	Science Room 119	1027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1453	Science Room 119	1027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1454	Science Room 119	1027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1455	Science Room 119	1027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1456	Science Room 119	1027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1457	Science Room 118	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1458	Science Room 118	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1459	Science Room 118	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1460	Science Room 118	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1461	Science Room 118	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1462	Science Room 118	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1463	Science Room 118	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1464	Science Room 118	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1466	Science Room 118	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1467	Science Room 118	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1468	Science Room 118	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1469	Science Room 118	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1470	Science Room 118	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1471	Science Room 118	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1472	Science Room 118	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1474	Prep Room 117/118	1025	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1475	Prep Room 117/118	1025	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1476	Prep Room 117/118	1025	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1477	Science Room 117	1024	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1478	Science Room 117	1024	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1479	Science Room 117	1024	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1480	Science Room 117	1024	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1481	Science Room 117	1024	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1482	Science Room 117	1024	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1483	Science Room 117	1024	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1484	Science Room 117	1024	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1485	Science Room 117	1024	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1486	Science Room 117	1024	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1487	Science Room 117	1024	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1488	Science Room 117	1024	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1489	Science Room 117	1024	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1490	Science Room 117	1024	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1491	Science Room 117	1024	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1492	Science Room 117	1024	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1493	Science Room 117	1024	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1495	Science Room 116	1023	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1496	Science Room 116	1023	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1497	Science Room 116	1023	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1498	Science Room 116	1023	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1499	Science Room 116	1023	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1500	Science Room 116	1023	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1501	Science Room 116	1023	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1502	Prep Room 115/116	1022	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1503	Science Room 115	1021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1504	Science Room 115	1021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1505	Science Room 115	1021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1506	Science Room 115	1021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1507	Room 119	1027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1508	Room 119	1027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1509	Room 119	1027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1510	Prep Room 115/116	1015A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1511	Science Storage Room 113	1014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1512	Science Storage Room 113	1014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1513	Men's Bathroom	1032	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1514	Boys Bathroom	1033	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1515	Boys Bathroom	1033	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1516	Corridor Near Room 121 (1034)	1040	Water Cooler	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1517	Corridor Near Room 121 (1034)	1040	Bottle Fill Station	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1518	Girls Bathroom	1037	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1519	Girls Bathroom	1037	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1520	Women's Bathroom	1038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1521	Women's Bathroom	1038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1522	Custodial Closet	1039	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1524	Guidance Office Bathroom	1043B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1525	Main Office Bathroom	1048A3	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1526	Main Office Interior Office	1048A2	Kitchen Faucet (Cold)	Potable	5/22/2024	1.0			Result Below Action Level Continue O&M
PMED-1527	Main Office Supply Room	1048A1	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1528	Corridor Near Guidance Suite (1043)	1053	Water Fountain-No Chiller	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-1529	Nurse's Office Bathroom (L-Z)	1050A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1530	Nurse's Office (L-Z)	1050	Nurse's Office Sink	Potable	5/22/2024	3.7			Result Below Action Level Continue O&M
PMED-1531	Nurse's Office Student Bathroom	1051B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1532	Nurse's Office (A-K)	1051	Nurse's Office Sink	Potable	5/22/2024	1.9			Result Below Action Level Continue O&M
PMED-1533	Nurse's Office Staff Bathroom	1051C	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1534	Women's Bathroom	1054	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1535	Custodial Closet	1054A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use



# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1536	Men's Bathroom	1055	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1538	Band Room 151 Instrument Storage	1062A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1539	Corridor Near Band Room 151 (1062)	1066	Water Fountain-No Chiller	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-1540	Custodial Office Bathroom	1064B2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1542	Boiler Room	1064C	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1543	Art Room 150	1068	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1544	Art Room 150	1068	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1545	Art Room 149	1069	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1546	Art Room 149	1069	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1549	Dark Room	1071A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1550	Dark Room	1071A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1551	Dark Room	1071A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1552	Dark Room	1071A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1553	Dark Room	1071A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1554	Corridor Near Art Room 148 (1070)	1073	Water Fountain-No Chiller	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-1555	Women's Bathroom	1072	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1556	Women's Bathroom	1072	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1557	Women's Bathroom	1072	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1558	Men's Bathroom	1105	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1559	Men's Bathroom	1105	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1560	Men's Bathroom	1105	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1562	Corridor Near Auditorium (1058)	1065	Bottle Fill Station	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1563	M1 Office	3058A	Water Cooler	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1564	M1 Office	3058A	Bottle Fill Station	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1565	M1 Bathroom	3058A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1566	M2 Bathroom	3059A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1567	Classroom M2	3059	Water Cooler	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1568	M1/M2 Shared Bathroom	3059B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1569	M3 Bathroom	3060B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1570	Classroom M3	3060	Water Cooler	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1571	M5 Bathroom	3062A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1572	Classroom M5	3060	Water Cooler	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1573	M5 Custodial Closet	3062B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1574	Science Office 265	4006	Office Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1575	Custodial Closet	4009	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1576	Girls Bathroom	4010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1577	Girls Bathroom	4010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1578	Girls Bathroom	4010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1579	Men's Bathroom	4011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1580	Women's Bathroom	4012	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1581	Corridor Near East Stairwell	4046	Water Cooler	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1583	Science Room 268	4015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1584	Science Room 268	4015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1585	Science Room 268	4015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1586	Science Room 268	4015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1587	Prep Room 268/270	4016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1588	Science Room 270	4017	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1589	Science Room 270	4017	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1590	Science Room 270	4017	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1591	Science Room 270	4017	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1592	Science Room 272	4021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1593	Science Room 272	4021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1594	Science Room 272	4021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1595	Science Room 272	4021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1596	Prep Room 272	4022	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1597	Science Room 274	4025	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1598	Science Room 274	4025	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1599	Science Room 274	4025	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1600	Prep Room 274/276	4026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1601	Science Room 276	4027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1602	Science Room 276	4027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1603	Science Room 276	4027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1606	Women's Bathroom	4030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1607	Men's Bathroom	4031	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1608	Girls Bathroom	4033	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1609	Girls Bathroom	4033	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1610	Girls Bathroom	4033	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1611	Custodial Closet	4034	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1612	Boys Bathroom	4035	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1613	Boys Bathroom	4035	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1614	Boys Bathroom	4035	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1615	English Department Office	4049	Office Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1616	Science Room 228	2004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1617	Science Room 228	2004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1618	Science Room 228	2004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1619	Science Room 228	2004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1620	Science Room 228	2004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1621	Science Room 228	2004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1622	Science Room 228	2004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1623	Science Room 228	2004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1624	Science Room 228	2004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1625	Science Room 228	2004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1626	Prep Room 228	2004A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1627	Science Room 229	2005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1628	Science Room 229	2005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1629	Science Room 229	2005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1630	Science Room 229	2005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1631	Science Room 229	2005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1632	Science Room 229	2005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1633	Science Room 229	2005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1634	Science Room 229	2005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1635	Science Room 229	2005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1636	Science Room 229	2005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1637	Corridor Near Science Room 230 (2006)	2014	Water Fountain-No Chiller	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-1638	Science Room 230	2006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1639	Science Room 230	2006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1640	Science Room 230	2006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1641	Science Room 230	2006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1642	Science Room 230	2006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1643	Science Room 230	2006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1644	Science Room 230	2006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1645	Science Room 230	2006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1646	Prep Room 230	2007A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1647	Prep Room 230	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1652	Science Room 231	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1653	Science Room 231	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1655	Science Room 231	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1659	Science Room 231	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1660	Science Room 231	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1661	Science Room 232	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1662	Science Room 232	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1663	Science Room 232	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1664	Science Room 232	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1665	Science Room 232	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1666	Science Room 232	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1668	Science Room 232	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1669	Prep Room 232/233	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1670	Custodial Closet	2012	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1671	Men's Bathroom	2013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1672	Corridor Near Room 243 (2048)	2056	Water Fountain-No Chiller	Potable	5/22/2024	OOS			Testing Required Before Return to Service

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1673	Corridor Near Room 243 (2048)	2056	Water Fountain-No Chiller	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-1674	Fan Room	2058	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1675	Faculty Room 200	2060	Kitchen Faucet (Cold)	Potable	5/31/2024	1.5			Result Below Action Level Continue O&M
PMED-1676	Corridor Near Room 207 (2069)	2073	Water Fountain-No Chiller	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-1677	Library Office Kitchen	2045A	Kitchen Faucet (Cold)	Potable	5/31/2024	2.1			Result Below Action Level Continue O&M
PMED-1679	Boys Bathroom	2015	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1680	Boys Bathroom	2015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1683	Girls Bathroom	2019	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1684	Girls Bathroom	2019	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1685	Girls Bathroom	2019	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1686	Custodial Closet	2020	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1687	Women's Bathroom	2023	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1688	Women's Bathroom	2023	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1689	Corridor Near Room 218 (2027)	2039	Water Fountain-No Chiller	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-1691	Boys Bathroom	5008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1692	Boys Bathroom	5008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1693	Boys Bathroom	5008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1694	Custodial Closet	5009	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1695	Girls Bathroom	5010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1696	Girls Bathroom	5010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1697	Girls Bathroom	5010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1698	Men's Bathroom	5011	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1699	Women's Bathroom	5012	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1700	Corridor Near East Stairwell	5039	Water Cooler	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1701	Corridor Near East Stairwell	5039	Bottle Fill Station	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1702	Office 368	5016	Office Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1703	Corridor Near West Stairwell	5039	Water Cooler	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1704	Corridor Near West Stairwell	5039	Bottle Fill Station	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1705	Women's Bathroom	5031	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1706	Men's Bathroom	5032	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1707	Girls Bathroom	5035	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1708	Girls Bathroom	5035	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1709	Girls Bathroom	5035	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1710	Custodial Closet	5036	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
PMED-1711	Boys Bathroom	5037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1712	Boys Bathroom	5037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1714	Courtyard - Exterior of Room 106 (1007)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1715	Courtyard - Exterior of Room 117 (1024)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1716	Courtyard - Exterior of Room 114 (1015)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1717	Courtyard - Exterior of Room 120 (1029)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use



# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1720	Courtyard - Exterior of Room 135 (1094)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1721	Courtyard - Exterior of Health Teachers Office (1087)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1722	Courtyard - Exterior of Room 180 (3036)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1723	Courtyard - Exterior of Room 176 (3028)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1727	Boys Bathroom	4008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1728	Boys Bathroom	4008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1729	Exterior of Art Room 150 (1068)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1732	Exterior of Stairwell (3039A)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1733	Exterior of Room 179 (3035)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1734	Exterior of Room 161 (3005)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1735	Exterior of Stairwell (3001)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1738	Exterior of Room 108 (1009)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1739	Exterior of Room 101 (1001)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1744	Classroom M4 Bathroom	3060A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1745	Art Room 148	1070	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1753	Room 139	1082	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1754	Room 139	1082	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1755	Room 139	1082	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1756	Room 139	1082	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1757	Room 139	1082	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1769	Women's Faculty Bathroom	1038	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1770	Women's Faculty Bathroom	1038	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1771	Men's Faculty Bathroom	1002	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1772	Men's Faculty Bathroom	1002	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1773	Room 104 School Store	1005	Bottled Water Dispenser	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1774	Room 104 School Store	1005	Bottled Water Dispenser	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1775	Room 104 School Store	1005	Bottled Water Dispenser	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1776	Room 104 School Store	1005	Bottled Water Dispenser	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1777	Corridor (Room 101-109)	1011	Water Fountain-No Chiller	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-1778	Cafeteria Boys Bathroom	1012A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1779	Kitchen	1012C1	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-1780	Kitchen	1012C1	Bottle Fill Station	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1781	Kitchen Locker Room	1012C1I1	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1782	Kitchen Locker Room	1012C1I1	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1783	Kitchen Compressor Room	1012C1G	Ice Machine	Potable	5/22/2024	1.2			Result Below Action Level Continue O&M
PMED-1784	Courtyard - Exterior of Room 117 (1024)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1785	Boys Bathroom	3010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1786	Boys Bathroom	3010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1787	Boys Bathroom	3010	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1788	Boys Bathroom	3010	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1789	Girls Bathroom	3012	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1790	Girls Bathroom	3012	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1791	Corridor Near Room 175	N/A	Bottle Fill Station	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1792	Girls Bathroom	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1793	Boys Bathroom	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1794	Boys Bathroom	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1795	Boys Bathroom	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1796	Boys Bathroom	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1797	Corridor Near Team Locker Room #1	N/A	Water Cooler	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1798	Corridor Near Team Locker Room #1	N/A	Bottle Fill Station	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1799	Team Locker Room #1	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1800	Team Locker Room #2	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1801	Team Locker Room #3	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1802	Team Locker Room #4	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1803	Exterior Girls Bathroom	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1804	Exterior of Weight Room (3048)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1805	Exterior Boys Bathroom	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1806	Boys Bathroom	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1807	Girls Bathroom	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1808	Boys Locker Room Bathroom	1092C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1809	Boys Locker Room Bathroom	1092C	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1810	Girls Locker Room Bathroom	1090E	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1811	Girls Locker Room Bathroom	1090E	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1812	Room 140	1081	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1813	Room 141	1080	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1814	Room 141	1080	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-1815	Room 141	1080	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-1816	Room 141	1080	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-1817	Room 141	1080	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-1818	Room 141	1080	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-1819	Room 141	1080	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-1820	Room 141	1080	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1821	Room 141	1080	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1822	Room 142	1079	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1823	Girls Locker Room	1099	Water Cooler	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1824	Girls Locker Room	1099	Bottle Fill Station	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1825	Girls Locker Room Bathroom	1099D	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1826	Girls Locker Room Bathroom	1099D	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1827	Room 135	1094	Ice Machine	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1828	Room 135	1094	Kitchen Faucet (Cold)	Potable	5/22/2024	1.8			Result Below Action Level Continue O&M

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1829	Room 135	1094	Kitchen Non Potable	Non-Applicable					Placarded for Non-Drinking Use
PMED-1830	Room 135	1094	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-1831	Room 135	1094	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
PMED-1832	Room 135	1094	Kitchen Non Potable	Non-Applicable					Placarded for Non-Drinking Use
PMED-1833	Boys Locker Room Bathroom	1100B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1834	Boys Locker Room Bathroom	1100B1	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1835	Boys Locker Room Vestibule	1100	Water Cooler	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1836	Boys Locker Room Vestibule	1100	Bottle Fill Station	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1837	Women's Bathroom	1072	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1838	Women's Bathroom	1072	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1839		N/A		Non-Applicable					Placarded for Non-Drinking Use
PMED-1840	Men's Bathroom Adj. Auditorium	1105	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1841	Men's Bathroom Adj. Auditorium	1105	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1842	Corridor From 154-132B	1065	Water Cooler	Potable	5/22/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1843	Girls Bathroom	1037	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1844	Girls Bathroom	1037	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1845	Boys Bathroom	1033	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1846	Boys Bathroom	1033	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1847	Room 118	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1848	Room 118	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1849	Room 118	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1850	Corridor (Room 114-120)	1031	Water Fountain-No Chiller	Potable	5/22/2024	OOS			Testing Required Before Return to Service
PMED-1851	Prep Room 115/116	1022	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1852	Prep Room 115/116	1022	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1853	Room 113 Science Storage	1014	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1854	Boys Bathroom	4008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1855	Boys Bathroom	4008	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1856	Girls Bathroom	4010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1857	Mens Bathroom	4011	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1858	Womens Bathroom	4012	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1859	Corridor Near West Stairwell	4046	Water Cooler	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1860	Corridor Near West Stairwell	4046	Bottle Fill Station	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1861	Womens Bathroom	4030	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1862	Mens Bathroom	4031	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1863	Girls Bathroom	4033	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1864	Boys Bathroom	4035	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1865	Room 231 Science	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1866	Room 231 Science	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1867	Room 231 Science	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1868	Room 231 Science	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School


Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1869	Room 231 Science	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1870	Room 231 Science	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1871	Room 231 Science	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1872	Room 231 Science	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1873	Room 232	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1874	Girls Bathroom	2019	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1875	Girls Bathroom	2019	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1876	Corridor Between Rooms 213 & 233	2040	Water Cooler	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1877	Corridor Between Rooms 213 & 233	2040	Bottle Fill Station	Potable	5/31/2024	<1.00 ND			Result Below Action Level Continue O&M
PMED-1878	Men's Bathroom	2015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1879	Men's Bathroom	2015	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1880	Math Office 365	5006	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1881	Math Office 365	5006	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1882	Math Office 365	5006	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1883	Boys Bathroom	5008	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1884	Girls Bathroom	5010	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1885	Mens Bathroom	5011	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1886	Womens Bathroom	5012	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1887	Womens Bathroom	5031	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1888	Mens Bathroom	5032	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

# Patchogue-Medford High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
PMED-1889	Girls Bathroom	5035	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1890	Boys Bathroom	5037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
PMED-1891	Boys Bathroom	5037	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1892	Courtyard- Exterior of Room 124 (1116)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1893	Courtyard - Exterior of Room 130 (1111)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1894	Courtyard - Exterior of Nurse's Office (1050)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1895	Courtyard - Exterior of Room 129 (1112)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1896	Greenhouse	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
PMED-1897	Greenhouse	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1898	Grenhouse	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1899	Greenhouse	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1900	Greenhouse	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1901	Greenhouse	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1902	Greenhouse	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1903	Greenhouse	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1904	Greenhouse	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1905	Exterior of Kitchen Loading Dock (1012C1I2)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1906	Exterior of Cafeteria	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1907	Exterior of Music Room 154 (1059)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
PMED-1908	Exterior of Room 142 (1079)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use



Attachment 3:  
  
Laboratory  
Analytical Reports




**J.C. Broderick & Associates, Inc.**

*Environmental Consulting & Testing*

1775 Expressway Drive North

Hauppauge, New York 11788

631.584.5492 fax 631.584.3395



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

24-57728

Building:

Medford Elementary School

MES

# EC 53560

Client:

Patchogue-Medford Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-0006	Hallway	5004	Corridor Near Main Office (5005)	WC	5/29/2024	6:36:00 AM
PMED-0007	Hallway	5004	Corridor Near Main Office (5005)	WF	5/29/2024	6:36:00 AM
PMED-0015	Hallway	4008	Lower Level Hallway	WC	5/29/2024	6:50:00 AM
PMED-0016	Hallway	4008	Lower Level Hallway	WF	5/29/2024	6:50:00 AM
PMED-0020	Nurse Office	5007	Nurse's Office	NS	5/29/2024	6:39:00 AM
PMED-0038	Hallway	1013	Corridor Near Library (1009)	WC	5/29/2024	6:40:00 AM
PMED-0039	Hallway	1013	Corridor Near Library (1009)	WF	5/29/2024	6:40:00 AM
PMED-0051	Hallway	1032	Corridor Near Gymnasium (1028A)	WC	5/29/2024	6:42:00 AM
PMED-0052	Hallway	1032	Corridor Near Gymnasium (1028A)	WF	5/29/2024	6:42:00 AM
PMED-0064	Hallway	3020	Corridor Near Room 37 (3012)	WC	5/29/2024	6:48:00 AM
PMED-0065	Hallway	3020	Corridor Near Room 37 (3012)	WF	5/29/2024	6:48:00 AM
PMED-0067	Hallway	2018	Corridor Near Room 23 (2003)	WC	5/29/2024	6:46:00 AM
PMED-0068	Hallway	2018	Corridor Near Room 23 (2003)	WF	5/29/2024	6:47:00 AM
PMED-0077	Kitchen	1033A	Kitchen	KC	5/29/2024	6:33:00 AM


Pl 200.8  
Bulb  
6/19/24

Samples Submitted

14

2024 MAY 31 P 12: 22

RECEIVED  
ANALYTICAL, INC.  
CHARLE PLACE, NY



### Building Address

274 Medford Avenue

Patchogue, NY 11772

Analysis Type: ELAP 200.5

Lab Received:

5/29/24 12:22 PM

Signature:

*[Handwritten Signature]*

Samplers Name: Luke Coulter

Samplers Signature:

*[Handwritten Signature]*

JCB Project Manager: Meghan Gwynn

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453560  
**LIMS Reference ID:** EC53560  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #: 24-57728, Medford Elementary School,  
 Patchogue-Medford Union Free School District,  
 274 Medford Avenue, Patchogue, NY 11772

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 12:22  
**Reported:** 06/27/2024 09:21

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-0006 Lims Reference ID: EC53560-01 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 17:09	06/19/24 17:09	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0007 Lims Reference ID: EC53560-02 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 17:10	06/19/24 17:10	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0015 Lims Reference ID: EC53560-03 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 17:12	06/19/24 17:12	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0016 Lims Reference ID: EC53560-04 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 17:13	06/19/24 17:13	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0020 Lims Reference ID: EC53560-05 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 17:15	06/19/24 17:15	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0038 Lims Reference ID: EC53560-06 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 17:16	06/19/24 17:16	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0039 Lims Reference ID: EC53560-07 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 15:33	06/19/24 15:33	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0051 Lims Reference ID: EC53560-08 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 15:38	06/19/24 15:38	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0052 Lims Reference ID: EC53560-09 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 15:39	06/19/24 15:39	BA	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453560  
**LIMS Reference ID:** EC53560  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #: 24-57728, Medford Elementary School,  
 Patchogue-Medford Union Free School District,  
 274 Medford Avenue, Patchogue, NY 11772

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 12:22  
**Reported:** 06/27/2024 09:21

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-0064 Lims Reference ID: EC53560-10 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 15:41	06/19/24 15:41	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0065 Lims Reference ID: EC53560-11 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 15:45	06/19/24 15:45	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0067 Lims Reference ID: EC53560-12 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 15:46	06/19/24 15:46	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0068 Lims Reference ID: EC53560-13 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 15:48	06/19/24 15:48	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0077 Lims Reference ID: EC53560-14 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	25.6		10	10.0	µg/L	06/19/24 16:20	06/19/24 16:20	BA	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453560  
**LIMS Reference ID:** EC53560  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #: 24-57728, Medford Elementary School,  
 Patchogue-Medford Union Free School District,  
 274 Medford Avenue, Patchogue, NY 11772

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 12:22  
**Reported:** 06/27/2024 09:21

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	09/01/2024

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453560  
**LIMS Reference ID:** EC53560  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** #: 24-57728, Medford Elementary School,  
Patchogue-Medford Union Free School District,  
274 Medford Avenue, Patchogue, NY 11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 12:22  
**Reported:** 06/27/2024 09:21

**Notes and Definitions**


<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. All results for soil samples are reported on a dry weight basis, unless otherwise noted.

EC53536



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

**JCB #:** 24-57728  
**Building:** Bay Elementary School  
BAY


**Client:** Patchogue-Medford Union Free School District  
**Retest/New Install** [ ]  
**Turn Around:** Normal 1 wk Rush \_\_\_\_\_

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-0091	Kitchen	1002B	Kitchen	KC	5/21/2024	5:59:00 AM
PMED-0094	Faculty Lounge	1005	Faculty Room	KC	5/21/2024	6:01:00 AM
PMED-0103	Hallway	1023	Corridor Across from Gym (1007)	WC	5/21/2024	6:06:00 AM
PMED-0104	Hallway	1023	Corridor Across from Gym (1007)	WF	5/21/2024	6:07:00 AM
PMED-0110	Nurse Office	1038	Nurse's Office	NS	5/21/2024	6:22:00 AM
PMED-0112	Hallway	1039	Corridor Near Nurse's Office (1038)	WC	5/21/2024	6:08:00 AM
PMED-0113	Hallway	1039	Corridor Near Nurse's Office (1038)	WF	5/21/2024	6:09:00 AM
PMED-0128	Hallway	1049	Corridor Near Room 112 (1047)	WC	5/21/2024	6:11:00 AM
PMED-0129	Hallway	1049	Corridor Near Room 112 (1047)	WF	5/21/2024	6:11:00 AM
PMED-0132	Office	1046B	Library Work Room	KC	5/21/2024	6:13:00 AM
PMED-0141	Hallway	1066	Corridor Near Custodial Closet (1056)	WC	5/21/2024	6:15:00 AM
PMED-0142	Hallway	1066	Corridor Near Custodial Closet (1056)	WF	5/21/2024	6:16:00 AM

Samples Submitted 12

16 200.8 *[Signature]* 6/15/24

RECEIVED  
EHSL ANALYTICAL, INC.  
CARLE PLACE, NY  
2024 MAY 30 P 12:38



**Building Address**  
114 Bay Avenue  
Patchogue, NY 11772

**Analysis Type:** ELAP 200.5  
**Lab Received:** *[Signature]* 5/30/24  
**Signature:** *[Signature]*

**Samplers Name:** Meghan Guynn  
**Samplers Signature:** *[Signature]*  
**JCB Project Manager:** Meghan Guynn

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453536  
**LIMS Reference ID:** EC53536  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #24-57728, Bay Elementary School,  
 Patchogue-Medford Union Free School District,  
 114 Bay Avenue, Patchogue, NY 11772

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:38  
**Reported:** 06/27/2024 09:55

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-0091 Lims Reference ID: EC53536-01 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<5.0		5	5.0	µg/L	06/14/24 16:52	06/14/24 16:52	BA	EPA 200.8 (Dig)/EPA 200.8
Sample: PMED-0094 Lims Reference ID: EC53536-02 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	3.1		1	1.0	µg/L	06/18/24 16:21	06/18/24 16:21	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0103 Lims Reference ID: EC53536-03 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 17:16	06/15/24 17:16	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0104 Lims Reference ID: EC53536-04 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 17:20	06/15/24 17:20	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0110 Lims Reference ID: EC53536-05 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	5.0		1	1.0	µg/L	06/15/24 17:21	06/15/24 17:21	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0112 Lims Reference ID: EC53536-06 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 17:23	06/15/24 17:23	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0113 Lims Reference ID: EC53536-07 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 17:24	06/15/24 17:24	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0128 Lims Reference ID: EC53536-08 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 17:26	06/15/24 17:26	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0129 Lims Reference ID: EC53536-09 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 17:30	06/15/24 17:30	BA	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453536  
**LIMS Reference ID:** EC53536  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #24-57728, Bay Elementary School,  
 Patchogue-Medford Union Free School District,  
 114 Bay Avenue, Patchogue, NY 11772

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:38  
**Reported:** 06/27/2024 09:55

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
<b>Sample: PMED-0132</b>		<b>Lims Reference ID: EC53536-10</b>		<b>Matrix: Drinking Water</b>		<b>Sampled: 05/21/24 00:00:00</b>			
<b>Metals</b>									
Lead	1.6	1		1.0	µg/L	06/15/24 17:31	06/15/24 17:31	BA	EPA 200.8 (DA)/EPA 200.8
<b>Sample: PMED-0141</b>		<b>Lims Reference ID: EC53536-11</b>		<b>Matrix: Drinking Water</b>		<b>Sampled: 05/21/24 00:00:00</b>			
<b>Metals</b>									
Lead	<1.0	1		1.0	µg/L	06/15/24 17:33	06/15/24 17:33	BA	EPA 200.8 (DA)/EPA 200.8
<b>Sample: PMED-0142</b>		<b>Lims Reference ID: EC53536-12</b>		<b>Matrix: Drinking Water</b>		<b>Sampled: 05/21/24 00:00:00</b>			
<b>Metals</b>									
Lead	<1.0	1		1.0	µg/L	06/15/24 17:34	06/15/24 17:34	BA	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453536  
**LIMS Reference ID:** EC53536  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** #24-57728, Bay Elementary School,  
Patchogue-Medford Union Free School District,  
114 Bay Avenue, Patchogue, NY 11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:38  
**Reported:** 06/27/2024 09:55

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	09/01/2024

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453536  
**LIMS Reference ID:** EC53536  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** #24-57728, Bay Elementary School,  
Patchogue-Medford Union Free School District,  
114 Bay Avenue, Patchogue, NY 11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:38  
**Reported:** 06/27/2024 09:55

**Notes and Definitions**


<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. All results for soil samples are reported on a dry weight basis, unless otherwise noted.

EC53526



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 24-57728  
Building: Barton Elementary School  
BES

Client: Patchogue-Medford Union Free School District

Retest/New Install:   
Turn Around: Normal 1 wk Rush

19 200-8  
Barton  
6/11/24


Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-0164	Kitchen	1002	Kitchen	KC	5/29/2024	6:05:00 AM
PMED-0168	Kitchen	1002	Kitchen	KC	5/29/2024	6:05:00 AM
PMED-0169	Cafeteria	1004	Cafeteria	WC	5/29/2024	6:07:00 AM
PMED-0170	Cafeteria	1004	Cafeteria	WF	5/29/2024	6:07:00 AM
PMED-0177	Kitchen	1012A	Main Office Kitchen	KC	5/29/2024	6:11:00 AM
PMED-0184	Nurse Office	1022	Nurse's Office	NS	5/29/2024	6:13:00 AM
PMED-0194	Hallway	1044	Corridor Near Library (1023)	WC	5/29/2024	6:14:00 AM
PMED-0195	Hallway	1044	Corridor Near Library (1023)	WF	5/29/2024	6:15:00 AM
PMED-0211	Hallway	4012	Corridor Near Room 121 (4001)	WC	5/29/2024	6:18:00 AM
PMED-0212	Hallway	4012	Corridor Near Room 121 (4001)	WF	5/29/2024	6:18:00 AM
PMED-0219	Hallway	4012	Corridor Near Room 126/128 (4006)	WC	5/29/2024	6:20:00 AM
PMED-0220	Hallway	4012	Corridor Near Room 126/128 (4006)	WF	5/29/2024	6:20:00 AM
PMED-0227	Hallway	1058	Corridor Near Men's Bathroom (1054)	WC	5/29/2024	6:26:00 AM
PMED-0228	Hallway	1058	Corridor Near Men's Bathroom (1054)	WF	5/29/2024	6:26:00 AM
PMED-0234	Hallway	5011	Corridor Near Room 230 (5001)	WC	5/29/2024	6:31:00 AM
PMED-0235	Hallway	5011	Corridor Near Room 230 (5001)	WF	5/29/2024	6:31:00 AM
PMED-0242	Hallway	5011	Corridor Near Faculty Bathroom (5008)	WC	5/29/2024	6:32:00 AM
PMED-0243	Hallway	5011	Corridor Near Faculty Bathroom (5008)	WF	5/29/2024	6:32:00 AM

2024 MAY 30 P 12:37  
RECEIVED  
SCHOOL DISTRICT  
PATCHOGUE-MEDFORD  
UNION FREE SCHOOL DISTRICT


**Building Address**  
199 Barton Avenue  
Patchogue, NY 11772

**Analysis Type:** ELAP 200.5  
**Lab Received:** A. Minnified  
**Signature:** *A. Minnified*  
5/30/24 12:37pm

**Samplers Name:** *Danielle Antognini*  
**Samplers Signature:** *Danielle Antognini*  
**JCB Project Manager:** *Heather Guyton*



EC53526



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 24-57728

Building: Barton Elementary School

BES

Client: Patchogue-Medford Union Free School District

Retest/New Install   
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-3094	OF	1001	Custodial Office	BW	5/29/2024	6:34:00 AM
PMED-3114	CR	2027	214	BW	5/29/2024	6:34:00 AM
PMED-3124	HA	2036	Corridor 206 To 214	WC	5/29/2024	6:29:00 AM
PMED-3125	HA	2036	Corridor 206 To 214	WF	5/29/2024	6:29:00 AM

Samples Submitted 22

P6 200.8  
Barton  
6/11/24

RECEIVED  
EHSL ANALYTICAL, INC.  
CARLE PLACE, NY  
2024 MAY 30 P 12:37

**Building Address**  
199 Barton Avenue  
Patchogue, NY 11772

**Analysis Type:** ELAP 200.5  
**Lab Received:** A. Minnifield  
**Signature:** A. Minnifield  
5/30/24 12:37pm

**Samplers Name:** Danielle Bolognini  
**Samplers Signature:** [Signature]  
**JCB Project Manager:** Heather Gwynn



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453526  
**LIMS Reference ID:** EC53526  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** 24-57728, Barton Elementary School,  
Patchogue- Medford Union Free School  
District, 199 Barton Avenue Patchogue, NY  
11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:37  
**Reported:** 06/27/2024 08:49

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-0164 Lims Reference ID: EC53526-01 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	1.4		1	1.0	µg/L	06/11/24 18:19	06/11/24 18:19	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0168 Lims Reference ID: EC53526-02 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	1.4		1	1.0	µg/L	06/11/24 18:20	06/11/24 18:20	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0169 Lims Reference ID: EC53526-03 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 18:44	06/11/24 18:44	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0170 Lims Reference ID: EC53526-04 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 18:45	06/11/24 18:45	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0177 Lims Reference ID: EC53526-05 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	3.8		1	1.0	µg/L	06/11/24 18:24	06/11/24 18:24	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0184 Lims Reference ID: EC53526-06 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	1.1		1	1.0	µg/L	06/11/24 18:25	06/11/24 18:25	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0194 Lims Reference ID: EC53526-07 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 18:27	06/11/24 18:27	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0195 Lims Reference ID: EC53526-08 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 18:28	06/11/24 18:28	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0211 Lims Reference ID: EC53526-09 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 15:16	06/15/24 15:16	BA	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453526  
**LIMS Reference ID:** EC53526  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** 24-57728, Barton Elementary School,  
 Patchogue- Medford Union Free School  
 District, 199 Barton Avenue Patchogue, NY  
 11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:37  
**Reported:** 06/27/2024 08:49

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-0212 Lims Reference ID: EC53526-10 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 15:18	06/15/24 15:18	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0219 Lims Reference ID: EC53526-11 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 15:19	06/15/24 15:19	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0220 Lims Reference ID: EC53526-12 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 16:48	06/14/24 16:48	BA	EPA 200.8 (Dig)/EPA 200.8
Sample: PMED-0227 Lims Reference ID: EC53526-13 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	1.1		1	1.0	µg/L	06/15/24 15:21	06/15/24 15:21	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0228 Lims Reference ID: EC53526-14 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 15:22	06/15/24 15:22	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0234 Lims Reference ID: EC53526-15 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 15:23	06/15/24 15:23	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0235 Lims Reference ID: EC53526-16 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 16:54	06/18/24 16:54	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0242 Lims Reference ID: EC53526-17 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 16:58	06/18/24 16:58	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0243 Lims Reference ID: EC53526-18 Matrix: Drinking Water Sampled: 05/29/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 16:59	06/18/24 16:59	BA	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453526  
**LIMS Reference ID:** EC53526  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** 24-57728, Barton Elementary School,  
Patchogue- Medford Union Free School  
District, 199 Barton Avenue Patchogue, NY  
11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:37  
**Reported:** 06/27/2024 08:49

**Analytical Results**  
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
<b>Sample: PMED-3094</b>		<b>Lims Reference ID: EC53526-19</b>		<b>Matrix: Drinking Water</b>		<b>Sampled: 05/29/24 00:00:00</b>			
<b>Metals</b>									
Lead	<1.0	1		1.0	µg/L	06/18/24 17:00	06/18/24 17:00	BA	EPA 200.8 (DA)/EPA 200.8
<b>Sample: PMED-3114</b>		<b>Lims Reference ID: EC53526-20</b>		<b>Matrix: Drinking Water</b>		<b>Sampled: 05/29/24 00:00:00</b>			
<b>Metals</b>									
Lead	<1.0	1		1.0	µg/L	06/18/24 17:04	06/18/24 17:04	BA	EPA 200.8 (DA)/EPA 200.8
<b>Sample: PMED-3124</b>		<b>Lims Reference ID: EC53526-21</b>		<b>Matrix: Drinking Water</b>		<b>Sampled: 05/29/24 00:00:00</b>			
<b>Metals</b>									
Lead	<1.0	1		1.0	µg/L	06/18/24 17:06	06/18/24 17:06	BA	EPA 200.8 (DA)/EPA 200.8
<b>Sample: PMED-3125</b>		<b>Lims Reference ID: EC53526-22</b>		<b>Matrix: Drinking Water</b>		<b>Sampled: 05/29/24 00:00:00</b>			
<b>Metals</b>									
Lead	<1.0	1		1.0	µg/L	06/18/24 17:07	06/18/24 17:07	BA	EPA 200.8 (DA)/EPA 200.8





**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453526  
**LIMS Reference ID:** EC53526  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** 24-57728, Barton Elementary School,  
Patchogue- Medford Union Free School  
District, 199 Barton Avenue Patchogue, NY  
11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:37  
**Reported:** 06/27/2024 08:49

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	09/01/2024

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453526  
**LIMS Reference ID:** EC53526  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** 24-57728, Barton Elementary School,  
Patchogue- Medford Union Free School  
District, 199 Barton Avenue Patchogue, NY  
11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:37  
**Reported:** 06/27/2024 08:49


**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. All results for soil samples are reported on a dry weight basis, unless otherwise noted.



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 24-57728  
Building: River Elementary School

RES

# EC 53538


Client: Patchogue-Medford Union Free School District

Retest/New Install   
Turn Around: Normal 1 wk Rush \_\_\_\_\_

to 200-8  
6/15/24

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-0299	Kitchen	1002	Kitchen	KC	5/22/2024	5:56:00 AM
PMED-0302	Nurse Office	1024	Nurse's Office	NS	5/22/2024	6:00:00 AM
PMED-0307	Hallway	1027	Corridor Near Faculty Room (1020)	WC	5/22/2024	6:01:00 AM
PMED-0308	Hallway	1027	Corridor Near Faculty Room (1020)	WF	5/22/2024	6:02:00 AM
PMED-0314	Hallway	1027	Corridor Near Kindergarten 1 (1008)	WC	5/22/2024	6:04:00 AM
PMED-0324	Storage	1012D	Main Office Kitchen	KC	5/22/2024	6:16:00 AM
PMED-0330	Hallway	2022	Corridor Near Room 24A (2018)	WC	5/22/2024	6:10:00 AM
PMED-0331	Hallway	2022	Corridor Near Room 24A (2018)	WF	5/22/2024	6:11:00 AM
PMED-0338	Hallway	2022	Corridor Near Room 19 (2008)	WC	5/22/2024	6:09:00 AM
PMED-0339	Hallway	2022	Corridor Near Room 19 (2008)	WF	5/22/2024	6:09:00 AM
PMED-0346	Hallway	3014	Corridor Near Room 32A (3011)	WC	5/22/2024	6:13:00 AM
PMED-0347	Hallway	3014	Corridor Near Room 32A (3011)	WF	5/22/2024	6:13:00 AM
PMED-0352	Faculty Lounge	1020	Faculty Room	KC	5/22/2024	6:03:00 AM
PMED-1980	CA	1001	Cafeteria	WC	5/22/2024	5:58:00 AM
PMED-1981	CA	1001	Cafeteria	WF	5/22/2024	5:59:00 AM
PMED-1986	HA	1027	Corridor Near Kindergarten 1 (1008)	WF	5/22/2024	6:05:00 AM

RECEIVED  
E.D. COLLEGE, C.  
2024 MAY 30 12:57



**Building Address**

46 River Avenue  
Patchogue, NY 11772

Analysis Type: ELAP 200.5

Lab Received:

Signature:


*[Handwritten signatures]*

Samplers Name: Meghan Gwynn

Samplers Signature:

JCB Project Manager:

*[Handwritten signatures]*  
Meghan Gwynn



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

**JCB #:** 24-57728  
**Building:** River Elementary School  
RES

**Client:** Patchogue-Medford Union Free School District  
**Retest/New Install [ ]**  
**Turn Around:** Normal 1 wk Rush \_\_\_\_\_

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
-----------	-----------------------	----------	------------------	-------------	-------------	-------------

Samples Submitted 16

# EL 53538

*Pl. 200.8 h/w 0115pm*

RECEIVED  
EHSL ANALYTICAL, INC.  
CARLE PLACE, NY  
2024 MAY 30 P 12:37

**Building Address**  
46 River Avenue  
Patchogue, NY 11772

**Analysis Type:** ELAP 200.5

**Lab Received:** *atelle*

**Signature:** *[Signature]*

**Samplers Name:** *Meghan Guynn*

**Samplers Signature:** *[Signature]*

**JCB Project Manager:** *Meghan Guynn*

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453538  
**LIMS Reference ID:** EC53538  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #24-57728, River Elementary School,  
 Patchogue-Medford Union Free School District,  
 46 River Avenue, Patchogue, NY 11772

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:37  
**Reported:** 06/27/2024 10:01

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
<b>Sample: PMED-0299</b>									
			<b>Lims Reference ID:</b>		<b>EC53538-01</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 05/22/24 00:00:00</b>	
<b>Metals</b>									
Lead	15.6		5	5.0	µg/L	06/15/24 18:07	06/15/24 18:07	BA	EPA 200.8 (DA)/EPA 200.8
<b>Sample: PMED-0302</b>									
			<b>Lims Reference ID:</b>		<b>EC53538-02</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 05/22/24 00:00:00</b>	
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 17:40	06/15/24 17:40	BA	EPA 200.8 (DA)/EPA 200.8
<b>Sample: PMED-0307</b>									
			<b>Lims Reference ID:</b>		<b>EC53538-03</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 05/22/24 00:00:00</b>	
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 17:41	06/15/24 17:41	BA	EPA 200.8 (DA)/EPA 200.8
<b>Sample: PMED-0308</b>									
			<b>Lims Reference ID:</b>		<b>EC53538-04</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 05/22/24 00:00:00</b>	
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 17:43	06/15/24 17:43	BA	EPA 200.8 (DA)/EPA 200.8
<b>Sample: PMED-0314</b>									
			<b>Lims Reference ID:</b>		<b>EC53538-05</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 05/22/24 00:00:00</b>	
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 17:47	06/15/24 17:47	BA	EPA 200.8 (DA)/EPA 200.8
<b>Sample: PMED-0324</b>									
			<b>Lims Reference ID:</b>		<b>EC53538-06</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 05/22/24 00:00:00</b>	
<b>Metals</b>									
Lead	1.3		1	1.0	µg/L	06/15/24 17:49	06/15/24 17:49	BA	EPA 200.8 (DA)/EPA 200.8
<b>Sample: PMED-0330</b>									
			<b>Lims Reference ID:</b>		<b>EC53538-07</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 05/22/24 00:00:00</b>	
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 17:50	06/15/24 17:50	BA	EPA 200.8 (DA)/EPA 200.8
<b>Sample: PMED-0331</b>									
			<b>Lims Reference ID:</b>		<b>EC53538-08</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 05/22/24 00:00:00</b>	
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 17:52	06/15/24 17:52	BA	EPA 200.8 (DA)/EPA 200.8
<b>Sample: PMED-0338</b>									
			<b>Lims Reference ID:</b>		<b>EC53538-09</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 05/22/24 00:00:00</b>	
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 17:53	06/15/24 17:53	BA	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453538  
**LIMS Reference ID:** EC53538  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #24-57728, River Elementary School,  
 Patchogue-Medford Union Free School District,  
 46 River Avenue, Patchogue, NY 11772

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:37  
**Reported:** 06/27/2024 10:01

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-0339 Lims Reference ID: EC53538-10 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 17:54	06/15/24 17:54	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0346 Lims Reference ID: EC53538-11 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 18:31	06/15/24 18:31	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0347 Lims Reference ID: EC53538-12 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 18:35	06/15/24 18:35	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0352 Lims Reference ID: EC53538-13 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	2.5		1	1.0	µg/L	06/15/24 18:37	06/15/24 18:37	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1980 Lims Reference ID: EC53538-14 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 18:38	06/15/24 18:38	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1981 Lims Reference ID: EC53538-15 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 18:39	06/15/24 18:39	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1986 Lims Reference ID: EC53538-16 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 18:41	06/15/24 18:41	BA	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453538  
**LIMS Reference ID:** EC53538  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** #24-57728, River Elementary School,  
Patchogue-Medford Union Free School District,  
46 River Avenue, Patchogue, NY 11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:37  
**Reported:** 06/27/2024 10:01

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	09/01/2024

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453538  
**LIMS Reference ID:** EC53538  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** #24-57728, River Elementary School,  
Patchogue-Medford Union Free School District,  
46 River Avenue, Patchogue, NY 11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:37  
**Reported:** 06/27/2024 10:01

**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.


Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. All results for soil samples are reported on a dry weight basis, unless otherwise noted.



ECS4748



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 24-57728

Building: River Elementary School

RES

Client:

Patchogue-Medford Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush \_\_\_\_\_

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-0299	Kitchen	1002	Kitchen	KC	7/12/2024	12:49:00 PM

Samples Submitted 1

RECEIVED  
 EHSL ANALYTICAL, INC.  
 CARLE PLACE, NY  
 2024 JUL 15 P 6:25

**Building Address**

46 River Avenue  
Patchogue, NY 11772

Analysis Type: ELAP 200.5

Lab Received: *CSH*

Signature: *[Signature]*

Samplers Name: Meghan Gwynn

Samplers Signature: *[Signature]*

JCB Project Manager: M. Gwynn





**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062454748  
**LIMS Reference ID:** EC54748  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** JCB#: 24-57728, River Elementary School,  
Patchogue-Medford Union Free School District,  
46 River Avenue, Patchogue, NY 11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 07/15/2024 18:25  
**Reported:** 07/22/2024 13:48

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	09/01/2024

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062454748  
**LIMS Reference ID:** EC54748  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** JCB#: 24-57728, River Elementary School,  
Patchogue-Medford Union Free School District,  
46 River Avenue, Patchogue, NY 11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 07/15/2024 18:25  
**Reported:** 07/22/2024 13:48

**Notes and Definitions**


<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. All results for soil samples are reported on a dry weight basis, unless otherwise noted.

# EC53528



## Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

**JCB #:** 24-57728  
**Building:** Tremont Elementary School  
TES

**Client:** Patchogue-Medford Union Free School District  
Retest/New Install   
Turn Around: Normal 1 wk  Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-0371	Hallway	1015	Corridor Near Room 6 (1004)	WC	5/22/2024	6:30:00 AM
PMED-0374	Office	1012	Library Work Room	KC	5/22/2024	6:26:00 AM
PMED-0390	Office	1009	Custodial Office	KC	5/22/2024	6:24:00 AM
PMED-0393	Kitchen	1016	Kitchen	KC	5/22/2024	5:56:00 AM
PMED-0394	Kitchen	1016	Kitchen	KC	5/22/2024	5:56:00 AM
PMED-0395	Kitchen	1016	Kitchen	KC	5/22/2024	5:57:00 AM
PMED-0398	Cafeteria	1017	Cafeteria	WC	5/22/2024	5:59:00 AM
PMED-0399	Cafeteria	1017	Cafeteria	WF	5/22/2024	5:59:00 AM
PMED-0401	Hallway	1029	Corridor Near Gymnasium (1019)	WC	5/22/2024	6:22:00 AM
PMED-0402	Hallway	1029	Corridor Near Gymnasium (1019)	WF	5/22/2024	6:22:00 AM
PMED-0413	Nurse Office	1031	Nurse's Office	NS	5/22/2024	6:14:00 AM
PMED-0418	Faculty Lounge	1033	Faculty Room	KC	5/22/2024	6:13:00 AM
PMED-0420	Hallway	1042	Corridor Near Faculty Room (1033)	WC	5/22/2024	6:11:00 AM
PMED-0421	Hallway	1042	Corridor Near Faculty Room (1033)	WF	5/22/2024	6:11:00 AM
PMED-0442	Hallway	1060	Corridor Near Room 23 (1053)	WC	5/22/2024	6:05:00 AM
PMED-0443	Hallway	1060	Corridor Near Room 23 (1053)	WF	5/22/2024	6:05:00 AM
PMED-0467	Hallway	2024	Corridor Near New Gymnasium (2023)	WC	5/22/2024	6:01:00 AM
PMED-0468	Hallway	2024	Corridor Near New Gymnasium (2023)	WF	5/22/2024	6:01:00 AM

5/18/24  
5/20/24  
5/22/24  
5/23/24  
5/24/24  
5/25/24  
5/26/24  
5/27/24  
5/28/24  
5/29/24  
5/30/24  
5/31/24  
6/1/24  
6/2/24  
6/3/24  
6/4/24  
6/5/24  
6/6/24  
6/7/24  
6/8/24  
6/9/24  
6/10/24  
6/11/24  
6/12/24  
6/13/24  
6/14/24  
6/15/24  
6/16/24  
6/17/24  
6/18/24  
6/19/24  
6/20/24  
6/21/24  
6/22/24  
6/23/24  
6/24/24  
6/25/24  
6/26/24  
6/27/24  
6/28/24  
6/29/24  
6/30/24  
7/1/24  
7/2/24  
7/3/24  
7/4/24  
7/5/24  
7/6/24  
7/7/24  
7/8/24  
7/9/24  
7/10/24  
7/11/24  
7/12/24  
7/13/24  
7/14/24  
7/15/24  
7/16/24  
7/17/24  
7/18/24  
7/19/24  
7/20/24  
7/21/24  
7/22/24  
7/23/24  
7/24/24  
7/25/24  
7/26/24  
7/27/24  
7/28/24  
7/29/24  
7/30/24  
7/31/24  
8/1/24  
8/2/24  
8/3/24  
8/4/24  
8/5/24  
8/6/24  
8/7/24  
8/8/24  
8/9/24  
8/10/24  
8/11/24  
8/12/24  
8/13/24  
8/14/24  
8/15/24  
8/16/24  
8/17/24  
8/18/24  
8/19/24  
8/20/24  
8/21/24  
8/22/24  
8/23/24  
8/24/24  
8/25/24  
8/26/24  
8/27/24  
8/28/24  
8/29/24  
8/30/24  
8/31/24  
9/1/24  
9/2/24  
9/3/24  
9/4/24  
9/5/24  
9/6/24  
9/7/24  
9/8/24  
9/9/24  
9/10/24  
9/11/24  
9/12/24  
9/13/24  
9/14/24  
9/15/24  
9/16/24  
9/17/24  
9/18/24  
9/19/24  
9/20/24  
9/21/24  
9/22/24  
9/23/24  
9/24/24  
9/25/24  
9/26/24  
9/27/24  
9/28/24  
9/29/24  
9/30/24  
10/1/24  
10/2/24  
10/3/24  
10/4/24  
10/5/24  
10/6/24  
10/7/24  
10/8/24  
10/9/24  
10/10/24  
10/11/24  
10/12/24  
10/13/24  
10/14/24  
10/15/24  
10/16/24  
10/17/24  
10/18/24  
10/19/24  
10/20/24  
10/21/24  
10/22/24  
10/23/24  
10/24/24  
10/25/24  
10/26/24  
10/27/24  
10/28/24  
10/29/24  
10/30/24  
10/31/24  
11/1/24  
11/2/24  
11/3/24  
11/4/24  
11/5/24  
11/6/24  
11/7/24  
11/8/24  
11/9/24  
11/10/24  
11/11/24  
11/12/24  
11/13/24  
11/14/24  
11/15/24  
11/16/24  
11/17/24  
11/18/24  
11/19/24  
11/20/24  
11/21/24  
11/22/24  
11/23/24  
11/24/24  
11/25/24  
11/26/24  
11/27/24  
11/28/24  
11/29/24  
11/30/24  
12/1/24  
12/2/24  
12/3/24  
12/4/24  
12/5/24  
12/6/24  
12/7/24  
12/8/24  
12/9/24  
12/10/24  
12/11/24  
12/12/24  
12/13/24  
12/14/24  
12/15/24  
12/16/24  
12/17/24  
12/18/24  
12/19/24  
12/20/24  
12/21/24  
12/22/24  
12/23/24  
12/24/24  
12/25/24  
12/26/24  
12/27/24  
12/28/24  
12/29/24  
12/30/24  
12/31/24

RECEIVED  
ENVIRONMENTAL ANALYTICAL, INC.  
300 FREDERICK ST  
ROCKY HILL, CT 06067  
5/22/2024 12:22 PM

**Building Address**  
143 Tremont Avenue  
Medford, NY 11763


**Analysis Type:** ELAP 200.5

**Lab Received:** A. Minnifield  
**Signature:** A. Minnifield  
5/30/24 12:52pm


**Samplers Name:** Danielle Bolognini

**Samplers Signature:** [Signature]

**JCB Project Manager:** Meghan Brynne



# EC53528



## Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

**JCB #:** 24-57728  
**Building:** Tremont Elementary School  
TES

**Client:** Patchogue-Medford Union Free School District  
Retest/New Install   
Turn Around: Normal 1 wk Rush \_\_\_\_\_

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-1967	Nurse Office	1031	Health Office	IM	5/22/2024	6:17:00 AM

Samples Submitted 19

RECEIVED  
EMSL ANALYTICAL, INC.  
CARLE PLACE, NY

2024 MAY 30 P 12: 52

*Handwritten:* 6/18/24  
8.006  
16

Building Address  
143 Tremont Avenue  
Medford , NY 11763

**Analysis Type:** ELAP 200.5

**Lab Recieved:** A. MINNIFIELD

**Signature:** *A. Minnifield*  
5/30/24 12:52pm

**Samplers Name:** Danielle Caloganni

**Samplers Signature:** *Danielle Caloganni*

**JCB Project Manager:** *Highan Emrynn*

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453528  
**LIMS Reference ID:** EC53528  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** 24-57728, Tremont Elementary School, TES,  
 Patchogue- Medford Union Free School  
 District, 143 Tremont Avenue Medford, NY  
 11763  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:52  
**Reported:** 06/27/2024 08:55

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-0371 Lims Reference ID: EC53528-01 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 15:45	06/18/24 15:45	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0374 Lims Reference ID: EC53528-02 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	2.0		1	1.0	µg/L	06/18/24 15:49	06/18/24 15:49	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0390 Lims Reference ID: EC53528-03 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	3.5		1	1.0	µg/L	06/18/24 15:51	06/18/24 15:51	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0393 Lims Reference ID: EC53528-04 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	3.5		1	1.0	µg/L	06/18/24 15:52	06/18/24 15:52	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0394 Lims Reference ID: EC53528-05 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	3.5		1	1.0	µg/L	06/18/24 15:56	06/18/24 15:56	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0395 Lims Reference ID: EC53528-06 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	5.6		1	1.0	µg/L	06/18/24 15:57	06/18/24 15:57	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0398 Lims Reference ID: EC53528-07 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 15:58	06/18/24 15:58	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0399 Lims Reference ID: EC53528-08 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 16:00	06/18/24 16:00	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0401 Lims Reference ID: EC53528-09 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 16:01	06/18/24 16:01	BA	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453528  
**LIMS Reference ID:** EC53528  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** 24-57728, Tremont Elementary School, TES,  
Patchogue- Medford Union Free School  
District, 143 Tremont Avenue Medford, NY  
11763  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:52  
**Reported:** 06/27/2024 08:55

**Analytical Results**  
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-0402 Lims Reference ID: EC53528-10 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 16:02	06/18/24 16:02	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0413 Lims Reference ID: EC53528-11 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 16:04	06/18/24 16:04	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0418 Lims Reference ID: EC53528-12 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	2.4		1	1.0	µg/L	06/18/24 16:08	06/18/24 16:08	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0420 Lims Reference ID: EC53528-13 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 16:12	06/18/24 16:12	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0421 Lims Reference ID: EC53528-14 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 16:13	06/18/24 16:13	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0442 Lims Reference ID: EC53528-15 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 16:14	06/18/24 16:14	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0443 Lims Reference ID: EC53528-16 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 16:16	06/18/24 16:16	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0467 Lims Reference ID: EC53528-17 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 16:17	06/18/24 16:17	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0468 Lims Reference ID: EC53528-18 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 16:18	06/18/24 16:18	BA	EPA 200.8 (DA)/EPA 200.8





**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453528

**LIMS Reference ID:** EC53528

**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** 24-57728, Tremont Elementary School, TES,  
Patchogue- Medford Union Free School  
District, 143 Tremont Avenue Medford, NY  
11763  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:52  
**Reported:** 06/27/2024 08:55

**Analytical Results  
(Continued)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

**Sample:** PMED-1967

**Lims Reference ID:** EC53528-19 **Matrix:** Drinking Water

**Sampled:** 05/22/24 00:00:00

**Metals**

Lead	<1.0		1	1.0	µg/L	06/18/24 16:20	06/18/24 16:20	BA	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	-----	------	----------------	----------------	----	--------------------------



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453528  
**LIMS Reference ID:** EC53528  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** 24-57728, Tremont Elementary School, TES,  
Patchogue- Medford Union Free School  
District, 143 Tremont Avenue Medford, NY  
11763  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:52  
**Reported:** 06/27/2024 08:55

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	09/01/2024

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453528  
**LIMS Reference ID:** EC53528  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** 24-57728, Tremont Elementary School, TES,  
Patchogue- Medford Union Free School  
District, 143 Tremont Avenue Medford, NY  
11763  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:52  
**Reported:** 06/27/2024 08:55


**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. All results for soil samples are reported on a dry weight basis, unless otherwise noted.



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 24-57728  
Building: Tremont Elementary School

EC 54743

Client: Patchogue-Medford Union Free School District

TES

Retest/New Install   
Turn Around: Normal 1 wk Rush \_\_\_\_\_

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-0395	Kitchen	1016	Kitchen	KC	7/12/2024	12:14:00 PM

Samples Submitted 1

*2024  
7-12-24  
M. Gwynn*

RECEIVED  
EHSL ANALYTICAL, INC.  
CARLE PLACE, NY  
2024 JUL 15 P 6:25

**Building Address**  
143 Tremont Avenue  
Medford, NY 11763

Analysis Type: ELAP 200.5

Lab Received: *[Signature]*

Signature: *[Signature]*

Samplers Name: *Meghan Gwynn*

Samplers Signature: *[Signature]*

JCB Project Manager: *M. Gwynn*



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062454743  
**LIMS Reference ID:** EC54743  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** JCB#: 24-57728, Tremont Elementary School,  
Patchogue-Medford Union Free School District,  
143 Tremont Avenue, Medford, NY 11763  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 07/15/2024 18:25  
**Reported:** 07/22/2024 13:45

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: PMED-0395 Lims Reference ID: EC54743-01 Matrix: Drinking Water Sampled: 07/12/24 00:00:00

**Metals**

Lead	12.2		1	1.0	µg/L	07/20/24 13:02	07/20/24 13:02	JH	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	-----	------	----------------	----------------	----	--------------------------



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062454743  
**LIMS Reference ID:** EC54743  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** JCB#: 24-57728, Tremont Elementary School,  
Patchogue-Medford Union Free School District,  
143 Tremont Avenue, Medford, NY 11763  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 07/15/2024 18:25  
**Reported:** 07/22/2024 13:45

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	09/01/2024

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062454743  
**LIMS Reference ID:** EC54743  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** JCB#: 24-57728, Tremont Elementary School,  
Patchogue-Medford Union Free School District,  
143 Tremont Avenue, Medford, NY 11763  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 07/15/2024 18:25  
**Reported:** 07/22/2024 13:45


**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. All results for soil samples are reported on a dry weight basis, unless otherwise noted.



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

**JCB #:** 24-57728  
**Building:** Eagle Elementary School  
EES

EC 53551

**Client:** Patchogue-Medford Union Free School District  
Retest/New Install   
Turn Around  Normal 1 wk  Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-0499	Hallway	1033	Corridor Near Room 8 (1028)	WC	5/21/2024	6:03:00 AM
PMED-0513	Faculty Lounge	1011B	Main Office Kitchen	KC	5/21/2024	6:04:00 AM
PMED-0514	Hallway	1033	Corridor Near Book Room 6 (1026)	WC	5/21/2024	6:05:00 AM
PMED-0515	Hallway	1033	Corridor Near Book Room 6 (1026)	WF	5/21/2024	6:05:00 AM
PMED-0516	Nurse Office	1012A	Nurse's Office	NS	5/21/2024	6:06:00 AM
PMED-0525	Hallway	1033	Corridor Near Room 3 (1022)	WC	5/21/2024	6:08:00 AM
PMED-0526	Hallway	1033	Corridor Near Room 3 (1022)	WF	5/21/2024	6:08:00 AM
PMED-0549	Hallway	1052	Corridor Near Music Room 46 (1049)	WC	5/21/2024	6:18:00 AM
PMED-0550	Hallway	1052	Corridor Near Music Room 46 (1049)	WF	5/21/2024	6:18:00 AM
PMED-0559	Cafeteria	1042	Cafeteria	WC	5/21/2024	6:19:00 AM
PMED-0560	Cafeteria	1042	Cafeteria	WF	5/21/2024	6:20:00 AM
PMED-0562	Kitchen	1043	Kitchen	KC	5/21/2024	6:21:00 AM
PMED-0563	Kitchen	1043	Kitchen	KC	5/21/2024	6:23:00 AM
PMED-0564	Kitchen	1043	Kitchen	KC	5/21/2024	6:24:00 AM
PMED-0565	Kitchen	1043	Kitchen	KC	5/21/2024	6:25:00 AM
PMED-0572	Hallway	4009	Corridor Near Secondary Gym (4008)	WC	5/21/2024	6:30:00 AM
PMED-0573	Hallway	4009	Corridor Near Secondary Gym (4008)	WF	5/21/2024	6:30:00 AM
PMED-0585	Hallway	2034	Corridor Near Girls Bathroom (2030)	WC	5/21/2024	6:11:00 AM

RECEIVED  
MAY 20 12:38  
MIDDLEBURY COLLEGE  
LABORATORY

**Building Address**  
1000 Wave Avenue  
Medford, NY 11763

**Analysis Type:** ELAP 200.5

**Lab Received:** *[Signature]*

**Signature:** *[Signature]*

**Samplers Name:** Luke Coulter

**Samplers Signature:** *[Signature]*

**JCB Project Manager:** Meghan Gwynn

Courier



EC 53551



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

**JCB #:** 24-57728  
**Building:** Eagle Elementary School  
EES

**Client:** Patchogue-Medford Union Free School District  
Retest/New Install   
Turn Around: Normal 1 wk Rush \_\_\_\_\_

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-0586	Hallway	2034	Corridor Near Girls Bathroom (2030)	WF	5/21/2024	6:11:00 AM
PMED-0596	Faculty Lounge	2005	Faculty Room	KC	5/21/2024	6:12:00 AM
PMED-0602	Office	2010A	Library Work Room	KC	5/21/2024	6:13:00 AM
PMED-0609	Hallway	2034	Corridor Near Custodial Closet (2019)	WC	5/21/2024	6:14:00 AM
PMED-0610	Hallway	2034	Corridor Near Custodial Closet (2019)	WF	5/21/2024	6:15:00 AM
PMED-1913	HA	1033	Corridor 12 To Exit Adjacent To 22	WF	5/21/2024	6:03:00 AM
PMED-1917	FL	2005	Faculty Room	BW	5/21/2024	6:12:00 AM

Samples Submitted 25

RECEIVED  
EHSL ANALYTICAL, INC.  
CARLE PLACE, NY  
2024 MAY 30 P 12: 38

**Building Address**  
1000 Wave Avenue  
Medford, NY 11763

**Analysis Type:** ELAP 200.5

**Lab Received:** Carle

**Signature:** [Signature]

**Samplers Name:** Luke Coulter

**Samplers Signature:** [Signature]

**JCB Project Manager:** Meghan Gwynn

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453551  
**LIMS Reference ID:** EC53551  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #24-57728, Eagle Elementary School,  
 Patchogue-Medford Union Free School District,  
 1000 Wave Avenue, Medford, NY 11763

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish

**Received:** 05/30/2024 12:38  
**Reported:** 06/27/2024 10:08

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-0499 Lims Reference ID: EC53551-01 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 18:45	06/15/24 18:45	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0513 Lims Reference ID: EC53551-02 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	2.1		1	1.0	µg/L	06/15/24 18:47	06/15/24 18:47	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0514 Lims Reference ID: EC53551-03 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 18:48	06/15/24 18:48	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0515 Lims Reference ID: EC53551-04 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 18:50	06/15/24 18:50	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0516 Lims Reference ID: EC53551-05 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 18:51	06/15/24 18:51	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0525 Lims Reference ID: EC53551-06 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 18:55	06/15/24 18:55	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0526 Lims Reference ID: EC53551-07 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 18:57	06/15/24 18:57	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0549 Lims Reference ID: EC53551-08 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 18:58	06/15/24 18:58	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0550 Lims Reference ID: EC53551-09 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 19:03	06/15/24 19:03	BA	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453551  
**LIMS Reference ID:** EC53551  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** #24-57728, Eagle Elementary School,  
Patchogue-Medford Union Free School District,  
1000 Wave Avenue, Medford, NY 11763  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:38  
**Reported:** 06/27/2024 10:08

**Analytical Results**  
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-0559 Lims Reference ID: EC53551-10 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 19:04	06/15/24 19:04	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0560 Lims Reference ID: EC53551-11 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 19:05	06/15/24 19:05	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0562 Lims Reference ID: EC53551-12 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	274		10	10.0	µg/L	06/15/24 19:23	06/15/24 19:23	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0563 Lims Reference ID: EC53551-13 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	2.8		1	1.0	µg/L	06/15/24 19:08	06/15/24 19:08	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0564 Lims Reference ID: EC53551-14 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	1.1		1	1.0	µg/L	06/15/24 19:10	06/15/24 19:10	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0565 Lims Reference ID: EC53551-15 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	1.3		1	1.0	µg/L	06/14/24 22:04	06/14/24 22:04	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0572 Lims Reference ID: EC53551-16 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 22:08	06/14/24 22:08	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0573 Lims Reference ID: EC53551-17 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 22:10	06/14/24 22:10	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0585 Lims Reference ID: EC53551-18 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 22:11	06/14/24 22:11	BA	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453551  
**LIMS Reference ID:** EC53551  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #24-57728, Eagle Elementary School,  
 Patchogue-Medford Union Free School District,  
 1000 Wave Avenue, Medford, NY 11763

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:38  
**Reported:** 06/27/2024 10:08

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-0586 Lims Reference ID: EC53551-19 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 22:16	06/14/24 22:16	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0596 Lims Reference ID: EC53551-20 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	3.4		1	1.0	µg/L	06/14/24 22:17	06/14/24 22:17	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0602 Lims Reference ID: EC53551-21 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	1.5		1	1.0	µg/L	06/14/24 22:18	06/14/24 22:18	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0609 Lims Reference ID: EC53551-22 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 22:20	06/14/24 22:20	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0610 Lims Reference ID: EC53551-23 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 22:21	06/14/24 22:21	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1913 Lims Reference ID: EC53551-24 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 22:23	06/14/24 22:23	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1917 Lims Reference ID: EC53551-25 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 22:24	06/15/24 13:00	BA	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453551  
**LIMS Reference ID:** EC53551  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** #24-57728, Eagle Elementary School,  
Patchogue-Medford Union Free School District,  
1000 Wave Avenue, Medford, NY 11763  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:38  
**Reported:** 06/27/2024 10:08

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	09/01/2024

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453551  
**LIMS Reference ID:** EC53551  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** #24-57728, Eagle Elementary School,  
Patchogue-Medford Union Free School District,  
1000 Wave Avenue, Medford, NY 11763  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:38  
**Reported:** 06/27/2024 10:08

**Notes and Definitions**


<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. All results for soil samples are reported on a dry weight basis, unless otherwise noted.

# EC53553



## Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

**JCB #:** 24-57728

**Building:** Administration Building

AB

**Client:**

Patchogue-Medford Union Free School District

Retest/New Install


Turn Around: Normal 1 wk Rush \_\_\_\_\_

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-3033	HA	1006	Conference Room	BW	5/30/2024	7:15:00 AM
PMED-3034	HA	1006	Conference Room	BW	5/30/2024	7:15:00 AM
PMED-3035	Office	1012C1	Business Office 2 Inner Office Closet	KC	5/30/2024	7:32:00 AM
PMED-3037	HA	2011	2nd Floor Corridor	BW	5/30/2024	7:18:00 AM
PMED-3038	HA	2011	2nd Floor Corridor	BW	5/30/2024	7:18:00 AM

Samples Submitted 5

RECEIVED  
EHSL ANALYTICAL, INC.  
CARLE PLACE, NY  
2024 MAY 31 P 1:42

*Ab 2008  
Patched  
6/11/24*



Building Address

241 South Ocean Avenue  
Patchogue, NY 11772

**Analysis Type:** ELAP 200.5

**Lab Received:** A. Minnifield

**Signature:** A. Minnifield

5/31/25 1:42pm

**Samplers Name:** Conor Malanaphy

**Samplers Signature:** Conor Malanaphy

**JCB Project Manager:** Meghan Gwynn

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453553  
**LIMS Reference ID:** EC53553  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** 24-57728, Administration Building, Patchogue-Medford Union Free School District, 241 South Ocean Avenue Patchogue, NY 11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 13:42  
**Reported:** 06/27/2024 10:12

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
<b>Sample: PMED-3033</b>									
			<b>Lims Reference ID:</b>		<b>EC53553-01</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 05/30/24 00:00:00</b>	
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 20:26	06/14/24 20:26	BA	EPA 200.8 (DA)/EPA 200.8
<b>Sample: PMED-3034</b>									
			<b>Lims Reference ID:</b>		<b>EC53553-02</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 05/30/24 00:00:00</b>	
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 20:31	06/14/24 20:31	BA	EPA 200.8 (DA)/EPA 200.8
<b>Sample: PMED-3035</b>									
			<b>Lims Reference ID:</b>		<b>EC53553-03</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 05/30/24 00:00:00</b>	
<b>Metals</b>									
Lead	36.1		1	1.0	µg/L	06/14/24 20:32	06/14/24 20:32	BA	EPA 200.8 (DA)/EPA 200.8
<b>Sample: PMED-3037</b>									
			<b>Lims Reference ID:</b>		<b>EC53553-04</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 05/30/24 00:00:00</b>	
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 20:33	06/14/24 20:33	BA	EPA 200.8 (DA)/EPA 200.8
<b>Sample: PMED-3038</b>									
			<b>Lims Reference ID:</b>		<b>EC53553-05</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 05/30/24 00:00:00</b>	
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 20:35	06/14/24 20:35	BA	EPA 200.8 (DA)/EPA 200.8





**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453553  
**LIMS Reference ID:** EC53553  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** 24-57728, Administration Building, Patchogue-Medford Union Free School District, 241 South Ocean Avenue Patchogue, NY 11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 13:42  
**Reported:** 06/27/2024 10:12

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	09/01/2024

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453553

**LIMS Reference ID:** EC53553

**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** 24-57728, Administration Building, Patchogue-Medford Union Free School District, 241 South Ocean Avenue Patchogue, NY 11772

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish

**Received:** 05/31/2024 13:42

**Reported:** 06/27/2024 10:12

**Notes and Definitions**


<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. All results for soil samples are reported on a dry weight basis, unless otherwise noted.

EC 53557



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 24-57728  
Building: South Ocean Middle School  
SOMS

Client: Patchogue-Medford Union Free School District  
Retest/New Install [ ]  
Turn Around: Normal 1 wk Rush \_\_\_\_\_

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-0637	Office	1001	Director Office 100	BW	5/30/2024	6:33:00 AM
PMED-0639	Special	1003A	Print Shop Printing Center	KC	5/30/2024	6:31:00 AM
PMED-0640	OF	1008B	Custodial Office	BW	5/30/2024	6:28:00 AM
PMED-0644	Nurse Office	1009	Nurse's Office	NS	5/30/2024	6:27:00 AM
PMED-0660	Hallway	1024	Corridor Near Kitchen (1017)	WC	5/30/2024	6:20:00 AM
PMED-0661	Hallway	1024	Corridor Near Kitchen (1017)	WF	5/30/2024	6:23:00 AM
PMED-0662	Kitchen	1017	Kitchen	KC	5/30/2024	6:16:00 AM
PMED-0663	Kitchen	1017	Kitchen	KC	5/30/2024	6:17:00 AM
PMED-0681	Hallway	2034	Corridor Near Room 208 (2033)	WC	5/30/2024	6:50:00 AM
PMED-0682	Hallway	2034	Corridor Near Room 208 (2033)	WF	5/30/2024	6:50:00 AM
PMED-0687	Hallway	2018	Corridor Near Psychologist Office 205 (2016A)	WC	5/30/2024	6:54:00 AM
PMED-0688	Hallway	2018	Corridor Near Psychologist Office 205 (2016A)	WF	5/30/2024	6:54:00 AM
PMED-0698	Hallway	2018	Corridor Near Room 215 (2003)	WC	5/30/2024	6:52:00 AM
PMED-0699	Hallway	2018	Corridor Near Room 215 (2003)	WF	5/30/2024	6:52:00 AM
PMED-0722	Hallway	3007	Corridor Near Room 323 (3001)	WC	5/30/2024	7:01:00 AM
PMED-0723	Hallway	3007	Corridor Near Room 323 (3001)	WF	5/30/2024	7:01:00 AM
PMED-3008	OF	1001	Directors Office 100	BW	5/30/2024	6:34:00 AM
PMED-3009	OF	1003A	Print Shop Printing Center	BW	5/30/2024	6:30:00 AM

16 200-8  
Parker  
6/19/24

RECEIVED  
EHS ANALYTICAL  
LABORATORY  
MAY 31 2024

Building Address  
225 South Ocean Avenue  
Patchogue, NY 11772

Analysis Type: ELAP 200.5


Lab Received:


5-29-24 12:13 PM  
Signature: *[Handwritten Signature]*

Samplers Name: Conor Malanaphy

Samplers Signature: *[Handwritten Signature]*

JCB Project Manager: Meghan Gwynn





# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 24-57728  
Building: South Ocean Middle School  
SOMS

# EC 53557

Client: Patchogue-Medford Union Free School District  
Retest/New Install [ ]  
Turn Around: Normal 1 wk Rush \_\_\_\_\_

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-3011	HA	1024	Corridor Between Guidance Office & Kitchen	WC	5/30/2024	6:22:00 AM
PMED-3016	HA	1024	Corridor Between Guidance Office & Kitchen	WF	5/30/2024	6:20:00 AM
PMED-3017	LR	1038	Girls Locker Room	WC	5/30/2024	6:40:00 AM
PMED-3018	LR	1038	Girls Locker Room	WF	5/30/2024	6:40:00 AM
PMED-3019	LR	1041	Boys Locker Room	WC	5/30/2024	6:42:00 AM
PMED-3020	LR	1041	Boys Locker Room	WF	5/30/2024	6:42:00 AM
PMED-3022	HA	3012	Hallway From Men's Bathroom To Staircase (Near Elevator)	WC	5/30/2024	6:58:00 AM
PMED-3023	HA	3012	Hallway From Men's Bathroom To Staircase (Near Elevator)	WF	5/30/2024	6:58:00 AM
PMED-3028	HA	4007	4th Floor Corridor (Includes Stairwell Near Elevator)	WC	5/30/2024	7:05:00 AM
PMED-3029	HA	4007	4th Floor Corridor (Includes Stairwell Near Elevator)	WF	5/30/2024	7:05:00 AM

Samples Submitted 28

Pl 200.5  
Patched  
6/19/24

RECEIVED  
EHSL ANALYTICAL, INC.  
CARLE PLACE, NY  
2024 MAY 31 P 12:13

Building Address  
225 South Ocean Avenue  
Patchogue, NY 11772

Analysis Type: ELAP 200.5

Lab Received: 5-31-24 12:13PM

Signature: *[Handwritten Signature]*

Samplers Name: *Conor Malanophy*

Samplers Signature: *Conor Malanophy*

JCB Project Manager: *Meghen Gwynn*



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453557  
**LIMS Reference ID:** EC53557  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** #: 24-57728, South Ocean Middle School,  
Patchogue-Medford Union Free School District,  
225 South Ocean Avenue, Patchogue, NY  
11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 12:13  
**Reported:** 06/27/2024 09:05

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-0637 Lims Reference ID: EC53557-01 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 20:39	06/14/24 20:39	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0639 Lims Reference ID: EC53557-02 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	417		10	10.0	µg/L	06/14/24 21:28	06/14/24 21:28	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0640 Lims Reference ID: EC53557-03 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 20:42	06/14/24 20:42	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0644 Lims Reference ID: EC53557-04 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	4.1		1	1.0	µg/L	06/14/24 20:44	06/14/24 20:44	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0660 Lims Reference ID: EC53557-05 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 20:45	06/14/24 20:45	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0661 Lims Reference ID: EC53557-06 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 21:26	06/14/24 21:26	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0662 Lims Reference ID: EC53557-07 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	37.9		1	1.0	µg/L	06/14/24 20:51	06/14/24 20:51	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0663 Lims Reference ID: EC53557-08 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	1.1		1	1.0	µg/L	06/14/24 20:52	06/14/24 20:52	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0681 Lims Reference ID: EC53557-09 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 20:57	06/14/24 20:57	BA	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453557  
**LIMS Reference ID:** EC53557  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #: 24-57728, South Ocean Middle School,  
 Patchogue-Medford Union Free School District,  
 225 South Ocean Avenue, Patchogue, NY  
 11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 12:13  
**Reported:** 06/27/2024 09:05

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-0682 Lims Reference ID: EC53557-10 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 20:58	06/14/24 20:58	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0687 Lims Reference ID: EC53557-11 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 20:59	06/14/24 20:59	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0688 Lims Reference ID: EC53557-12 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 21:01	06/14/24 21:01	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0698 Lims Reference ID: EC53557-13 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 18:17	06/19/24 18:17	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0699 Lims Reference ID: EC53557-14 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 18:18	06/19/24 18:18	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0722 Lims Reference ID: EC53557-15 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 16:37	06/19/24 16:37	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0723 Lims Reference ID: EC53557-16 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 16:41	06/19/24 16:41	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-3008 Lims Reference ID: EC53557-17 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 16:43	06/19/24 16:43	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-3009 Lims Reference ID: EC53557-18 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 16:44	06/19/24 16:44	BA	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453557  
**LIMS Reference ID:** EC53557  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #: 24-57728, South Ocean Middle School,  
 Patchogue-Medford Union Free School District,  
 225 South Ocean Avenue, Patchogue, NY  
 11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 12:13  
**Reported:** 06/27/2024 09:05

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-3011 Lims Reference ID: EC53557-19 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 16:46	06/19/24 16:46	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-3016 Lims Reference ID: EC53557-20 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 16:50	06/19/24 16:50	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-3017 Lims Reference ID: EC53557-21 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 16:52	06/19/24 16:52	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-3018 Lims Reference ID: EC53557-22 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 16:53	06/19/24 16:53	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-3019 Lims Reference ID: EC53557-23 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 16:54	06/19/24 16:54	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-3020 Lims Reference ID: EC53557-24 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 16:56	06/19/24 16:56	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-3022 Lims Reference ID: EC53557-25 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 16:57	06/19/24 16:57	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-3023 Lims Reference ID: EC53557-26 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 17:02	06/19/24 17:02	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-3028 Lims Reference ID: EC53557-27 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 17:03	06/19/24 17:03	BA	EPA 200.8 (DA)/EPA 200.8







**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453557  
**LIMS Reference ID:** EC53557  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** #: 24-57728, South Ocean Middle School,  
Patchogue-Medford Union Free School District,  
225 South Ocean Avenue, Patchogue, NY  
11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 12:13  
**Reported:** 06/27/2024 09:05

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	09/01/2024

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453557  
**LIMS Reference ID:** EC53557  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** #: 24-57728, South Ocean Middle School,  
Patchogue-Medford Union Free School District,  
225 South Ocean Avenue, Patchogue, NY  
11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 12:13  
**Reported:** 06/27/2024 09:05


**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. All results for soil samples are reported on a dry weight basis, unless otherwise noted.



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

**JCB #:** 24-57728  
**Building:** South Ocean Middle School  
SOMS

EC 54742

**Client:** Patchogue-Medford Union Free School District  
 Retest/New Install [ ]  
**Turn Around:** Normal 1 wk Rush \_\_\_\_\_

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-0662	Kitchen	1017	Kitchen	KC	7/12/2024	12:57:00 PM

Samples Submitted 1

*Handwritten notes:*  
pb 2008  
shahy

RECEIVED  
EHSL ANALYTICAL, INC.  
CARLE PLACE, NY  
2024 JUL 15 P 6:25

**Building Address**  
225 South Ocean Avenue  
Patchogue, NY 11772

**Analysis Type:** ELAP 200.5  
**Lab Received:** *Charles*  
**Signature:** *[Signature]*

**Samplers Name:** *Megha Guynn*  
**Samplers Signature:** *[Signature]*  
**JCB Project Manager:** *M. Guynn*



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062454742  
**LIMS Reference ID:** EC54742  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** JCB#: 24-57728, South Ocean Middle School,  
Patchogue-Medford Union Free School District,  
225 South Ocean Avenue, Patchogue, NY  
11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 07/15/2024 18:25  
**Reported:** 07/22/2024 13:42

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: PMED-0662

Lims Reference ID: EC54742-01 Matrix: Drinking Water

Sampled: 07/12/24 00:00:00

**Metals**

Lead	5.6		1	1.0	µg/L	07/20/24 12:58	07/20/24 12:58	JH	EPA 200.8 (DA)/EPA 200.8
------	-----	--	---	-----	------	----------------	----------------	----	--------------------------



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062454742  
**LIMS Reference ID:** EC54742  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** JCB#: 24-57728, South Ocean Middle School,  
Patchogue-Medford Union Free School District,  
225 South Ocean Avenue, Patchogue, NY  
11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 07/15/2024 18:25  
**Reported:** 07/22/2024 13:42

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	09/01/2024

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062454742  
**LIMS Reference ID:** EC54742  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** JCB#: 24-57728, South Ocean Middle School,  
Patchogue-Medford Union Free School District,  
225 South Ocean Avenue, Patchogue, NY  
11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 07/15/2024 18:25  
**Reported:** 07/22/2024 13:42

**Notes and Definitions**


<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. All results for soil samples are reported on a dry weight basis, unless otherwise noted.

EC S 3546



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395


JCB #: 24-57728  
Building: Canaan Elementary School  
CES

Client: Patchogue-Medford Union Free School District  
Retest/New Install   
Turn Around: Normal 1 wk Rush \_\_\_\_\_

Pls 2008 Rollin C112124

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-0766	Hallway	1013	Corridor Near Room 7 (1006)	WC	5/21/2024	6:26:00 AM
PMED-0767	Hallway	1013	Corridor Near Room 7 (1006)	WF	5/21/2024	6:27:00 AM
PMED-0783	Hallway	3018	Corridor Near Music Room 807 (3014)	WC	5/21/2024	6:21:00 AM
PMED-0784	Hallway	3018	Corridor Near Music Room 807 (3014)	WF	5/21/2024	6:21:00 AM
PMED-0796	Hallway	3025	Corridor Near Gymnasium (3024)	WC	5/21/2024	6:19:00 AM
PMED-0797	Hallway	3025	Corridor Near Gymnasium (3024)	WF	5/21/2024	6:19:00 AM
PMED-0805	Nurse Office	1019A	Nurse's Office	NS	5/21/2024	6:14:00 AM
PMED-0810	Faculty Lounge	1022	Faculty Room	KC	5/21/2024	6:10:00 AM
PMED-0814	Kitchen	1026	Kitchen	KC	5/21/2024	5:59:00 AM
PMED-0817	Kitchen	1026A	Kitchen	KC	5/21/2024	6:00:00 AM
PMED-0818	Kitchen	1026A	Kitchen	KC	5/21/2024	6:00:00 AM
PMED-0820	Cafeteria	1034	Cafeteria	WC	5/21/2024	6:04:00 AM
PMED-0821	Cafeteria	1034	Cafeteria	WF	5/21/2024	6:04:00 AM
PMED-0824	Hallway	1032	Corridor Near Women's Bathroom (1023)	WC	5/21/2024	6:06:00 AM
PMED-0825	Hallway	1032	Corridor Near Women's Bathroom (1023)	WF	5/21/2024	6:06:00 AM
PMED-0829	Office	1037A	Library Work Room	KC	5/21/2024	6:29:00 AM
PMED-0854	Hallway	2020	Corridor Near Boys Bathroom (2009)	WC	5/21/2024	6:41:00 AM
PMED-0855	Hallway	2020	Corridor Near Boys Bathroom (2009)	WF	5/21/2024	6:42:00 AM

RECEIVED  
EHS/ANALYTICAL INC.  
02/21/24 10:30 PM



**Building Address**

59 Fry Boulevard  
Patchogue, NY 11772

Analysis Type: ELAP 200.5

Lab Received: afaele

Signature: [Signature]

Samplers Name: Aileen McNamee

Samplers Signature: Aileen McNamee

JCB Project Manager: Meghan Gwynn



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

**JCB #:** 24-57728  
**Building:** Canaan Elementary School  
CES

# EC 53546

**Client:** Patchogue-Medford Union Free School District

**Retest/New Install:**   
**Turn Around:** Normal 1 wk Rush

*Pls 200.8  
For Shur 6/12/24*

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-0871	Hallway	4017	Corridor Outside Room 40 (4014)	WC	5/21/2024	6:33:00 AM
PMED-0872	Hallway	4017	Corridor Outside Room 40 (4014)	WF	5/21/2024	6:34:00 AM
PMED-1920	HA	1032	Corridor Child Care To Gym	WC	5/21/2024	6:12:00 AM
PMED-1921	HA	1032	Corridor Child Care To Gym	WF	5/21/2024	6:12:00 AM
PMED-1922	FL	1028A	Custodial Break Room Office	BW	5/21/2024	6:49:00 AM
PMED-1923	FL	1028A	Custodial Break Room Office	BW	5/21/2024	6:50:00 AM
PMED-1924	FL	1022	Faculty Lounge	BW	5/21/2024	6:08:00 AM
PMED-1925	FL	1022	Faculty Lounge	BW	5/21/2024	6:08:00 AM

Samples Submitted 26

RECEIVED  
EHSL ANALYTICAL, INC.  
CARLE PLACE, NY  
2024 MAY 30 P 12:39

**Building Address**  
59 Fry Boulevard  
Patchogue, NY 11772

**Analysis Type:** ELAP 200.5  
**Lab Received:** *[Signature]*  
**Signature:** *[Signature]*

**Samplers Name:** *Aileen McNamee*  
**Samplers Signature:** *Aileen McNamee*  
**JCB Project Manager:** *Meghan Gwynn*



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453546  
**LIMS Reference ID:** EC53546  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #24-57728, Canaan Elementary School,  
 Patchogue-Medford Union Free School District,  
 59 Fry Boulevard, Patchogue, NY 11772

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:39  
**Reported:** 06/27/2024 09:51

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-0766 Lims Reference ID: EC53546-01 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 19:43	06/11/24 19:43	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0767 Lims Reference ID: EC53546-02 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 19:47	06/11/24 19:47	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0783 Lims Reference ID: EC53546-03 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 19:48	06/11/24 19:48	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0784 Lims Reference ID: EC53546-04 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 19:49	06/11/24 19:49	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0796 Lims Reference ID: EC53546-05 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 19:51	06/11/24 19:51	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0797 Lims Reference ID: EC53546-06 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 19:55	06/11/24 19:55	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0805 Lims Reference ID: EC53546-07 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 19:56	06/11/24 19:56	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0810 Lims Reference ID: EC53546-08 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	2.2		1	1.0	µg/L	06/11/24 19:57	06/11/24 19:57	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0814 Lims Reference ID: EC53546-09 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	3.4		1	1.0	µg/L	06/11/24 19:59	06/11/24 19:59	BA	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453546  
**LIMS Reference ID:** EC53546  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #24-57728, Canaan Elementary School,  
 Patchogue-Medford Union Free School District,  
 59 Fry Boulevard, Patchogue, NY 11772

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:39  
**Reported:** 06/27/2024 09:51

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-0817 Lims Reference ID: EC53546-10 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	2.9		1	1.0	µg/L	06/11/24 20:00	06/11/24 20:00	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0818 Lims Reference ID: EC53546-11 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	3.6		1	1.0	µg/L	06/11/24 20:01	06/11/24 20:01	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0820 Lims Reference ID: EC53546-12 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 20:05	06/11/24 20:05	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0821 Lims Reference ID: EC53546-13 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 20:07	06/11/24 20:07	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0824 Lims Reference ID: EC53546-14 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 20:10	06/11/24 20:10	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0825 Lims Reference ID: EC53546-15 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 20:12	06/11/24 20:12	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0829 Lims Reference ID: EC53546-16 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	3.5		1	1.0	µg/L	06/11/24 20:13	06/11/24 20:13	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0854 Lims Reference ID: EC53546-17 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 20:14	06/11/24 20:14	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0855 Lims Reference ID: EC53546-18 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 20:16	06/11/24 20:16	BA	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453546  
**LIMS Reference ID:** EC53546  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #24-57728, Canaan Elementary School,  
 Patchogue-Medford Union Free School District,  
 59 Fry Boulevard, Patchogue, NY 11772

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:39  
**Reported:** 06/27/2024 09:51

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-0871 Lims Reference ID: EC53546-19 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 20:17	06/11/24 20:17	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0872 Lims Reference ID: EC53546-20 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 20:18	06/11/24 20:18	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1920 Lims Reference ID: EC53546-21 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 20:47	06/11/24 20:47	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1921 Lims Reference ID: EC53546-22 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 20:50	06/11/24 20:50	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1922 Lims Reference ID: EC53546-23 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 20:52	06/11/24 20:52	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1923 Lims Reference ID: EC53546-24 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 20:53	06/11/24 20:53	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1924 Lims Reference ID: EC53546-25 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 20:54	06/11/24 20:54	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1925 Lims Reference ID: EC53546-26 Matrix: Drinking Water Sampled: 05/21/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 20:58	06/11/24 20:58	BA	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453546  
**LIMS Reference ID:** EC53546  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** #24-57728, Canaan Elementary School,  
Patchogue-Medford Union Free School District,  
59 Fry Boulevard, Patchogue, NY 11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:39  
**Reported:** 06/27/2024 09:51

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	09/01/2024

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453546  
**LIMS Reference ID:** EC53546  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** #24-57728, Canaan Elementary School,  
Patchogue-Medford Union Free School District,  
59 Fry Boulevard, Patchogue, NY 11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/30/2024 12:39  
**Reported:** 06/27/2024 09:51

**Notes and Definitions**


<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. All results for soil samples are reported on a dry weight basis, unless otherwise noted.

EC53571



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 24-57728  
Building: Saxton Middle School  
SMS

Client: Patchogue-Medford Union Free School District

Retest/New Install [ ]  
Turn Around: ~~Normal 1 wk~~ Rush \_\_\_\_\_

16 2008  
Parker  
6/24/24


Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-0895	Faculty Lounge	2039	Faculty Room	KC	5/30/2024	5:43:00 AM
PMED-0896	Hallway	2058	Corridor Near Room 218 (2038)	WC	5/30/2024	5:43:00 AM
PMED-0897	Hallway	2058	Corridor Near Room 218 (2038)	WF	5/30/2024	5:43:00 AM
PMED-0921	Hallway	2032	Corridor Near Room 217 (2026)	WF	5/30/2024	5:41:00 AM
PMED-0937	Custodial Closet	1045B1	Girls Locker Room Custodial Closet	SP	5/30/2024	6:01:00 AM
PMED-0943	Hallway	1051	Corridor Near Gymnasium (1044)	WC	5/30/2024	6:03:00 AM
PMED-0944	Hallway	1051	Corridor Near Gymnasium (1044)	WF	5/30/2024	6:03:00 AM
PMED-0952	Custodial Closet	1050B2	Boys Locker Room Custodial Closet	SP	5/30/2024	6:05:00 AM
PMED-0960	Hallway	1056	Corridor Near Art Room 110 (1055)	WF	5/30/2024	6:07:00 AM
PMED-0972	Nurse Office	1019	Nurse's Office	NS	5/30/2024	6:10:00 AM
PMED-0981	Office	1026K	Office Across from Safe	KC	5/30/2024	6:15:00 AM
PMED-0994	Hallway	1040	Corridor Near Room 114 (1034)	WC	5/30/2024	6:17:00 AM
PMED-0995	Hallway	1040	Corridor Near Room 114 (1034)	WF	5/30/2024	6:17:00 AM
PMED-1009	Kitchen	1063	Kitchen	KC	5/30/2024	5:57:00 AM
PMED-1016	Kitchen	1063	Kitchen	KC	5/30/2024	5:56:00 AM
PMED-1017	Kitchen	1063	Kitchen	KC	5/30/2024	5:56:00 AM
PMED-1024	Faculty Lounge	1087C	Plant & Facilities Faculty Room	KC	5/30/2024	5:46:00 AM
PMED-1027	Hallway	1095	Corridor Near Bathroom (1093)	WC	5/30/2024	5:48:00 AM

RECEIVED  
ENSL ANALYTICAL, INC.  
31 P 1:13


**Building Address**  
121 Saxton Street  
Patchogue, NY 11772

**Analysis Type:** ELAP 200.5  
**Lab Received:** Crack  
**Signature:** [Signature]

**Samplers Name:** Luke Coulter  
**Samplers Signature:** [Signature]  
**JCB Project Manager:** Meghan Gwynn



EC53571



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 24-57728  
Building: Saxton Middle School  
SMS

Client: Patchogue-Medford Union Free School District

Retest/New Install [ ]  
Turn Around: Normal 1 wk Rush

Handwritten notes: No 200-3, Patches, 6/14/24

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-1028	Hallway	1095	Corridor Near Bathroom (1093)	WF	5/30/2024	5:48:00 AM
PMED-1036	Faculty Lounge	3003	Faculty Room	KC	5/30/2024	6:25:00 AM
PMED-1037	Special	0007	Maintenance Area	WC	5/30/2024	5:36:00 AM
PMED-1038	Special	0007	Maintenance Area	WF	5/30/2024	5:36:00 AM
PMED-1045	Faculty Lounge	1077	Faculty Room	KC	5/30/2024	5:51:00 AM
PMED-1048	Office	1078	ENL Room	KC	5/30/2024	5:50:00 AM
PMED-3044	HA	2032	Corridor From Storage 7 To Room 211	WC	5/30/2024	5:41:00 AM
PMED-3045	HA	2015	Corridor Between Room 200 & Room 206	WC	5/30/2024	5:40:00 AM
PMED-3046	HA	2015	Corridor Between Room 200 & Room 206	WF	5/30/2024	5:40:00 AM
PMED-3050	HA	1056	Corridor Between Room 109 & 110	WC	5/30/2024	6:07:00 AM
PMED-3052	HA	1081	Main Lobby	WC	5/30/2024	6:13:00 AM
PMED-3053	HA	1081	Main Lobby	WF	5/30/2024	6:13:00 AM
PMED-3058	CA	1062	Cafeteria North	WC	5/30/2024	5:59:00 AM
PMED-3059	CA	1062	Cafeteria North	WF	5/30/2024	5:59:00 AM
PMED-3060	CA	1066	Cafeteria South	WC	5/30/2024	5:53:00 AM
PMED-3061	CA	1066	Cafeteria South	WF	5/30/2024	5:53:00 AM

RECEIVED  
EHS ANALYTICAL INC.  
5/30/2024 1:10 PM

**Building Address**  
121 Saxton Street  
Patchogue, NY 11772

Analysis Type: **ELAP 200.5**  
Lab Recieved: [Signature]  
Signature: [Signature]

Samplers Name: Luke Cuyler  
Samplers Signature: [Signature]  
JCB Project Manager: Meghan Cuyler

EC 53571



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

**JCB #:** 24-57728  
**Building:** Saxton Middle School  
SMS

**Client:** Patchogue-Medford Union Free School District  
**Retest/New Install** [ ]  
**Turn Around:** Normal 1 wk ~~Rush~~

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
-----------	-----------------------	----------	------------------	-------------	-------------	-------------

Samples Submitted 34

Pl 200-8  
Walker  
Chavez

RECEIVED  
EHSL ANALYTICAL, INC.  
CARLEPLACE, NY  
2024 MAY 31 P 1:43

**Building Address**  
121 Saxton Street  
Patchogue, NY 11772

**Analysis Type:** ELAP 200.5  
**Lab Recieved:** Waele  
**Signature:** [Signature]

**Samplers Name:** Luke Coulter  
**Samplers Signature:** [Signature]  
**JCB Project Manager:** Meghan Cuyom



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453571  
**LIMS Reference ID:** EC53571  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #24-57728, Saxton Middle School,  
 Patchogue-Medford Union Free School District,  
 121 Saxton Street, Patchogue, NY 11772

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 13:43  
**Reported:** 06/27/2024 10:16

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-0895 Lims Reference ID: EC53571-01 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	4.7		1	1.0	µg/L	06/11/24 21:00	06/11/24 21:00	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0896 Lims Reference ID: EC53571-02 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 13:30	06/14/24 13:30	BA	EPA 200.8 (Dig)/EPA 200.8
Sample: PMED-0897 Lims Reference ID: EC53571-03 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 13:34	06/14/24 13:34	BA	EPA 200.8 (Dig)/EPA 200.8
Sample: PMED-0921 Lims Reference ID: EC53571-04 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 21:01	06/11/24 21:01	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0937 Lims Reference ID: EC53571-05 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	45.9		1	1.0	µg/L	06/11/24 21:02	06/11/24 21:02	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0943 Lims Reference ID: EC53571-06 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 21:04	06/11/24 21:04	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0944 Lims Reference ID: EC53571-07 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 21:05	06/11/24 21:05	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0952 Lims Reference ID: EC53571-08 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	7.2		1	1.0	µg/L	06/11/24 21:09	06/11/24 21:09	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0960 Lims Reference ID: EC53571-09 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 21:10	06/11/24 21:10	BA	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453571  
**LIMS Reference ID:** EC53571  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #24-57728, Saxton Middle School,  
 Patchogue-Medford Union Free School District,  
 121 Saxton Street, Patchogue, NY 11772

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 13:43  
**Reported:** 06/27/2024 10:16

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-0972 Lims Reference ID: EC53571-10 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	2.0		1	1.0	µg/L	06/11/24 21:14	06/11/24 21:14	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0981 Lims Reference ID: EC53571-11 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	7.5		1	1.0	µg/L	06/11/24 21:15	06/11/24 21:15	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0994 Lims Reference ID: EC53571-12 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 21:17	06/11/24 21:17	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-0995 Lims Reference ID: EC53571-13 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/11/24 21:18	06/11/24 21:18	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1009 Lims Reference ID: EC53571-14 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	7.6		1	1.0	µg/L	06/13/24 18:34	06/13/24 18:34	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1016 Lims Reference ID: EC53571-15 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	1.8		1	1.0	µg/L	06/11/24 21:21	06/11/24 21:21	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1017 Lims Reference ID: EC53571-16 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	1.1		1	1.0	µg/L	06/11/24 21:22	06/11/24 21:22	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1024 Lims Reference ID: EC53571-17 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	28.1		1	1.0	µg/L	06/12/24 18:00	06/12/24 18:00	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1027 Lims Reference ID: EC53571-18 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/12/24 18:04	06/12/24 18:04	BA	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453571  
**LIMS Reference ID:** EC53571  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** #24-57728, Saxton Middle School,  
Patchogue-Medford Union Free School District,  
121 Saxton Street, Patchogue, NY 11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 13:43  
**Reported:** 06/27/2024 10:16

**Analytical Results**  
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-1028 Lims Reference ID: EC53571-19 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/12/24 18:05	06/12/24 18:05	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1036 Lims Reference ID: EC53571-20 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	6.3		1	1.0	µg/L	06/12/24 18:07	06/12/24 18:07	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1037 Lims Reference ID: EC53571-21 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/12/24 18:08	06/12/24 18:08	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1038 Lims Reference ID: EC53571-22 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/12/24 18:13	06/12/24 18:13	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1045 Lims Reference ID: EC53571-23 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	3.7		1	1.0	µg/L	06/12/24 18:14	06/12/24 18:14	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1048 Lims Reference ID: EC53571-24 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	2.0		1	1.0	µg/L	06/14/24 13:36	06/14/24 13:36	BA	EPA 200.8 (Dig)/EPA 200.8
Sample: PMED-3044 Lims Reference ID: EC53571-25 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/12/24 18:15	06/12/24 18:15	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-3045 Lims Reference ID: EC53571-26 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/12/24 18:17	06/12/24 18:17	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-3046 Lims Reference ID: EC53571-27 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/12/24 18:18	06/12/24 18:18	BA	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453571  
**LIMS Reference ID:** EC53571  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #24-57728, Saxton Middle School,  
 Patchogue-Medford Union Free School District,  
 121 Saxton Street, Patchogue, NY 11772

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 13:43  
**Reported:** 06/27/2024 10:16

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-3050 Lims Reference ID: EC53571-28 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/12/24 18:20	06/12/24 18:20	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-3052 Lims Reference ID: EC53571-29 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/12/24 18:24	06/12/24 18:24	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-3053 Lims Reference ID: EC53571-30 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/12/24 18:26	06/12/24 18:26	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-3058 Lims Reference ID: EC53571-31 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/12/24 18:30	06/12/24 18:30	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-3059 Lims Reference ID: EC53571-32 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/12/24 18:31	06/12/24 18:31	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-3060 Lims Reference ID: EC53571-33 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/12/24 18:33	06/12/24 18:33	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-3061 Lims Reference ID: EC53571-34 Matrix: Drinking Water Sampled: 05/30/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/14/24 21:02	06/14/24 21:02	BA	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453571  
**LIMS Reference ID:** EC53571  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** #24-57728, Saxton Middle School,  
Patchogue-Medford Union Free School District,  
121 Saxton Street, Patchogue, NY 11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 13:43  
**Reported:** 06/27/2024 10:16

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	09/01/2024

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453571  
**LIMS Reference ID:** EC53571  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** #24-57728, Saxton Middle School,  
Patchogue-Medford Union Free School District,  
121 Saxton Street, Patchogue, NY 11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 13:43  
**Reported:** 06/27/2024 10:16


**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. All results for soil samples are reported on a dry weight basis, unless otherwise noted.



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

EC 54750

JCB #: 24-57728  
Building: Saxton Middle School  
SMS

Client: Patchogue-Medford Union Free School District  
(Retest/New Install)   
Turn Around: Normal 1 wk Rush \_\_\_\_\_

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-0937	Custodial Closet	1045B1	Girls Locker Room Custodial Closet	SP	7/12/2024	12:28:00 PM
PMED-0952	Custodial Closet	1050B2	Boys Locker Room Custodial Closet	SP	7/12/2024	12:29:00 PM
PMED-0984	Office	1026K	Office Across from Safe	KC	7/12/2024	12:31:00 PM

Samples Submitted 3

*Handwritten notes:*  
1026K  
7/20/24  
7/20/24

RECEIVED  
EHSL ANALYTICAL, INC.  
CARLE PLACE, NY  
2024 JUL 15 P 6:25

**Building Address**  
121 Saxton Street  
Patchogue, NY 11772

Analysis Type: ELAP 200.5

Lab Received: *[Signature]*

Signature: *[Signature]*

Samplers Name: Meghan Gwynn

Samplers Signature: *[Signature]*

JCB Project Manager: M. Gwynn



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062454750  
**LIMS Reference ID:** EC54750  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** JCB#: 24-57728, Saxton Middle School,  
Patchogue-Medford Union Free School District,  
121 Saxton Street, Patchogue, NY 11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 07/15/2024 18:25  
**Reported:** 07/22/2024 13:49

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
<b>Sample: PMED-0937</b>		<b>Lims Reference ID: EC54750-01</b>		<b>Matrix: Drinking Water</b>		<b>Sampled: 07/12/24 00:00:00</b>			
<b>Metals</b>									
Lead	3.2	1	1.0	µg/L	07/20/24 13:08	07/20/24 13:08	JH	EPA 200.8 (DA)/EPA 200.8	
<b>Sample: PMED-0952</b>		<b>Lims Reference ID: EC54750-02</b>		<b>Matrix: Drinking Water</b>		<b>Sampled: 07/12/24 00:00:00</b>			
<b>Metals</b>									
Lead	12.0	1	1.0	µg/L	07/20/24 13:10	07/20/24 13:10	JH	EPA 200.8 (DA)/EPA 200.8	
<b>Sample: PMED-0981</b>		<b>Lims Reference ID: EC54750-03</b>		<b>Matrix: Drinking Water</b>		<b>Sampled: 07/12/24 00:00:00</b>			
<b>Metals</b>									
Lead	3.1	1	1.0	µg/L	07/20/24 13:11	07/20/24 13:11	JH	EPA 200.8 (DA)/EPA 200.8	





**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062454750  
**LIMS Reference ID:** EC54750  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** JCB#: 24-57728, Saxton Middle School,  
Patchogue-Medford Union Free School District,  
121 Saxton Street, Patchogue, NY 11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 07/15/2024 18:25  
**Reported:** 07/22/2024 13:49

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	09/01/2024

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062454750  
**LIMS Reference ID:** EC54750  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** JCB#: 24-57728, Saxton Middle School,  
Patchogue-Medford Union Free School District,  
121 Saxton Street, Patchogue, NY 11772  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 07/15/2024 18:25  
**Reported:** 07/22/2024 13:49


**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. All results for soil samples are reported on a dry weight basis, unless otherwise noted.



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

# EC 5355A

**JCB #:** 24-57728  
**Building:** Oregon Middle School  
OMS

**Client:** Patchogue-Medford Union Free School District  
**Retest/New Install**   
**Turn Around:** Normal 1 wk Rush \_\_\_\_\_

P 200.8  
Pulley  
6/18/24


Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-1065	Hallway	1006	Corridor Near Band Room (4000)	WC	5/31/2024	6:07:00 AM
PMED-1066	Hallway	1006	Corridor Near Band Room (4000)	WF	5/31/2024	6:07:00 AM
PMED-1074	Faculty Lounge	1009	Faculty Room	KC	5/31/2024	6:09:00 AM
PMED-1077	Kitchen	1011	Kitchen	KC	5/31/2024	6:01:00 AM
PMED-1078	Kitchen	1011	Kitchen	KC	5/31/2024	6:02:00 AM
PMED-1079	Kitchen	1011	Kitchen	KC	5/31/2024	6:04:00 AM
PMED-1080	Kitchen	1011	Kitchen	KC	5/31/2024	6:04:00 AM
PMED-1107	Home Economics	1041	Home Economics Room 110	EC	5/31/2024	6:24:00 AM
PMED-1108	Nurse Office	1043	Nurse's Office	NS	5/31/2024	6:26:00 AM
PMED-1109	Nurse Office	1043	Nurse's Office	NS	5/31/2024	6:26:00 AM
PMED-1125	Hallway	4002	Boys Locker Room Vestibule	WC	5/31/2024	6:33:00 AM
PMED-1126	Hallway	4002	Boys Locker Room Vestibule	WF	5/31/2024	6:33:00 AM
PMED-1127	Hallway	4006	Girls Locker Room Vestibule	WC	5/31/2024	6:35:00 AM
PMED-1128	Hallway	4006	Girls Locker Room Vestibule	WF	5/31/2024	6:35:00 AM
PMED-1144	Hallway	1068	Corridor Near Book Storage B (1048)	WC	5/31/2024	6:37:00 AM
PMED-1145	Hallway	1068	Corridor Near Book Storage B (1048)	WF	5/31/2024	6:37:00 AM
PMED-1147	Hallway	1068	Corridor Near Room 118 (1057)	DW	5/31/2024	6:42:00 AM
PMED-1148	Hallway	1059	Corridor Near Room 125 (4008)	WC	5/31/2024	6:44:00 AM


RECEIVED  
ELAP  
MAY 31 2024  
NY

**Building Address**  
109 Oregon Avenue  
Medford, NY 11763

**Analysis Type:** ELAP 200.5  
**Lab Received:** 5-31-24 12:22PM  
**Signature:** *[Handwritten Signature]*

**Samplers Name:** Aileen McNamee  
**Samplers Signature:** *[Handwritten Signature]*  
**JCB Project Manager:** Meghan Gwynn





# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 24-57728  
Building: Oregon Middle School  
OMS

# IC 53554

Client: Patchogue-Medford Union Free School District

Retest/New Install   
Turn Around: Normal 1 wk Rush \_\_\_\_\_

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-1149	Hallway	1059	Corridor Near Room 125 (4008)	WF	5/31/2024	6:45:00 AM
PMED-1933	FL	1009	Faculty Room	WC	5/31/2024	6:10:00 AM
PMED-1934	FL	1009	Faculty Room	WF	5/31/2024	6:10:00 AM
PMED-1935	FL	1016A1	Main Office Storage Room	BW	5/31/2024	6:16:00 AM
PMED-1936	FL	1016A1	Main Office Storage Room	BW	5/31/2024	6:17:00 AM
PMED-1937	HA	1033	Corridor Between Room 100 And Main Office	WC	5/31/2024	6:20:00 AM
PMED-1938	HA	1033	Corridor Between Room 100 And Main Office	WF	5/31/2024	6:20:00 AM
PMED-1949	HA	2023	Corridor Between Library & Room 215	WC	5/31/2024	6:49:00 AM
PMED-1950	HA	2023	Corridor Between Library & Room 215	WF	5/31/2024	6:49:00 AM

Samples Submitted 27

Pl 200.8  
6/18/24

RECEIVED  
EHSL ANALYTICAL, INC.  
CARLE PLACE, NY  
2024 MAY 31 P 12: 22

**Building Address**  
109 Oregon Avenue  
Medford, NY 11763

**Analysis Type:** ELAP 200.5

**Lab Received:** 5/31/24 12:02 PM

**Signature:** *[Signature]*

**Sampler's Name:** Aileen McNamee

**Sampler's Signature:** *[Signature]*

**JCB Project Manager:** Meghan Gwynn

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453554  
**LIMS Reference ID:** EC53554  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #: 24-57728, Oregon Middle School,  
 Patchogue-Medford Union Free School District,  
 109 Oregon Avenue, Medford, NY 11763

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 12:22  
**Reported:** 06/27/2024 09:01

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-1065 Lims Reference ID: EC53554-01 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 13:03	06/15/24 13:03	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1066 Lims Reference ID: EC53554-02 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/15/24 13:04	06/15/24 13:04	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1074 Lims Reference ID: EC53554-03 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	3.1		1	1.0	µg/L	06/15/24 13:05	06/15/24 13:05	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1077 Lims Reference ID: EC53554-04 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	1.9		1	1.0	µg/L	06/15/24 13:07	06/15/24 13:07	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1078 Lims Reference ID: EC53554-05 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	6.4		1	1.0	µg/L	06/15/24 13:08	06/15/24 13:08	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1079 Lims Reference ID: EC53554-06 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	5.6		1	1.0	µg/L	06/15/24 13:10	06/15/24 13:10	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1080 Lims Reference ID: EC53554-07 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	2.1		1	1.0	µg/L	06/15/24 13:11	06/15/24 13:11	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1107 Lims Reference ID: EC53554-08 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	1.7		1	1.0	µg/L	06/15/24 13:15	06/15/24 13:15	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1108 Lims Reference ID: EC53554-09 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	2.4		1	1.0	µg/L	06/15/24 13:17	06/15/24 13:17	BA	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453554  
**LIMS Reference ID:** EC53554  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #: 24-57728, Oregon Middle School,  
 Patchogue-Medford Union Free School District,  
 109 Oregon Avenue, Medford, NY 11763

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 12:22  
**Reported:** 06/27/2024 09:01

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-1109 Lims Reference ID: EC53554-10 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	3.1		1	1.0	µg/L	06/19/24 17:40	06/19/24 17:40	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1125 Lims Reference ID: EC53554-11 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 17:44	06/19/24 17:44	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1126 Lims Reference ID: EC53554-12 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 17:45	06/19/24 17:45	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1127 Lims Reference ID: EC53554-13 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 17:47	06/19/24 17:47	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1128 Lims Reference ID: EC53554-14 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 17:48	06/19/24 17:48	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1144 Lims Reference ID: EC53554-15 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 17:53	06/19/24 17:53	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1145 Lims Reference ID: EC53554-16 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 17:54	06/19/24 17:54	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1147 Lims Reference ID: EC53554-17 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	36.7		1	1.0	µg/L	06/19/24 17:55	06/19/24 17:55	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1148 Lims Reference ID: EC53554-18 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 17:57	06/19/24 17:57	BA	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453554  
**LIMS Reference ID:** EC53554  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #: 24-57728, Oregon Middle School,  
 Patchogue-Medford Union Free School District,  
 109 Oregon Avenue, Medford, NY 11763

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 12:22  
**Reported:** 06/27/2024 09:01

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-1149 Lims Reference ID: EC53554-19 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 17:58	06/19/24 17:58	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1933 Lims Reference ID: EC53554-20 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 18:00	06/19/24 18:00	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1934 Lims Reference ID: EC53554-21 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 18:04	06/19/24 18:04	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1935 Lims Reference ID: EC53554-22 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 18:06	06/19/24 18:06	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1936 Lims Reference ID: EC53554-23 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 18:10	06/19/24 18:10	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1937 Lims Reference ID: EC53554-24 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 18:11	06/19/24 18:11	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1938 Lims Reference ID: EC53554-25 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 18:13	06/19/24 18:13	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1949 Lims Reference ID: EC53554-26 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 18:14	06/19/24 18:14	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1950 Lims Reference ID: EC53554-27 Matrix: Drinking Water Sampled: 05/31/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 18:16	06/19/24 18:16	BA	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453554  
**LIMS Reference ID:** EC53554  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** #: 24-57728, Oregon Middle School,  
Patchogue-Medford Union Free School District,  
109 Oregon Avenue, Medford, NY 11763  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 12:22  
**Reported:** 06/27/2024 09:01

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	09/01/2024

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.





**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453554  
**LIMS Reference ID:** EC53554  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** #: 24-57728, Oregon Middle School,  
Patchogue-Medford Union Free School District,  
109 Oregon Avenue, Medford, NY 11763  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 12:22  
**Reported:** 06/27/2024 09:01


**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. All results for soil samples are reported on a dry weight basis, unless otherwise noted.



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 24-57728  
Building: Oregon Middle School  
OMS

EC 54747

Client: Patchogue-Medford Union Free School District  
(Retest/New Install)   
Turn Around: Normal 1 wk Rush \_\_\_\_\_

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-1078	Kitchen	1011	Kitchen	KC	7/12/2024	12:03:00 PM

Samples Submitted 1

Handwritten notes: 02-8, JCB, 7/12/24

RECEIVED  
EMSL ANALYTICAL, INC.  
CARLE PLACE, NY  
2024 JUL 15 P 6:25

**Building Address**  
109 Oregon Avenue  
Medford, NY 11763

Analysis Type: ELAP 200.5

Lab Received: [Signature]

Signature: [Signature]

Sampler's Name: Maghan Gwynn

Sampler's Signature: [Signature]

JCB Project Manager: M. Gwynn





**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062454747  
**LIMS Reference ID:** EC54747  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** JCB#: 24-57728, Oregon Middle School,  
Patchogue-Medford Union Free School District,  
109 Oregon Avenue, Medford, NY 11763  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 07/15/2024 18:25  
**Reported:** 07/22/2024 13:46

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	09/01/2024

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062454747  
**LIMS Reference ID:** EC54747  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** JCB#: 24-57728, Oregon Middle School,  
Patchogue-Medford Union Free School District,  
109 Oregon Avenue, Medford, NY 11763  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 07/15/2024 18:25  
**Reported:** 07/22/2024 13:46

**Notes and Definitions**


<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. All results for soil samples are reported on a dry weight basis, unless otherwise noted.

**\$C 53561**



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

**JCB #:** 24-57728  
**Building:** Patchogue-Medford High School  
PHS

**Client:** Patchogue-Medford Union Free School District

**Retest/New Install** [ ]  
**Turn Around:** Normal 1 wk Rush \_\_\_\_\_

Pl 200-8  
B/S  
6/18/24


Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-1205	Cafeteria	1012	Cafeteria	WC	5/22/2024	5:50:00 AM
PMED-1206	Cafeteria	1012	Cafeteria	WF	5/22/2024	5:50:00 AM
PMED-1208	Kitchen	1012C1	Kitchen	KC	5/22/2024	5:40:00 AM
PMED-1209	Kitchen	1012C1	Kitchen	KC	5/22/2024	5:40:00 AM
PMED-1217	Kitchen	1012C1	Kitchen	KC	5/22/2024	5:41:00 AM
PMED-1218	Kitchen	1012C1	Kitchen	KC	5/22/2024	5:41:00 AM
PMED-1220	Kitchen	1012C1	Kitchen	WC	5/22/2024	5:43:00 AM
PMED-1223	Kitchen	1012C1	Kitchen	KC	5/22/2024	5:45:00 AM
PMED-1242	Faculty Lounge	3004F	Security Suite Faculty Room	KC	5/22/2024	5:55:00 AM
PMED-1252	Hallway	3009	Corridor Near Room 163 (3015)	WC	5/22/2024	5:57:00 AM
PMED-1253	Hallway	3009	Corridor Near Room 163 (3015)	WF	5/22/2024	5:57:00 AM
PMED-1337	Hallway	3030	Corridor Near Room 175 (3024)	WC	5/22/2024	5:56:00 AM
PMED-1338	Hallway	4046	Corridor Near East Stairwell	WF	5/22/2024	5:56:00 AM
PMED-1355	Office	3044	Trainer's Office	IM	5/22/2024	6:00:00 AM
PMED-1394	Special	1078	Robotics Room 143	DW	5/22/2024	6:04:00 AM
PMED-1419	Home Economics	1095	Home Economics Room 134	EC	5/22/2024	6:10:00 AM
PMED-1420	Home Economics	1095	Home Economics Room 134	EC	5/22/2024	6:11:00 AM
PMED-1516	Hallway	1040	Corridor Near Room 121 (1034)	WC	5/22/2024	6:35:00 AM


RECEIVED  
ESL N.Y.C. DISTRICT  
C.L. PL  
2024 MAY 31 P 12:08

**Building Address**  
181 Buffalo Avenue  
Medford, NY 11763

**Analysis Type:** ELAP 200.5  
**Lab Received:** 5-31-24 12:08 PM  
**Signature:** *[Handwritten Signature]*

**Samplers Name:** Luke Coulter  
**Samplers Signature:** *[Handwritten Signature]*  
**JCB Project Manager:** Meghan Gwynn





# Lead in Water: Chain of Custody for

# EC 53561

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

24-57728

Building:

Patchogue-Medford High School

Client:

Patchogue-Medford Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush \_\_\_\_\_

PHS

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-1517	Hallway	1040	Corridor Near Room 121 (1034)	WF	5/22/2024	6:35:00 AM
PMED-1526	Office	1048A2	Main Office Interior Office	KC	5/22/2024	6:40:00 AM
PMED-1530	Nurse Office	1050	Nurse's Office (L-Z)	NS	5/22/2024	5:35:00 AM
PMED-1532	Nurse Office	1051	Nurse's Office (A-K)	NS	5/22/2024	5:35:00 AM
PMED-1562	Hallway	1065	Corridor Near Auditorium (1058)	WF	5/22/2024	6:36:00 AM
PMED-1563	Office	3058A	M1 Office	WC	5/31/2024	6:20:00 AM
PMED-1564	Office	3058A	M1 Office	WF	5/31/2024	6:20:00 AM
PMED-1567	Classroom	3059	Classroom M2	WC	5/31/2024	6:22:00 AM
PMED-1570	Classroom	3060	Classroom M3	WC	5/31/2024	6:24:00 AM
PMED-1572	Classroom	3060	Classroom M5	WC	5/31/2024	6:26:00 AM
PMED-1581	Hallway	4046	Corridor Near East Stairwell	WC	5/22/2024	6:45:00 AM
PMED-1675	Faculty Lounge	2060	Faculty Room 200	KC	5/31/2024	6:03:00 AM
PMED-1677	Kitchen	2045A	Library Office Kitchen	KC	5/31/2024	5:59:00 AM
PMED-1700	Hallway	5039	Corridor Near East Stairwell	WC	5/31/2024	6:07:00 AM
PMED-1701	Hallway	5039	Corridor Near East Stairwell	WF	5/31/2024	6:07:00 AM
PMED-1703	Hallway	5039	Corridor Near West Stairwell	WC	5/31/2024	6:10:00 AM
PMED-1704	Hallway	5039	Corridor Near West Stairwell	WF	5/31/2024	6:10:00 AM
PMED-1773	CR	1005	Room 104 School Store	BW	5/31/2024	5:50:00 AM

Pls 2008 follow 6/18/24

RECEIVED  
PHS ANALYTICAL INC.  
MAY 21 11 00 AM '24

### Building Address

181 Buffalo Avenue  
Medford, NY 11763

Analysis Type: ELAP 200.5

Lab Received:

5-31-24 12:08 PM

Signature:

*[Handwritten Signature]*

Samplers Name:


Luke Coulter

Samplers Signature:

*[Handwritten Signature]*

JCB Project Manager:

Meghan Brynn



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 24-57728  
Building: Patchogue-Medford High School  
PHS

# EC 53561

Client: Patchogue-Medford Union Free School District

Retest/New Install   
Turn Around: Normal 1 wk Rush \_\_\_\_\_

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-1774	CR	1005	Room 104 School Store	BW	5/31/2024	5:50:00 AM
PMED-1775	CR	1005	Room 104 School Store	BW	5/31/2024	5:51:00 AM
PMED-1776	CR	1005	Room 104 School Store	BW	5/31/2024	5:52:00 AM
PMED-1780	KI	1012C1	Kitchen	WF	5/22/2024	5:43:00 AM
PMED-1783	SP	1012C1G	Kitchen Compressor Room	IM	5/22/2024	5:49:00 AM
PMED-1791	HA		Corridor Near Room 175	WF	5/22/2024	6:15:00 AM
PMED-1797	HA		Corridor Near Team Locker Room #1	WC	5/22/2024	6:18:00 AM
PMED-1798	HA		Corridor Near Team Locker Room #1	WF	5/22/2024	6:18:00 AM
PMED-1823	LR	1099	Girls Locker Room	WC	5/22/2024	6:21:00 AM
PMED-1824	LR	1099	Girls Locker Room	WF	5/22/2024	6:21:00 AM
PMED-1827	Classroom	1094	Room 135	IM	5/22/2024	6:24:00 AM
PMED-1828	Classroom	1094	Room 135	KC	5/22/2024	6:26:00 AM
PMED-1835	LR	1100	Boys Locker Room Vestibule	WC	5/22/2024	6:30:00 AM
PMED-1836	LR	1100	Boys Locker Room Vestibule	WF	5/22/2024	6:30:00 AM
PMED-1842	HA	1065	Corridor From 154-132B	WC	5/22/2024	6:28:00 AM
PMED-1859	HA	4046	Corridor Near West Stairwell	WC	5/31/2024	6:12:00 AM
PMED-1860	HA	4046	Corridor Near West Stairwell	WF	5/31/2024	6:10:00 AM
PMED-1876	HA	2040	Corridor Between Rooms 213 & 233	WC	5/31/2024	6:14:00 AM

16 200-8  
Baker  
6/18/24


RECEIVED  
EISL ANALYTICAL INC.  
MAY 22 12:21 PM '24

**Building Address**  
181 Buffalo Avenue  
Medford, NY 11763

**Analysis Type:** ELAP 200.5  
**Lab Received:** 5-31-24 12:08 PM  
**Signature:** *[Signature]*

**Samplers Name:** Luke Caulter  
**Samplers Signature:** *[Signature]*  
**JCB Project Manager:** Meghan Gwynn





# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

**JCB #:** 24-57728  
**Building:** Patchogue-Medford High School  
PHS

# EC 53561

**Client:** Patchogue-Medford Union Free School District

Retest/New Install [ ]  
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
PMED-1877	HA	2040	Corridor Between Rooms 213 & 233	WF	5/31/2024	6:14:00 AM

Samples Submitted 55

Pl 2008 Buffalo 6/18/24

RECEIVED  
EHSL ANALYTICAL, INC.  
CARLE PLACE, NY  
2024 MAY 31 P 12:08

**Building Address**  
181 Buffalo Avenue  
Medford, NY 11763

**Analysis Type:** ELAP 200.5

**Lab Received:** 5-31-24 12:08 PM

**Signature:** *[Handwritten Signature]*

**Samplers Name:** Luke Coulter

**Samplers Signature:** *[Handwritten Signature]*

**JCB Project Manager:** Meghan Anyon

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453561  
**LIMS Reference ID:** EC53561  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #24-57728, Patchogue-Medford High School,  
 Patchogue-Medford Union Free School District,  
 181 Buffalo Avenue, Medford, NY 11763

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 12:08  
**Reported:** 06/27/2024 09:25

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-1205 Lims Reference ID: EC53561-01 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 15:51	06/19/24 15:51	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1206 Lims Reference ID: EC53561-02 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 15:52	06/19/24 15:52	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1208 Lims Reference ID: EC53561-03 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 15:54	06/19/24 15:54	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1209 Lims Reference ID: EC53561-04 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	3.0		1	1.0	µg/L	06/19/24 15:58	06/19/24 15:58	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1217 Lims Reference ID: EC53561-05 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	1.1		1	1.0	µg/L	06/19/24 16:02	06/19/24 16:02	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1218 Lims Reference ID: EC53561-06 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	2.2		1	1.0	µg/L	06/19/24 16:04	06/19/24 16:04	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1220 Lims Reference ID: EC53561-07 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 16:05	06/19/24 16:05	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1223 Lims Reference ID: EC53561-08 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	3.9		1	1.0	µg/L	06/19/24 16:06	06/19/24 16:06	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1242 Lims Reference ID: EC53561-09 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 16:08	06/19/24 16:08	BA	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453561  
**LIMS Reference ID:** EC53561  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #24-57728, Patchogue-Medford High School,  
 Patchogue-Medford Union Free School District,  
 181 Buffalo Avenue, Medford, NY 11763

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 12:08  
**Reported:** 06/27/2024 09:25

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-1252 Lims Reference ID: EC53561-10 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 16:09	06/19/24 16:09	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1253 Lims Reference ID: EC53561-11 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 16:11	06/19/24 16:11	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1337 Lims Reference ID: EC53561-12 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/19/24 16:12	06/19/24 16:12	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1338 Lims Reference ID: EC53561-13 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 13:18	06/18/24 13:18	BP	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1355 Lims Reference ID: EC53561-14 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	1.1		1	1.0	µg/L	06/18/24 13:22	06/18/24 13:22	BP	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1394 Lims Reference ID: EC53561-15 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	2.0		1	1.0	µg/L	06/18/24 13:24	06/18/24 13:24	BP	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1419 Lims Reference ID: EC53561-16 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	3.1		1	1.0	µg/L	06/18/24 13:25	06/18/24 13:25	BP	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1420 Lims Reference ID: EC53561-17 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	4.0		1	1.0	µg/L	06/18/24 13:26	06/18/24 13:26	BP	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1516 Lims Reference ID: EC53561-18 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 13:30	06/18/24 13:30	BP	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453561  
**LIMS Reference ID:** EC53561  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #24-57728, Patchogue-Medford High School,  
 Patchogue-Medford Union Free School District,  
 181 Buffalo Avenue, Medford, NY 11763

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 12:08  
**Reported:** 06/27/2024 09:25

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-1517 Lims Reference ID: EC53561-19 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 13:32	06/18/24 13:32	BP	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1526 Lims Reference ID: EC53561-20 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	1.0		1	1.0	µg/L	06/18/24 13:33	06/18/24 13:33	BP	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1530 Lims Reference ID: EC53561-21 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	3.7		1	1.0	µg/L	06/18/24 13:34	06/18/24 13:34	BP	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1532 Lims Reference ID: EC53561-22 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	1.9		1	1.0	µg/L	06/18/24 13:36	06/18/24 13:36	BP	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1562 Lims Reference ID: EC53561-23 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 13:37	06/18/24 13:37	BP	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1563 Lims Reference ID: EC53561-24 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 13:41	06/18/24 13:41	BP	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1564 Lims Reference ID: EC53561-25 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 12:38	06/18/24 12:38	BP	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1567 Lims Reference ID: EC53561-26 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 12:39	06/18/24 12:39	BP	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1570 Lims Reference ID: EC53561-27 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 12:41	06/18/24 12:41	BP	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453561  
**LIMS Reference ID:** EC53561  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #24-57728, Patchogue-Medford High School,  
 Patchogue-Medford Union Free School District,  
 181 Buffalo Avenue, Medford, NY 11763

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 12:08  
**Reported:** 06/27/2024 09:25

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-1572 Lims Reference ID: EC53561-28 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 12:45	06/18/24 12:45	BP	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1581 Lims Reference ID: EC53561-29 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 12:46	06/18/24 12:46	BP	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1675 Lims Reference ID: EC53561-30 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	1.5		1	1.0	µg/L	06/18/24 12:47	06/18/24 12:47	BP	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1677 Lims Reference ID: EC53561-31 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	2.1		1	1.0	µg/L	06/18/24 12:48	06/18/24 12:48	BP	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1700 Lims Reference ID: EC53561-32 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 12:50	06/18/24 12:50	BP	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1701 Lims Reference ID: EC53561-33 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 18:00	06/18/24 18:00	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1703 Lims Reference ID: EC53561-34 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 18:04	06/18/24 18:04	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1704 Lims Reference ID: EC53561-35 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 18:05	06/18/24 18:05	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1773 Lims Reference ID: EC53561-36 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 18:07	06/18/24 18:07	BA	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453561  
**LIMS Reference ID:** EC53561  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #24-57728, Patchogue-Medford High School,  
 Patchogue-Medford Union Free School District,  
 181 Buffalo Avenue, Medford, NY 11763

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 12:08  
**Reported:** 06/27/2024 09:25

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-1774 Lims Reference ID: EC53561-37 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 18:08	06/18/24 18:08	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1775 Lims Reference ID: EC53561-38 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 18:41	06/18/24 18:41	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1776 Lims Reference ID: EC53561-39 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 18:43	06/18/24 18:43	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1780 Lims Reference ID: EC53561-40 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 18:44	06/18/24 18:44	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1783 Lims Reference ID: EC53561-41 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	1.2		1	1.0	µg/L	06/18/24 18:45	06/18/24 18:45	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1791 Lims Reference ID: EC53561-42 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 18:47	06/18/24 18:47	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1797 Lims Reference ID: EC53561-43 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 18:48	06/18/24 18:48	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1798 Lims Reference ID: EC53561-44 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 18:52	06/18/24 18:52	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1823 Lims Reference ID: EC53561-45 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 18:53	06/18/24 18:53	BA	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453561  
**LIMS Reference ID:** EC53561  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #24-57728, Patchogue-Medford High School,  
 Patchogue-Medford Union Free School District,  
 181 Buffalo Avenue, Medford, NY 11763

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 12:08  
**Reported:** 06/27/2024 09:25

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: PMED-1824 Lims Reference ID: EC53561-46 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 19:10	06/18/24 19:10	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1827 Lims Reference ID: EC53561-47 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 19:12	06/18/24 19:12	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1828 Lims Reference ID: EC53561-48 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	1.8		1	1.0	µg/L	06/18/24 19:13	06/18/24 19:13	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1835 Lims Reference ID: EC53561-49 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 19:14	06/18/24 19:14	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1836 Lims Reference ID: EC53561-50 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 19:16	06/18/24 19:16	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1842 Lims Reference ID: EC53561-51 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 19:17	06/18/24 19:17	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1859 Lims Reference ID: EC53561-52 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 19:18	06/18/24 19:18	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1860 Lims Reference ID: EC53561-53 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/18/24 17:08	06/18/24 17:08	BA	EPA 200.8 (DA)/EPA 200.8
Sample: PMED-1876 Lims Reference ID: EC53561-54 Matrix: Drinking Water Sampled: 05/22/24 00:00:00									
<b>Metals</b>									
Lead	<1.0		1	1.0	µg/L	06/21/24 13:28	06/21/24 13:28	BP	EPA 200.8 (Dig)/EPA 200.8





**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062453561  
**LIMS Reference ID:** EC53561  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 mgwynn@jcbroderick.com

**Project Name:** #24-57728, Patchogue-Medford High School,  
 Patchogue-Medford Union Free School District,  
 181 Buffalo Avenue, Medford, NY 11763

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 12:08  
**Reported:** 06/27/2024 09:25

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	09/01/2024

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062453561  
**LIMS Reference ID:** EC53561  
**EMSL Customer ID:** JCBR50

**Attention:** Meghan Gwynn  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
mgwynn@jcbroderick.com

**Project Name:** #24-57728, Patchogue-Medford High School,  
Patchogue-Medford Union Free School District,  
181 Buffalo Avenue, Medford, NY 11763  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 05/31/2024 12:08  
**Reported:** 06/27/2024 09:25

**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.


Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. All results for soil samples are reported on a dry weight basis, unless otherwise noted.

# Attachment 4:

# Laboratory Certifications



**J.C. Broderick & Associates, Inc.**

*Environmental Consulting & Testing*

1775 Expressway Drive North

Hauppauge, New York 11788

631.584.5492 fax 631.584.3395

NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2025  
Issued April 01, 2024

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

*MR. DANIEL CLARKE  
EMSL ANALYTICAL, INC.  
528 MINEOLA AVE.  
CARLE PLACE, NY 11514*

*NY Lab Id No: 11469*

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2016) for the category  
ENVIRONMENTAL ANALYSES POTABLE WATER  
All approved analytes are listed below:*

**Bacteriology**

Coliform, Total / E. coli (Qualitative)	SM 21, 23 9222A,B,C SM 20, 21-23 9223B (-04) (Colilert)
E. coli (Enumeration)	SM 21, 23 9222A,B,C
Heterotrophic Plate Count	SM 20, 21-23 9215B (-04)

**Metals I**

Lead, Total	EPA 200.5 EPA 200.8 Rev. 5.4
-------------	---------------------------------

**Miscellaneous**

Asbestos	EPA 100.2
----------	-----------



**Serial No.: 68787**

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to [elap@health.ny.gov](mailto:elap@health.ny.gov).

