



Foster Plaza 8, Suite 400
730 Holiday Drive
Pittsburgh, PA 15220
412-503-4343

October 2, 2024

Dr. Brian White, Superintendent
Butler Area School District
110 Campus Lane
Butler, PA 16001

Subject: *Butler Area School District
Potable Water Lead Testing Results – Intermediate High School*

Dear Dr. White:

Gannett Fleming TranSystems is pleased to submit the lead testing results for resampling of drinking water fixtures at the Butler Area School District's Intermediate High School.

This facility receives potable water from the Pennsylvania American Water Company which is the public water supplier for the Butler area.

Sampling was conducted on August 20, 2024 at forty (40) locations at the Intermediate High School.

Sampling was conducted by Gannett Fleming TranSystems personnel following United States Environmental Protection Agency (USEPA) 3Ts guidance recommendations for conducting lead sampling in schools. Sampling locations were identified, and sampling was conducted using 250 mL samples. The original USEPA 3Ts guidance recommended that sampling locations showing more than 0.020 mg/L of lead in the sample be examined to determine the cause of the elevated result. Recent revisions to the 3Ts guidance do not specify a remediation level for lead; rather, USEPA encourages schools to prioritize remediation efforts based on the highest lead sample results and to use the steps in the 3Ts guidance to pinpoint potential lead sources to reduce their lead levels.

Of the forty (40) samples collected none exceeded the USEPA's suggested 0.020 mg/L Action Level for lead in 250 mL first draw samples.

Please find attached the laboratory reports for this testing.

Gannett Fleming TranSystems would like to thank the School District's administrative and maintenance staff for their assistance in completing this project. Please feel free to contact us if you have any questions or comments.

Sincerely,
GANNETT FLEMING TRANSYSTEMS

VITTORIA LAROSA
Water/Wastewater Designer

Attachments

cc: Les Zang, Butler Area School District
GFTS File



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A4H2103

Client Sample ID: Vault sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 9:14
Lab Sample ID: A4H2103-55	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00206	0.015	0.000400	mg/L		08/22/24 1556	08/22/24 1556	SEV

Client Sample ID: Lower Floor Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 9:15
Lab Sample ID: A4H2103-56	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1557	08/22/24 1557	SEV

Client Sample ID: Office Men Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:04
Lab Sample ID: A4H2103-57	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1558	08/22/24 1558	SEV

Client Sample ID: Office Women Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:08
Lab Sample ID: A4H2103-58	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1602	08/22/24 1602	SEV

Client Sample ID: Security Desk Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:02
Lab Sample ID: A4H2103-59	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1603	08/22/24 1603	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A4H2103

Client Sample ID: Nurses Sink 1	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:14
Lab Sample ID: A4H2103-60	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1604	08/22/24 1604	SEV

Client Sample ID: Aux Gum Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:00
Lab Sample ID: A4H2103-61	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1607	08/22/24 1607	SEV

Client Sample ID: Pool Left Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:46
Lab Sample ID: A4H2103-62	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1610	08/22/24 1610	SEV

Client Sample ID: Pool Right Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:47
Lab Sample ID: A4H2103-63	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000761	0.015	0.000400	mg/L		08/22/24 1614	08/22/24 1614	SEV

Client Sample ID: Weight Room Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 7:59
Lab Sample ID: A4H2103-64	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1615	08/22/24 1615	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A4H2103

Client Sample ID: Training Room Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 7:58
Lab Sample ID: A4H2103-65	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1615	08/22/24 1615	SEV

Client Sample ID: Training Room Ice	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 7:56
Lab Sample ID: A4H2103-66	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1616	08/22/24 1616	SEV

Client Sample ID: 141 men Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:07
Lab Sample ID: A4H2103-67	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000499	0.015	0.000400	mg/L		08/22/24 1617	08/22/24 1617	SEV

Client Sample ID: Cafe A Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 7:45
Lab Sample ID: A4H2103-68	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00398	0.015	0.000400	mg/L		08/22/24 1618	08/22/24 1618	SEV

Client Sample ID: Cafe A Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 7:47
Lab Sample ID: A4H2103-69	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1619	08/22/24 1619	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A4H2103

Client Sample ID: Cafe B Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 7:53
Lab Sample ID: A4H2103-70	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1623	08/22/24 1623	SEV

Client Sample ID: Cafe C Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:35
Lab Sample ID: A4H2103-71	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1624	08/22/24 1624	SEV

Client Sample ID: Cafe D Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:42
Lab Sample ID: A4H2103-72	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1629	08/22/24 1629	SEV

Client Sample ID: 140 Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 7:52
Lab Sample ID: A4H2103-73	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1630	08/22/24 1630	SEV

Client Sample ID: 126 Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 7:51
Lab Sample ID: A4H2103-74	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000431	0.015	0.000400	mg/L		08/22/24 1631	08/22/24 1631	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A4H2103

Client Sample ID: 124 Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 7:49
Lab Sample ID: A4H2103-75	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1632	08/22/24 1632	SEV

Client Sample ID: 108 Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:20
Lab Sample ID: A4H2103-76	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1633	08/22/24 1633	SEV

Client Sample ID: 103 Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:18
Lab Sample ID: A4H2103-77	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1634	08/22/24 1634	SEV

Client Sample ID: Lounge Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:11
Lab Sample ID: A4H2103-78	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00415	0.015	0.000400	mg/L		08/22/24 1635	08/22/24 1635	SEV

Client Sample ID: 207 Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:41
Lab Sample ID: A4H2103-79	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1636	08/22/24 1636	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A4H2103

Client Sample ID: English WRR Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:38
Lab Sample ID: A4H2103-80	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1637	08/22/24 1637	SEV

Client Sample ID: 246 Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:54
Lab Sample ID: A4H2103-81	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1643	08/22/24 1643	SEV

Client Sample ID: 243 Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:52
Lab Sample ID: A4H2103-82	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1646	08/22/24 1646	SEV

Client Sample ID: Rm 115 Sink 1	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:22
Lab Sample ID: A4H2103-83	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00116	0.015	0.000400	mg/L		08/22/24 1647	08/22/24 1647	SEV

Client Sample ID: Rm 115 Sink 2	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:23
Lab Sample ID: A4H2103-84	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00101	0.015	0.000400	mg/L		08/22/24 1648	08/22/24 1648	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A4H2103

Client Sample ID: Rm 115 Sink 3	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:24
Lab Sample ID: A4H2103-85	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00106	0.015	0.000400	mg/L		08/22/24 1649	08/22/24 1649	SEV

Client Sample ID: Rm 115 Sink 4	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:25
Lab Sample ID: A4H2103-86	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00165	0.015	0.000400	mg/L		08/22/24 1652	08/22/24 1652	SEV

Client Sample ID: Rm 115 Sink 5	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:27
Lab Sample ID: A4H2103-87	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000812	0.015	0.000400	mg/L		08/22/24 1653	08/22/24 1653	SEV

Client Sample ID: Rm 116 sink 1	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:28
Lab Sample ID: A4H2103-88	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00107	0.015	0.000400	mg/L		08/22/24 1654	08/22/24 1654	SEV

Client Sample ID: Rm 116 sink 2	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:29
Lab Sample ID: A4H2103-89	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000702	0.015	0.000400	mg/L		08/22/24 1655	08/22/24 1655	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A4H2103

Client Sample ID: Rm 116 sink 3	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:30
Lab Sample ID: A4H2103-90	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000716	0.015	0.000400	mg/L		08/22/24 1656	08/22/24 1656	SEV

Client Sample ID: Rm 116 sink 4	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:31
Lab Sample ID: A4H2103-91	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000846	0.015	0.000400	mg/L		08/22/24 1657	08/22/24 1657	SEV

Client Sample ID: Rm 116 sink 5	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:32
Lab Sample ID: A4H2103-92	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000841	0.015	0.000400	mg/L		08/22/24 1700	08/22/24 1700	SEV

Client Sample ID: Rm 116 sink 6	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:33
Lab Sample ID: A4H2103-93	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000879	0.015	0.000400	mg/L		08/22/24 1701	08/22/24 1701	SEV

Client Sample ID: Rm 116 sink 7	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:34
Lab Sample ID: A4H2103-94	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000871	0.015	0.000400	mg/L		08/22/24 1704	08/22/24 1704	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A4H2103

Client Sample ID: Police	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:03
Lab Sample ID: A4H2103-95	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1705	08/22/24 1705	SEV

Client Sample ID: Food Serive Ice	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 08/20/2024
Lab Sample ID: A4H2103-96	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1706	08/22/24 1706	SEV

Client Sample ID: 400-2 fountain	Collected By: Vittoria LaRosa
Sample Matrix: Drinking Water	Collection Date: 08/20/2024 8:18
Lab Sample ID: A4H2103-97	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		08/22/24 1707	08/22/24 1707	SEV

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories Inc., Pittsburgh Division
02-00257

Pennsylvania Department of Environmental Protection
Pennsylvania Department of Environmental Protection - PARULE

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.
The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.

Reviewed and Approved By:

Carolyn Vollenentine
Service Center Manager
Reported: 08/30/2024 14:01



Gannett Fleming, Inc. - Pittsburgh, PA
PM: Carolyn Vollentine

CHAIN OF CUSTODY RECORD

Number
Instructions on back

TO BE COMPLETED BY MICROBAC

Lab Report Address Invoice Addr

Client Name: Gannett Fleming, Inc Client Name: Same

Address: Foster plaza 8, Suite 400, 730 holiday Dr Address:

City, State, Zip: Pittsburgh, PA 15220 City, State, Zip:

Contact: Eric Buzza Contact:

Telephone No.: (412) 503-4343 Telephone No.:

Send Report via: Mail Fax e-mail (address)

Project: LHT Stormwater *Risk Assessment 30* Location: *Neville Island IHS*

Sampled by (PRINT): Eric Buzza Sampler Signature: *E. Buzza*

business days) b)

Temperature Upon Receipt (°C)
Therm ID

Holding Time

16.8°C T434

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

(needed by)

Report Type

Results Only Level 1 Level 2 Level 3 Level 4 EDD

Send Invoice via: Mail Fax e-mail (address)

Compliance Monitoring? Yes No

Agency/Program NPDES

PO No.:

Sampler Phone No.: (412) 503-4343

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Additional Notes
					<i>DWG</i>		<i>U</i>	<i>Lead</i>

See Attached

Possible Hazard Identification Comments

Hazardous Non-Hazardous Radioactive

Sample Disposition Dispose as appropriate Return Archive

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Date/Time

Date/Time

Date/Time

Received By (signature)

Received By (signature)

Received By (signature)

Date/Time

Date/Time

Date/Time